

Quarterly Groundwater Monitoring Report

Prepared for

Black & Decker (U.S.) Inc.

Hampstead, Maryland

April 2010

Prepared by

WESTON SOLUTIONS, INC.

West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION	1-1
2. SITE CHARACTERISTICS	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 1st Quarter 2010.....	2-2
Table 2-2 Groundwater Elevation Data – 1st Quarter 2010	2-3
Table 2-3 Effluent Characteristics Summary – 1st Quarter 2010	2-4
Table 2-4 Summary of Groundwater Analytical Results - February 2010.....	2-5
Table 3-1 Treatment System Maintenance Activities – 1st Quarter 2010.....	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of January through March 2010.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of January through March 2010, the extraction wells were pumping at an average combined rate of approximately 167 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of January through March 2010 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of January through March 2010, approximately 18.6 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (86.1%) and tetrachloroethene (PCE) (13.9%). Analytical results of the groundwater collected from the air stripper for the period of January through March 2010 are included in Appendix C.

A summary of the analytical results from the third quarter (February 2010) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 1st Quarter 2010
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
January 2010	6,627,345
February 2010	6,213,673
March 2010	7,395,042

Table 2-2
Groundwater Elevation Data - 1st Quarter 2010
Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV.	TOTAL DEPTH	1/15/2010		2/18/2010*		3/11/2010	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NC	DRY	NC	DRY	NC
EW-2	849.21	110	66.58	782.63	88.17	761.04	92.47	756.74
EW-3	846.64	118	82.50	764.14	79.40	767.24	79.81	766.83
EW-4	858.01	97.5	PC	NC	PC	NC	PC	NC
EW-5	864.17	98	78.40	785.77	86.72	777.45	89.32	774.85
EW-6	831.98	115	102.87	729.11	102.90	729.08	99.28	732.70
EW-7	818.38	78	50.94	767.44	45.41	772.97	40.68	777.70
EW-8	811.13	98	91.72	719.41	92.05	719.08	89.31	721.82
EW-9	811.35	141	101.90	709.45	102.61	708.74	101.61	709.74
EW-10	807.74	INA	47.85	759.89	52.17	755.57	47.72	760.02
RFW-1A	864.37	78	50.90	813.47	47.16	817.21	47.40	816.97
RFW-1B	864.23	200	50.91	813.32	47.22	817.01	47.46	816.77
RFW-2A	857.41	35	14.41	843.00	12.36	845.05	11.96	845.45
RFW-2B	857.73	75	15.06	842.67	12.98	844.75	12.34	845.39
RFW-3B	839.21	153	33.94	805.27	NA	NC	33.29	805.92
RFW-4A	830.37	62	34.56	795.81	35.00	795.37	33.91	796.46
RFW-4B	830.37	120	35.03	795.34	34.92	795.45	33.80	796.57
RFW-5A	817.50	30	DRY	NC	DRY	NC	DRY	NC
RFW-6	785.04	120	3.18	781.86	3.24	781.80	2.86	782.18
RFW-7	805.14	29	6.94	798.20	NA	NC	6.40	798.74
RFW-8	860.07	56	DRY	NC	DRY	NC	DRY	NC
RFW-9	862.02	49	24.22	837.80	24.36	837.66	23.78	838.24
RFW-10	852.06	58	DRY	NC	DRY	NC	DRY	NC
RFW-11A	849.32	72	Damaged	NC	Damaged	NC	Damaged	NC
RFW-11B	849.62	116	65.71	783.91	64.83	784.79	66.84	782.78
RFW-12B	844.87	264	50.48	794.39	48.83	796.04	48.86	796.01
RFW-13	849.11	150	59.89	789.22	NA	NC	65.67	783.44
RFW-14B	812.39	281	46.94	765.45	46.81	765.58	47.53	764.86
RFW-16	856.14	41	DRY	NC	DRY	NC	DRY	NC
RFW-17	834.66	60.5	27.37	807.29	24.56	810.10	24.61	810.05
RFW-20	842.49	142	34.17	808.32	31.82	810.67	31.62	810.87
RFW-21	832.65	102	22.16	810.49	20.08	812.57	19.83	812.82
PH-7	805.94	89	26.02	779.92	25.91	780.03	22.69	783.25
PH-9	814.94	98	54.16	760.78	55.94	759.00	54.47	760.47
PH-11	820.68	78	45.06	775.62	NA	NC	51.01	769.67
PH-12	828.35	87	47.78	780.57	NA	NC	52.78	775.57
B-3	803.02	83	8.67	794.35	NA	NC	9.63	793.39
Amoco	842.29	INA	NA	NC	NA	NC	NA	NC
Hamp. Town #22	804.96	INA	17.49	787.47	NA	NC	20.46	784.50
Pembroke #1	INA	INA	12.31	NC	NA	NC	11.31	NC
Pembroke #2	INA	INA	Damaged	NC	Damaged	NC	Damaged	NC
N. Houcks. Rd.	INA	INA	10.68	NC	NA	NC	9.85	NC
E. Century St.	INA	INA	19.39	NC	NA	NC	19.08	NC
Lwr. Beckleys. Rd.	INA	INA	55.08	NC	NA	NC	54.26	NC

NA - Not Available/Not Accessible

NC - Not Calculable

INA - Information not available

PC - Pump Cycles

* - Due to heavy snow many wells were inaccessible

Table 2-3
Effluent Characteristics Summary - 1st Quarter 2010
Black & Decker
Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				January 2010	February 2010	March 2010	
001	FLOW	average	MGD	NA	0.191	0.232	0.279
		maximum	MGD	NA	0.846	0.389	0.655
	1,1,1-Trichloroethane		ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene		ug/l	5	< 1	< 1	< 1
	Trichloroethylene		ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	< 5	13.0
		quarterly average	mg/l	10	< 5	< 5	7.0
	pH	minimum	STD	6.0	6.00	6.20	6.30
		maximum	STD	8.5	6.20	7.20	6.60
	BOD		mg/l	15	0.0	0.0	0.0
TSS	maximum	mg/l	30	0.0	0.0	0.0	
	quarterly average	mg/l	20	0.0	0.0	0.0	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.297	0.283	0.280
		maximum	MGD	NA	0.377	0.431	0.362
	Fecal Coliform		MPN/100ml	200	1.0	1.0	1.0
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.225
		maximum	MGD	NA	NR	NR	0.299
	1,1,1-Trichloroethane		ug/l	NA	NR	NR	< 1
	Tetrachloroethylene		ug/l	NA	NR	NR	< 1
	Trichloroethylene		ug/l	NA	NR	NR	< 1

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

Table 2-4

Summary of Groundwater Analytical Results - February 2010
 Black & Decker
 Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3.5	2.8	1 U	1 U	1 U	4.4	24	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	410	130	1100	150	10	4	10	1.1	1 J	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1.5
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	62	3.4	22	5.9	17	9.6	63	110	100	1 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

NS = Not Sampled

Table 2-4
Summary of Groundwater Analytical Results - February 2010
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
Methylene Chloride	ug/L	2 U	2 U	2 U	2 U	NS	2 U	2 U	2 U	NS	2 U	NS	NS	2 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	NS	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	NS	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1.3	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1.6	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	3.7	NS	1 U	NS	NS	25	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	NS	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1.6	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	1 U	1 U	NS	30	28	50	NS	1 U	NS	NS	15	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	NS	5 U	5 U	5 U	NS	5 U	NS	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	NS	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	NS	17	16	69	NS	1.4	NS	NS	8.5	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS

Notes: DUP = Duplicate sample
 NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
 J = Indicates an estimated value.

Table 2-4

Summary of Groundwater Analytical Results - February 2010
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	RFW-20	RFW-21	Town #22	Town #23	Trip Blank
		USEPA drinking water method 524.2														
Chloromethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	NS	NS	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	NS	NS	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	NS	NS	2 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Acetone	ug/L	NS	5 U	5 U	NS	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	NS	NS	5 U	ABD	ABD	ABD	5 U	NA	NA	NS	NS	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	3	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Chloroform	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	9.8	0.5 U	0.5 U	NS	NS	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	NS	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	6.8	0.5 U	0.5 U	NS	NS	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Trichloroethene	ug/L	NS	7.9	280	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	2.8	0.5 U	0.5 U	NS	NS	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Benzene	ug/L	NS	1 U	1 U	NS	NS	1.5	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Bromoform	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1.7	0.5 U	0.5 U	NS	NS	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	NS	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
2-Hexanone	ug/L	NS	5 U	5 U	NS	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
Tetrachloroethene	ug/L	NS	1 U	25	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Toluene	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Styrene	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division. Samples from all of the other wells are analyzed with USEPA Method 8260.

NS = Not sampled

U = Compound was analyzed but not detected.

ABD = Well has been abandoned

analytical data package is included in Appendix D. Wells RFW-3B, RFW-7 and RFW-13 were not accessible due to heavy snow falls.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from wells RFW-4B and EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (January through March 2010) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 1st Quarter 2010
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Jan-10	Alarm at the stripper due to a power outage. Reset the system everything back online.
Jan-10	Alarm at the stripper due to wet well supply failure due to a frozen supply pipe. The pipe was thawed and the system is back online.
Jan-10	Alarm at stripper due to a high wet well. Reset the system and everything is back online.
Jan-10	Replace the heater in EW-5
Feb-10	Alarm at stripper. EW-5 tripped off. Heating elements in EW-5 heater are bad. The well is reset, a temporary heater is used until the heating elements are replaced. in the heater.
Mar-10	Alarm at stripper due to a power outage. Reset the system everything back online.
Mar-10	Alarm at the stripper due to a high column blower failure. The system was reset everything is okay.
Mar-10	EW-8 tripped off due to a bad control relay. Replaced the relay and the well is back online.

4. RECOMMENDATIONS

For the reporting period of January through March 2010, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(JANUARY – MARCH 2010)

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 626 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrance Jones 0763, Gary Dickerson 0782

Permit Number: 02-DP-0022
Superintendent: Earle Villarreal

Certification # 1017

Month: January
Year: 2010

Final Effluent outfall 001											Outfall 101					Outfall 201			Operator		
Date	Appearance	Discharge MGD	pH	Cl ₂ mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin inches	Alum Gpd	Hypochlorite Gpd	Post Cl ₂ mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l		Trichloroethene ug/l	Discharge mgd
1	Clear	0.16000									0.267000		0.0	5.0	1.0	5.0				0.183305	gdickerson
2	Clear	0.13500									0.312000		0.0	5.0	1.0	5.0				0.211153	djones
3	Clear	0.11000									0.317000		0.0	5.0	1.0	5.0				0.227532	djones
4	Clear	0.09600									0.275000		0.0	5.0	1.0	5.0				0.221972	gdickerson
5	Clear	0.11300	6.15	0.00							0.289000		0.0	5.0	1.0	5.0				0.209149	gdickerson
6	Clear	0.14600			< 1.00	< 1.00	< 1.00	< 2.0	< 4.0	< 5.0	0.303000	< 1.8	0.0	10.0	1.0	5.0				0.219937	djones
7	Clear	0.13300	6.23	0.00							0.298000		0.0	10.0	1.0	5.0				0.220453	djones
8	Clear	0.14700									0.308000		0.0	10.0	1.0	5.0				0.216629	gdickerson
9	Clear	0.11900									0.270000		0.0	10.0	1.0	5.0				0.199657	gdickerson
10	Clear	0.12300									0.265000		0.0	5.0	1.0	5.0				0.220021	gdickerson
11	Clear	0.14000									0.303000		0.0	5.0	1.0	5.0				0.226791	djones
12	Clear	0.13700	6.11	0.00							0.296000		0.0	5.0	1.0	5.0				0.212351	djones
13	Clear	0.11500									0.313000	< 1.8	0.0	5.0	1.0	5.0				0.219525	djones
14	Clear	0.08700	6.07	0.00							0.280000		0.0	5.0	1.0	5.0				0.213232	djones
15	Clear	0.07200									0.222000		0.0	5.0	1.0	5.0				0.168193	djones
16	Clear	0.09300									0.279000		0.0	5.0	1.0	5.0				0.223326	djones
17	Clear	0.62900									0.323000		0.0	5.0	1.0	5.0				0.227788	djones
18	Clear	0.20700									0.289000		0.0	5.0	1.0	5.0				0.218506	gdickerson
19	Clear	0.17300	6.03	0.00							0.313000		0.0	5.0	1.0	5.0				0.207249	gdickerson
20	Clear	0.16600									0.299000		0.0	10.0	1.0	5.0	< 1.0	< 1.0	< 1.0	0.220468	djones
21	Clear	0.17900	6.10	0.00							0.377000	< 1.8	0.0	5.0	1.0	5.0				0.227615	djones
22	Clear	0.15100									0.308000		0.0	5.0	1.0	5.0				0.179822	djones
23	Clear	0.17500									0.354000		0.0	5.0	1.0	5.0				0.232339	djones
24	Clear	0.84600									0.328000		0.0	5.0	1.0	5.0				0.236200	gdickerson
25	Clear	0.45200									0.245000		0.0	5.0	1.0	5.0				0.196617	djones
26	Clear	0.20100	6.17	0.00							0.297000		0.0	5.0	1.0	5.0				0.231992	djones
27	Clear	0.14300									0.276000	< 1.8	0.0	10.0	1.0	5.0				0.208329	djones
28	Clear	0.16400	6.22	0.00							0.316000		0.0	5.0	1.0	5.0				0.213679	djones
29	Clear	0.16300									0.319000		0.0	5.0	1.0	5.0				0.223944	djones
30	Clear	0.16100									0.231000		0.0	5.0	1.0	5.0				0.169468	djones
31	Clear	0.18400									0.327000		0.0	5.0	1.0	5.0				0.240103	djones
Total		5.92000									9.199000									6.627345	
Average		0.19097	6.1	<0.10	0	0	0	0	0	0	0.296742	1	0.0	6.0	1.0	5.0	0	0	0	0.213785	
Minimum		0.07200	6.0	0.00	0	0	0	0	0	0	0.222000	1	0.0	5.0	1.0	5.0	0	0	0	0.168193	
Maximum		0.84600	6.2	<0.10	0	0	0	0	0	0	0.377000	1	0.0	10.0	1.0	5.0	0	0	0	0.240103	MOR 5-11-09

COMMENTS:

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:

Facility: BTR Capital Group

Permit Number: 02-DP-0022

Month: February

Maryland Environmental Service

Address: 626 Hanover Pike, Hampstead Maryland

Superintendent: Earle Villarreal

Certification # 1017

Year: 2010

259 Najoles Road, Millersville MD

Additional Op's & cert # - Dorrance Jones 0763, Martin Whitt 0666, David Smith 9153, Gary Kesselring 1962, Dave Coale 1662

Date	Appearance	Final Effluent outfall 001									Outfall 101						Outfall 201			Operator
		Discharge MGD	pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	
1	Clear	0.15900								0.258000		0.0	5.0	1.0	5.0				0.210292	mwhitt
2	Clear	0.21300	7.21	0.00						0.264000		0.0	5.0	1.0	5.0				0.233163	mwhitt
3	Clear	0.18900								0.245000	< 1.8	0.0	5.0	1.0	5.0				0.116581	djones
4	Clear	0.17200	6.20	0.00						0.272000		0.0	2.0	1.0	5.0				0.232914	djones
5	Clear	0.27700								0.277000		0.0	1.0	1.0	5.0				0.103769	djones
6	Clear	0.28800								0.277000		0.0	1.0	1.0	5.0				0.283393	djones
7	Clear	0.32700								0.277000		0.0	2.0	1.0	5.0				0.283393	dcoale
8	Clear	0.28400								0.296000		0.0	3.0	1.0	5.0				0.251250	djones
9	Clear	0.38900								0.166000		0.0	5.0	1.0	5.0				0.120787	djones
10	Clear	0.28000								0.431000		0.0	5.0	1.0	5.0				0.227734	dcoale
11	Clear	0.19800								0.244000		0.0	5.0	1.0	5.0				0.227734	dcoale
12	Clear	0.15000	6.21	0.00						0.295000	< 1.8	0.0	2.0	1.0	5.0				0.175734	djones
13	Clear	0.18500								0.280000		0.0	3.0	1.0	5.0				0.226511	djones
14	Clear	0.21500	6.36	0.00						0.343000		0.0	5.0	1.0	5.0				0.260778	djones
15	Clear	0.21800								0.290000		0.0	5.0	1.0	5.0				0.245778	mwhitt
16	Clear	0.21900								0.249000		0.0	5.0	1.0	5.0				0.210997	dsmith
17	Clear	0.10000	6.68	0.00	< 1.00	< 1.00	< 1.00	< 2.0	< 4.0	< 5.3	0.271000	< 1.8	0.0	5.0	1.0	5.0			0.245350	mwhitt
18	Clear	0.16100	6.45	0.00						0.222000		0.0	5.0	1.0	5.0				0.203107	gkesselring
19	Clear	0.20400	6.43	0.00						0.341000		0.0	2.0	1.0	5.0				0.253125	mwhitt
20	Clear	0.19100								0.293000		0.0	3.0	1.0	5.0				0.239462	mwhitt
21	Clear	0.17200								0.261000		0.0	5.0	1.0	5.0				0.246802	mwhitt
22	Clear	0.33800								0.289000		0.0	5.0	1.0	5.0				0.216984	djones
23	Clear	0.33600	6.20	0.00						0.298000		0.0	5.0	1.0	2.2				0.233255	djones
24	Clear	0.35400								0.276000	< 1.8	0.0	5.0	1.0	5.0				0.217297	djones
25	Clear	0.25100	6.49	0.00						0.313000		0.0	5.0	1.0	5.0				0.235062	djones
26	Clear	0.17600								0.272000		0.0	5.0	1.0	5.0				0.209296	djones
27	Clear	0.19200								0.290000		0.0	5.0	1.0	5.0				0.232837	djones
28	Clear	0.24800								0.347000		0.0	5.0	1.0	5.0				0.270288	djones
29																				
30																				
31																				
Total		6.48600								7.937000										
Average		0.23164	6.5	<0.10	0	0	0	2	0	0	0.283464	1	0.0	4.1	1.0	4.9	#DIV/0!	#DIV/0!	#DIV/0!	0.221917
Minimum		0.10000	6.2	0.00	0	0	0	2	0	0	0.166000	1	0.0	1.0	1.0	2.2	0	0	0	0.103769
Maximum		0.38900	7.2	<0.10	0	0	0	0	0	0	0.431000	1	0.0	5.0	1.0	5.0	0	0	0	0.283393

COMMENTS:

MOR 5:11-09

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:

Facility: BTR Capital Group

Permit Number: 02-DP-0022

Month: March

Maryland Environmental Service
259 Najoles Road, Millersville MD

Address: 626 Hanover Pike, Hampstead Maryland

Superintendent: Earle Villarreal

Certification # 1017

Year: 2010

Additional Op's & cert # - Dorrance Jones 0763, Martin Whitt 0666, Dave Smith 9153, Francis Schmidt 2757, Jammal Downs 2755, Gary Kesselring 1962

Final Effluent outfall 001											Outfall 101					Outfall 201			Operator		
Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l		Trichloroethene ug/l	Discharge mgd
1	Clear	0.22400									0.261000		0.0	5.0	1.0	5.0				0.202124	mwhitt
2	Clear	0.23000	6.59	0.00							0.265000		0.0	5.0	1.0	5.0				0.258908	mwhitt
3	Clear	0.25100			< 1.00	< 1.00	< 1.00	< 2.0	< 4.0	< 5.0	0.312000	< 1.8	0.0	2.0	1.0	5.0				0.231198	djones
4	Clear	0.21800	6.55	0.00							0.308000		0.0	1.0	1.0	5.0				0.254265	djones
5	Clear	0.17300									0.260000		0.0	2.0	1.0	5.0				0.189388	djones
6	Clear	0.20900									0.342000		0.0	2.0	1.0	5.0				0.267736	djones
7	Clear	0.19000									0.292000		0.0	3.0	1.0	5.0				0.251571	mwhitt
8	Clear	0.16900									0.260000		0.0	5.0	1.0	4.2				0.217330	fschmidt
9	Clear	0.17800	6.30	0.00							0.303000		0.0	5.0	1.0	5.0				0.248715	fschmidt
10	Clear	0.16200									0.270000	< 1.8	0.0	5.0	1.0	5.0				0.208329	djones
11	Clear	0.45500	6.46	0.00							0.324000		0.0	2.0	1.0	5.0				0.267902	gkesselring
12	Clear	0.65500									0.258000		0.0	3.0	1.0	5.0				0.191235	fschmidt
13	Clear	0.10990									0.258000		0.0	5.0	1.0	5.0				0.227942	djones
14	Clear	0.46400									0.324000		0.0	5.0	1.0	5.0				0.272855	djones
15	Clear	0.24500	6.50	0.00							0.277000		0.0	2.0	1.0	5.0				0.252626	dsmith
16	Clear	0.14300									0.256000		0.0	3.0	1.0	5.0				0.215863	fschmidt
17	Clear	0.28500									0.298000	< 1.8	0.0	2.0	1.0	5.0				0.246169	fschmidt
18	Clear	0.29700	6.41	0.00							0.320000		0.0	3.0	1.0	5.0				0.258910	djones
19	Clear	0.24700									0.250000		0.0	5.0	1.0	5.0				0.192054	fschmidt
20	Clear	0.29400									0.302000		0.0	5.0	1.0	5.0				0.235293	djones
21	Clear	0.34500									0.362000		0.0	5.0	1.0	5.0				0.299051	dsmith
22	Clear	0.28400									0.292000		0.0	2.0	1.0	5.0				0.215678	djones
23	Clear	0.25600	6.33	0.00							0.242000		0.0	2.0	1.0	5.0				0.240537	djones
24	Clear	0.28000								13.0	0.265000	< 1.8	0.0	2.0	1.0	5.0				0.261461	djones
25	Clear	0.26000	6.56	0.00							0.256000		0.0	2.0	1.0	5.0				0.250298	jdowns
26	Clear	0.25400									0.201000		0.0	2.0	1.0	5.0				0.187809	jdowns
27	Clear	0.30700									0.257000		0.0	5.0	1.0	5.0				0.242722	djones
28	Clear	0.37200									0.296000		0.0	5.0	1.0	5.0				0.275588	djones
29	Clear	0.33600	6.41	0.00							0.261000		0.0	5.0	1.0	5.0				0.238233	dsmith
30	Clear	0.38600									0.266000		0.0	5.0	1.0	5.0				0.257027	dsmith
31	Clear	0.37700									0.257000	< 1.8	0.0	5.0	1.0	5.0				0.236225	djones
Total		8.65590									8.695000									7.395042	
Average		0.27922	6.5	<0.10	0	0	0	2	0	7	0.280484	1	0.0	3.5	1.0	5.0	#DIV/0!	#DIV/0!	#DIV/0!	0.238550	
Minimum		0.10990	6.3	0.00	0	0	0	2	0	0	0.201000	1	0.0	1.0	1.0	4.2	0	0	0	0.187809	
Maximum		0.65500	6.6	<0.10	0	0	0	0	0	13	0.362000	1	0.0	5.0	1.0	5.0	0	0	0	0.299051	MOR 5-11-09

COMMENTS:

**APPENDIX B
DISCHARGE MONITORING REPORTS
(JANUARY – MARCH 2010)**

PERMITTEE NAME/CLASS (Include Facility Name/Location if different)
 NAME **AGIGFI Hampstead, Inc**
 ADDRESS **626 Hanover Pike**
Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**
 ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
10	01	01	10	01	31
(20-21)		(22-23)		(24-25)	
		(26-27)		(28-29)	
				(30-31)	

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUANTITY OR CONCENTRATION (46-53) (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	0	(19)	0	ONE/MONTH GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15			ONE/MONTH GRAB
pH 00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	6.0	*****	6.2	(12)	0	TWO/WEEK GRAB
	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	8.5			TWO/WEEK GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	0	0	(19)	0	ONE/MONTH GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	20	30			ONE/MONTH GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	*****	190968	846000	(07)	*****	*****	*****		0	MEASURED RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****		****	MEASURED RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONE/MONTH GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.01	0.19			ONE/MONTH GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	0		0	ONE/MONTH GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5			ONE/MONTH GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	0		0	ONE/MONTH GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5			ONE/MONTH GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE			
Jim Harkins, Director MES			410 729-8350	10	02	23	
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**
 ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**
 ATTN:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
10	01	01	TO	10	01	31	
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)	

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
TRICHLOROETHENE	*****	*****	*****	****	*****	*****	0	ug/l	0	ONE/MONTH	GRAB
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5			ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE	*****	*****	*****	****	*****	0	0	(19)	0	ONE/MONTH	GRAB
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **410 729-8350**
 DATE **10 02 23**
 AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ **AG/GFI Hampstead, Inc**
 Facility Name/Location (if different)
 NAME **AG/GFI Hampstead, Inc**
 ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MD0001881
 PERMIT NUMBER


101
 DISCHARGE NUMBER

Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**
 ATTN:

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	01	01	TO	10	01	31
(20-21)		(22-23)		(24-25)		(26-27)
				(28-29)		(30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	296742	377000	('07)	*****	*****	*****	*****	0	ONE/ MONTH	GRAB	
	PERMIT REQUIREMENT	REPORT	REPORT	*****	*****	*****	*****	0	ONE/ MONTH	GRAB	
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	*****	1	(30)	0	ONE/ WEEK	GRAB	
	PERMIT REQUIREMENT	*****	*****	*****	*****	200	MPN	0	ONE/ WEEK	GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE			
Jim Harkins, Director MES			410 729-8350	10	02	23	
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**
 ADDRESS **626 Hanover Pike**
Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**
 ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

Form Approved. **12345**
 OMB No. 2040-0004.
 Approval expires 05-31-98

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 10	02	01	TO 10	02	28
(20-21)		(22-23)	(24-25)	(26-27)	(28-29) (30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (46-53)			QUANTITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	0	(19)	0	ONE/MONTH GRAB
pH	*****	*****	*****	*****	6.2	*****	7.2	(12)	0	TWO/WEEK GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	0	0	(19)	0	ONE/MONTH GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	231643	389000	(07)	*****	*****	*****	*****	0	MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	<0.1	<0.1	<0.1	(19)	0	ONE/MONTH GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	0	0	ONE/MONTH GRAB	
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	0	0	ONE/MONTH GRAB	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
410	729-8350	10	03	23
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME AND ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**
 ADDRESS **626 Hanover Pike**
Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**
 ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT
 (2-16) (DMR) (17-19)

State Discharge Permit
02-DP-0022

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	10	02	01		10	02	28
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (46-53)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (3 Card Only) (46-53)	MAXIMUM	UNITS	MINIMUM (4 Card Only) (38-45)	AVERAGE	MAXIMUM				
TRICHLOROETHENE		*****	*****		*****	*****	0	ug/l	0	ONE/MONTH	GRAB
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5			ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE		*****	*****		*****	0	0	(19)	0	ONE/MONTH	GRAB
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: **410 729-8350**
 AREA CODE NUMBER

DATE: **10 03 23**
 YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**
 ADDRESS **626 Hanover Pike**
Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**
 ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
 02-DP-0022

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MD0001881
 PERMIT NUMBER

101
 DISCHARGE NUMBER

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
10	02	01		10	02	28	
(20-21)		(22-23)		(24-25)		(26-27)	
				(28-29)		(30-31)	


*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	283464	431000	(07)	*****	*****	*****	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	0	ONE/MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	ONE/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200	MPN	ONE/WEEK	GRAB
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT



TELEPHONE		DATE		
410	729-8350	10	03	23
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

ADDRESS **626 Hanover Pike**

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

Hampstead, MD 21074

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	10	03	01		10	03	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only (46-53))			QUANTITY OR CONCENTRATION (4 Card Only (38-45))				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(19)	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15	MG/L		ONE/ MONTH	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	****	6.3	*****	6.6	(12)	0	TWO/ WEEK	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	8.5	SU		TWO/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	20	30	MG/L		ONE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 00550 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	279223	655000	(07)	*****	*****	*****		0	MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.011	0.019	MG/L		ONE/ MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0		0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0		0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
Jim Harkins, Director MES			410	729-8350	10	04	23
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
 02-DP-0022

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	10	03	01		10	03	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (46-53)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (46-53)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	ug/l	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5			ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	7	13	(19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
410 729-8350
 AREA CODE NUMBER
 DATE
10 04 23
 YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

State Discharge Permit
02-DP-0022

MD0001881

PERMIT NUMBER

101

DISCHARGE NUMBER

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
10	03	01		10	03	31	
(20-21)		(22-23)		(24-25)		(26-27)	
		(28-29)		(30-31)			

*** NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-43)	AVERAGE (46-53)	MAXIMUM (54-61)			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	REPORT *****	280484	362000	(07) GPD	*****	*****	*****	0	ONE/ MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	1	0	ONE/ WEEK	GRAB
							200		MPN	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
410	729-8350	10	04	23
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**
 ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MD0001881
 PERMIT NUMBER

201
 DISCHARGE NUMBER

Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**
 ATTN:

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	01	01		10	03	31
(20-21)		(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS (54-61)	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	224845	299051	(07)	*****	*****	*****	0	MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****	MEASURED	RECORD
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	0	ONE/ QUARTER	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT *****	REPORT *****	ug/l	ONE/ QUARTER	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	0	ONE/ QUARTER	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT *****	REPORT *****	ug/l	ONE/ QUARTER	GRAB
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	0	ONE/ QUARTER	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT *****	REPORT *****	ug/l	ONE/ QUARTER	GRAB
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **410 729-8350**
 DATE **10 04 27**
 AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 Quarterly Report! Outfall 201 quarterly sample's collected on 01/06/10.

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(JANUARY – MARCH 2010)

REPORT OF ANALYSIS

Maryland Environmental Services (A)
 259 Najoles Road
 Millersville, MD 21108

Order Number: A10010246
 Project Name: Black & Decker WWTP
 Receive Date: 1/6/2010
 Client Code: MES_A
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10010246-01 **Sample Date: 1/6/2010 10:05**

Site: Black & Decker 001 Matrix: Waste Water
 Client Sample ID:
 Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	<2	mg/L	2	SM 5210 B	1/7/2010 11:30:00 AM	Skent
Total Suspended Solids	<4	mg/L	4	SM 2540D	1/12/2010 1:44:00 PM	KPlatt

Sample # A10010246-01A **Sample Date: 1/6/2010 10:05**

Site: Black & Decker 001 Matrix: Waste Water
 Client Sample ID: A
 Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	<5	mg/L	5	EPA 1664	1/7/2010 2:00:00 PM	SHess

Sample # A10010246-01B **Sample Date: 1/6/2010 10:05**


Site: Black & Decker 001 Matrix: Waste Water
 Client Sample ID: B
 Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	1/13/2010 4:48:00 AM	JKozlowski
Tetrachloroethene	<1	ug/L	1	EPA 8260B	1/13/2010 4:48:00 AM	JKozlowski
Trichloroethene	<1	ug/L	1	EPA 8260B	1/13/2010 4:48:00 AM	JKozlowski

Approved: *Wanda Van Arsdale*
 Quality Assurance Manager

Reported: 1/15/2010 3:23:34 PM

RDL = Reporting Detection Limit N/A = Not Applicable
 Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



630 Churchmans Road
 Newark, Delaware 19702
 302-266-9121 • 454-8720 (FAX)
 WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
 259 Najoles Road
 Millersville, MD 21108

Order Number: A10020789
 Project Name: Black & Decker WWTP
 Receive Date: 2/17/2010
 Client Code: MES_A
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10020789-01 **Sample Date: 2/17/2010 8:30**

Site: Black & Decker 001 Matrix: Waste Water
 Client Sample ID:
 Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	< 2	mg/L	2	SM 5210 B	2/18/2010 11:35:00 AM	Skent
Total Suspended Solids	< 4	mg/L	4	SM 2540D	2/22/2010 1:13:00 PM	KPlatt

Sample # A10020789-02 **Sample Date: 2/17/2010 8:30**

Site: Black & Decker 001 Matrix: Waste Water
 Client Sample ID:
 Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	< 5.3	mg/L	5.3	EPA 1664	2/25/2010 1:10:00 PM	JMcGuire

Sample # A10020789-03 **Sample Date: 2/17/2010 8:30**

Site: Black & Decker 001 Matrix: Waste Water
 Client Sample ID:
 Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	2/18/2010 10:02:00 PM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	2/18/2010 10:02:00 PM	JKozlowski
Trichloroethene	< 1	ug/L	1	EPA 8260B	2/18/2010 10:02:00 PM	JKozlowski

Approved: 
 Quality Assurance Manager

Reported: 3/2/2010 12:49:23 PM

RDL = Reporting Detection Limit N/A = Not Applicable
 Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A10030274
Project Name: Black & Decker WWTP
Receive Date: 3/3/2010
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10030274-01 **Sample Date: 3/3/2010 9:50**

Site: Black & Decker 101 Matrix: Waste Water
Client Sample ID:
Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	< 2	mg/L	2	SM 5210 B	3/4/2010 10:50:00 AM	Skent
Total Suspended Solids	< 4	mg/L	4	SM 2540D	3/9/2010 1:45:00 PM	KPlatt

Sample # A10030274-02 **Sample Date: 3/3/2010 9:50**

Site: Black & Decker 101 Matrix: Waste Water
Client Sample ID:
Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	< 5	mg/L	5	EPA 1664	3/8/2010 1:45:00 PM	JMcGuire

Sample # A10030274-03 **Sample Date: 3/3/2010 9:50**


Site: Black & Decker 101 Matrix: Waste Water
Client Sample ID:
Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	3/9/2010 3:42:00 AM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	3/9/2010 3:42:00 AM	JKozlowski
Trichloroethene	< 1	ug/L	1	EPA 8260B	3/9/2010 3:42:00 AM	JKozlowski

Approved: *Warren Van Andell*
Quality Assurance Manager

Reported: 3/15/2010 1:22:39 PM

RDL = Reporting Detection Limit N/A = Not Applicable
Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



630 Churchmans Road
 Newark, Delaware 19702
 302-266-9121 • 454-8720 (FAX)
 WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
 259 Najoles Road
 Millersville, MD 21108

Order Number: A10031517
 Project Name: Black & Decker WWTP
 Receive Date: 3/24/2010
 Client Code: MES_A
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10031517-01

Sample Date: 3/24/2010 9:15

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	13.0	mg/L	5.4	EPA 1664	4/2/2010 2:00:00 PM	JMcGuire

Approved: *Keith A. Hausknecht*
President

Reported: 4/7/2010 8:41:10 AM

RDL = Reporting Detection Limit N/A = Not Applicable
 Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568

APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(FEBRUARY 2010)

ANALYTICAL REPORT

Job Number: 500-24183-1

Job Description: Black and Decker

For:

Weston Solutions, Inc.

1400 Weston Way

PO BOX 2653

West Chester, PA 19380

Attention: Mr. Tom Cornuet



Approved for release.
Richard C Wright
Project Manager II
3/4/2010 12:41 PM

Richard C Wright
Project Manager II
richard.wright@testamericainc.com
03/04/2010

cc: Greg Flasiński

These test results meet all the requirements of NELAC for accredited parameters.

The Lab Certification ID# is 100201.

All questions regarding this test report should be directed to the TestAmerica Project Manager whose signature appears on this report. All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.

Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.

TestAmerica Laboratories, Inc.

TestAmerica Chicago 2417 Bond Street, University Park, IL 60484

Tel (708) 534-5200 Fax (708) 534-5211 www.testamericainc.com



Job Narrative
500-24183-1

Comments

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

GC/MS VOA

Method(s) 8260B: The laboratory control sample (LCS) for preparation batch 81056 exceeded control limits for the following analytes: 2-Hexanone. These analytes were biased high in the LCS and were not detected in the associated samples; therefore, the data have been reported.

Method(s) 8260B: The laboratory control sample (LCS) for preparation batch 81296 exceeded control limits for the following analytes: Bromomethane. These analytes were biased high in the LCS and were not detected in the associated samples; therefore, the data have been reported.

Method(s) 8260B: The trip blank associated with these samples contained a detection above the reporting limit (RL) for the following analytes: Chloroform, Bromodichloromethane, Dibromochloromethane, and Bromoform. The sample was re-analyzed with duplicate results.

Method(s) 8260B: The following sample(s) was diluted due to the abundance of target analytes: EW-4 (500-24183-3). Elevated reporting limits (RLs) are provided.

Method(s) 8260B: The continuing calibration verification 6C0302A (CCV) for Bromomethane recovered above the upper control limit. The samples associated with this CCV were non-detects for the affected analytes; therefore, the data have been reported.

No other analytical or quality issues were noted.

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-24183-1	EW-2				
cis-1,2-Dichloroethene		3.5	1.0	ug/L	8260B
Trichloroethene		410	10	ug/L	8260B
Tetrachloroethene		62	1.0	ug/L	8260B
500-24183-2	EW-3				
cis-1,2-Dichloroethene		2.8	1.0	ug/L	8260B
Trichloroethene		130	5.0	ug/L	8260B
Tetrachloroethene		3.4	1.0	ug/L	8260B
500-24183-3	EW-4				
Trichloroethene		1100	50	ug/L	8260B
Tetrachloroethene		22	5.0	ug/L	8260B
500-24183-4	EW-5				
Trichloroethene		150	5.0	ug/L	8260B
Tetrachloroethene		5.9	1.0	ug/L	8260B
500-24183-5	EW-6				
Trichloroethene		10	1.0	ug/L	8260B
Tetrachloroethene		17	1.0	ug/L	8260B
500-24183-6	EW-7				
cis-1,2-Dichloroethene		4.4	1.0	ug/L	8260B
Trichloroethene		4.0	1.0	ug/L	8260B
Tetrachloroethene		9.6	1.0	ug/L	8260B
500-24183-7	EW-8				
cis-1,2-Dichloroethene		24	1.0	ug/L	8260B
Trichloroethene		10	1.0	ug/L	8260B
Tetrachloroethene		63	1.0	ug/L	8260B
500-24183-8	EW-9				
Trichloroethene		1.1	1.0	ug/L	8260B
Tetrachloroethene		110	2.0	ug/L	8260B

TestAmerica Chicago

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-24183-9FD	EW-9 DUP				
Trichloroethene		0.95 J	1.0	ug/L	8260B
Tetrachloroethene		100	2.0	ug/L	8260B
500-24183-11	RFW-17				
Benzene		1.5	1.0	ug/L	8260B
500-24183-16	RFW-6				
Tetrachloroethene		1.4	1.0	ug/L	8260B
500-24183-17	RFW-12B				
cis-1,2-Dichloroethene		3.0	1.0	ug/L	8260B
Trichloroethene		280	5.0	ug/L	8260B
Tetrachloroethene		25	1.0	ug/L	8260B
500-24183-18	RFW-4A				
Trichloroethene		30	1.0	ug/L	8260B
Tetrachloroethene		17	1.0	ug/L	8260B
500-24183-19FD	RFW-4A DUP				
Trichloroethene		28	1.0	ug/L	8260B
Tetrachloroethene		16	1.0	ug/L	8260B
500-24183-20	RFW-4B				
cis-1,2-Dichloroethene		3.7	1.0	ug/L	8260B
Trichloroethene		50	1.0	ug/L	8260B
Tetrachloroethene		69	1.0	ug/L	8260B
500-24183-21	RFW-9				
1,1-Dichloroethene		1.3	1.0	ug/L	8260B
1,1-Dichloroethane		1.6	1.0	ug/L	8260B
cis-1,2-Dichloroethene		25	1.0	ug/L	8260B
1,1,1-Trichloroethane		1.6	1.0	ug/L	8260B
Trichloroethene		15	1.0	ug/L	8260B
Tetrachloroethene		8.5	1.0	ug/L	8260B

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-24183-22 Trichloroethene	RFW-11B	7.9	1.0	ug/L	8260B
500-24183-23TB Chloroform	TRIP BLANK	9.8	1.0	ug/L	8260B
Bromodichloromethane		6.8	1.0	ug/L	8260B
Dibromochloromethane		2.8	1.0	ug/L	8260B
Bromoform		1.7	1.0	ug/L	8260B

METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Description	Lab Location	Method	Preparation Method
Matrix: Water			
VOC	TAL CHI	SW846 8260B	
Purge and Trap	TAL CHI		SW846 5030B

Lab References:

TAL CHI = TestAmerica Chicago

Method References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

METHOD / ANALYST SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

<u>Method</u>	<u>Analyst</u>	<u>Analyst ID</u>
SW846 8260B	Alikpala, Elaine	EA
SW846 8260B	Manzano, Louis	LM
SW846 8260B	Swaney, Garth E	GES

SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
500-24183-1	EW-2	Water	02/18/2010 1730	02/23/2010 0950
500-24183-2	EW-3	Water	02/19/2010 0945	02/23/2010 0950
500-24183-3	EW-4	Water	02/19/2010 1200	02/23/2010 0950
500-24183-4	EW-5	Water	02/18/2010 1130	02/23/2010 0950
500-24183-5	EW-6	Water	02/18/2010 1440	02/23/2010 0950
500-24183-6	EW-7	Water	02/18/2010 1415	02/23/2010 0950
500-24183-7	EW-8	Water	02/18/2010 1400	02/23/2010 0950
500-24183-8	EW-9	Water	02/18/2010 1340	02/23/2010 0950
500-24183-9FD	EW-9 DUP	Water	02/18/2010 1340	02/23/2010 0950
500-24183-10	EW-10	Water	02/18/2010 1330	02/23/2010 0950
500-24183-11	RFW-17	Water	02/18/2010 1140	02/23/2010 0950
500-24183-12	RFW-1A	Water	02/18/2010 1240	02/23/2010 0950
500-24183-13	RFW-1B	Water	02/18/2010 1800	02/23/2010 0950
500-24183-14	RFW-2A	Water	02/18/2010 1430	02/23/2010 0950
500-24183-15	RFW-2B	Water	02/18/2010 1445	02/23/2010 0950
500-24183-16	RFW-6	Water	02/19/2010 0700	02/23/2010 0950
500-24183-17	RFW-12B	Water	02/19/2010 0745	02/23/2010 0950
500-24183-18	RFW-4A	Water	02/19/2010 0830	02/23/2010 0950
500-24183-19FD	RFW-4A DUP	Water	02/19/2010 0830	02/23/2010 0950
500-24183-20	RFW-4B	Water	02/19/2010 0900	02/23/2010 0950
500-24183-21	RFW-9	Water	02/19/2010 1050	02/23/2010 0950
500-24183-22	RFW-11B	Water	02/19/2010 1245	02/23/2010 0950
500-24183-23TB	TRIP BLANK	Water	02/18/2010 0800	02/23/2010 0950



SAMPLE RESULTS

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-2
 Lab Sample ID: 500-24183-1

Date Sampled: 02/18/2010 1730
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 02/24/2010 1833			
Prep Method: 5030B		Date Prepared: 02/24/2010 1833			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	3.5	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	62	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-2
 Lab Sample ID: 500-24183-1

Date Sampled: 02/18/2010 1730
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		72 - 135	
Toluene-d8 (Surr)	95	%		80 - 120	
4-Bromofluorobenzene (Surr)	94	%		77 - 120	
Dibromofluoromethane	102	%		79 - 133	
Method: 8260B Run Type: DL			Date Analyzed: 02/24/2010 1856		
Prep Method: 5030B			Date Prepared: 02/24/2010 1856		
Trichloroethene	410	ug/L	2.4	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	104	%		72 - 135	
Toluene-d8 (Surr)	96	%		80 - 120	
4-Bromofluorobenzene (Surr)	97	%		77 - 120	
Dibromofluoromethane	102	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-3
 Lab Sample ID: 500-24183-2

Date Sampled: 02/19/2010 0945
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	02/24/2010	1920	
Prep Method: 5030B		Date Prepared:	02/24/2010	1920	
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	2.8	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	3.4	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-3
 Lab Sample ID: 500-24183-2

Date Sampled: 02/19/2010 0945
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		72 - 135	
Toluene-d8 (Surr)	93	%		80 - 120	
4-Bromofluorobenzene (Surr)	97	%		77 - 120	
Dibromofluoromethane	102	%		79 - 133	
Method: 8260B Run Type: DL			Date Analyzed: 02/24/2010 1943		
Prep Method: 5030B			Date Prepared: 02/24/2010 1943		
Trichloroethene	130	ug/L	1.2	5.0	5.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	104	%		72 - 135	
Toluene-d8 (Surr)	94	%		80 - 120	
4-Bromofluorobenzene (Surr)	95	%		77 - 120	
Dibromofluoromethane	106	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-4
 Lab Sample ID: 500-24183-3

Date Sampled: 02/19/2010 1200
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 02/24/2010 2007			
Prep Method: 5030B		Date Prepared: 02/24/2010 2007			
Benzene	<5.0	ug/L	0.85	5.0	5.0
Dichlorodifluoromethane	<5.0	ug/L	1.6	5.0	5.0
Chloromethane	<5.0	ug/L	1.2	5.0	5.0
Vinyl chloride	<5.0	ug/L	1.0	5.0	5.0
Bromomethane	<5.0	ug/L	1.9	5.0	5.0
Chloroethane	<5.0	ug/L	1.8	5.0	5.0
Trichlorofluoromethane	<5.0	ug/L	1.0	5.0	5.0
1,1-Dichloroethene	<5.0	ug/L	0.95	5.0	5.0
Carbon disulfide	<25	ug/L	2.8	25	5.0
Acetone	<25	ug/L	8.0	25	5.0
Methylene Chloride	<10	ug/L	3.4	10	5.0
trans-1,2-Dichloroethene	<5.0	ug/L	1.6	5.0	5.0
1,1-Dichloroethane	<5.0	ug/L	1.2	5.0	5.0
2,2-Dichloropropane	<5.0	ug/L	1.2	5.0	5.0
cis-1,2-Dichloroethene	<5.0	ug/L	1.4	5.0	5.0
Methyl Ethyl Ketone	<25	ug/L	12	25	5.0
Bromochloromethane	<5.0	ug/L	1.8	5.0	5.0
Chloroform	<5.0	ug/L	0.75	5.0	5.0
1,1,1-Trichloroethane	<5.0	ug/L	0.90	5.0	5.0
1,1-Dichloropropene	<5.0	ug/L	0.80	5.0	5.0
Carbon tetrachloride	<5.0	ug/L	1.2	5.0	5.0
1,2-Dichloroethane	<5.0	ug/L	1.2	5.0	5.0
1,2-Dichloropropane	<5.0	ug/L	1.0	5.0	5.0
Dibromomethane	<5.0	ug/L	1.5	5.0	5.0
Bromodichloromethane	<5.0	ug/L	0.95	5.0	5.0
cis-1,3-Dichloropropene	<5.0	ug/L	0.85	5.0	5.0
methyl isobutyl ketone	<25	ug/L	4.2	25	5.0
Toluene	<5.0	ug/L	0.95	5.0	5.0
trans-1,3-Dichloropropene	<5.0	ug/L	1.2	5.0	5.0
1,1,2-Trichloroethane	<5.0	ug/L	1.3	5.0	5.0
Tetrachloroethene	22	ug/L	1.1	5.0	5.0
1,3-Dichloropropane	<5.0	ug/L	0.85	5.0	5.0
2-Hexanone	<25	ug/L	4.0	25	5.0
Dibromochloromethane	<5.0	ug/L	1.2	5.0	5.0
1,2-Dibromoethane	<5.0	ug/L	1.8	5.0	5.0
Chlorobenzene	<5.0	ug/L	0.85	5.0	5.0
1,1,1,2-Tetrachloroethane	<5.0	ug/L	0.95	5.0	5.0
Ethylbenzene	<5.0	ug/L	0.90	5.0	5.0
m&p-Xylene	<10	ug/L	1.6	10	5.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-4
 Lab Sample ID: 500-24183-3

Date Sampled: 02/19/2010 1200
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<5.0	ug/L	1.9	5.0	5.0
Styrene	<5.0	ug/L	0.75	5.0	5.0
Bromoform	<5.0	ug/L	2.1	5.0	5.0
Isopropylbenzene	<5.0	ug/L	1.0	5.0	5.0
Bromobenzene	<5.0	ug/L	1.0	5.0	5.0
1,1,2,2-Tetrachloroethane	<5.0	ug/L	1.4	5.0	5.0
1,2,3-Trichloropropane	<5.0	ug/L	2.4	5.0	5.0
N-Propylbenzene	<5.0	ug/L	0.95	5.0	5.0
2-Chlorotoluene	<5.0	ug/L	0.90	5.0	5.0
1,3,5-Trimethylbenzene	<5.0	ug/L	0.90	5.0	5.0
4-Chlorotoluene	<5.0	ug/L	1.0	5.0	5.0
tert-Butylbenzene	<5.0	ug/L	0.80	5.0	5.0
1,2,4-Trimethylbenzene	<5.0	ug/L	0.70	5.0	5.0
sec-Butylbenzene	<5.0	ug/L	0.80	5.0	5.0
1,3-Dichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
p-Isopropyltoluene	<5.0	ug/L	0.80	5.0	5.0
1,4-Dichlorobenzene	<5.0	ug/L	1.0	5.0	5.0
n-Butylbenzene	<5.0	ug/L	0.90	5.0	5.0
1,2-Dichlorobenzene	<5.0	ug/L	0.85	5.0	5.0
1,2-Dibromo-3-Chloropropane	<10	ug/L	4.8	10	5.0
1,2,4-Trichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
Hexachlorobutadiene	<5.0	ug/L	1.3	5.0	5.0
Naphthalene	<5.0	ug/L	2.2	5.0	5.0
1,2,3-Trichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	103	%		72 - 135	
Toluene-d8 (Surr)	95	%		80 - 120	
4-Bromofluorobenzene (Surr)	95	%		77 - 120	
Dibromofluoromethane	104	%		79 - 133	
Method: 8260B Run Type: DL			Date Analyzed: 02/24/2010 2030		
Prep Method: 5030B			Date Prepared: 02/24/2010 2030		
Trichloroethene	1100	ug/L	12	50	50
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		72 - 135	
Toluene-d8 (Surr)	93	%		80 - 120	
4-Bromofluorobenzene (Surr)	92	%		77 - 120	
Dibromofluoromethane	102	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-5
 Lab Sample ID: 500-24183-4

Date Sampled: 02/18/2010 1130
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 02/24/2010 2054			
Prep Method: 5030B		Date Prepared: 02/24/2010 2054			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	5.9	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-5
 Lab Sample ID: 500-24183-4

Date Sampled: 02/18/2010 1130
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		72 - 135	
Toluene-d8 (Surr)	97	%		80 - 120	
4-Bromofluorobenzene (Surr)	97	%		77 - 120	
Dibromofluoromethane	104	%		79 - 133	
Method: 8260B Run Type: DL			Date Analyzed: 02/24/2010 2117		
Prep Method: 5030B			Date Prepared: 02/24/2010 2117		
Trichloroethene	150	ug/L	1.2	5.0	5.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	106	%		72 - 135	
Toluene-d8 (Surr)	94	%		80 - 120	
4-Bromofluorobenzene (Surr)	94	%		77 - 120	
Dibromofluoromethane	107	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-6
 Lab Sample ID: 500-24183-5

Date Sampled: 02/18/2010 1440
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	02/24/2010	2140	
Prep Method: 5030B		Date Prepared:	02/24/2010	2140	
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	10	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	17	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-6
 Lab Sample ID: 500-24183-5

Date Sampled: 02/18/2010 1440
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	105	%		72 - 135	
Toluene-d8 (Surr)	94	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		77 - 120	
Dibromofluoromethane	103	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-7
 Lab Sample ID: 500-24183-6

Date Sampled: 02/18/2010 1415
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 02/24/2010 2204			
Prep Method: 5030B		Date Prepared: 02/24/2010 2204			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	4.4	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	4.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	9.6	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-7
 Lab Sample ID: 500-24183-6

Date Sampled: 02/18/2010 1415
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		72 - 135	
Toluene-d8 (Surr)	94	%		80 - 120	
4-Bromofluorobenzene (Surr)	95	%		77 - 120	
Dibromofluoromethane	101	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-8
 Lab Sample ID: 500-24183-7

Date Sampled: 02/18/2010 1400
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	02/24/2010 2227		
Prep Method: 5030B		Date Prepared:	02/24/2010 2227		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	24	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	10	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	63	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-8
 Lab Sample ID: 500-24183-7

Date Sampled: 02/18/2010 1400
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	105	%		72 - 135	
Toluene-d8 (Surr)	92	%		80 - 120	
4-Bromofluorobenzene (Surr)	97	%		77 - 120	
Dibromofluoromethane	105	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-9
 Lab Sample ID: 500-24183-8

Date Sampled: 02/18/2010 1340
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	02/24/2010	2251	
Prep Method: 5030B		Date Prepared:	02/24/2010	2251	
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	1.1	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-9
 Lab Sample ID: 500-24183-8

Date Sampled: 02/18/2010 1340
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	106	%		72 - 135	
Toluene-d8 (Surr)	94	%		80 - 120	
4-Bromofluorobenzene (Surr)	93	%		77 - 120	
Dibromofluoromethane	107	%		79 - 133	
Method: 8260B Run Type: DL			Date Analyzed: 02/24/2010 2314		
Prep Method: 5030B			Date Prepared: 02/24/2010 2314		
Tetrachloroethene	110	ug/L	0.44	2.0	2.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	111	%		72 - 135	
Toluene-d8 (Surr)	94	%		80 - 120	
4-Bromofluorobenzene (Surr)	94	%		77 - 120	
Dibromofluoromethane	111	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-9 DUP
 Lab Sample ID: 500-24183-9

Date Sampled: 02/18/2010 1340
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	02/24/2010	2337	
Prep Method: 5030B		Date Prepared:	02/24/2010	2337	
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	0.95 J	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0 *	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-9 DUP
 Lab Sample ID: 500-24183-9

Date Sampled: 02/18/2010 1340
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	104	%	72 - 135
Toluene-d8 (Surr)	91	%	80 - 120
4-Bromofluorobenzene (Surr)	95	%	77 - 120
Dibromofluoromethane	105	%	79 - 133

Method: 8260B Run Type: DL

Date Analyzed: 02/26/2010 0257

Prep Method: 5030B

Date Prepared: 02/26/2010 0257

Tetrachloroethene	100	ug/L	0.44	2.0	2.0
-------------------	-----	------	------	-----	-----

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	100	%	72 - 135
Toluene-d8 (Surr)	91	%	80 - 120
4-Bromofluorobenzene (Surr)	97	%	77 - 120
Dibromofluoromethane	110	%	79 - 133

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-10
 Lab Sample ID: 500-24183-10

Date Sampled: 02/18/2010 1330
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 02/26/2010 0320			
Prep Method: 5030B		Date Prepared: 02/26/2010 0320			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-10
 Lab Sample ID: 500-24183-10

Date Sampled: 02/18/2010 1330
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		72 - 135	
Toluene-d8 (Surr)	91	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		77 - 120	
Dibromofluoromethane	110	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-17
 Lab Sample ID: 500-24183-11

Date Sampled: 02/18/2010 1140
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 02/26/2010 0344			
Prep Method: 5030B		Date Prepared: 02/26/2010 0344			
Benzene	1.5	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-17
 Lab Sample ID: 500-24183-11

Date Sampled: 02/18/2010 1140
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	104	%		72 - 135	
Toluene-d8 (Surr)	93	%		80 - 120	
4-Bromofluorobenzene (Surr)	98	%		77 - 120	
Dibromofluoromethane	110	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-1A
 Lab Sample ID: 500-24183-12

Date Sampled: 02/18/2010 1240
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 02/26/2010 0407			
Prep Method: 5030B		Date Prepared: 02/26/2010 0407			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-1A
 Lab Sample ID: 500-24183-12

Date Sampled: 02/18/2010 1240
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		72 - 135	
Toluene-d8 (Surr)	91	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		77 - 120	
Dibromofluoromethane	108	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-1B
 Lab Sample ID: 500-24183-13

Date Sampled: 02/18/2010 1800
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 02/26/2010 0430			
Prep Method: 5030B		Date Prepared: 02/26/2010 0430			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-1B
 Lab Sample ID: 500-24183-13

Date Sampled: 02/18/2010 1800
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		72 - 135	
Toluene-d8 (Surr)	92	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		77 - 120	
Dibromofluoromethane	110	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-2A
 Lab Sample ID: 500-24183-14

Date Sampled: 02/18/2010 1430
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	02/26/2010 0453		
Prep Method: 5030B		Date Prepared:	02/26/2010 0453		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-2A
 Lab Sample ID: 500-24183-14

Date Sampled: 02/18/2010 1430
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	104	%		72 - 135	
Toluene-d8 (Surr)	91	%		80 - 120	
4-Bromofluorobenzene (Surr)	95	%		77 - 120	
Dibromofluoromethane	110	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-2B
 Lab Sample ID: 500-24183-15

Date Sampled: 02/18/2010 1445
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed: 02/26/2010 0516		
Prep Method: 5030B			Date Prepared: 02/26/2010 0516		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-2B
 Lab Sample ID: 500-24183-15

Date Sampled: 02/18/2010 1445
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	104	%		72 - 135	
Toluene-d8 (Surr)	92	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		77 - 120	
Dibromofluoromethane	108	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-6
 Lab Sample ID: 500-24183-16

Date Sampled: 02/19/2010 0700
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 02/26/2010 0539			
Prep Method: 5030B		Date Prepared: 02/26/2010 0539			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	1.4	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-6
 Lab Sample ID: 500-24183-16

Date Sampled: 02/19/2010 0700
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	106	%		72 - 135	
Toluene-d8 (Surr)	91	%		80 - 120	
4-Bromofluorobenzene (Surr)	98	%		77 - 120	
Dibromofluoromethane	116	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-12B
 Lab Sample ID: 500-24183-17

Date Sampled: 02/19/2010 0745
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 02/26/2010 0648			
Prep Method: 5030B		Date Prepared: 02/26/2010 0648			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	3.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	25	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-12B
 Lab Sample ID: 500-24183-17

Date Sampled: 02/19/2010 0745
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	105	%		72 - 135	
Toluene-d8 (Surr)	92	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		77 - 120	
Dibromofluoromethane	111	%		79 - 133	
Method: 8260B Run Type: DL			Date Analyzed: 02/26/2010 0711		
Prep Method: 5030B			Date Prepared: 02/26/2010 0711		
Trichloroethene	280	ug/L	1.2	5.0	5.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		72 - 135	
Toluene-d8 (Surr)	92	%		80 - 120	
4-Bromofluorobenzene (Surr)	97	%		77 - 120	
Dibromofluoromethane	114	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-4A
 Lab Sample ID: 500-24183-18

Date Sampled: 02/19/2010 0830
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 03/02/2010 2009			
Prep Method: 5030B		Date Prepared: 03/02/2010 2009			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	30	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	17	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-4A
 Lab Sample ID: 500-24183-18

Date Sampled: 02/19/2010 0830
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	110	%		72 - 135	
Toluene-d8 (Surr)	101	%		80 - 120	
4-Bromofluorobenzene (Surr)	98	%		77 - 120	
Dibromofluoromethane	108	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-4A DUP
 Lab Sample ID: 500-24183-19

Date Sampled: 02/19/2010 0830
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	03/02/2010 2032		
Prep Method: 5030B		Date Prepared:	03/02/2010 2032		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	28	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	16	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-4A DUP
 Lab Sample ID: 500-24183-19

Date Sampled: 02/19/2010 0830
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	108	%		72 - 135	
Toluene-d8 (Surr)	98	%		80 - 120	
4-Bromofluorobenzene (Surr)	95	%		77 - 120	
Dibromofluoromethane	105	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-4B
 Lab Sample ID: 500-24183-20

Date Sampled: 02/19/2010 0900
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	03/02/2010 2055		
Prep Method: 5030B		Date Prepared:	03/02/2010 2055		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	3.7	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	50	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	69	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-4B
 Lab Sample ID: 500-24183-20

Date Sampled: 02/19/2010 0900
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	112	%		72 - 135	
Toluene-d8 (Surr)	98	%		80 - 120	
4-Bromofluorobenzene (Surr)	98	%		77 - 120	
Dibromofluoromethane	110	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-9
 Lab Sample ID: 500-24183-21

Date Sampled: 02/19/2010 1050
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	03/02/2010 2118		
Prep Method: 5030B		Date Prepared:	03/02/2010 2118		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	1.3	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	1.6	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	25	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	1.6	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	15	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	8.5	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-9
 Lab Sample ID: 500-24183-21

Date Sampled: 02/19/2010 1050
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	110	%		72 - 135	
Toluene-d8 (Surr)	97	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		77 - 120	
Dibromofluoromethane	110	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-11B
 Lab Sample ID: 500-24183-22

Date Sampled: 02/19/2010 1245
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	03/02/2010	2141	
Prep Method: 5030B		Date Prepared:	03/02/2010	2141	
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	7.9	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-11B
 Lab Sample ID: 500-24183-22

Date Sampled: 02/19/2010 1245
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		72 - 135	
Toluene-d8 (Surr)	97	%		80 - 120	
4-Bromofluorobenzene (Surr)	98	%		77 - 120	
Dibromofluoromethane	111	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: TRIP BLANK
 Lab Sample ID: 500-24183-23

Date Sampled: 02/18/2010 0800
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	03/02/2010	2204	
Prep Method: 5030B		Date Prepared:	03/02/2010	2204	
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	9.8	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	6.8	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	2.8	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: TRIP BLANK
 Lab Sample ID: 500-24183-23

Date Sampled: 02/18/2010 0800
 Date Received: 02/23/2010 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	1.7	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	112	%	72 - 135
Toluene-d8 (Surr)	93	%	80 - 120
4-Bromofluorobenzene (Surr)	96	%	77 - 120
Dibromofluoromethane	108	%	79 - 133

Method: 8260B Date Analyzed: 03/03/2010 1542
 Prep Method: 5030B Date Prepared: 03/03/2010 1542

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	111	%	72 - 135
Toluene-d8 (Surr)	95	%	80 - 120
4-Bromofluorobenzene (Surr)	98	%	77 - 120
Dibromofluoromethane	106	%	79 - 133

DATA REPORTING QUALIFIERS

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

<u>Lab Section</u>	<u>Qualifier</u>	<u>Description</u>
GC/MS VOA	*	LCS or LCSD exceeds the control limits
	J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

QUALITY CONTROL RESULTS

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

QC Association Summary

Lab Sample ID	Client Sample ID	Report Basis	Client Matrix	Method	Prep Batch
GC/MS VOA					
Analysis Batch:500-81056					
LCS 500-81056/5	Lab Control Sample	T	Water	8260B	
MB 500-81056/4	Method Blank	T	Water	8260B	
500-24183-1	EW-2	T	Water	8260B	
500-24183-1DL	EW-2	T	Water	8260B	
500-24183-2	EW-3	T	Water	8260B	
500-24183-2DL	EW-3	T	Water	8260B	
500-24183-3	EW-4	T	Water	8260B	
500-24183-3DL	EW-4	T	Water	8260B	
500-24183-4	EW-5	T	Water	8260B	
500-24183-4DL	EW-5	T	Water	8260B	
500-24183-5	EW-6	T	Water	8260B	
500-24183-6	EW-7	T	Water	8260B	
500-24183-7	EW-8	T	Water	8260B	
500-24183-8	EW-9	T	Water	8260B	
500-24183-8DL	EW-9	T	Water	8260B	
500-24183-9FD	EW-9 DUP	T	Water	8260B	
Analysis Batch:500-81145					
LCS 500-81145/6	Lab Control Sample	T	Water	8260B	
MB 500-81145/4	Method Blank	T	Water	8260B	
500-24183-9FDDL	EW-9 DUP	T	Water	8260B	
500-24183-10	EW-10	T	Water	8260B	
500-24183-11	RFW-17	T	Water	8260B	
500-24183-12	RFW-1A	T	Water	8260B	
500-24183-13	RFW-1B	T	Water	8260B	
500-24183-14	RFW-2A	T	Water	8260B	
500-24183-15	RFW-2B	T	Water	8260B	
500-24183-16	RFW-6	T	Water	8260B	
500-24183-17	RFW-12B	T	Water	8260B	
500-24183-17DL	RFW-12B	T	Water	8260B	
Analysis Batch:500-81296					
LCS 500-81296/8	Lab Control Sample	T	Water	8260B	
MB 500-81296/7	Method Blank	T	Water	8260B	
500-24183-18	RFW-4A	T	Water	8260B	
500-24183-19FD	RFW-4A DUP	T	Water	8260B	
500-24183-20	RFW-4B	T	Water	8260B	
500-24183-21	RFW-9	T	Water	8260B	
500-24183-22	RFW-11B	T	Water	8260B	
500-24183-23TB	TRIP BLANK	T	Water	8260B	
Analysis Batch:500-81369					
LCS 500-81369/9	Lab Control Sample	T	Water	8260B	
MB 500-81369/8	Method Blank	T	Water	8260B	
500-24183-23TB	TRIP BLANK	T	Water	8260B	

TestAmerica Chicago

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

QC Association Summary

<u>Lab Sample ID</u>	<u>Client Sample ID</u>	<u>Report Basis</u>	<u>Client Matrix</u>	<u>Method</u>	<u>Prep Batch</u>
----------------------	-------------------------	---------------------	----------------------	---------------	-------------------

Report Basis

T = Total

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Surrogate Recovery Report

8260B VOC

Client Matrix: Water

Lab Sample ID	Client Sample ID	DCA %Rec	TOL %Rec	BFB %Rec	DBFM %Rec
500-24183-1	EW-2	101	95	94	102
500-24183-1 DL	EW-2 DL	104	96	97	102
500-24183-2	EW-3	102	93	97	102
500-24183-2 DL	EW-3 DL	104	94	95	106
500-24183-3	EW-4	103	95	95	104
500-24183-3 DL	EW-4 DL	98	93	92	102
500-24183-4	EW-5	109	97	97	104
500-24183-4 DL	EW-5 DL	106	94	94	107
500-24183-5	EW-6	105	94	96	103
500-24183-6	EW-7	102	94	95	101
500-24183-7	EW-8	105	92	97	105
500-24183-8	EW-9	106	94	93	107
500-24183-8 DL	EW-9 DL	111	94	94	111
500-24183-9	EW-9 DUP	104	91	95	105
500-24183-9 DL	EW-9 DUP DL	100	91	97	110
500-24183-10	EW-10	101	91	96	110
500-24183-11	RFW-17	104	93	98	110
500-24183-12	RFW-1A	102	91	96	108
500-24183-13	RFW-1B	102	92	96	110
500-24183-14	RFW-2A	104	91	95	110
500-24183-15	RFW-2B	104	92	96	108
500-24183-16	RFW-6	106	91	98	116
500-24183-17	RFW-12B	105	92	96	111
500-24183-17 DL	RFW-12B DL	102	92	97	114
500-24183-18	RFW-4A	110	101	98	108
500-24183-19	RFW-4A DUP	108	98	95	105
500-24183-20	RFW-4B	112	98	98	110
500-24183-21	RFW-9	110	97	96	110
500-24183-22	RFW-11B	109	97	98	111

Surrogate	Acceptance Limits
DCA = 1,2-Dichloroethane-d4 (Surr)	72-135
TOL = Toluene-d8 (Surr)	80-120
BFB = 4-Bromofluorobenzene (Surr)	77-120
DBFM = Dibromofluoromethane	79-133

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Surrogate Recovery Report

8260B VOC

Client Matrix: Water

Lab Sample ID	Client Sample ID	DCA %Rec	TOL %Rec	BFB %Rec	DBFM %Rec
500-24183-23	TRIP BLANK	112	93	96	108
500-24183-23	TRIP BLANK	111	95	98	106
MB 500-81056/4		101	95	96	100
MB 500-81145/4		100	92	98	106
MB 500-81296/7		107	96	95	105
MB 500-81369/8		114	98	99	110
LCS 500-81056/5		101	97	98	98
LCS 500-81145/6		100	94	100	103
LCS 500-81296/8		104	98	96	102
LCS 500-81369/9		108	98	100	107

Surrogate	Acceptance Limits
DCA = 1,2-Dichloroethane-d4 (Surr)	72-135
TOL = Toluene-d8 (Surr)	80-120
BFB = 4-Bromofluorobenzene (Surr)	77-120
DBFM = Dibromofluoromethane	79-133

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Method Blank - Batch: 500-81056

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-81056/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/24/2010 1503
Date Prepared: 02/24/2010 1503

Analysis Batch: 500-81056
Prep Batch: N/A
Units: ug/L

Instrument ID: MS18
Lab File ID: 18m0224.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.17	1.0
Dichlorodifluoromethane	<1.0		0.31	1.0
Chloromethane	<1.0		0.24	1.0
Vinyl chloride	<1.0		0.20	1.0
Bromomethane	<1.0		0.38	1.0
Chloroethane	<1.0		0.36	1.0
Trichlorofluoromethane	<1.0		0.20	1.0
1,1-Dichloroethene	<1.0		0.19	1.0
Carbon disulfide	<5.0		0.55	5.0
Acetone	<5.0		1.6	5.0
Methylene Chloride	<2.0		0.67	2.0
trans-1,2-Dichloroethene	<1.0		0.32	1.0
1,1-Dichloroethane	<1.0		0.25	1.0
2,2-Dichloropropane	<1.0		0.24	1.0
cis-1,2-Dichloroethene	<1.0		0.27	1.0
Methyl Ethyl Ketone	<5.0		2.3	5.0
Bromochloromethane	<1.0		0.35	1.0
Chloroform	<1.0		0.15	1.0
1,1,1-Trichloroethane	<1.0		0.18	1.0
1,1-Dichloropropene	<1.0		0.16	1.0
Carbon tetrachloride	<1.0		0.25	1.0
1,2-Dichloroethane	<1.0		0.24	1.0
Trichloroethene	<1.0		0.24	1.0
1,2-Dichloropropane	<1.0		0.21	1.0
Dibromomethane	<1.0		0.30	1.0
Bromodichloromethane	<1.0		0.19	1.0
cis-1,3-Dichloropropene	<1.0		0.17	1.0
methyl isobutyl ketone	<5.0		0.84	5.0
Toluene	<1.0		0.19	1.0
trans-1,3-Dichloropropene	<1.0		0.24	1.0
1,1,2-Trichloroethane	<1.0		0.26	1.0
Tetrachloroethene	<1.0		0.22	1.0
1,3-Dichloropropane	<1.0		0.17	1.0
2-Hexanone	<5.0		0.80	5.0
Dibromochloromethane	<1.0		0.25	1.0
1,2-Dibromoethane	<1.0		0.37	1.0
Chlorobenzene	<1.0		0.17	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.19	1.0
Ethylbenzene	<1.0		0.18	1.0
m&p-Xylene	<2.0		0.32	2.0
o-Xylene	<1.0		0.38	1.0

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Method Blank - Batch: 500-81056

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-81056/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/24/2010 1503
Date Prepared: 02/24/2010 1503

Analysis Batch: 500-81056
Prep Batch: N/A
Units: ug/L

Instrument ID: MS18
Lab File ID: 18m0224.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Styrene	<1.0		0.15	1.0
Bromoform	<1.0		0.42	1.0
Isopropylbenzene	<1.0		0.20	1.0
Bromobenzene	<1.0		0.21	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.29	1.0
1,2,3-Trichloropropane	<1.0		0.48	1.0
N-Propylbenzene	<1.0		0.19	1.0
2-Chlorotoluene	<1.0		0.18	1.0
1,3,5-Trimethylbenzene	<1.0		0.18	1.0
4-Chlorotoluene	<1.0		0.21	1.0
tert-Butylbenzene	<1.0		0.16	1.0
1,2,4-Trimethylbenzene	<1.0		0.14	1.0
sec-Butylbenzene	<1.0		0.16	1.0
1,3-Dichlorobenzene	<1.0		0.24	1.0
p-Isopropyltoluene	<1.0		0.16	1.0
1,4-Dichlorobenzene	<1.0		0.21	1.0
n-Butylbenzene	<1.0		0.18	1.0
1,2-Dichlorobenzene	<1.0		0.17	1.0
1,2-Dibromo-3-Chloropropane	<2.0		0.96	2.0
1,2,4-Trichlorobenzene	<1.0		0.24	1.0
Hexachlorobutadiene	<1.0		0.26	1.0
Naphthalene	<1.0		0.44	1.0
1,2,3-Trichlorobenzene	<1.0		0.24	1.0

Surrogate	% Rec	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	101	72 - 135
Toluene-d8 (Surr)	95	80 - 120
4-Bromofluorobenzene (Surr)	96	77 - 120
Dibromofluoromethane	100	79 - 133

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Lab Control Sample - Batch: 500-81056

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-81056/5
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/24/2010 1440
Date Prepared: 02/24/2010 1440

Analysis Batch: 500-81056
Prep Batch: N/A
Units: ug/L

Instrument ID: MS18
Lab File ID: 18s0224.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	25.0	23.9	96	70 - 120	
Dichlorodifluoromethane	25.0	37.6	150	58 - 186	
Chloromethane	25.0	30.0	120	56 - 133	
Vinyl chloride	25.0	19.3	77	75 - 158	
Bromomethane	25.0	27.1	108	56 - 154	
Chloroethane	25.0	26.3	105	60 - 144	
Trichlorofluoromethane	25.0	27.6	111	58 - 146	
1,1-Dichloroethene	25.0	16.5	66	55 - 129	
Carbon disulfide	25.0	15.3	61	31 - 146	
Acetone	25.0	23.8	95	29 - 152	
Methylene Chloride	25.0	21.6	87	63 - 128	
trans-1,2-Dichloroethene	25.0	21.8	87	66 - 120	
1,1-Dichloroethane	25.0	23.6	94	65 - 120	
2,2-Dichloropropane	25.0	24.3	97	59 - 121	
cis-1,2-Dichloroethene	25.0	20.8	83	72 - 123	
Methyl Ethyl Ketone	25.0	27.3	109	47 - 138	
Bromochloromethane	25.0	23.6	95	63 - 122	
Chloroform	25.0	23.8	95	70 - 120	
1,1,1-Trichloroethane	25.0	24.4	97	64 - 122	
1,1-Dichloropropene	25.0	23.1	92	70 - 120	
Carbon tetrachloride	25.0	23.8	95	62 - 122	
1,2-Dichloroethane	25.0	25.2	101	62 - 120	
Trichloroethene	25.0	22.8	91	71 - 120	
1,2-Dichloropropane	25.0	24.7	99	75 - 120	
Dibromomethane	25.0	23.7	95	72 - 120	
Bromodichloromethane	25.0	25.9	104	74 - 120	
cis-1,3-Dichloropropene	26.9	26.2	98	65 - 120	
methyl isobutyl ketone	25.0	28.5	114	59 - 120	
Toluene	25.0	23.9	96	72 - 120	
trans-1,3-Dichloropropene	24.3	23.8	98	59 - 120	
1,1,2-Trichloroethane	25.0	24.7	99	68 - 126	
Tetrachloroethene	25.0	23.1	92	70 - 120	
1,3-Dichloropropane	25.0	24.3	97	77 - 120	
2-Hexanone	25.0	30.5	122	56 - 120	
Dibromochloromethane	25.0	26.2	105	64 - 120	
1,2-Dibromoethane	25.0	25.1	100	72 - 120	
Chlorobenzene	25.0	24.2	97	75 - 120	
1,1,1,2-Tetrachloroethane	25.0	25.0	100	70 - 121	
Ethylbenzene	25.0	25.4	102	76 - 120	
m&p-Xylene	50.0	50.6	101	74 - 120	
o-Xylene	25.0	24.6	98	74 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Lab Control Sample - Batch: 500-81056

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-81056/5
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/24/2010 1440
Date Prepared: 02/24/2010 1440

Analysis Batch: 500-81056
Prep Batch: N/A
Units: ug/L

Instrument ID: MS18
Lab File ID: 18s0224.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Styrene	25.0	25.7	103	76 - 120	
Bromoform	25.0	22.3	89	58 - 120	
Isopropylbenzene	25.0	23.5	94	64 - 120	
Bromobenzene	25.0	26.2	105	68 - 120	
1,1,2,2-Tetrachloroethane	25.0	27.2	109	69 - 120	
1,2,3-Trichloropropane	25.0	26.3	105	65 - 120	
N-Propylbenzene	25.0	26.7	107	66 - 120	
2-Chlorotoluene	25.0	27.2	109	68 - 120	
1,3,5-Trimethylbenzene	25.0	27.4	110	68 - 120	
4-Chlorotoluene	25.0	26.7	107	65 - 120	
tert-Butylbenzene	25.0	26.8	107	67 - 120	
1,2,4-Trimethylbenzene	25.0	26.9	108	70 - 120	
sec-Butylbenzene	25.0	26.9	108	71 - 120	
1,3-Dichlorobenzene	25.0	26.0	104	73 - 120	
p-Isopropyltoluene	25.0	24.8	99	70 - 120	
1,4-Dichlorobenzene	25.0	25.2	101	72 - 120	
n-Butylbenzene	25.0	26.4	106	72 - 120	
1,2-Dichlorobenzene	25.0	25.6	102	62 - 131	
1,2-Dibromo-3-Chloropropane	25.0	28.8	115	55 - 130	
1,2,4-Trichlorobenzene	25.0	22.7	91	54 - 120	
Hexachlorobutadiene	25.0	23.8	95	64 - 125	
Naphthalene	25.0	26.2	105	51 - 120	
1,2,3-Trichlorobenzene	25.0	23.5	94	57 - 120	
Surrogate		% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)		101		72 - 135	
Toluene-d8 (Surr)		97		80 - 120	
4-Bromofluorobenzene (Surr)		98		77 - 120	
Dibromofluoromethane		98		79 - 133	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Method Blank - Batch: 500-81145

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-81145/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/25/2010 2126
Date Prepared: 02/25/2010 2126

Analysis Batch: 500-81145
Prep Batch: N/A
Units: ug/L

Instrument ID: MS18
Lab File ID: 18m0225d.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.17	1.0
Dichlorodifluoromethane	<1.0		0.31	1.0
Chloromethane	<1.0		0.24	1.0
Vinyl chloride	<1.0		0.20	1.0
Bromomethane	<1.0		0.38	1.0
Chloroethane	<1.0		0.36	1.0
Trichlorofluoromethane	<1.0		0.20	1.0
1,1-Dichloroethene	<1.0		0.19	1.0
Carbon disulfide	<5.0		0.55	5.0
Acetone	<5.0		1.6	5.0
Methylene Chloride	<2.0		0.67	2.0
trans-1,2-Dichloroethene	<1.0		0.32	1.0
1,1-Dichloroethane	<1.0		0.25	1.0
2,2-Dichloropropane	<1.0		0.24	1.0
cis-1,2-Dichloroethene	<1.0		0.27	1.0
Methyl Ethyl Ketone	<5.0		2.3	5.0
Bromochloromethane	<1.0		0.35	1.0
Chloroform	<1.0		0.15	1.0
1,1,1-Trichloroethane	<1.0		0.18	1.0
1,1-Dichloropropene	<1.0		0.16	1.0
Carbon tetrachloride	<1.0		0.25	1.0
1,2-Dichloroethane	<1.0		0.24	1.0
Trichloroethene	<1.0		0.24	1.0
1,2-Dichloropropane	<1.0		0.21	1.0
Dibromomethane	<1.0		0.30	1.0
Bromodichloromethane	<1.0		0.19	1.0
cis-1,3-Dichloropropene	<1.0		0.17	1.0
methyl isobutyl ketone	<5.0		0.84	5.0
Toluene	<1.0		0.19	1.0
trans-1,3-Dichloropropene	<1.0		0.24	1.0
1,1,2-Trichloroethane	<1.0		0.26	1.0
Tetrachloroethene	<1.0		0.22	1.0
1,3-Dichloropropane	<1.0		0.17	1.0
2-Hexanone	<5.0		0.80	5.0
Dibromochloromethane	<1.0		0.25	1.0
1,2-Dibromoethane	<1.0		0.37	1.0
Chlorobenzene	<1.0		0.17	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.19	1.0
Ethylbenzene	<1.0		0.18	1.0
m&p-Xylene	<2.0		0.32	2.0
o-Xylene	<1.0		0.38	1.0

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Method Blank - Batch: 500-81145

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-81145/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/25/2010 2126
Date Prepared: 02/25/2010 2126

Analysis Batch: 500-81145
Prep Batch: N/A
Units: ug/L

Instrument ID: MS18
Lab File ID: 18m0225d.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Styrene	<1.0		0.15	1.0
Bromoform	<1.0		0.42	1.0
Isopropylbenzene	<1.0		0.20	1.0
Bromobenzene	<1.0		0.21	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.29	1.0
1,2,3-Trichloropropane	<1.0		0.48	1.0
N-Propylbenzene	<1.0		0.19	1.0
2-Chlorotoluene	<1.0		0.18	1.0
1,3,5-Trimethylbenzene	<1.0		0.18	1.0
4-Chlorotoluene	<1.0		0.21	1.0
tert-Butylbenzene	<1.0		0.16	1.0
1,2,4-Trimethylbenzene	<1.0		0.14	1.0
sec-Butylbenzene	<1.0		0.16	1.0
1,3-Dichlorobenzene	<1.0		0.24	1.0
p-Isopropyltoluene	<1.0		0.16	1.0
1,4-Dichlorobenzene	<1.0		0.21	1.0
n-Butylbenzene	<1.0		0.18	1.0
1,2-Dichlorobenzene	<1.0		0.17	1.0
1,2-Dibromo-3-Chloropropane	<2.0		0.96	2.0
1,2,4-Trichlorobenzene	<1.0		0.24	1.0
Hexachlorobutadiene	<1.0		0.26	1.0
Naphthalene	<1.0		0.44	1.0
1,2,3-Trichlorobenzene	<1.0		0.24	1.0

Surrogate	% Rec	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	100	72 - 135
Toluene-d8 (Surr)	92	80 - 120
4-Bromofluorobenzene (Surr)	98	77 - 120
Dibromofluoromethane	106	79 - 133

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Lab Control Sample - Batch: 500-81145

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-81145/6
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/25/2010 2103
Date Prepared: 02/25/2010 2103

Analysis Batch: 500-81145
Prep Batch: N/A
Units: ug/L

Instrument ID: MS18
Lab File ID: 18s0225d.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	25.0	21.4	86	70 - 120	
Dichlorodifluoromethane	25.0	35.4	142	58 - 186	
Chloromethane	25.0	24.9	100	56 - 133	
Vinyl chloride	25.0	19.0	76	75 - 158	
Bromomethane	25.0	28.5	114	56 - 154	
Chloroethane	25.0	25.4	102	60 - 144	
Trichlorofluoromethane	25.0	27.2	109	58 - 146	
1,1-Dichloroethene	25.0	15.4	62	55 - 129	
Carbon disulfide	25.0	12.0	48	31 - 146	
Acetone	25.0	19.4	78	29 - 152	
Methylene Chloride	25.0	20.0	80	63 - 128	
trans-1,2-Dichloroethene	25.0	20.6	83	66 - 120	
1,1-Dichloroethane	25.0	21.8	87	65 - 120	
2,2-Dichloropropane	25.0	24.3	97	59 - 121	
cis-1,2-Dichloroethene	25.0	19.8	79	72 - 123	
Methyl Ethyl Ketone	25.0	24.7	99	47 - 138	
Bromochloromethane	25.0	22.0	88	63 - 122	
Chloroform	25.0	23.3	93	70 - 120	
1,1,1-Trichloroethane	25.0	23.0	92	64 - 122	
1,1-Dichloropropene	25.0	22.0	88	70 - 120	
Carbon tetrachloride	25.0	22.4	89	62 - 122	
1,2-Dichloroethane	25.0	23.6	94	62 - 120	
Trichloroethene	25.0	21.6	87	71 - 120	
1,2-Dichloropropane	25.0	22.5	90	75 - 120	
Dibromomethane	25.0	22.5	90	72 - 120	
Bromodichloromethane	25.0	23.5	94	74 - 120	
cis-1,3-Dichloropropene	26.9	23.6	88	65 - 120	
methyl isobutyl ketone	25.0	24.0	96	59 - 120	
Toluene	25.0	21.6	86	72 - 120	
trans-1,3-Dichloropropene	24.3	22.0	90	59 - 120	
1,1,2-Trichloroethane	25.0	24.5	98	68 - 126	
Tetrachloroethene	25.0	21.3	85	70 - 120	
1,3-Dichloropropane	25.0	24.3	97	77 - 120	
2-Hexanone	25.0	27.4	110	56 - 120	
Dibromochloromethane	25.0	25.8	103	64 - 120	
1,2-Dibromoethane	25.0	23.3	93	72 - 120	
Chlorobenzene	25.0	23.5	94	75 - 120	
1,1,1,2-Tetrachloroethane	25.0	24.2	97	70 - 121	
Ethylbenzene	25.0	24.3	97	76 - 120	
m&p-Xylene	50.0	48.4	97	74 - 120	
o-Xylene	25.0	23.9	96	74 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Lab Control Sample - Batch: 500-81145

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-81145/6
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/25/2010 2103
Date Prepared: 02/25/2010 2103

Analysis Batch: 500-81145
Prep Batch: N/A
Units: ug/L

Instrument ID: MS18
Lab File ID: 18s0225d.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Styrene	25.0	24.9	100	76 - 120	
Bromoform	25.0	22.3	89	58 - 120	
Isopropylbenzene	25.0	22.4	90	64 - 120	
Bromobenzene	25.0	24.4	97	68 - 120	
1,1,2,2-Tetrachloroethane	25.0	26.5	106	69 - 120	
1,2,3-Trichloropropane	25.0	26.9	107	65 - 120	
N-Propylbenzene	25.0	25.2	101	66 - 120	
2-Chlorotoluene	25.0	25.2	101	68 - 120	
1,3,5-Trimethylbenzene	25.0	26.2	105	68 - 120	
4-Chlorotoluene	25.0	25.2	101	65 - 120	
tert-Butylbenzene	25.0	26.2	105	67 - 120	
1,2,4-Trimethylbenzene	25.0	26.2	105	70 - 120	
sec-Butylbenzene	25.0	26.2	105	71 - 120	
1,3-Dichlorobenzene	25.0	24.4	98	73 - 120	
p-Isopropyltoluene	25.0	24.8	99	70 - 120	
1,4-Dichlorobenzene	25.0	23.0	92	72 - 120	
n-Butylbenzene	25.0	25.8	103	72 - 120	
1,2-Dichlorobenzene	25.0	24.3	97	62 - 131	
1,2-Dibromo-3-Chloropropane	25.0	27.4	110	55 - 130	
1,2,4-Trichlorobenzene	25.0	21.8	87	54 - 120	
Hexachlorobutadiene	25.0	21.7	87	64 - 125	
Naphthalene	25.0	26.8	107	51 - 120	
1,2,3-Trichlorobenzene	25.0	23.1	93	57 - 120	
Surrogate		% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)		100		72 - 135	
Toluene-d8 (Surr)		94		80 - 120	
4-Bromofluorobenzene (Surr)		100		77 - 120	
Dibromofluoromethane		103		79 - 133	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Method Blank - Batch: 500-81296

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-81296/7
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/02/2010 1433
Date Prepared: 03/02/2010 1433

Analysis Batch: 500-81296
Prep Batch: N/A
Units: ug/L

Instrument ID: MS06
Lab File ID: 6M0302.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.17	1.0
Dichlorodifluoromethane	<1.0		0.31	1.0
Chloromethane	<1.0		0.24	1.0
Vinyl chloride	<1.0		0.20	1.0
Bromomethane	<1.0		0.38	1.0
Chloroethane	<1.0		0.36	1.0
Trichlorofluoromethane	<1.0		0.20	1.0
1,1-Dichloroethene	<1.0		0.19	1.0
Carbon disulfide	<5.0		0.55	5.0
Acetone	<5.0		1.6	5.0
Methylene Chloride	<2.0		0.67	2.0
trans-1,2-Dichloroethene	<1.0		0.32	1.0
1,1-Dichloroethane	<1.0		0.25	1.0
2,2-Dichloropropane	<1.0		0.24	1.0
cis-1,2-Dichloroethene	<1.0		0.27	1.0
Methyl Ethyl Ketone	<5.0		2.3	5.0
Bromochloromethane	<1.0		0.35	1.0
Chloroform	<1.0		0.15	1.0
1,1,1-Trichloroethane	<1.0		0.18	1.0
1,1-Dichloropropene	<1.0		0.16	1.0
Carbon tetrachloride	<1.0		0.25	1.0
1,2-Dichloroethane	<1.0		0.24	1.0
Trichloroethene	<1.0		0.24	1.0
1,2-Dichloropropane	<1.0		0.21	1.0
Dibromomethane	<1.0		0.30	1.0
Bromodichloromethane	<1.0		0.19	1.0
cis-1,3-Dichloropropene	<1.0		0.17	1.0
methyl isobutyl ketone	<5.0		0.84	5.0
Toluene	<1.0		0.19	1.0
trans-1,3-Dichloropropene	<1.0		0.24	1.0
1,1,2-Trichloroethane	<1.0		0.26	1.0
Tetrachloroethene	<1.0		0.22	1.0
1,3-Dichloropropane	<1.0		0.17	1.0
2-Hexanone	<5.0		0.80	5.0
Dibromochloromethane	<1.0		0.25	1.0
1,2-Dibromoethane	<1.0		0.37	1.0
Chlorobenzene	<1.0		0.17	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.19	1.0
Ethylbenzene	<1.0		0.18	1.0
m&p-Xylene	<2.0		0.32	2.0
o-Xylene	<1.0		0.38	1.0

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Method Blank - Batch: 500-81296

Method: 8260B

Preparation: 5030B

Lab Sample ID: MB 500-81296/7

Analysis Batch: 500-81296

Instrument ID: MS06

Client Matrix: Water

Prep Batch: N/A

Lab File ID: 6M0302.D

Dilution: 1.0

Units: ug/L

Initial Weight/Volume: 10 mL

Date Analyzed: 03/02/2010 1433

Final Weight/Volume: 10 mL

Date Prepared: 03/02/2010 1433

Analyte	Result	Qual	MDL	RL
Styrene	<1.0		0.15	1.0
Bromoform	<1.0		0.42	1.0
Isopropylbenzene	<1.0		0.20	1.0
Bromobenzene	<1.0		0.21	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.29	1.0
1,2,3-Trichloropropane	<1.0		0.48	1.0
N-Propylbenzene	<1.0		0.19	1.0
2-Chlorotoluene	<1.0		0.18	1.0
1,3,5-Trimethylbenzene	<1.0		0.18	1.0
4-Chlorotoluene	<1.0		0.21	1.0
tert-Butylbenzene	<1.0		0.16	1.0
1,2,4-Trimethylbenzene	<1.0		0.14	1.0
sec-Butylbenzene	<1.0		0.16	1.0
1,3-Dichlorobenzene	<1.0		0.24	1.0
p-Isopropyltoluene	<1.0		0.16	1.0
1,4-Dichlorobenzene	<1.0		0.21	1.0
n-Butylbenzene	<1.0		0.18	1.0
1,2-Dichlorobenzene	<1.0		0.17	1.0
1,2-Dibromo-3-Chloropropane	<2.0		0.96	2.0
1,2,4-Trichlorobenzene	<1.0		0.24	1.0
Hexachlorobutadiene	<1.0		0.26	1.0
Naphthalene	<1.0		0.44	1.0
1,2,3-Trichlorobenzene	<1.0		0.24	1.0

Surrogate	% Rec	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	107	72 - 135
Toluene-d8 (Surr)	96	80 - 120
4-Bromofluorobenzene (Surr)	95	77 - 120
Dibromofluoromethane	105	79 - 133

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Lab Control Sample - Batch: 500-81296

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-81296/8
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/02/2010 1347
Date Prepared: 03/02/2010 1347

Analysis Batch: 500-81296
Prep Batch: N/A
Units: ug/L

Instrument ID: MS06
Lab File ID: 6S0302.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	25.0	23.6	94	70 - 120	
Dichlorodifluoromethane	25.0	32.5	130	58 - 186	
Chloromethane	25.0	29.0	116	56 - 133	
Vinyl chloride	25.0	23.6	94	75 - 158	
Bromomethane	25.0	60.4	241	56 - 154	*
Chloroethane	25.0	30.0	120	60 - 144	
Trichlorofluoromethane	25.0	24.2	97	58 - 146	
1,1-Dichloroethene	25.0	24.3	97	55 - 129	
Carbon disulfide	25.0	19.2	77	31 - 146	
Acetone	25.0	25.8	103	29 - 152	
Methylene Chloride	25.0	25.1	100	63 - 128	
trans-1,2-Dichloroethene	25.0	25.6	103	66 - 120	
1,1-Dichloroethane	25.0	25.1	100	65 - 120	
2,2-Dichloropropane	25.0	25.6	102	59 - 121	
cis-1,2-Dichloroethene	25.0	22.6	90	72 - 123	
Methyl Ethyl Ketone	25.0	28.2	113	47 - 138	
Bromochloromethane	25.0	25.6	102	63 - 122	
Chloroform	25.0	24.8	99	70 - 120	
1,1,1-Trichloroethane	25.0	26.6	106	64 - 122	
1,1-Dichloropropene	25.0	24.1	96	70 - 120	
Carbon tetrachloride	25.0	21.9	88	62 - 122	
1,2-Dichloroethane	25.0	24.6	98	62 - 120	
Trichloroethene	25.0	23.8	95	71 - 120	
1,2-Dichloropropane	25.0	24.6	98	75 - 120	
Dibromomethane	25.0	24.9	100	72 - 120	
Bromodichloromethane	25.0	23.3	93	74 - 120	
cis-1,3-Dichloropropene	26.9	22.9	85	65 - 120	
methyl isobutyl ketone	25.0	25.3	101	59 - 120	
Toluene	25.0	23.6	95	72 - 120	
trans-1,3-Dichloropropene	24.3	19.2	79	59 - 120	
1,1,2-Trichloroethane	25.0	23.3	93	68 - 126	
Tetrachloroethene	25.0	22.4	89	70 - 120	
1,3-Dichloropropane	25.0	23.9	95	77 - 120	
2-Hexanone	25.0	25.2	101	56 - 120	
Dibromochloromethane	25.0	20.9	83	64 - 120	
1,2-Dibromoethane	25.0	24.2	97	72 - 120	
Chlorobenzene	25.0	22.6	90	75 - 120	
1,1,1,2-Tetrachloroethane	25.0	22.6	91	70 - 121	
Ethylbenzene	25.0	23.4	94	76 - 120	
m&p-Xylene	50.0	47.6	95	74 - 120	
o-Xylene	25.0	23.5	94	74 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Lab Control Sample - Batch: 500-81296

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-81296/8
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/02/2010 1347
Date Prepared: 03/02/2010 1347

Analysis Batch: 500-81296
Prep Batch: N/A
Units: ug/L

Instrument ID: MS06
Lab File ID: 6S0302.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Styrene	25.0	24.1	96	76 - 120	
Bromoform	25.0	23.2	93	58 - 120	
Isopropylbenzene	25.0	21.2	85	64 - 120	
Bromobenzene	25.0	23.5	94	68 - 120	
1,1,2,2-Tetrachloroethane	25.0	24.6	98	69 - 120	
1,2,3-Trichloropropane	25.0	24.2	97	65 - 120	
N-Propylbenzene	25.0	24.1	96	66 - 120	
2-Chlorotoluene	25.0	23.7	95	68 - 120	
1,3,5-Trimethylbenzene	25.0	24.2	97	68 - 120	
4-Chlorotoluene	25.0	23.1	93	65 - 120	
tert-Butylbenzene	25.0	23.5	94	67 - 120	
1,2,4-Trimethylbenzene	25.0	24.1	97	70 - 120	
sec-Butylbenzene	25.0	23.8	95	71 - 120	
1,3-Dichlorobenzene	25.0	23.3	93	73 - 120	
p-Isopropyltoluene	25.0	23.4	94	70 - 120	
1,4-Dichlorobenzene	25.0	22.8	91	72 - 120	
n-Butylbenzene	25.0	24.1	96	72 - 120	
1,2-Dichlorobenzene	25.0	23.7	95	62 - 131	
1,2-Dibromo-3-Chloropropane	25.0	20.2	81	55 - 130	
1,2,4-Trichlorobenzene	25.0	22.5	90	54 - 120	
Hexachlorobutadiene	25.0	22.7	91	64 - 125	
Naphthalene	25.0	23.7	95	51 - 120	
1,2,3-Trichlorobenzene	25.0	23.6	94	57 - 120	
Surrogate			% Rec	Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)			104	72 - 135	
Toluene-d8 (Surr)			98	80 - 120	
4-Bromofluorobenzene (Surr)			96	77 - 120	
Dibromofluoromethane			102	79 - 133	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Method Blank - Batch: 500-81369

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-81369/8
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/03/2010 1519
Date Prepared: 03/03/2010 1519

Analysis Batch: 500-81369
Prep Batch: N/A
Units: ug/L

Instrument ID: MS06
Lab File ID: 6M0303.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.17	1.0
Dichlorodifluoromethane	<1.0		0.31	1.0
Chloromethane	<1.0		0.24	1.0
Vinyl chloride	<1.0		0.20	1.0
Bromomethane	<1.0		0.38	1.0
Chloroethane	<1.0		0.36	1.0
Trichlorofluoromethane	<1.0		0.20	1.0
1,1-Dichloroethene	<1.0		0.19	1.0
Carbon disulfide	<5.0		0.55	5.0
Acetone	<5.0		1.6	5.0
Methylene Chloride	<2.0		0.67	2.0
trans-1,2-Dichloroethene	<1.0		0.32	1.0
1,1-Dichloroethane	<1.0		0.25	1.0
2,2-Dichloropropane	<1.0		0.24	1.0
cis-1,2-Dichloroethene	<1.0		0.27	1.0
Methyl Ethyl Ketone	<5.0		2.3	5.0
Bromochloromethane	<1.0		0.35	1.0
Chloroform	<1.0		0.15	1.0
1,1,1-Trichloroethane	<1.0		0.18	1.0
1,1-Dichloropropene	<1.0		0.16	1.0
Carbon tetrachloride	<1.0		0.25	1.0
1,2-Dichloroethane	<1.0		0.24	1.0
Trichloroethene	<1.0		0.24	1.0
1,2-Dichloropropane	<1.0		0.21	1.0
Dibromomethane	<1.0		0.30	1.0
Bromodichloromethane	<1.0		0.19	1.0
cis-1,3-Dichloropropene	<1.0		0.17	1.0
methyl isobutyl ketone	<5.0		0.84	5.0
Toluene	<1.0		0.19	1.0
trans-1,3-Dichloropropene	<1.0		0.24	1.0
1,1,2-Trichloroethane	<1.0		0.26	1.0
Tetrachloroethene	<1.0		0.22	1.0
1,3-Dichloropropane	<1.0		0.17	1.0
2-Hexanone	<5.0		0.80	5.0
Dibromochloromethane	<1.0		0.25	1.0
1,2-Dibromoethane	<1.0		0.37	1.0
Chlorobenzene	<1.0		0.17	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.19	1.0
Ethylbenzene	<1.0		0.18	1.0
m&p-Xylene	<2.0		0.32	2.0
o-Xylene	<1.0		0.38	1.0

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Method Blank - Batch: 500-81369

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-81369/8
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/03/2010 1519
Date Prepared: 03/03/2010 1519

Analysis Batch: 500-81369
Prep Batch: N/A
Units: ug/L

Instrument ID: MS06
Lab File ID: 6M0303.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Styrene	<1.0		0.15	1.0
Bromoform	<1.0		0.42	1.0
Isopropylbenzene	<1.0		0.20	1.0
Bromobenzene	<1.0		0.21	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.29	1.0
1,2,3-Trichloropropane	<1.0		0.48	1.0
N-Propylbenzene	<1.0		0.19	1.0
2-Chlorotoluene	<1.0		0.18	1.0
1,3,5-Trimethylbenzene	<1.0		0.18	1.0
4-Chlorotoluene	<1.0		0.21	1.0
tert-Butylbenzene	<1.0		0.16	1.0
1,2,4-Trimethylbenzene	<1.0		0.14	1.0
sec-Butylbenzene	<1.0		0.16	1.0
1,3-Dichlorobenzene	<1.0		0.24	1.0
p-Isopropyltoluene	<1.0		0.16	1.0
1,4-Dichlorobenzene	<1.0		0.21	1.0
n-Butylbenzene	<1.0		0.18	1.0
1,2-Dichlorobenzene	<1.0		0.17	1.0
1,2-Dibromo-3-Chloropropane	<2.0		0.96	2.0
1,2,4-Trichlorobenzene	<1.0		0.24	1.0
Hexachlorobutadiene	<1.0		0.26	1.0
Naphthalene	<1.0		0.44	1.0
1,2,3-Trichlorobenzene	<1.0		0.24	1.0

Surrogate	% Rec	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	114	72 - 135
Toluene-d8 (Surr)	98	80 - 120
4-Bromofluorobenzene (Surr)	99	77 - 120
Dibromofluoromethane	110	79 - 133

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Lab Control Sample - Batch: 500-81369

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-81369/9
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/03/2010 1432
Date Prepared: 03/03/2010 1432

Analysis Batch: 500-81369
Prep Batch: N/A
Units: ug/L

Instrument ID: MS06
Lab File ID: 6S0303.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	25.0	22.7	91	70 - 120	
Dichlorodifluoromethane	25.0	30.8	123	58 - 186	
Chloromethane	25.0	28.4	113	56 - 133	
Vinyl chloride	25.0	23.7	95	75 - 158	
Bromomethane	25.0	38.3	153	56 - 154	
Chloroethane	25.0	27.5	110	60 - 144	
Trichlorofluoromethane	25.0	24.9	100	58 - 146	
1,1-Dichloroethene	25.0	22.2	89	55 - 129	
Carbon disulfide	25.0	17.0	68	31 - 146	
Acetone	25.0	22.1	88	29 - 152	
Methylene Chloride	25.0	25.2	101	63 - 128	
trans-1,2-Dichloroethene	25.0	24.5	98	66 - 120	
1,1-Dichloroethane	25.0	25.7	103	65 - 120	
2,2-Dichloropropane	25.0	22.9	92	59 - 121	
cis-1,2-Dichloroethene	25.0	22.5	90	72 - 123	
Methyl Ethyl Ketone	25.0	33.6	135	47 - 138	
Bromochloromethane	25.0	25.4	102	63 - 122	
Chloroform	25.0	26.2	105	70 - 120	
1,1,1-Trichloroethane	25.0	25.4	102	64 - 122	
1,1-Dichloropropene	25.0	24.2	97	70 - 120	
Carbon tetrachloride	25.0	19.5	78	62 - 122	
1,2-Dichloroethane	25.0	25.8	103	62 - 120	
Trichloroethene	25.0	22.8	91	71 - 120	
1,2-Dichloropropane	25.0	25.3	101	75 - 120	
Dibromomethane	25.0	25.8	103	72 - 120	
Bromodichloromethane	25.0	24.2	97	74 - 120	
cis-1,3-Dichloropropene	26.9	23.3	87	65 - 120	
methyl isobutyl ketone	25.0	29.8	119	59 - 120	
Toluene	25.0	23.3	93	72 - 120	
trans-1,3-Dichloropropene	24.3	20.9	86	59 - 120	
1,1,2-Trichloroethane	25.0	27.5	110	68 - 126	
Tetrachloroethene	25.0	20.9	84	70 - 120	
1,3-Dichloropropane	25.0	25.7	103	77 - 120	
2-Hexanone	25.0	28.3	113	56 - 120	
Dibromochloromethane	25.0	21.5	86	64 - 120	
1,2-Dibromoethane	25.0	26.3	105	72 - 120	
Chlorobenzene	25.0	22.7	91	75 - 120	
1,1,1,2-Tetrachloroethane	25.0	22.5	90	70 - 121	
Ethylbenzene	25.0	23.1	92	76 - 120	
m&p-Xylene	50.0	47.6	95	74 - 120	
o-Xylene	25.0	23.1	92	74 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Lab Control Sample - Batch: 500-81369

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-81369/9
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/03/2010 1432
Date Prepared: 03/03/2010 1432

Analysis Batch: 500-81369
Prep Batch: N/A
Units: ug/L

Instrument ID: MS06
Lab File ID: 6S0303.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Styrene	25.0	24.3	97	76 - 120	
Bromoform	25.0	23.5	94	58 - 120	
Isopropylbenzene	25.0	20.2	81	64 - 120	
Bromobenzene	25.0	24.0	96	68 - 120	
1,1,2,2-Tetrachloroethane	25.0	25.5	102	69 - 120	
1,2,3-Trichloropropane	25.0	27.3	109	65 - 120	
N-Propylbenzene	25.0	23.4	93	66 - 120	
2-Chlorotoluene	25.0	23.6	94	68 - 120	
1,3,5-Trimethylbenzene	25.0	23.5	94	68 - 120	
4-Chlorotoluene	25.0	23.2	93	65 - 120	
tert-Butylbenzene	25.0	22.5	90	67 - 120	
1,2,4-Trimethylbenzene	25.0	23.8	95	70 - 120	
sec-Butylbenzene	25.0	22.5	90	71 - 120	
1,3-Dichlorobenzene	25.0	23.2	93	73 - 120	
p-Isopropyltoluene	25.0	22.2	89	70 - 120	
1,4-Dichlorobenzene	25.0	22.8	91	72 - 120	
n-Butylbenzene	25.0	22.6	90	72 - 120	
1,2-Dichlorobenzene	25.0	23.7	95	62 - 131	
1,2-Dibromo-3-Chloropropane	25.0	21.4	86	55 - 130	
1,2,4-Trichlorobenzene	25.0	22.1	88	54 - 120	
Hexachlorobutadiene	25.0	20.5	82	64 - 125	
Naphthalene	25.0	24.7	99	51 - 120	
1,2,3-Trichlorobenzene	25.0	23.4	93	57 - 120	
Surrogate		% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)		108		72 - 135	
Toluene-d8 (Surr)		98		80 - 120	
4-Bromofluorobenzene (Surr)		100		77 - 120	
Dibromofluoromethane		107		79 - 133	

Calculations are performed before rounding to avoid round-off errors in calculated results.

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

2417 Bond Street, University Park, IL 60488
Phone: 708.534.5200 Fax: 708.534.5211

EFFECTIVE 7/1/09 OUR
NEW ZIP CODE IS 60484

Report To _____ (optional)
Contact: _____
Company: _____
Address: _____
Address: _____
Phone: _____
Fax: _____
E-Mail: _____

Bill To _____ (optional)
Contact: _____
Company: _____
Address: _____
Address: _____
Phone: _____
Fax: _____
PO#/Reference# _____

Chain of Custody Record

Lab Job #: 500-24183

Chain of Custody Number: _____

Page 1 of 3

Temperature °C of Cooler: 3.0

Lab ID	MS/MSD	Sample ID	Sampling		# of Containers	Matrix	Preservative	Parameter	Comments
			Date	Time					
1		EW-2	2/18/10	1730	3	W	HCl		
2		EW-3	2/18/10	915					
3		EW-4	2/19/10	1200					
4		EW-5	2/18/10	1130					
5		EW-6		1440					
6		EW-7		1415					
7		EW-8		1400					
8		EW-9		1340					
9		EW-9 Dup		1340					
10		EW-10		1230					

- Preservative Key
1. HCL, Cool to 4°
 2. H2SO4, Cool to 4°
 3. HNO3, Cool to 4°
 4. NaOH, Cool to 4°
 5. NaOH/Zn, Cool to 4°
 6. Cool to 4°
 7. None
 8. Other

Turnaround Time Required (Business Days) 1 Day 2 Days 5 Days 10 days 15 Days Other

Sample Disposal Return to Client Disposal by Lab Archive for _____ Months (A fee may be assessed if samples are retained longer than 1 month)

Requested By: <u>[Signature]</u> Company: <u>Western</u> Date: <u>2/22/10</u> Time: <u>1600</u>	Received By: <u>[Signature]</u> Company: <u>TA</u> Date: <u>2/23/10</u> Time: <u>0950</u>
Requested By: _____ Company: _____ Date: _____ Time: _____	Received By: _____ Company: _____ Date: _____ Time: _____
Requested By: _____ Company: _____ Date: _____ Time: _____	Received By: _____ Company: _____ Date: _____ Time: _____

Lab Courier: _____
Shipped: FX
Hand Delivered: _____

- Matrix Key
- WW - Wastewater
 - W - Water
 - S - Soil
 - SL - Sludge
 - MS - Miscellaneous
 - OL - Oil
 - A - Air
 - SE - Sediment
 - SO - Soil
 - L - Leachate
 - WI - Wipe
 - DW - Drinking Water
 - O - Other

Client Comments: _____

Lab Comments: _____

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

2417 Bond Street, University Park, IL 60486
Phone: 708.534.5200 Fax: 708.534.5211

EFFECTIVE 7/1/09 OUR
NEW ZIP CODE IS 60484

Report To _____ (optional)
Contact: _____
Company: _____
Address: _____
Address: _____
Phone: _____
Fax: _____
E-Mail: _____

Bill To _____ (optional)
Contact: _____
Company: _____
Address: _____
Address: _____
Phone: _____
Fax: _____
PC#(Reference)# _____

Chain of Custody Record

Lab Job #: 500-24183
Chain of Custody Number: _____
Page 3 of 3
Temperature °C of Cooler: _____

Client		Client Project #		Preservative		Parameter		Matrix		Comments	
Western Solutions				HCL		V		O			
Project Name: Black + Decker		Lab Project #		A		V		O			
Project Location/State		Lab PM				O		A			
Lab ID	MS/MSD	Sample ID	Date	Time	# of Containers	Matrix					
21		RFW-9	2/15/10	1050	3	W	✓				
22		RFW-11B	2/12/10	1245	3	L	✓				
23		Trip Blank	2/18/10	800	2	L	✓				

- Preservative Key
1. HCL, Cool to 4°
 2. H2SO4, Cool to 4°
 3. HNO3, Cool to 4°
 4. NaOH, Cool to 4°
 5. NaOH/Zn, Cool to 4°
 6. Cool to 4°
 7. None
 8. Other

Turnaround Time Required (Business Days)

1 Day 2 Days 5 Days 10 days 15 Days Other

Sample Disposal

Return to Client Disposal by Lab Archive for _____ Months (A fee may be assessed if samples are retained longer than 1 month)

Requisitioned By: <i>[Signature]</i>	Company: Western	Date: 2/22/10	Time: 1600	Received By: <i>[Signature]</i>	Company: TA	Date: 2/23/10	Time: 0950
Requisitioned By:	Company:	Date:	Time:	Received By:	Company:	Date:	Time:
Requisitioned By:	Company:	Date:	Time:	Received By:	Company:	Date:	Time:

Lab Courier: _____
Shipped: FX
Hand Delivered: _____

Matrix Key

- | | |
|--------------------|---------------------|
| WW - Wastewater | SE - Sediment |
| W - Water | SO - Soil |
| S - Soil | L - Leachate |
| SL - Sludge | WI - Wipe |
| MS - Miscellaneous | DW - Drinking Water |
| OL - Oil | O - Other |
| A - Air | |

Client Comments:

Lab Comments:

Login Sample Receipt Check List

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Login Number: 24183

List Source: TestAmerica Chicago

Creator: Lunt, Jeff T

List Number: 1

Question	T / F / NA	Comment
Radioactivity either was not measured or, if measured, is at or below background	True	
The cooler's custody seal, if present, is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	3.0
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	True	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Is the Field Sampler's name present on COC?	True	
Sample Preservation Verified	True	

ANALYTICAL REPORT

Job Number: 680-55261-1

Job Description: Black & Decker

For:

Weston Solutions, Inc.

1400 Weston Way

PO BOX 2653

West Chester, PA 19380

Attention: Mr. Tom Cornuet



Approved for release.
Abbie G Yant
Project Manager I
3/8/2010 3:10 PM

Abbie G Yant

Project Manager I

abbie.yant@testamericainc.com

03/08/2010

The test results in this report meet NELAP requirements for parameters for which accreditation is required or available. Any exceptions to the NELAP requirements are noted. Results pertain only to samples listed in this report. This report may not be reproduced, except in full, without the written approval of the laboratory. Questions should be directed to the person who signed this report.

Savannah Certifications and ID #: A2LA: 0399.01; AL: 41450; ARDEQ: 88-0692; ARDOH; CA: 03217CA; CO; CT: PH0161; DE; FL: E87052; GA: 803; Guam; HI; IL: 200022; IN; IA: 353; KS: E-10322; KY EPPC: 90084; KY UST; LA DEQ: 30690; LA DHH: LA080008; ME: 2008022; MD: 250; MA: M-GA006; MI: 9925; MS; NFESC: 249; NV: GA00006; NJ: GA769; NM; NY: 10842; NC DWQ: 269; NC DHHS: 13701; PA: 68-00474; PR: GA00006; RI: LAO00244; SC: 98001001; TN: TN0296; TX: T104704185; USEPA: GA00006; VT: VT-87052; VA: 00302; WA; WV DEP: 094; WI DHHR: 9950 C; WI DNR: 999819810; WY/EPAR8: 8TMS-Q

TestAmerica Laboratories, Inc.

TestAmerica Savannah 5102 LaRoche Avenue, Savannah, GA 31404

Tel (912) 354-7858 Fax (912) 352-0165 www.testamericainc.com



Job Narrative
680-55261-1

Comments

No additional comments.

Receipt

The following samples were received at the laboratory with a cooler temperature of 8.9oC, which is outside the required temperature criteria: RFW-20 (680-55261-1), RFW-21 (680-55261-2), Trip Blank (680-55261-3). The client was contacted regarding this issue, and the laboratory was instructed to proceed with analysis.

All other samples were received in good condition within temperature requirements.

GC/MS VOA

Method(s) 524.2: A full list spike was utilized for this method. Due to the large number of spiked analytes, there is a high probability that one or more analytes will recover outside acceptance limits. The laboratory's SOP allows for four analytes to recover outside criteria for this method when a full list spike is utilized. The LCSD associated with batch 161965 had two analytes outside control limits; therefore, re-analysis was not performed. These results have been reported and qualified.

No other analytical or quality issues were noted.

METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 680-55261-1

Description	Lab Location	Method	Preparation Method
Matrix Water			
Volatile Organic Compounds (GC/MS)	TAL SAV	EPA-DW 524.2	

Lab References:

TAL SAV = TestAmerica Savannah

Method References:

EPA-DW = "Methods For The Determination Of Organic Compounds In Drinking Water", EPA/600/4-88/039, December 1988 And Its Supplements.

SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 680-55261-1

<u>Lab Sample ID</u>	<u>Client Sample ID</u>	<u>Client Matrix</u>	<u>Date/Time Sampled</u>	<u>Date/Time Received</u>
680-55261-1	RFW-20	Water	02/18/2010 1815	02/23/2010 0919
680-55261-2	RFW-21	Water	02/18/2010 0910	02/23/2010 0919
680-55261-3	Trip Blank	Water	02/18/2010 0800	02/23/2010 0919

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-55261-1

Client Sample ID: RFW-20

Lab Sample ID: 680-55261-1

Date Sampled: 02/18/2010 1815

Client Matrix: Water

Date Received: 02/23/2010 0919

524.2 Volatile Organic Compounds (GC/MS)

Method:	524.2	Analysis Batch: 680-161965	Instrument ID:	MSU
Preparation:	N/A		Lab File ID:	u0513.d
Dilution:	1.0		Initial Weight/Volume:	5 mL
Date Analyzed:	03/01/2010 1901		Final Weight/Volume:	5 mL
Date Prepared:				

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		5.0	10
Benzene	<0.50		0.18	0.50
Bromobenzene	<0.50		0.42	0.50
Bromoform	<0.50		0.39	0.50
Bromomethane	<1.0		0.45	1.0
Carbon tetrachloride	<0.50		0.22	0.50
Chlorobenzene	<0.50		0.27	0.50
Chlorobromomethane	<0.50		0.30	0.50
Chlorodibromomethane	<0.50		0.43	0.50
Chloroethane	<1.0		0.33	1.0
Chloroform	<0.50		0.29	0.50
Chloromethane	<0.50		0.32	0.50
2-Chlorotoluene	<0.50		0.17	0.50
4-Chlorotoluene	<0.50		0.16	0.50
cis-1,2-Dichloroethene	<0.50		0.37	0.50
cis-1,3-Dichloropropene	<0.50		0.32	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.30	0.50
Dibromomethane	<0.50		0.38	0.50
1,2-Dichlorobenzene	<0.50		0.17	0.50
1,3-Dichlorobenzene	<0.50		0.14	0.50
1,4-Dichlorobenzene	<0.50		0.18	0.50
Dichlorobromomethane	<1.0		0.54	1.0
Dichlorodifluoromethane	<0.50		0.34	0.50
1,1-Dichloroethane	<0.50		0.39	0.50
1,2-Dichloroethane	<0.50		0.17	0.50
1,1-Dichloroethene	<0.50		0.32	0.50
1,2-Dichloropropane	<0.50		0.45	0.50
1,3-Dichloropropane	<0.50		0.43	0.50
2,2-Dichloropropane	<0.50		0.31	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.32	0.50
Diisopropyl ether	<0.50		0.28	0.50
Ethylbenzene	<0.50		0.12	0.50
Ethylene Dibromide	<0.50		0.20	0.50
Freon 113	<0.50		0.15	0.50
Hexachlorobutadiene	<0.50		0.26	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.21	0.50
Methylene Chloride	<0.50		0.36	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.42	0.50
Naphthalene	<1.0		0.43	1.0
n-Butylbenzene	<0.50		0.17	0.50
N-Propylbenzene	<0.50		0.17	0.50

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-55261-1

Client Sample ID: RFW-20

Lab Sample ID: 680-55261-1

Date Sampled: 02/18/2010 1815

Client Matrix: Water

Date Received: 02/23/2010 0919

524.2 Volatile Organic Compounds (GC/MS)

Method:	524.2	Analysis Batch: 680-161965	Instrument ID:	MSU
Preparation:	N/A		Lab File ID:	u0513.d
Dilution:	1.0		Initial Weight/Volume:	5 mL
Date Analyzed:	03/01/2010 1901		Final Weight/Volume:	5 mL
Date Prepared:				

Analyte	Result (ug/L)	Qualifier	MDL	RL
o-Xylene	<0.50		0.27	0.50
sec-Butylbenzene	<0.50		0.14	0.50
Styrene	<0.50		0.28	0.50
Tert-amyl methyl ether	<0.50		0.20	0.50
tert-Butyl alcohol	<2.0		1.6	2.0
tert-Butylbenzene	<0.50		0.14	0.50
Tert-butyl ethyl ether	<0.50		0.26	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.16	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.18	0.50
Tetrachloroethene	<0.50		0.30	0.50
Toluene	<0.50		0.23	0.50
trans-1,2-Dichloroethene	<0.50		0.24	0.50
trans-1,3-Dichloropropene	<0.50		0.48	0.50
1,2,3-Trichlorobenzene	<0.50		0.14	0.50
1,2,4-Trichlorobenzene	<0.50		0.18	0.50
1,1,1-Trichloroethane	<0.50		0.27	0.50
1,1,2-Trichloroethane	<0.50		0.22	0.50
Trichloroethene	<0.50		0.37	0.50
Trichlorofluoromethane	<0.50		0.23	0.50
1,2,3-Trichloropropane	<0.50		0.18	0.50
Trihalomethanes, Total	<0.50		0.29	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.16	0.50
Vinyl chloride	<0.50		0.33	0.50
Xylenes, Total	<0.50		0.27	0.50

Surrogate	%Rec	Qualifier	Acceptance Limits
4-Bromofluorobenzene	90		70 - 130
1,2-Dichlorobenzene-d4	87		70 - 130

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-55261-1

Client Sample ID: RFW-21

Lab Sample ID: 680-55261-2

Date Sampled: 02/18/2010 0910

Client Matrix: Water

Date Received: 02/23/2010 0919

524.2 Volatile Organic Compounds (GC/MS)

Method:	524.2	Analysis Batch: 680-161965	Instrument ID:	MSU
Preparation:	N/A		Lab File ID:	u0514.d
Dilution:	1.0		Initial Weight/Volume:	5 mL
Date Analyzed:	03/01/2010 1924		Final Weight/Volume:	5 mL
Date Prepared:				

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		5.0	10
Benzene	<0.50		0.18	0.50
Bromobenzene	<0.50		0.42	0.50
Bromoform	<0.50		0.39	0.50
Bromomethane	<1.0		0.45	1.0
Carbon tetrachloride	<0.50		0.22	0.50
Chlorobenzene	<0.50		0.27	0.50
Chlorobromomethane	<0.50		0.30	0.50
Chlorodibromomethane	<0.50		0.43	0.50
Chloroethane	<1.0		0.33	1.0
Chloroform	<0.50		0.29	0.50
Chloromethane	<0.50		0.32	0.50
2-Chlorotoluene	<0.50		0.17	0.50
4-Chlorotoluene	<0.50		0.16	0.50
cis-1,2-Dichloroethene	<0.50		0.37	0.50
cis-1,3-Dichloropropene	<0.50		0.32	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.30	0.50
Dibromomethane	<0.50		0.38	0.50
1,2-Dichlorobenzene	<0.50		0.17	0.50
1,3-Dichlorobenzene	<0.50		0.14	0.50
1,4-Dichlorobenzene	<0.50		0.18	0.50
Dichlorobromomethane	<1.0		0.54	1.0
Dichlorodifluoromethane	<0.50		0.34	0.50
1,1-Dichloroethane	<0.50		0.39	0.50
1,2-Dichloroethane	<0.50		0.17	0.50
1,1-Dichloroethene	<0.50		0.32	0.50
1,2-Dichloropropane	<0.50		0.45	0.50
1,3-Dichloropropane	<0.50		0.43	0.50
2,2-Dichloropropane	<0.50		0.31	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.32	0.50
Diisopropyl ether	<0.50		0.28	0.50
Ethylbenzene	<0.50		0.12	0.50
Ethylene Dibromide	<0.50		0.20	0.50
Freon 113	<0.50		0.15	0.50
Hexachlorobutadiene	<0.50		0.26	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.21	0.50
Methylene Chloride	<0.50		0.36	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.42	0.50
Naphthalene	<1.0		0.43	1.0
n-Butylbenzene	<0.50		0.17	0.50
N-Propylbenzene	<0.50		0.17	0.50

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-55261-1

Client Sample ID: RFW-21

Lab Sample ID: 680-55261-2

Date Sampled: 02/18/2010 0910

Client Matrix: Water

Date Received: 02/23/2010 0919

524.2 Volatile Organic Compounds (GC/MS)

Method:	524.2	Analysis Batch: 680-161965	Instrument ID:	MSU
Preparation:	N/A		Lab File ID:	u0514.d
Dilution:	1.0		Initial Weight/Volume:	5 mL
Date Analyzed:	03/01/2010 1924		Final Weight/Volume:	5 mL
Date Prepared:				

Analyte	Result (ug/L)	Qualifier	MDL	RL
o-Xylene	<0.50		0.27	0.50
sec-Butylbenzene	<0.50		0.14	0.50
Styrene	<0.50		0.28	0.50
Tert-amyl methyl ether	<0.50		0.20	0.50
tert-Butyl alcohol	<2.0		1.6	2.0
tert-Butylbenzene	<0.50		0.14	0.50
Tert-butyl ethyl ether	<0.50		0.26	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.16	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.18	0.50
Tetrachloroethene	<0.50		0.30	0.50
Toluene	<0.50		0.23	0.50
trans-1,2-Dichloroethene	<0.50		0.24	0.50
trans-1,3-Dichloropropene	<0.50		0.48	0.50
1,2,3-Trichlorobenzene	<0.50		0.14	0.50
1,2,4-Trichlorobenzene	<0.50		0.18	0.50
1,1,1-Trichloroethane	<0.50		0.27	0.50
1,1,2-Trichloroethane	<0.50		0.22	0.50
Trichloroethene	<0.50		0.37	0.50
Trichlorofluoromethane	<0.50		0.23	0.50
1,2,3-Trichloropropane	<0.50		0.18	0.50
Trihalomethanes, Total	<0.50		0.29	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.16	0.50
Vinyl chloride	<0.50		0.33	0.50
Xylenes, Total	<0.50		0.27	0.50

Surrogate	%Rec	Qualifier	Acceptance Limits
4-Bromofluorobenzene	84		70 - 130
1,2-Dichlorobenzene-d4	85		70 - 130

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-55261-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-55261-3

Date Sampled: 02/18/2010 0800

Client Matrix: Water

Date Received: 02/23/2010 0919

524.2 Volatile Organic Compounds (GC/MS)

Method: 524.2 Analysis Batch: 680-161965 Instrument ID: MSU
 Preparation: N/A Lab File ID: u0505.d
 Dilution: 1.0 Initial Weight/Volume: 5 mL
 Date Analyzed: 03/01/2010 1551 Final Weight/Volume: 5 mL
 Date Prepared:

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		5.0	10
Benzene	<0.50		0.18	0.50
Bromobenzene	<0.50		0.42	0.50
Bromoform	<0.50		0.39	0.50
Bromomethane	<1.0		0.45	1.0
Carbon tetrachloride	<0.50		0.22	0.50
Chlorobenzene	<0.50		0.27	0.50
Chlorobromomethane	<0.50		0.30	0.50
Chlorodibromomethane	<0.50		0.43	0.50
Chloroethane	<1.0		0.33	1.0
Chloroform	<0.50		0.29	0.50
Chloromethane	<0.50		0.32	0.50
2-Chlorotoluene	<0.50		0.17	0.50
4-Chlorotoluene	<0.50		0.16	0.50
cis-1,2-Dichloroethene	<0.50		0.37	0.50
cis-1,3-Dichloropropene	<0.50		0.32	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.30	0.50
Dibromomethane	<0.50		0.38	0.50
1,2-Dichlorobenzene	<0.50		0.17	0.50
1,3-Dichlorobenzene	<0.50		0.14	0.50
1,4-Dichlorobenzene	<0.50		0.18	0.50
Dichlorobromomethane	<1.0		0.54	1.0
Dichlorodifluoromethane	<0.50		0.34	0.50
1,1-Dichloroethane	<0.50		0.39	0.50
1,2-Dichloroethane	<0.50		0.17	0.50
1,1-Dichloroethene	<0.50		0.32	0.50
1,2-Dichloropropane	<0.50		0.45	0.50
1,3-Dichloropropane	<0.50		0.43	0.50
2,2-Dichloropropane	<0.50		0.31	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.32	0.50
Diisopropyl ether	<0.50		0.28	0.50
Ethylbenzene	<0.50		0.12	0.50
Ethylene Dibromide	<0.50		0.20	0.50
Freon 113	<0.50		0.15	0.50
Hexachlorobutadiene	<0.50		0.26	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.21	0.50
Methylene Chloride	<0.50		0.36	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.42	0.50
Naphthalene	<1.0		0.43	1.0
n-Butylbenzene	<0.50		0.17	0.50
N-Propylbenzene	<0.50		0.17	0.50

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-55261-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-55261-3

Date Sampled: 02/18/2010 0800

Client Matrix: Water

Date Received: 02/23/2010 0919

524.2 Volatile Organic Compounds (GC/MS)

Method:	524.2	Analysis Batch: 680-161965	Instrument ID:	MSU
Preparation:	N/A		Lab File ID:	u0505.d
Dilution:	1.0		Initial Weight/Volume:	5 mL
Date Analyzed:	03/01/2010 1551		Final Weight/Volume:	5 mL
Date Prepared:				

Analyte	Result (ug/L)	Qualifier	MDL	RL
o-Xylene	<0.50		0.27	0.50
sec-Butylbenzene	<0.50		0.14	0.50
Styrene	<0.50		0.28	0.50
Tert-amyl methyl ether	<0.50		0.20	0.50
tert-Butyl alcohol	<2.0		1.6	2.0
tert-Butylbenzene	<0.50		0.14	0.50
Tert-butyl ethyl ether	<0.50		0.26	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.16	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.18	0.50
Tetrachloroethene	<0.50		0.30	0.50
Toluene	<0.50		0.23	0.50
trans-1,2-Dichloroethene	<0.50		0.24	0.50
trans-1,3-Dichloropropene	<0.50		0.48	0.50
1,2,3-Trichlorobenzene	<0.50		0.14	0.50
1,2,4-Trichlorobenzene	<0.50		0.18	0.50
1,1,1-Trichloroethane	<0.50		0.27	0.50
1,1,2-Trichloroethane	<0.50		0.22	0.50
Trichloroethene	<0.50		0.37	0.50
Trichlorofluoromethane	<0.50		0.23	0.50
1,2,3-Trichloropropane	<0.50		0.18	0.50
Trihalomethanes, Total	<0.50		0.29	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.16	0.50
Vinyl chloride	<0.50		0.33	0.50
Xylenes, Total	<0.50		0.27	0.50

Surrogate	%Rec	Qualifier	Acceptance Limits
4-Bromofluorobenzene	91		70 - 130
1,2-Dichlorobenzene-d4	88		70 - 130

DATA REPORTING QUALIFIERS

Client: Weston Solutions, Inc.

Job Number: 680-55261-1

Lab Section	Qualifier	Description
GC/MS VOA	*	LCS or LCSD exceeds the control limits

Client: Weston Solutions, Inc.

Surrogate Recovery Report

524.2 Volatile Organic Compounds (GC/MS)

Client Matrix: Water

Lab Sample ID	Client Sample ID	BFB %Rec	DCZ %Rec
680-55261-1	RFW-20	90	87
680-55261-2	RFW-21	84	85
680-55261-3	Trip Blank	91	88
MB 680-161965/9		94	89
LCS 680-161965/6		105	108
LCSD 680-161965/7		105	104

Surrogate	Acceptance Limits
BFB = 4-Bromofluorobenzene	70-130
DCZ = 1,2-Dichlorobenzene-d4	70-130

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-55261-1

Method Blank - Batch: 680-161965

Method: 524.2
Preparation: N/A

Lab Sample ID: MB 680-161965/9
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/01/2010 1315
Date Prepared: N/A

Analysis Batch: 680-161965
Prep Batch: N/A
Units: ug/L

Instrument ID: MSU
Lab File ID: uq0324.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	Result	Qual	MDL	RL
Acetone	<10		5.0	10
Benzene	<0.50		0.18	0.50
Bromobenzene	<0.50		0.42	0.50
Bromoform	<0.50		0.39	0.50
Bromomethane	<1.0		0.45	1.0
Carbon tetrachloride	<0.50		0.22	0.50
Chlorobenzene	<0.50		0.27	0.50
Chlorobromomethane	<0.50		0.30	0.50
Chlorodibromomethane	<0.50		0.43	0.50
Chloroethane	<1.0		0.33	1.0
Chloroform	<0.50		0.29	0.50
Chloromethane	<0.50		0.32	0.50
2-Chlorotoluene	<0.50		0.17	0.50
4-Chlorotoluene	<0.50		0.16	0.50
cis-1,2-Dichloroethene	<0.50		0.37	0.50
cis-1,3-Dichloropropene	<0.50		0.32	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.30	0.50
Dibromomethane	<0.50		0.38	0.50
1,2-Dichlorobenzene	<0.50		0.17	0.50
1,3-Dichlorobenzene	<0.50		0.14	0.50
1,4-Dichlorobenzene	<0.50		0.18	0.50
Dichlorobromomethane	<1.0		0.54	1.0
Dichlorodifluoromethane	<0.50		0.34	0.50
1,1-Dichloroethane	<0.50		0.39	0.50
1,2-Dichloroethane	<0.50		0.17	0.50
1,1-Dichloroethene	<0.50		0.32	0.50
1,2-Dichloropropane	<0.50		0.45	0.50
1,3-Dichloropropane	<0.50		0.43	0.50
2,2-Dichloropropane	<0.50		0.31	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.32	0.50
Diisopropyl ether	<0.50		0.28	0.50
Ethylbenzene	<0.50		0.12	0.50
Ethylene Dibromide	<0.50		0.20	0.50
Freon 113	<0.50		0.15	0.50
Hexachlorobutadiene	<0.50		0.26	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.21	0.50
Methylene Chloride	<0.50		0.36	0.50
2-Butanone (MEK)	<10		5.0	10

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-55261-1

Method Blank - Batch: 680-161965

Method: 524.2
Preparation: N/A

Lab Sample ID: MB 680-161965/9
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/01/2010 1315
Date Prepared: N/A

Analysis Batch: 680-161965
Prep Batch: N/A
Units: ug/L

Instrument ID: MSU
Lab File ID: uq0324.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	Result	Qual	MDL	RL
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.42	0.50
Naphthalene	<1.0		0.43	1.0
n-Butylbenzene	<0.50		0.17	0.50
N-Propylbenzene	<0.50		0.17	0.50
o-Xylene	<0.50		0.27	0.50
sec-Butylbenzene	<0.50		0.14	0.50
Styrene	<0.50		0.28	0.50
Tert-amyl methyl ether	<0.50		0.20	0.50
tert-Butyl alcohol	<2.0		1.6	2.0
tert-Butylbenzene	<0.50		0.14	0.50
Tert-butyl ethyl ether	<0.50		0.26	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.16	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.18	0.50
Tetrachloroethene	<0.50		0.30	0.50
Toluene	<0.50		0.23	0.50
trans-1,2-Dichloroethene	<0.50		0.24	0.50
trans-1,3-Dichloropropene	<0.50		0.48	0.50
1,2,3-Trichlorobenzene	<0.50		0.14	0.50
1,2,4-Trichlorobenzene	<0.50		0.18	0.50
1,1,1-Trichloroethane	<0.50		0.27	0.50
1,1,2-Trichloroethane	<0.50		0.22	0.50
Trichloroethene	<0.50		0.37	0.50
Trichlorofluoromethane	<0.50		0.23	0.50
1,2,3-Trichloropropane	<0.50		0.18	0.50
Trihalomethanes, Total	<0.50		0.29	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.16	0.50
Vinyl chloride	<0.50		0.33	0.50
Xylenes, Total	<0.50		0.27	0.50

Surrogate	% Rec	Acceptance Limits
4-Bromofluorobenzene	94	70 - 130
1,2-Dichlorobenzene-d4	89	70 - 130

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-55261-1

**Lab Control Sample/
Lab Control Sample Duplicate Recovery Report - Batch: 680-161965**

**Method: 524.2
Preparation: N/A**

LCS Lab Sample ID: LCS 680-161965/6
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/01/2010 1131
Date Prepared: N/A

Analysis Batch: 680-161965
Prep Batch: N/A
Units: ug/L

Instrument ID: MSU
Lab File ID: uq0321.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

LCSD Lab Sample ID: LCSD 680-161965/7
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/01/2010 1203
Date Prepared: N/A

Analysis Batch: 680-161965
Prep Batch: N/A
Units: ug/L

Instrument ID: MSU
Lab File ID: uq0322.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	LCS Qual	LCSD Qual
	LCS	LCSD					
Acetone	94	100	70 - 130	6	30		
Benzene	106	102	70 - 130	4	30		
Bromobenzene	116	112	70 - 130	3	30		
Bromoform	121	120	70 - 130	1	30		
Bromomethane	119	133	70 - 130	11	30		*
Carbon tetrachloride	122	118	70 - 130	4	30		
Chlorobenzene	112	106	70 - 130	5	30		
Chlorobromomethane	103	101	70 - 130	2	30		
Chlorodibromomethane	116	108	70 - 130	7	30		
Chloroethane	113	117	70 - 130	3	30		
Chloroform	103	104	70 - 130	1	30		
Chloromethane	108	118	70 - 130	8	30		
2-Chlorotoluene	110	109	70 - 130	1	30		
4-Chlorotoluene	109	110	70 - 130	2	30		
cis-1,2-Dichloroethene	108	107	70 - 130	1	30		
cis-1,3-Dichloropropene	120	117	70 - 130	3	30		
1,2-Dibromo-3-Chloropropane	117	119	70 - 130	2	30		
Dibromomethane	111	106	70 - 130	4	30		
1,2-Dichlorobenzene	107	107	70 - 130	0	30		
1,3-Dichlorobenzene	113	115	70 - 130	2	30		
1,4-Dichlorobenzene	116	116	70 - 130	0	30		
Dichlorobromomethane	115	108	70 - 130	7	30		
Dichlorodifluoromethane	116	133	70 - 130	14	30		*
1,1-Dichloroethane	103	103	70 - 130	0	30		
1,2-Dichloroethane	102	94	70 - 130	8	30		
1,1-Dichloroethene	98	95	70 - 130	3	30		
1,2-Dichloropropane	105	102	70 - 130	3	30		
1,3-Dichloropropane	119	117	70 - 130	2	30		
2,2-Dichloropropane	120	122	70 - 130	2	30		
1,1-Dichloropropene	108	105	70 - 130	3	30		
1,3-Dichloropropene, Total	119	116	70 - 130	2	30		
Diisopropyl ether	101	106	70 - 130	4	30		

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-55261-1

Lab Control Sample/

Lab Control Sample Duplicate Recovery Report - Batch: 680-161965

Method: 524.2

Preparation: N/A

LCS Lab Sample ID: LCS 680-161965/6
 Client Matrix: Water
 Dilution: 1.0
 Date Analyzed: 03/01/2010 1131
 Date Prepared: N/A

Analysis Batch: 680-161965
 Prep Batch: N/A
 Units: ug/L

Instrument ID: MSU
 Lab File ID: uq0321.d
 Initial Weight/Volume: 5 mL
 Final Weight/Volume: 5 mL

LCSD Lab Sample ID: LCSD 680-161965/7
 Client Matrix: Water
 Dilution: 1.0
 Date Analyzed: 03/01/2010 1203
 Date Prepared: N/A

Analysis Batch: 680-161965
 Prep Batch: N/A
 Units: ug/L

Instrument ID: MSU
 Lab File ID: uq0322.d
 Initial Weight/Volume: 5 mL
 Final Weight/Volume: 5 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	LCS Qual	LCSD Qual
	LCS	LCSD					
Ethylbenzene	111	111	70 - 130	0	30		
Ethylene Dibromide	113	109	70 - 130	4	30		
Freon 113	108	111	70 - 130	3	30		
Hexachlorobutadiene	114	115	70 - 130	1	30		
2-Hexanone	115	117	70 - 130	1	30		
Isopropylbenzene	110	122	70 - 130	10	30		
4-Isopropyltoluene	122	126	70 - 130	3	30		
Methylene Chloride	99	100	70 - 130	1	30		
2-Butanone (MEK)	94	98	70 - 130	5	30		
4-Methyl-2-pentanone (MIBK)	115	115	70 - 130	0	30		
m-Xylene & p-Xylene	112	112	70 - 130	0	30		
Naphthalene	123	117	70 - 130	5	30		
n-Butylbenzene	122	128	70 - 130	4	30		
n-Propylbenzene	112	115	70 - 130	2	30		
o-Xylene	119	118	70 - 130	1	30		
sec-Butylbenzene	115	119	70 - 130	3	30		
Styrene	122	122	70 - 130	1	30		
Tert-amyl methyl ether	89	91	70 - 130	2	30		
tert-Butyl alcohol	110	110	70 - 130	0	30		
tert-Butylbenzene	119	120	70 - 130	0	30		
Tert-butyl ethyl ether	92	105	70 - 130	13	30		
1,1,1,2-Tetrachloroethane	123	121	70 - 130	2	30		
1,1,2,2-Tetrachloroethane	116	110	70 - 130	5	30		
Tetrachloroethene	114	114	70 - 130	0	30		
Toluene	109	107	70 - 130	2	30		
trans-1,2-Dichloroethene	108	103	70 - 130	5	30		
trans-1,3-Dichloropropene	117	115	70 - 130	2	30		
1,2,3-Trichlorobenzene	120	116	70 - 130	3	30		
1,2,4-Trichlorobenzene	122	124	70 - 130	2	30		
1,1,1-Trichloroethane	110	109	70 - 130	1	30		
1,1,2-Trichloroethane	109	109	70 - 130	0	30		
Trichloroethene	113	112	70 - 130	0	30		

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-55261-1

**Lab Control Sample/
Lab Control Sample Duplicate Recovery Report - Batch: 680-161965**

**Method: 524.2
Preparation: N/A**

LCS Lab Sample ID: LCS 680-161965/6
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/01/2010 1131
Date Prepared: N/A

Analysis Batch: 680-161965
Prep Batch: N/A
Units: ug/L

Instrument ID: MSU
Lab File ID: uq0321.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

LCSD Lab Sample ID: LCSD 680-161965/7
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/01/2010 1203
Date Prepared: N/A

Analysis Batch: 680-161965
Prep Batch: N/A
Units: ug/L

Instrument ID: MSU
Lab File ID: uq0322.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	LCS Qual	LCSD Qual
	LCS	LCSD					
Trichlorofluoromethane	105	115	70 - 130	9	30		
1,2,3-Trichloropropane	113	106	70 - 130	7	30		
1,2,4-Trimethylbenzene	110	110	70 - 130	0	30		
1,3,5-Trimethylbenzene	111	113	70 - 130	1	30		
Vinyl chloride	106	110	70 - 130	4	30		
Xylenes, Total	114	114	70 - 130	1	30		
Surrogate	% Rec		LCSD % Rec	Acceptance Limits			
4-Bromofluorobenzene	105		105	70 - 130			
1,2-Dichlorobenzene-d4	108		104	70 - 130			

Calculations are performed before rounding to avoid round-off errors in calculated results.



Weston Solutions, Inc.
1400 Weston Way
P.O. Box 2653
West Chester, Pennsylvania 19380
610-701-3000 • Fax 610-701-3186
www.westonsolutions.com

29 April 2010

Mr. Charlie Zeleski
Carroll County Health Department
Bureau of Environmental Health
P.O. Box 845
290 S. Center St.
Westminster, MD 21158

Re: Black & Decker Hampstead Facility

Dear Mr. Zeleski:

On behalf of our client, Black & Decker (U.S.) Inc. (Black & Decker), Weston Solutions, Inc. (WESTON®) provides enclosed with this letter a copy of the Quarterly Groundwater Monitoring Report for the period of January through March 2010.

If you have any questions regarding the enclosure, please contact me at (610) 701-3776.

Very truly yours,

WESTON SOLUTIONS, INC.

A handwritten signature in cursive script that reads "Thomas Cornuet".

Thomas Cornuet, P.G.
Project Manager

Enclosure

cc: L. Biagioni, B&D
J. Freed, B&D
T. Lynch III, M&S
L. Bove, WESTON (w/o encl.)





Weston Solutions, Inc.
1400 Weston Way
P.O. Box 2653
West Chester, Pennsylvania 19380
610-701-3000 • Fax 610-701-3186
www.westonsolutions.com

29 April 2010

Mr. Arthur O'Connell
Waste Management Administration
Maryland Department of the Environment
1800 Washington Blvd
Baltimore, MD 21230

Re: Black & Decker Hampstead Facility

Dear Mr. O'Connell

On behalf of our client, Black & Decker (U.S.) Inc. (Black & Decker), Weston Solutions, Inc. (WESTON®) provides enclosed with this letter two copies of the Quarterly Groundwater Monitoring Report for the period of January through March 2010. This report has been drafted for your review pursuant to the Administrative Consent Order of 13 April 1995.

If you have any questions regarding the enclosure, please contact me at (610) 701-3776.

Very truly yours,

WESTON SOLUTIONS, INC.

A handwritten signature in cursive script, appearing to read "Thomas Cornuet".

Thomas Cornuet, P.G.
Project Manager

Enclosure

cc: L. Biagioni, B&D
J. Freed, B&D
T. Lynch III, M&S
K. Decker, Town of Hampstead
L. Bove, WESTON (w/o encl.)
B. Dietz, MDE (w/o encl.)

