

Quarterly Groundwater Monitoring Report

Prepared for

Black & Decker (U.S.) Inc.

Hampstead, Maryland

October 2010

Prepared by

WESTON SOLUTIONS, INC.

West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION	1-1
2. SITE CHARACTERISTICS	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 3rd Quarter 2010	2-2
Table 2-2 Groundwater Elevation Data – 3rd Quarter 2010.....	2-3
Table 2-3 Effluent Characteristics Summary – 3rd Quarter 2010.....	2-4
Table 2-4 Summary of Groundwater Analytical Results - August 2010	2-5
Table 3-1 Treatment System Maintenance Activities – 3rd Quarter 2010.....	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of July through September 2010.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of July through September 2010, the extraction wells were pumping at an average combined rate of approximately 169 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of July through September 2010 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of July through September 2010, approximately 15.8 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (86.7 %) and tetrachloroethene (PCE) (13.3 %). Analytical results of the groundwater collected from the air stripper for the period of July through September 2010 are included in Appendix C.

A summary of the analytical results from the third quarter (August 2010) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 3rd Quarter 2010
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
July 2010	7,505,570
August 2010	7,175,989
September 2010	6,655,915

Table 2-2
Groundwater Elevation Data - 3rd Quarter 2010
Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV.	TOTAL DEPTH	7/15/2010		8/18/2010		9/7/2010	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NC	DRY	NC	DRY	NC
EW-2	849.21	110	86.11	763.10	93.61	755.60	94.10	755.11
EW-3	846.64	118	83.87	762.77	86.71	759.93	88.40	758.24
EW-4	858.01	97.5	PC	NC	PC	NC	PC	NC
EW-5	864.17	98	90.14	774.03	91.17	773.00	91.25	772.92
EW-6	831.98	115	92.60	739.38	98.67	733.31	99.26	732.72
EW-7	818.38	78	46.03	772.35	45.28	773.10	52.60	765.78
EW-8	811.13	98	93.31	717.82	92.84	718.29	92.51	718.62
EW-9	811.35	141	102.00	709.35	102.00	709.35	103.00	708.35
EW-10	807.74	INA	49.73	758.01	52.69	755.05	54.60	753.14
RFW-1A	864.37	78	49.01	815.36	51.37	813.00	51.63	812.74
RFW-1B	864.23	200	49.06	815.17	51.39	812.84	51.67	812.56
RFW-2A	857.41	35	15.11	842.30	17.02	840.39	16.83	840.58
RFW-2B	857.73	75	15.52	842.21	17.61	840.12	17.17	840.56
RFW-3B	839.21	153	29.71	809.50	34.93	804.28	34.86	804.35
RFW-4A	830.37	62	35.54	794.83	36.51	793.86	36.43	793.94
RFW-4B	830.37	120	35.43	794.94	36.48	793.89	36.39	793.98
RFW-5A	817.50	30	DRY	NC	DRY	NC	DRY	NC
RFW-6	785.04	120	5.01	780.03	3.11	781.93	2.61	782.43
RFW-7	805.14	29	7.92	797.22	6.32	798.82	7.42	797.72
RFW-8	860.07	56	DRY	NC	DRY	NC	DRY	NC
RFW-9	862.02	49	26.13	835.89	26.47	835.55	26.47	835.55
RFW-10	852.06	58	DRY	NC	DRY	NC	DRY	NC
RFW-11A	849.32	72	Damaged	NC	Damaged	NC	Damaged	NC
RFW-11B	849.62	116	62.12	787.50	63.41	786.21	63.89	785.73
RFW-12B	844.87	264	50.93	793.94	49.95	794.92	50.11	794.76
RFW-13	849.11	150	58.61	790.50	58.11	791.00	59.61	789.50
RFW-14B	812.39	281	53.21	759.18	54.02	758.37	54.26	758.13
RFW-16	856.14	41	DRY	NC	DRY	NC	DRY	NC
RFW-17	834.66	60.5	23.89	810.77	25.81	808.85	26.41	808.25
RFW-20	842.49	142	31.41	811.08	33.48	809.01	34.10	808.39
RFW-21	832.65	102	19.29	813.36	21.05	811.60	21.34	811.31
PH-7	805.94	89	25.41	780.53	29.90	776.04	29.01	776.93
PH-9	814.94	98	39.80	775.14	41.62	773.32	38.67	776.27
PH-11	820.68	78	51.47	769.21	51.88	768.80	51.28	769.40
PH-12	828.35	87	51.81	776.54	53.97	774.38	53.79	774.56
B-3	803.02	83	10.02	793.00	10.55	792.47	9.91	793.11
Amoco	842.29	INA	NA	NC	NA	NC	NA	NC
Hamp. Town #22	804.96	INA	3.89	801.07	3.43	801.53	4.76	800.20
Pembroke #1	INA	INA	11.83	NC	12.33	NC	12.21	NC
Pembroke #2	INA	INA	Damaged	NC	Damaged	NC	Damaged	NC
N. Houcks. Rd.	INA	INA	10.53	NC	10.89	NC	9.83	NC
E. Century St.	INA	INA	19.08	NC	19.58	NC	19.74	NC
Lwr. Beckleys. Rd.	INA	INA	55.87	NC	55.69	NC	54.73	NC

NA - Not Available/Not Accessible

NC - Not Calculable

INA - Information not available

PC - Pump Cycles

Table 2-3
 Effluent Characteristics Summary - 3rd Quarter 2010
 Black & Decker
 Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				July 2010	August 2010	September 2010	
001	FLOW	average	MGD	NA	0.129	0.142	0.102
		maximum	MGD	NA	0.236	0.338	0.130
	1,1,1-Trichloroethane		ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene		ug/l	5	< 1	< 1	< 1
	Trichloroethylene		ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		quarterly average	mg/l	10	< 5	< 5	< 5
	pH	minimum	STD	6.0	6.6	6.5	6.5
		maximum	STD	8.5	8.4	7.6	6.9
	BOD		mg/l	15	3.0	3.0	3.0
	TSS	maximum	mg/l	30	0.0	5.0	7.0
quarterly average		mg/l	20	0.0	5.0	7.0	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.217	0.203	0.208
		maximum	MGD	NA	0.327	0.248	0.288
	Fecal Coliform		MPN/100ml	200	1.0	1.0	1.0
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.232
		maximum	MGD	NA	NR	NR	0.287
	1,1,1-Trichloroethane		ug/l	NA	NR	NR	< 1
	Tetrachloroethylene		ug/l	NA	NR	NR	< 1
	Trichloroethylene		ug/l	NA	NR	NR	< 1

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

Table 2-4
Summary of Groundwater Analytical Results - August 2010
Black & Decker
Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3.4	2.2	1 U	1 U	1 U	2.2	20	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	380	76	920	130	7.4	2	8	1 U	1 U	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	50	2.5	19	4.2	15	4.8	52	84	83	1.6
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

Table 2-4
Summary of Groundwater Analytical Results - August 2010
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	NS	2 U	2 U	NS	2 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.2	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.3	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	2.6	0.9 J	0.9 J	2	NS	1 U	1 U	NS	16	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	0.8 J	0.8 J	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	37	36	17	NS	1.2	4.4	NS	14	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	29	29	29	NS	1.7	1 U	NS	6.5	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicate sample
NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
J = Indicates an estimated value.

Table 2-4
Summary of Groundwater Analytical Results - August 2010
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	RFW-20	RFW-21	Town #22	Town #23	Trip Blank
		USEPA drinking water method 524.2														
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	NS	NS	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	NS	NS	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	NS	2 U	ABD	ABD	ABD	2 U	0.5 U	0.5 U	NS	NS	0.5 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	NA	NA	NS	NS	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	2.9	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Trichloroethene	ug/L	NS	6.2	180	2.8	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
Tetrachloroethene	ug/L	NS	1 U	17	15	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division.
 Samples from all of the other wells are analyzed with USEPA Method 8260.
 NS = Not sampled
 U = Compound was analyzed but not detected.
 ABD = Well has been abandoned

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from well EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (July through September 2010) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 3rd Quarter 2010
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Jul-10	Alarm at the air stripper due to high wet well, reset the system. The system is back online.
Jul-10	Turn EW-3 off for 1 hour to replace a leaking valve. EW-3 back online.
Jul-10	Alarm at air stripper. A 4-inch plastic butterfly valve broke it was replaced it with a spool piece of pipe. The air stripper is back online.
Aug-10	Alarm at the air stripper due to a bad control relay in EW - 6. Replaced the control relay in EW - 6, well is back online.
Aug-10	Alarm at the air stripper due to a power outage, reset the system. The system is back online.
Aug-10	Installed a new 4-inch butterfly valve, the stripper was down for three hours, the system is back online.
Aug-10	Alarm at the air stripper, EW-9 is down due to a bad control relay. The control relay is replaced the well is back online.
Aug-10	Alarm at the air stripper, high column and blower failure. Reset the system, the stripper is back online.

4. RECOMMENDATIONS

For the reporting period of July through September 2010, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(JULY – SEPTEMBER 2010)

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Superintendent: Earle Villarreal Certification # 1017

Black & Decker WTP

PWSID # 106 0004 County: Carroll

Operated by:
Maryland Environmental Service

Address: BTR CAPITAL GROUP, Hampstead, MD 21073
625 Hanover Pike, Hampstead, Carroll County, Maryland

Month: July

Year: 2010

GENERAL			DOMESTIC WATER				CHEMICAL					MONITORING			DISTRIBUTION		RAW WATER		Comments	
Date	Day	Weather	Flow meter reading	MGD Total FQIR	pH P.O.E	Free Cl2	Na2CO3 Level	Na2CO3 (gpd)	NaOCL Level	NaOCL (gpd)	VOC'S (ppb)	Bacti Pos/Neg	pH su	TRC mg/l	DISTRIBUTION LOCATION	Operator Initials	pH su	TOTAL RAW WATER:WELL (mgd)		
1	Thurs	Clear	0	0.0020	7.5	1.26	40.00	1.00	67.00	0.00						djones		0.216367		
2	Fri	Clear	0	0.0076	7.1	1.31	38.00	2.00	67.00	0.00			7.33	1.02	Admin 2nd Fl	djones		0.271661		
3	Sat	Clear	0	0.0000	7.6	1.18	38.00	0.00	67.00	0.00						djones		0.192132		
4	Sun	Clear	0	0.0025	7.8	1.05	37.00	1.00	67.00	0.00						bm		0.271567		
5	Mon	Clear	0	0.0000	7.8	1.34	37.00	0.00	67.00	0.00						bm		0.247666		
6	Tue	Clear	0	0.0025	7.8	1.20	36.00	1.00	67.00	0.00						bm		0.256844		
7	Wed	Clear	0	0.0054	7.6	1.32	35.00	1.00	67.00	0.00						bm		0.222859		
8	Thurs	Clear	0	0.0029	9.0	1.17	34.00	1.00	67.00	0.00						fs		0.242040		
9	Fri	Clear	0	0.0076	7.1	1.28	32.00	2.00	67.00	0.00			6.7	0.77	Eng Lab	djones	4.60	0.286802		
10	Sat	Rain	0	0.0000	8.2	1.07	32.00	32.00	67.00	0.00						mw		0.237200		
11	Sun	Clear	0	0.0024	8.2	1.23	31.00	31.00	67.00	0.00						mw		0.249631		
12	Mon	Cloudy	0	0.0027	7.0	1.27	30.00	30.00	67.00	0.00						djones		0.216187		
13	Tue	Cloudy	0	0.0055	7.5	1.24	28.00	28.00	67.00	0.00			6.5	0.92	Eng Lab	djones		0.249075	Absent	
14	Wed	Rain	0	0.0053	7.5	1.25	27.00	27.00	67.00	0.00			7.3	1.08	Admin 1st Fl	djones	4.67	0.270425		
15	Thurs	Clear	0	0.0068	7.7	1.30	26.00	26.00	67.00	0.00						djones		0.233102		
16	Fri	Clear	0	0.0051	7.3	1.26	45.00	45.00	67.00	0.00			7.1	1.02	Admin 2nd Fl	djones		0.230416		
17	Sat	Clear	0	0.0025	7.5	1.14	44.00	44.00	67.00	0.00						djones		0.208760		
18	Sun	Clear	0	0.0000	7.3	1.04	44.00	44.00	67.00	0.00						djones		0.243565		
19	Mon	Cloudy	0	0.0050	7.4	1.05	43.00	43.00	67.00	0.00						dsmith		0.270921		
20	Tue	Cloudy	0	0.0050	7.7	1.64	42.00	42.00	67.00	0.00						jdowns		0.236877		
21	Wed	Cloudy	0	0.0050	8.3	1.58	40.00	40.00	67.00	0.00			7.8	1.25	Eng Lab	djones		0.267500		
22	Thurs	Clear	0	0.0039	8.1	1.44	38.00	2.00	67.00	0.00						djones	4.55	0.207500		
23	Fri	Clear	0	0.0064	8.3	1.46	36.00	2.00	67.00	0.00			7.9	1.07	Eng Lab	bm		0.262364		
24	Sat	Clear	0	0.0023	8.2	1.40	35.00	1.00	67.00	0.00						dsmith		0.190588		
25	Sun	Clear	0	0.0000	8.1	1.35	35.00	0.00	67.00	0.00						dsmith		0.240076		
26	Mon	Clear	0	0.0043	8.3	1.40	34.00	1.00	67.00	0.00						dsmith		0.270304		
27	Tue	Clear	0	0.0060	7.5	1.45	32.00	2.00	67.00	0.00			7.1	1.08	Admin 1st Fl	bm		0.251378		
28	Wed	Clear	0	0.0052	6.9	1.33	30.00	2.00	67.00	0.00						gd		0.244726		
29	Thurs	Cloudy	0	0.0052	8.4	1.64	28.00	2.00	67.00	0.00						gd		0.247213		
30	Fri	Clear	0	0.0037	8.4	1.18	27.00	1.00	67.00	0.00			8.3	0.99	Admin 2nd Fl	gd		0.229091		
31	Sat	Clear	0	0.0046	7.0	1.10	25.00	2.00	67.00	0.00						gd		0.240733		
Total				0.1174	239.9	39.93	1079.0	456.00	2077.0	0.00	0.0	0.0	66	9					7.505570	
Average				0.0038	7.74	1.29	34.81	14.71	67.00	0.00	0.0	0.0	7.34	1.02					0.242115	
Minimum				0.0000	6.94	1.04	25.00	0.00	67.00	0.00	0.0	0.0	6.52	0.77					0.190588	MOR
Maximum				0.0076	8.95	1.64	45.00	45.00	67.00	0.00	0.0	0.0	8.29	1.25					0.286802	12/04/08

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Superintendent: Earle Villarreal Certification # 1017

Black & Decker WTP

PWSID # 106 0004 County: Carroll
 Address: BTR CAPITAL GROUP, Hampstead, MD 21073
 625 Hanover Pike, Hampstead, Carroll County, Maryland

Operated by
 Maryland Environmental Service

Month: August

Year: 2010



GENERAL (DOMESTIC WATER)			CHEMICAL								MONITORING		DISTRIBUTION		RAW WATER		Comments		
Date	Day	Weather	Flow meter reading 0	MGD Total FQIR	pH P.O.E	Free Cl2	Na2CO3 Level	Na2CO3 (gpd)	NaOCl Level	NaOCl (gpd)	VOC'S (ppb)	Bacti Pos/Neg	pH su	TRC mg/l	DISTRIBUTION LOCATION	Operator Initials		pH su	TOTAL RAW WATER WELL (mgd)
1	Sun	Clear	0	0.0000	6.6	1.16	25.00	0.00	67.00	0.00						gd		0.218796	
2	Mon	Cloudy	0	0.0026	7.0	1.18	24.00	1.00	67.00	0.00			6.70	0.65	Eng Lab	djones		0.228394	
3	Tue	Cloudy	0	0.0071	7.3	1.24	21.00	3.00	67.00	0.00						djones		0.264380	
4	Wed	Cloudy	0	0.0051	7.2	1.33	38.00	3.00	67.00	0.00			7.0	1.14	Admin 1st Fl	djones		0.234729	
5	Thur	Cloudy	0	0.0060	7.1	1.27	36.00	2.00	67.00	0.00						djones		0.228993	
6	Fri	Clear	0	0.0108	6.9	1.08	34.00	2.00	67.00	0.00			6.8	0.97	Admin 2nd Fl	djones	4.97	0.241216	
7	Sat	Clear	0	0.0082	6.7	1.21	31.00	3.00	67.00	0.00						djones		0.184680	
8	Sun	Clear	0	0.0108	6.8	1.20	28.00	3.00	65.00	2.00						djones		0.238240	
9	Mon	Clear	0	0.0120	8.0	1.51	43.00	5.00	65.00	0.00			6.9	1.20	Eng Lab	gd		0.270252	
10	Tue	Clear	0	0.0040	7.0	1.54	41.00	2.00	65.00	0.00						bm		0.221330	
11	Wed	Clear	0	0.0070	7.0	1.73	39.00	2.00	65.00	0.00			6.7	1.33	Loading Dock	djones		0.253174	
12	Thur	Cloudy	0	0.0050	7.1	1.67	38.00	1.00	65.00	0.00						djones	4.75	0.231394	
13	Fri	Rain	0	0.0049	7.2	1.61	37.00	1.00	65.00	0.00			6.8	1.44	Admin 2nd Fl	djones		0.236565	
14	Sat	Cloudy	0	0.0023	7.2	1.60	36.00	1.00	65.00	0.00						dsmith		0.164308	
15	Sun	Cloudy	0	0.0000	7.2	1.65	36.00	0.00	65.00	0.00						dsmith		0.239848	
16	Mon	Cloudy	0	0.0048	6.8	1.42	34.00	2.00	65.00	0.00			6.9	1.32	Admin 1st Fl	djones		0.265990	
17	Tue	Cloudy	0	0.0028	7.4	1.45	33.00	1.00	65.00	0.00						djones		0.212410	
18	Wed	Rain	0	0.0075	7.3	1.55	31.00	2.00	65.00	0.00			7.1	1.27	Eng Lab	djones	4.76	0.264988	
19	Thur	Clear	0	0.0048	7.7	1.48	30.00	1.00	65.00	0.00						djones		0.241343	
20	Fri	Clear	0	0.0051	7.6	1.56	28.00	2.00	65.00	0.00			6.8	1.32	Admin 2nd Fl	djones		0.225647	
21	Sat	Clear	0	0.0024	6.7	1.35	27.00	1.00	65.00	0.00						gd		0.218093	
22	Sun	Cloudy	0	0.0000	7.0	1.20	27.00	0.00	65.00	0.00						gd		0.220939	
23	Mon	Clear	0	0.0051	7.0	1.40	26.00	1.00	65.00	0.00			7.4	1.07	Loading Dock	djones		0.246286	
24	Tue	Cloudy	0	0.0052	7.5	1.24	46.00	2.00	65.00	0.00						djones		0.232305	
25	Wed	Cloudy	0	0.0051	7.0	1.22	45.00	1.00	65.00	0.00			7.0	0.99	Eng Lab	djones	4.83	0.224457	
26	Thur	Clear	0	0.0050	7.4	1.26	43.00	2.00	65.00	0.00						djones		0.214047	
27	Fri	Clear	0	0.0052	7.0	1.27	42.00	1.00	65.00	0.00			7.0	0.98	Admin 1st Fl	djones		0.247906	
28	Sat	Clear	0	0.0024	7.1	1.06	41.00	1.00	65.00	0.00						djones		0.185807	
29	Sun	Clear	0	0.0000	7.6	1.05	41.00	0.00	65.00	0.00						djones		0.230857	
30	Mon	Clear	0	0.0051	7.6	1.18	39.00	2.00	65.00	0.00			6.9	0.90	Eng Lab	bm		0.271477	
31	Tue	Clear	0	0.0049	7.3	1.07	38.00	1.00	65.00	0.00						bm		0.217138	
Total				0.1512	222.0	41.74	1078.0	49.00	2029.0	2.00	0.0	0.0	90	14					7.175989
Average				0.0049	7.16	1.35	34.77	1.58	65.45	0.06	0.0	0.0	6.90	1.13					0.231484
Minimum				0.0000	6.61	1.05	21.00	0.00	65.00	0.00	0.0	0.0	6.65	0.65					0.164308
Maximum				0.0120	7.97	1.73	46.00	5.00	67.00	2.00	0.0	0.0	7.37	1.44					0.271477

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Superintendent: Earle Villarreal Certification # 1017

Black & Decker WTP

PWSID # 106 0004 County: Carroll
 Address: BTR CAPITAL GROUP, Hampstead, MD 21073
 625 Hanover Pike, Hampstead, Carroll County, Maryland

Month: September

Operated by
 Maryland Environmental Service

Year: 2010

GENERAL (DOMESTIC WATER)				CHEMICAL							MONITORING				DISTRIBUTION		RAW WATER		Comments
Date	Day	Weather	Flow meter reading "	MGD Total FQIR	pH P.O.E	Free Cl ₂	Na ₂ CO ₃ Level	Na ₂ CO ₃ (gpd)	NaOCl Level	NaOCl (gpd)	VOC'S (ppb)	Bacti Pos/Neg	pH su	TRC mg/l	DISTRIBUTION LOCATION	Operator Initials	pH su	TOTAL RAW WATER WELL (mgd)	
1	Wed	Clear	0	0.0052	6.9	1.07	37.00	1.00	64.00	0.00			7.02	0.94	Loading Dock	Djones		0.236397	
2	Thur	Clear	0	0.0041	7.2	1.11	36.00	1.00	64.00	0.00						Djones	4.68	0.204273	
3	Fri	Cloudy	0	0.0059	7.2	1.43	35.00	1.00	64.00	0.00			6.81	1.13	Admin 2nd Fl	Djones		0.249125	
4	Sat	Clear	0	0.0023	7.4	1.30	34.00	1.00	64.00	0.00						BM		0.201540	
5	Sun	Clear	0	0.0000	7.2	1.17	34.00	0.00	64.00	0.00						BM		0.220032	
6	Mon	Clear	0	0.0025	7.7	1.28	33.00	1.00	64.00	0.00						GD		0.243987	
7	Tue	Clear	0	0.0026	7.6	1.34	32.00	1.00	64.00	0.00						Djones		0.234804	
8	Wed	Clear	0	0.0052	7.5	1.42	31.00	1.00	64.00	0.00			6.8	0.85	Eng Lab	Djones	4.62	0.193622	
9	Thur	Clear	0	0.0052	7.5	1.45	29.00	2.00	64.00	0.00						Djones		0.239281	
10	Fri	Cloudy	0	0.0050	7.6	1.37	48.00	1.00	64.00	0.00			7.2	1.27	Admin 2nd Fl	Djones		0.240887	
11	Sat	Clear	0	0.0025	7.0	1.32	47.00	1.00	64.00	0.00						GD		0.206603	
12	Sun	Rain	0	0.0023	7.0	1.32	46.00	1.00	64.00	0.00						GD		0.226380	
13	Mon	Clear	0	0.0027	7.0	1.30	45.00	1.00	64.00	0.00						Dsmith		0.221486	
14	Tue	Clear	0	0.0050	7.1	1.24	43.00	2.00	64.00	0.00						Djones		0.207981	
15	Wed	Clear	0	0.0053	7.5	1.25	42.00	1.00	64.00	0.00			7.3	1.14	Admin 1st Fl	Djones	4.71	0.239516	
16	Thur	Cloudy	0	0.0066	7.3	1.19	41.00	1.00	64.00	0.00			7.5	1.00	Eng Lab	Djones		0.233625	
17	Fri	Clear	0	0.0057	7.7	1.24	39.00	2.00	64.00	0.00						Djones		0.232618	
18	Sat	Clear	0	0.0025	7.4	1.18	38.00	1.00	64.00	0.00						Djones		0.170183	
19	Sun	Clear	0	0.0009	7.6	1.05	37.00	1.00	64.00	0.00						Djones		0.223862	
20	Mon	Clear	0	0.0041	7.8	1.30	36.00	1.00	64.00	0.00			7.3	1.02	Loading Dock	BM		0.260726	
21	Tue	Clear	0	0.0059	7.6	1.44	35.00	1.00	64.00	0.00						BM		0.215010	
22	Wed	Clear	0	0.0052	7.8	1.38	33.00	2.00	64.00	0.00			7.5	1.28	Admin 2nd Fl	Djones		0.226898	
23	Thur	Clear	0	0.0051	7.5	1.39	31.00	2.00	64.00	0.00						Djones	4.80	0.200355	
24	Fri	Clear	0	0.0048	7.8	1.35	30.00	1.00	64.00	0.00			7.5	1.13	Eng Lab	Djones		0.221935	
25	Sat	Clear	0	0.0051	7.1	1.17	28.00	2.00	64.00	0.00						GD		0.228223	
26	Sun	Cloudy	0	0.0000	6.8	1.03	28.00	0.00	64.00	0.00						GD		0.206854	
27	Mon	Rain	0	0.0045	7.4	1.14	27.00	1.00	64.00	0.00			7.2	0.97	Admin 1st Fl	Djones		0.237710	
28	Tue	Clear	0	0.0052	7.6	1.04	24.00	3.00	64.00	0.00						AP		0.215218	
29	Wed	Cloudy	0	0.0051	6.7	1.24	23.00	1.00	64.00	0.00			6.6	1.17	Loading Dock	Djones		0.215744	
30	Thur	Rain	0	0.0041	7.2	1.20	42.00	1.00	64.00	0.00						Djones	4.82	0.201040	
31																			
Total				0.1206	220.5	37.71	1064.0	36.00	1920.0	0.00	0.0	0.0	79	12				6.655915	
Average				0.0040	7.35	1.26	35.47	1.20	64.00	0.00	0.0	0.0	7.14	1.08				0.221864	
Minimum				0.0000	6.72	1.03	23.00	0.00	64.00	0.00	0.0	0.0	6.61	0.85				0.170183	
Maximum				0.0066	7.83	1.45	48.00	3.00	64.00	0.00	0.0	0.0	7.50	1.28				0.260726	MOR 12/04/08

**APPENDIX B
DISCHARGE MONITORING REPORTS
(JULY - SEPTEMBER 2010)**

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.
 Address 626 Hanover Pike
 Hampstead, MD 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires:

Facility Black and Decker WWTP
 Location 626 Hanover Pike
 Attn:

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
10	07	01	TO	10	07	31	
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)	

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form

State Discharge Permit
 02-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING (3 Card Only) (46-53)			QUALITY OR CONCENTRATION (4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (54-61)	MAXIMUM	UNITS	MINIMUM (54-61)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	3	(19)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY:MX	MG/L		ONCE/MONTH	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	****	6.6	*****	8.4	(12)	0	TWICE/WEEK	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY:MN	*****	8.5 DAILY:MX	SU		TWICE/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA:AVG	30 DAILY:MX	MG/L		ONCE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	128,806	236,000	(07)	*****	*****	*****	****	0	Measured	RECORD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA:AVG	0.019 DAILY:MX	MG/L		ONCE/MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY:MX	UG/L		ONCE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY:MX	UG/L		ONCE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
 James M. Harkins
 MES Director
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUES IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 551001 AND 33 U.S.C. 55 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE NUMBER: 410 729-8350
 DATE: 10 08 27
 AREA CODE NUMBER YEAR MONTH DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments he

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name AG/GFI Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address 626 Hanover Pike

MD0001881

001

Approval expires

Hampstead, MD 21074

PERMIT NUMBER

DISCHARGE NUMBER

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	07	01	TO	10	07	31
(20-21) (22-23) (24-25)				(26-27) (28-29) (30-31)		

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53) QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45) QUALITY OR CONCENTRATION (46-53) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB	
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY:MX	UG/L		ONCE/ MONTH	GRAB	
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/ MONTH	GRAB	
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10 30DA AVG	15 DAILY:MX	MG/L		ONCE/ MONTH	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.							TELEPHONE		DATE		
James M. Harkins MES Director TYPED OR PRINTED								410	729-8350	10	08	26
	SIGNATURE OF PRICIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

MONITORING PERIOD

FROM		YEAR	MO	DAY	TO	YEAR	MO	DAY
		10	07	01		10	07	31
		(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	216,903	327,000	(07)	*****	*****	*****	****	0	ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	GRAB	
COLIFORM, FECAL GENERAL 74055 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/ WEEK	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX	MPN		ONCE/ WEEK	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUES IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 551001 AND 33 U.S.C. 55 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.							TELEPHONE		DATE		
James M. Harkins MES Director	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							410	729-8350	10	08	27
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc
 Address 626 Hanover Pike
 Hampstead, MD 21074

Facility Black and Decker WWTP
 Location 626 Hanover Pike
 Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) MD0001881 PERMIT NUMBER
 (17-19) 001 DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	08	01	TO	10	08	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form

State Discharge Permit
 02-DP-0022.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(45-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C)	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	3	(19)	0	ONCE/MONTH	GRAB
00310 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX			ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	6.5	*****	7.6	(12)	0	TWICE/WEEK	GRAB
pH	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY MN	*****	8.5 DAILY MX			TWICE/WEEK	GRAB
00400 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	5	5	(19)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA AVG	30 DAILY MX			ONCE/MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	142,387	338,000	(07)	*****	*****	*****		0	Measured	RECORD
00530 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****			Measured	RECORD
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX			ONCE/MONTH	GRAB
50050 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			ONCE/MONTH	GRAB
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
50060 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
TETRACHLOROETHYLENE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			ONCE/MONTH	GRAB
34475 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			ONCE/MONTH	GRAB
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
34506 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	James M. Harkins MES Director	SIGNATURE OF PRICIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT			TELEPHONE		DATE				
TYPED OR PRINTED					410	729-8350	10	09	23		
COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments he					AREA CODE	NUMBER	YEAR	MONTH	DAY		

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved

OMB No.

Approval expires

*** NO DISCHARGE ***


NOTE: Read instructions before completing this form

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	10	08	01		10	08	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53)			QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB		
79141 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	****	*****	*****	5	UG/L	0	ONCE/MONTH	GRAB		
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	****	*****	*****	0	(19)	0	ONCE/MONTH	GRAB		
OIL AND GREASE TOTAL RECOVERABLE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	****	*****	*****	10	MG/L	0	ONCE/MONTH	GRAB		
70030 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	****	*****	*****	15	MG/L	0	ONCE/MONTH	GRAB		
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	****	*****	*****	30DA AVG	MG/L	0	ONCE/MONTH	GRAB		
	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	****	*****	*****	DAILY MX	MG/L	0	ONCE/MONTH	GRAB		
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	****	*****	*****	DAILY MX	MG/L	0	ONCE/MONTH	GRAB		
	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	****	*****	*****							
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	****	*****	*****							
	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	****	*****	*****							
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	****	*****	*****							
	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	****	*****	*****							
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	****	*****	*****							
	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	****	*****	*****							
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	****	*****	*****							
	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	****	*****	*****							
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	****	*****	*****							
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)										TELEPHONE		DATE			
James M. Harkins											410	729-8350	10	09	23	
MES Director											AREA CODE	NUMBER	YEAR	MONTH	DAY	
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT															

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
10	08	01	10	08	31


FROM

TO

(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53)			QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45)				QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS					
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	202,516	248,000	(07)				*****	*****	*****	****	0	ONCE/ MONTH	GRAB			
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	*****	*****	*****	*****		ONCE/ MONTH	GRAB			
COLIFORM, FECAL GENERAL 74055 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1			200 DAILY MX	(30)	0	ONCE/ WEEK	GRAB			
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX				MPN		ONCE/ WEEK	GRAB			
	SAMPLE MEASUREMENT																
	PERMIT REQUIREMENT																
	SAMPLE MEASUREMENT																
	PERMIT REQUIREMENT																
	SAMPLE MEASUREMENT																
	PERMIT REQUIREMENT																
	SAMPLE MEASUREMENT																
	PERMIT REQUIREMENT																
	SAMPLE MEASUREMENT																
	PERMIT REQUIREMENT																
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)											TFI PHONE		DATE			
James M. Harkins MES Director												410	729-8350	10	09	23	
TYPED OR PRINTED												AREA CODE	NUMBER	YEAR	MONTH	DAY	

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc
 Address 626 Hanover Pike
Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn: _____

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
10	09	01	10	09	30
(20-21)		(22-23)		(24-25)	
		(26-27)		(28-29)	
		(30-31)			

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	3	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	****	6.5	*****	6.9	(12)	0	TWICE/ WEEK	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY MN	*****	8.5 DAILY MX	SU		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	7	7	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	101,933	130,000	(07)	*****	*****	*****	****	0	Measured	RECORD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L		ONCE/ MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER James M. Harkins MES Director TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUES IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PPHONE		DATE		
		410	729-8350	10	10	21
SIGNATURE OF PRICIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments he

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name AG/GFI Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address 626 Hanover Pike

MD0001881

001

Approval expires

Hampstead, MD 21074

PERMIT NUMBER

DISCHARGE NUMBER

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP

MONITORING PERIOD

Location 626 Hanover Pike


YEAR	MO	DAY	YEAR	MO	DAY
10	09	01	10	09	30

State Discharge Permit

Attn:

02-DP-0022

FROM (20-21) (22-23) (24-25) TO (26-27) (28-29) (30-31)

PARAMETER (32-37)		QUANTITY OR LOADING (54-61)			QUALITY OR CONCENTRATION (54-61)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)					
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB	
79141 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L		ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE						DAILY MX						
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/ MONTH	GRAB	
70030 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE						30DA AVG	DAILY MX					
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)							TELEPHONE		DATE		
James M. Harkins MES Director								410	729-8350	10	10	21
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MONTH	DAY
COMMENT AND EXPANION OF ANY VIOLATIONS (Reference all attachments here)												

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.
 Address 626 Hanover Pike
 Hampstead, MD 21074

Facility Black and Decker WWTP
 Location 626 Hanover Pike
 Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) MD0001881 (17-19) 101
 PERMIT NUMBER DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
10	09	01	10	09	30
(20-21)		(22-23)	(24-25)	(26-27)	
				(28-29)	
				(30-31)	

State Discharge Permit
 02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	208,467	288,000	(07)	*****	*****	*****	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****			
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	0	ONCE/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX			
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER James M. Harkins MES Director TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS 1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
		410	729-8350	10	10	21
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.
 Address 626 Hanover Pike
Hampstead, MD 21074

Facility Black and Decker WWTP
 Location 626 Hanover Pike
 Attn: _____

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)	(17-19)
MD0001881	201
PERMIT NUMBER	DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	07	01	TO	10	09	30
(20-21)				(28-29)		
(22-23)				(30-31)		
(24-25)				(26-27)		

State Discharge Permit
 02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	231,930	286,802	(07)	*****	*****	*****	****	0	Measured	Record
50050 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	Record
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/Quarter	Grab
TETRACHLOROETHYLENE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/Quarter	Grab
34475 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/Quarter	Grab
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/Quarter	Grab
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/Quarter	Grab
34506 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/Quarter	Grab
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/Quarter	Grab
TRICHLOROETHENE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/Quarter	Grab
79141 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/Quarter	Grab
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/Quarter	Grab
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)			TFI PHONE		DATE				
James M. Harkins MES Director					410 729-8350		10	10	21		
TYPED OR PRINTED					AREA CODE NUMBER		YEAR	MONTH	DAY		
COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT									

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(JULY - SEPTEMBER 2010)



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A10070369
Project Name: Black & Decker WWTP
Receive Date: 7/7/2010
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10070369-01 **Sample Date: 7/7/2010 9:35**

Site: Black & Decker 001 Matrix: Waste Water
Client Sample ID:
Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	3	mg/L	2	SM 5210 B	7/8/2010 11:15:00 AM	Skent
Total Suspended Solids	< 4	mg/L	4	SM 2540D	7/13/2010 12:13:00 PM	KPlatt

Sample # A10070369-01A **Sample Date: 7/7/2010 9:35**

Site: Black & Decker 001 Matrix: Waste Water
Client Sample ID: A
Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	< 5	mg/L	5	EPA 1664	7/15/2010 3:15:00 PM	JMcGuire

Sample # A10070369-01B **Sample Date: 7/7/2010 9:35**

Site: Black & Decker 001 Matrix: Waste Water
Client Sample ID: B
Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	7/13/2010 1:40:00 AM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	7/13/2010 1:40:00 AM	JKozlowski
Trichloroethene	< 1	ug/L	1	EPA 8260B	7/13/2010 1:40:00 AM	JKozlowski

Approved: *Warren Van Arsdale*
Quality Assurance Manager

Reported: 7/23/2010 9:35:17 AM

RDL = Reporting Detection Limit N/A = Not Applicable
Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A10070856
Project Name: Black & Decker WWTP
Receive Date: 7/15/2010
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10070856-01 **Sample Date: 7/7/2010 9:15**

Site: Black & Decker 101

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Fecal Coliform, MPN	<1.8	MPN/100 mL	N/A	SM 9221 E	7/7/2010 1:27:00 PM	ChesapeakeEnvironmentalLa

Approved: *Waverly Van Arsdale*
Quality Assurance Manager

Reported: 7/16/2010 12:40:55 PM

RDL = Reporting Detection Limit N/A = Not Applicable
Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



630 Churchmans Road
 Newark, Delaware 19702
 302-266-9121 • 454-8720 (FAX)
 WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
 259 Najoles Road
 Millersville, MD 21108

Order Number: A10070688
 Project Name: Black & Decker WWTP
 Receive Date: 7/13/2010
 Client Code: MES_A
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10070688-01 **Sample Date: 7/13/2010 9:30**

Site: Black & Decker 201

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	7/16/2010 8:04:00 AM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	7/16/2010 8:04:00 AM	JKozlowski
Trichloroethene	< 1	ug/L	1	EPA 8260B	7/16/2010 8:04:00 AM	JKozlowski

Approved: *Walter Van Andell*
 Quality Assurance Manager

Reported: 7/20/2010 10:20:05 AM

RDL = Reporting Detection Limit N/A = Not Applicable
 Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A10080105
Project Name: Black & Decker WWTP
Receive Date: 8/3/2010
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10080105-01 **Sample Date: 8/3/2010 9:50**

Site: Black & Decker 101
Client Sample ID:
Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	3	mg/L	2	SM 5210 B	8/4/2010 7:30:00 AM	Skent
Total Suspended Solids	5	mg/L	4	SM 2540D	8/9/2010 1:12:00 PM	Kplatt

Sample # A10080105-02 **Sample Date: 8/3/2010 9:50**

Site: Black & Decker 101
Client Sample ID:
Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	< 5	mg/L	5	EPA 1664	8/5/2010 6:25:00 PM	JMcGuire

Sample # A10080105-03 **Sample Date: 8/3/2010 9:50**

Site: Black & Decker 101
Client Sample ID:
Sample Comments: None


Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	8/12/2010 10:19:00 AM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	8/12/2010 10:19:00 AM	JKozlowski
Trichloroethene	< 1	ug/L	1	EPA 8260B	8/12/2010 10:19:00 AM	JKozlowski

Approved: *Keith A. Hausknecht*
President

Reported: 8/13/2010 1:39:38 PM

RDL = Reporting Detection Limit N/A = Not Applicable
Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



630 Churchmans Road
 Newark, Delaware 19702
 302-266-9121 • 454-8720 (FAX)
 WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
 259 Najoles Road
 Millersville, MD 21108

Order Number: A10081586
 Project Name: Black & Decker WWTP
 Receive Date: 8/26/2010
 Client Code: MES_A
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10081586-01 **Sample Date: 8/17/2010 9:20**

Site: Black & Decker 101

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Fecal Coliform, MPN	<1.8	MPN/100 mL	N/A	SM 9221 E	8/17/2010 2:20:00 PM	ChesapeakeEnvironmentalLa

Approved: *Warren Van Ardell*
Quality Assurance Manager

Reported: 8/27/2010 8:26:38 AM

RDL = Reporting Detection Limit N/A = Not Applicable
 Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A10090465
Project Name: Black & Decker WWTP
Receive Date: 9/8/2010
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10090465-01 **Sample Date: 9/8/2010 9:15**

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	3	mg/L	2	SM 5210 B	9/9/2010 11:05:00 AM	Skent
Total Suspended Solids	7	mg/L	4	SM 2540D	9/14/2010 8:40:00 AM	Jsantiago

Sample # A10090465-02 **Sample Date: 9/8/2010 9:18**

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	< 5	mg/L	5	EPA 1664	9/10/2010 3:20:00 PM	JMcGuire

Sample # A10090465-03 **Sample Date: 9/8/2010 9:20**

Site: Black & Decker 001

Matrix: Waste Water


Client Sample ID:

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	9/11/2010 12:04:00 AM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	9/11/2010 12:04:00 AM	JKozlowski
Trichlorofluoromethane	< 1	ug/L	1	EPA 8260B	9/11/2010 12:04:00 AM	JKozlowski

Approved: *Waverly Van Arsdale*
Quality Assurance Manager

Reported: 9/21/2010 10:31:22 AM



630 Churchmans Road
 Newark, Delaware 19702
 302-266-9121 • 454-8720 (FAX)
 WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
 259 Najoles Road
 Millersville, MD 21108

Order Number: A10091758
 Project Name: Black & Decker WWTP
 Receive Date: 9/30/2010
 Client Code: MES_A
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10091758-01

Sample Date: 9/21/2010 9:10

Site: Black & Decker 101

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Fecal Coliform, MPN	<1.8	MPN/100 mL	N/A	SM 9221 E	9/21/2010 1:06:00 PM	ChesapeakeEnvironmentalL

Approved:

Warren Van Arsdale
 Quality Assurance Manager

Reported:

9/30/2010 2:48:12 PM

RDL = Reporting Detection Limit N/A = Not Applicable
 Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568

**APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(AUGUST 2010)**

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

Job Number: 500-27304-1

Job Description: Black and Decker

For:

Weston Solutions, Inc.

1400 Weston Way

PO BOX 2653

West Chester, PA 19380

Attention: Mr. Tom Cornuet



Approved for release.
Richard C Wright
Project Manager II
8/25/2010 8:28 AM

Richard C Wright

Project Manager II

richard.wright@testamericainc.com

08/25/2010

cc: Greg Flasiniski

These test results meet all the requirements of NELAC for accredited parameters.

The Lab Certification ID#:

TestAmerica Chicago 100201

All questions regarding this test report should be directed to the TestAmerica Project Manager whose signature appears on this report. All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.

Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.

TestAmerica Laboratories, Inc.

TestAmerica Chicago 2417 Bond Street, University Park, IL 60484

Tel (708) 534-5200 Fax (708) 534-5211 www.testamericainc.com



Job Narrative
500-27304-1

Comments

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

GC/MS VOA

Method(s) 8260B: The following sample(s) was diluted due to the abundance of target analytes: EW-4 (500-27304-19). Elevated reporting limits (RLs) are provided.

No other analytical or quality issues were noted.

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-27304-5 cis-1,2-Dichloroethene	RFW-3B	2.6	1.0	ug/L	8260B
500-27304-6 cis-1,2-Dichloroethene Chloroform Trichloroethene Tetrachloroethene	RFW-4A	0.93 0.76 37 29	J J 1.0 1.0 1.0 1.0	ug/L ug/L ug/L ug/L	8260B 8260B 8260B 8260B
500-27304-7FD cis-1,2-Dichloroethene Chloroform Trichloroethene Tetrachloroethene	RFW-4A DUP	0.91 0.78 36 29	J J 1.0 1.0 1.0 1.0	ug/L ug/L ug/L ug/L	8260B 8260B 8260B 8260B
500-27304-8 cis-1,2-Dichloroethene Trichloroethene Tetrachloroethene	RFW-4B	2.0 17 29	1.0 1.0 1.0	ug/L ug/L ug/L	8260B 8260B 8260B
500-27304-9 Trichloroethene Tetrachloroethene	RFW-6	1.2 1.7	1.0 1.0	ug/L ug/L	8260B 8260B
500-27304-10 Trichloroethene	RFW-7	4.4	1.0	ug/L	8260B
500-27304-11 1,1-Dichloroethene 1,1-Dichloroethane cis-1,2-Dichloroethene Trichloroethene Tetrachloroethene	RFW-9	1.2 1.3 16 14 6.5	1.0 1.0 1.0 1.0 1.0	ug/L ug/L ug/L ug/L ug/L	8260B 8260B 8260B 8260B 8260B
500-27304-12 Trichloroethene	RFW-11B	6.2	1.0	ug/L	8260B

TestAmerica Chicago

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-27304-13	RFW-12B				
cis-1,2-Dichloroethene		2.9	1.0	ug/L	8260B
Trichloroethene		180	5.0	ug/L	8260B
Tetrachloroethene		17	1.0	ug/L	8260B
500-27304-14	RFW-13				
cis-1,2-Dichloroethene		1.0	1.0	ug/L	8260B
Trichloroethene		2.8	1.0	ug/L	8260B
Tetrachloroethene		15	1.0	ug/L	8260B
500-27304-17	EW-2				
cis-1,2-Dichloroethene		3.4	1.0	ug/L	8260B
Trichloroethene		380	10	ug/L	8260B
Tetrachloroethene		50	1.0	ug/L	8260B
500-27304-18	EW-3				
cis-1,2-Dichloroethene		2.2	1.0	ug/L	8260B
Trichloroethene		76	1.0	ug/L	8260B
Tetrachloroethene		2.5	1.0	ug/L	8260B
500-27304-19	EW-4				
Trichloroethene		920	50	ug/L	8260B
Tetrachloroethene		19	5.0	ug/L	8260B
500-27304-20	EW-5				
Trichloroethene		130	5.0	ug/L	8260B
Tetrachloroethene		4.2	1.0	ug/L	8260B
500-27304-21	EW-6				
Trichloroethene		7.4	1.0	ug/L	8260B
Tetrachloroethene		15	1.0	ug/L	8260B
500-27304-22	EW-7				
cis-1,2-Dichloroethene		2.2	1.0	ug/L	8260B
Trichloroethene		2.0	1.0	ug/L	8260B
Tetrachloroethene		4.8	1.0	ug/L	8260B

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-27304-23	EW-8				
cis-1,2-Dichloroethene		20	1.0	ug/L	8260B
Trichloroethene		8.0	1.0	ug/L	8260B
Tetrachloroethene		52	1.0	ug/L	8260B
500-27304-24	EW-9				
Tetrachloroethene		84	1.0	ug/L	8260B
500-27304-25FD	EW-9 DUP				
Tetrachloroethene		83	1.0	ug/L	8260B
500-27304-26	EW-10				
Tetrachloroethene		1.6	1.0	ug/L	8260B

METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Description	Lab Location	Method	Preparation Method
Matrix: Water			
VOC	TAL CHI	SW846 8260B	
Purge and Trap	TAL CHI		SW846 5030B

Lab References:

TAL CHI = TestAmerica Chicago

Method References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

METHOD / ANALYST SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

<u>Method</u>	<u>Analyst</u>	<u>Analyst ID</u>
SW846 8260B	Drabek, Dave J	DJD

SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
500-27304-1	RFW-1A	Water	08/16/2010 1010	08/19/2010 1015
500-27304-2	RFW-1B	Water	08/16/2010 1745	08/19/2010 1015
500-27304-3	RFW-2A	Water	08/16/2010 1100	08/19/2010 1015
500-27304-4	RFW-2B	Water	08/16/2010 1110	08/19/2010 1015
500-27304-5	RFW-3B	Water	08/17/2010 0730	08/19/2010 1015
500-27304-6	RFW-4A	Water	08/17/2010 0840	08/19/2010 1015
500-27304-7FD	RFW-4A DUP	Water	08/17/2010 0840	08/19/2010 1015
500-27304-8	RFW-4B	Water	08/17/2010 1010	08/19/2010 1015
500-27304-9	RFW-6	Water	08/16/2010 0700	08/19/2010 1015
500-27304-10	RFW-7	Water	08/16/2010 1255	08/19/2010 1015
500-27304-11	RFW-9	Water	08/17/2010 1255	08/19/2010 1015
500-27304-12	RFW-11B	Water	08/17/2010 1400	08/19/2010 1015
500-27304-13	RFW-12B	Water	08/17/2010 0745	08/19/2010 1015
500-27304-14	RFW-13	Water	08/16/2010 1540	08/19/2010 1015
500-27304-15	RFW-17	Water	08/16/2010 1200	08/19/2010 1015
500-27304-16TB	TRIP BLANK	Water	08/16/2010 0700	08/19/2010 1015
500-27304-17	EW-2	Water	08/17/2010 1300	08/19/2010 1015
500-27304-18	EW-3	Water	08/17/2010 1310	08/19/2010 1015
500-27304-19	EW-4	Water	08/17/2010 1115	08/19/2010 1015
500-27304-20	EW-5	Water	08/16/2010 0945	08/19/2010 1015
500-27304-21	EW-6	Water	08/16/2010 1525	08/19/2010 1015
500-27304-22	EW-7	Water	08/16/2010 1515	08/19/2010 1015
500-27304-23	EW-8	Water	08/16/2010 1510	08/19/2010 1015
500-27304-24	EW-9	Water	08/16/2010 1500	08/19/2010 1015
500-27304-25FD	EW-9 DUP	Water	08/16/2010 1500	08/19/2010 1015
500-27304-26	EW-10	Water	08/16/2010 1600	08/19/2010 1015

SAMPLE RESULTS

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-1A
 Lab Sample ID: 500-27304-1

Date Sampled: 08/16/2010 1010
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/21/2010 1353			
Prep Method: 5030B		Date Prepared: 08/21/2010 1353			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-1A
 Lab Sample ID: 500-27304-1

Date Sampled: 08/16/2010 1010
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoforn	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	93	%		80 - 129	
Toluene-d8 (Surr)	102	%		80 - 115	
4-Bromofluorobenzene (Surr)	95	%		80 - 115	
Dibromofluoromethane	90	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-1B
 Lab Sample ID: 500-27304-2

Date Sampled: 08/16/2010 1745
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/21/2010 1417			
Prep Method: 5030B		Date Prepared: 08/21/2010 1417			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-1B
 Lab Sample ID: 500-27304-2

Date Sampled: 08/16/2010 1745
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		80 - 129	
Toluene-d8 (Surr)	102	%		80 - 115	
4-Bromofluorobenzene (Surr)	96	%		80 - 115	
Dibromofluoromethane	94	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-2A
 Lab Sample ID: 500-27304-3

Date Sampled: 08/16/2010 1100
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/21/2010 1442			
Prep Method: 5030B		Date Prepared: 08/21/2010 1442			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-2A
 Lab Sample ID: 500-27304-3

Date Sampled: 08/16/2010 1100
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	99	%		80 - 129	
Toluene-d8 (Surr)	104	%		80 - 115	
4-Bromofluorobenzene (Surr)	95	%		80 - 115	
Dibromofluoromethane	92	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-2B
 Lab Sample ID: 500-27304-4

Date Sampled: 08/16/2010 1110
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	08/21/2010 1506		
Prep Method: 5030B		Date Prepared:	08/21/2010 1506		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-2B
 Lab Sample ID: 500-27304-4

Date Sampled: 08/16/2010 1110
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		80 - 129	
Toluene-d8 (Surr)	103	%		80 - 115	
4-Bromofluorobenzene (Surr)	98	%		80 - 115	
Dibromofluoromethane	95	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-3B
 Lab Sample ID: 500-27304-5

Date Sampled: 08/17/2010 0730
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/21/2010 1531			
Prep Method: 5030B		Date Prepared: 08/21/2010 1531			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	2.6	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-3B
 Lab Sample ID: 500-27304-5

Date Sampled: 08/17/2010 0730
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		80 - 129	
Toluene-d8 (Surr)	100	%		80 - 115	
4-Bromofluorobenzene (Surr)	93	%		80 - 115	
Dibromofluoromethane	95	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-4A
 Lab Sample ID: 500-27304-6

Date Sampled: 08/17/2010 0840
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	08/21/2010 1555		
Prep Method: 5030B		Date Prepared:	08/21/2010 1555		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	0.93	J ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	0.76	J ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	37	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	29	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-4A
 Lab Sample ID: 500-27304-6

Date Sampled: 08/17/2010 0840
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		80 - 129	
Toluene-d8 (Surr)	100	%		80 - 115	
4-Bromofluorobenzene (Surr)	90	%		80 - 115	
Dibromofluoromethane	93	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-4A DUP
 Lab Sample ID: 500-27304-7

Date Sampled: 08/17/2010 0840
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/21/2010 1620			
Prep Method: 5030B		Date Prepared: 08/21/2010 1620			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	0.91 J	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	0.78 J	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	36	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	29	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-4A DUP
 Lab Sample ID: 500-27304-7

Date Sampled: 08/17/2010 0840
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	96	%		80 - 129	
Toluene-d8 (Surr)	97	%		80 - 115	
4-Bromofluorobenzene (Surr)	92	%		80 - 115	
Dibromofluoromethane	92	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-4B
 Lab Sample ID: 500-27304-8

Date Sampled: 08/17/2010 1010
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/21/2010 1644			
Prep Method: 5030B		Date Prepared: 08/21/2010 1644			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	2.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	17	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	29	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-4B
 Lab Sample ID: 500-27304-8

Date Sampled: 08/17/2010 1010
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	97	%		80 - 129	
Toluene-d8 (Surr)	103	%		80 - 115	
4-Bromofluorobenzene (Surr)	92	%		80 - 115	
Dibromofluoromethane	94	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-6
 Lab Sample ID: 500-27304-9

Date Sampled: 08/16/2010 0700
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/21/2010 1709			
Prep Method: 5030B		Date Prepared: 08/21/2010 1709			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	1.2	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	1.7	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-6
 Lab Sample ID: 500-27304-9

Date Sampled: 08/16/2010 0700
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		80 - 129	
Toluene-d8 (Surr)	97	%		80 - 115	
4-Bromofluorobenzene (Surr)	96	%		80 - 115	
Dibromofluoromethane	98	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-7
 Lab Sample ID: 500-27304-10

Date Sampled: 08/16/2010 1255
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/21/2010 1733			
Prep Method: 5030B		Date Prepared: 08/21/2010 1733			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	4.4	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-7
 Lab Sample ID: 500-27304-10

Date Sampled: 08/16/2010 1255
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		80 - 129	
Toluene-d8 (Surr)	102	%		80 - 115	
4-Bromofluorobenzene (Surr)	91	%		80 - 115	
Dibromofluoromethane	95	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-9
 Lab Sample ID: 500-27304-11

Date Sampled: 08/17/2010 1255
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/21/2010 1758			
Prep Method: 5030B		Date Prepared: 08/21/2010 1758			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	1.2	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	1.3	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	16	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	14	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	6.5	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-9
 Lab Sample ID: 500-27304-11

Date Sampled: 08/17/2010 1255
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	99	%		80 - 129	
Toluene-d8 (Surr)	101	%		80 - 115	
4-Bromofluorobenzene (Surr)	91	%		80 - 115	
Dibromofluoromethane	97	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-11B
 Lab Sample ID: 500-27304-12

Date Sampled: 08/17/2010 1400
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/21/2010 1822			
Prep Method: 5030B		Date Prepared: 08/21/2010 1822			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	6.2	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-11B
 Lab Sample ID: 500-27304-12

Date Sampled: 08/17/2010 1400
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate					
1,2-Dichloroethane-d4 (Surr)	97	%		80 - 129	
Toluene-d8 (Surr)	104	%		80 - 115	
4-Bromofluorobenzene (Surr)	92	%		80 - 115	
Dibromofluoromethane	98	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-12B
 Lab Sample ID: 500-27304-13

Date Sampled: 08/17/2010 0745
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/21/2010 1847			
Prep Method: 5030B		Date Prepared: 08/21/2010 1847			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	2.9	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	17	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-12B
 Lab Sample ID: 500-27304-13

Date Sampled: 08/17/2010 0745
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		80 - 129	
Toluene-d8 (Surr)	101	%		80 - 115	
4-Bromofluorobenzene (Surr)	92	%		80 - 115	
Dibromofluoromethane	102	%		80 - 124	
Method: 8260B	Run Type: DL		Date Analyzed: 08/21/2010 1911		
Prep Method: 5030B			Date Prepared: 08/21/2010 1911		
Trichloroethene	180	ug/L	1.2	5.0	5.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		80 - 129	
Toluene-d8 (Surr)	104	%		80 - 115	
4-Bromofluorobenzene (Surr)	92	%		80 - 115	
Dibromofluoromethane	102	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-13
 Lab Sample ID: 500-27304-14

Date Sampled: 08/16/2010 1540
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/21/2010 1936			
Prep Method: 5030B		Date Prepared: 08/21/2010 1936			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	2.8	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	15	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-13
 Lab Sample ID: 500-27304-14

Date Sampled: 08/16/2010 1540
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromofom	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	96	%		80 - 129	
Toluene-d8 (Surr)	103	%		80 - 115	
4-Bromofluorobenzene (Surr)	91	%		80 - 115	
Dibromofluoromethane	96	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-17
 Lab Sample ID: 500-27304-15

Date Sampled: 08/16/2010 1200
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/23/2010 1047			
Prep Method: 5030B		Date Prepared: 08/23/2010 1047			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-17
 Lab Sample ID: 500-27304-15

Date Sampled: 08/16/2010 1200
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate					Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	100	%		80 - 129	
Toluene-d8 (Surr)	100	%		80 - 115	
4-Bromofluorobenzene (Surr)	96	%		80 - 115	
Dibromofluoromethane	93	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: TRIP BLANK
 Lab Sample ID: 500-27304-16

Date Sampled: 08/16/2010 0700
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/23/2010 1111			
Prep Method: 5030B		Date Prepared: 08/23/2010 1111			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: TRIP BLANK
 Lab Sample ID: 500-27304-16

Date Sampled: 08/16/2010 0700
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	99	%		80 - 129	
Toluene-d8 (Surr)	103	%		80 - 115	
4-Bromofluorobenzene (Surr)	93	%		80 - 115	
Dibromofluoromethane	96	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-2
 Lab Sample ID: 500-27304-17

Date Sampled: 08/17/2010 1300
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/23/2010 1135			
Prep Method: 5030B		Date Prepared: 08/23/2010 1135			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	3.4	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	50	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-2
 Lab Sample ID: 500-27304-17

Date Sampled: 08/17/2010 1300
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	103	%		80 - 129	
Toluene-d8 (Surr)	107	%		80 - 115	
4-Bromofluorobenzene (Surr)	105	%		80 - 115	
Dibromofluoromethane	100	%		80 - 124	
Method: 8260B	Run Type: DL		Date Analyzed: 08/23/2010 1200		
Prep Method: 5030B			Date Prepared: 08/23/2010 1200		
Trichloroethene	380	ug/L	2.4	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	100	%		80 - 129	
Toluene-d8 (Surr)	106	%		80 - 115	
4-Bromofluorobenzene (Surr)	97	%		80 - 115	
Dibromofluoromethane	97	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-3
 Lab Sample ID: 500-27304-18

Date Sampled: 08/17/2010 1310
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/23/2010 1224			
Prep Method: 5030B		Date Prepared: 08/23/2010 1224			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	2.2	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	76	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	2.5	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-3
 Lab Sample ID: 500-27304-18

Date Sampled: 08/17/2010 1310
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		80 - 129	
Toluene-d8 (Surr)	104	%		80 - 115	
4-Bromofluorobenzene (Surr)	96	%		80 - 115	
Dibromofluoromethane	96	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-4
 Lab Sample ID: 500-27304-19

Date Sampled: 08/17/2010 1115
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed: 08/23/2010 1249		
Prep Method: 5030B			Date Prepared: 08/23/2010 1249		
Benzene	<5.0	ug/L	0.85	5.0	5.0
Dichlorodifluoromethane	<5.0	ug/L	1.6	5.0	5.0
Chloromethane	<5.0	ug/L	1.2	5.0	5.0
Vinyl chloride	<5.0	ug/L	1.0	5.0	5.0
Bromomethane	<5.0	ug/L	1.9	5.0	5.0
Chloroethane	<5.0	ug/L	1.8	5.0	5.0
Trichlorofluoromethane	<5.0	ug/L	1.0	5.0	5.0
1,1-Dichloroethene	<5.0	ug/L	0.95	5.0	5.0
Carbon disulfide	<25	ug/L	2.8	25	5.0
Acetone	<25	ug/L	8.0	25	5.0
Methylene Chloride	<10	ug/L	3.4	10	5.0
trans-1,2-Dichloroethene	<5.0	ug/L	1.6	5.0	5.0
1,1-Dichloroethane	<5.0	ug/L	1.2	5.0	5.0
2,2-Dichloropropane	<5.0	ug/L	1.2	5.0	5.0
cis-1,2-Dichloroethene	<5.0	ug/L	1.4	5.0	5.0
Methyl Ethyl Ketone	<25	ug/L	12	25	5.0
Bromochloromethane	<5.0	ug/L	1.8	5.0	5.0
Chloroform	<5.0	ug/L	0.75	5.0	5.0
1,1,1-Trichloroethane	<5.0	ug/L	0.90	5.0	5.0
1,1-Dichloropropene	<5.0	ug/L	0.80	5.0	5.0
Carbon tetrachloride	<5.0	ug/L	1.2	5.0	5.0
1,2-Dichloroethane	<5.0	ug/L	1.2	5.0	5.0
1,2-Dichloropropane	<5.0	ug/L	1.0	5.0	5.0
Dibromomethane	<5.0	ug/L	1.5	5.0	5.0
Bromodichloromethane	<5.0	ug/L	0.95	5.0	5.0
cis-1,3-Dichloropropene	<5.0	ug/L	0.85	5.0	5.0
methyl isobutyl ketone	<25	ug/L	4.2	25	5.0
Toluene	<5.0	ug/L	0.95	5.0	5.0
trans-1,3-Dichloropropene	<5.0	ug/L	1.2	5.0	5.0
1,1,2-Trichloroethane	<5.0	ug/L	1.3	5.0	5.0
Tetrachloroethene	19	ug/L	1.1	5.0	5.0
1,3-Dichloropropane	<5.0	ug/L	0.85	5.0	5.0
2-Hexanone	<25	ug/L	4.0	25	5.0
Dibromochloromethane	<5.0	ug/L	1.2	5.0	5.0
1,2-Dibromoethane	<5.0	ug/L	1.8	5.0	5.0
Chlorobenzene	<5.0	ug/L	0.85	5.0	5.0
1,1,1,2-Tetrachloroethane	<5.0	ug/L	0.95	5.0	5.0
Ethylbenzene	<5.0	ug/L	0.90	5.0	5.0
m&p-Xylene	<10	ug/L	1.6	10	5.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-4
 Lab Sample ID: 500-27304-19

Date Sampled: 08/17/2010 1115
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<5.0	ug/L	1.9	5.0	5.0
Styrene	<5.0	ug/L	0.75	5.0	5.0
Bromoform	<5.0	ug/L	2.1	5.0	5.0
Isopropylbenzene	<5.0	ug/L	1.0	5.0	5.0
Bromobenzene	<5.0	ug/L	1.0	5.0	5.0
1,1,2,2-Tetrachloroethane	<5.0	ug/L	1.4	5.0	5.0
1,2,3-Trichloropropane	<5.0	ug/L	2.4	5.0	5.0
N-Propylbenzene	<5.0	ug/L	0.95	5.0	5.0
2-Chlorotoluene	<5.0	ug/L	0.90	5.0	5.0
1,3,5-Trimethylbenzene	<5.0	ug/L	0.90	5.0	5.0
4-Chlorotoluene	<5.0	ug/L	1.0	5.0	5.0
tert-Butylbenzene	<5.0	ug/L	0.80	5.0	5.0
1,2,4-Trimethylbenzene	<5.0	ug/L	0.70	5.0	5.0
sec-Butylbenzene	<5.0	ug/L	0.80	5.0	5.0
1,3-Dichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
p-Isopropyltoluene	<5.0	ug/L	0.80	5.0	5.0
1,4-Dichlorobenzene	<5.0	ug/L	1.0	5.0	5.0
n-Butylbenzene	<5.0	ug/L	0.90	5.0	5.0
1,2-Dichlorobenzene	<5.0	ug/L	0.85	5.0	5.0
1,2-Dibromo-3-Chloropropane	<10	ug/L	4.8	10	5.0
1,2,4-Trichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
Hexachlorobutadiene	<5.0	ug/L	1.3	5.0	5.0
Naphthalene	<5.0	ug/L	2.2	5.0	5.0
1,2,3-Trichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	100	%		80 - 129	
Toluene-d8 (Surr)	104	%		80 - 115	
4-Bromofluorobenzene (Surr)	96	%		80 - 115	
Dibromofluoromethane	98	%		80 - 124	
Method: 8260B	Run Type: DL		Date Analyzed: 08/23/2010 1314		
Prep Method: 5030B			Date Prepared: 08/23/2010 1314		
Trichloroethene	920	ug/L	12	50	50
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		80 - 129	
Toluene-d8 (Surr)	105	%		80 - 115	
4-Bromofluorobenzene (Surr)	99	%		80 - 115	
Dibromofluoromethane	100	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-5
 Lab Sample ID: 500-27304-20

Date Sampled: 08/16/2010 0945
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/23/2010 1339			
Prep Method: 5030B		Date Prepared: 08/23/2010 1339			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	4.2	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-5
 Lab Sample ID: 500-27304-20

Date Sampled: 08/16/2010 0945
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	102	%	80 - 129
Toluene-d8 (Surr)	103	%	80 - 115
4-Bromofluorobenzene (Surr)	99	%	80 - 115
Dibromofluoromethane	100	%	80 - 124

Method: 8260B Run Type: DL

Date Analyzed: 08/23/2010 1403

Prep Method: 5030B

Date Prepared: 08/23/2010 1403

Trichloroethene	130	ug/L	1.2	5.0	5.0
-----------------	-----	------	-----	-----	-----

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	102	%	80 - 129
Toluene-d8 (Surr)	104	%	80 - 115
4-Bromofluorobenzene (Surr)	99	%	80 - 115
Dibromofluoromethane	98	%	80 - 124

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-6
 Lab Sample ID: 500-27304-21

Date Sampled: 08/16/2010 1525
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/23/2010 1428			
Prep Method: 5030B		Date Prepared: 08/23/2010 1428			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	7.4	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	15	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-6
 Lab Sample ID: 500-27304-21

Date Sampled: 08/16/2010 1525
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	92	%		80 - 129	
Toluene-d8 (Surr)	93	%		80 - 115	
4-Bromofluorobenzene (Surr)	86	%		80 - 115	
Dibromofluoromethane	86	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-7
 Lab Sample ID: 500-27304-22

Date Sampled: 08/16/2010 1515
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/23/2010 1452			
Prep Method: 5030B		Date Prepared: 08/23/2010 1452			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	2.2	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	2.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	4.8	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-7
 Lab Sample ID: 500-27304-22

Date Sampled: 08/16/2010 1515
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	93	%		80 - 129	
Toluene-d8 (Surr)	99	%		80 - 115	
4-Bromofluorobenzene (Surr)	90	%		80 - 115	
Dibromofluoromethane	93	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-8
 Lab Sample ID: 500-27304-23

Date Sampled: 08/16/2010 1510
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/23/2010 1516			
Prep Method: 5030B		Date Prepared: 08/23/2010 1516			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	20	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	8.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	52	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-8
 Lab Sample ID: 500-27304-23

Date Sampled: 08/16/2010 1510
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		80 - 129	
Toluene-d8 (Surr)	103	%		80 - 115	
4-Bromofluorobenzene (Surr)	98	%		80 - 115	
Dibromofluoromethane	101	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-9
 Lab Sample ID: 500-27304-24

Date Sampled: 08/16/2010 1500
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/23/2010 1541			
Prep Method: 5030B		Date Prepared: 08/23/2010 1541			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	84	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-9
 Lab Sample ID: 500-27304-24

Date Sampled: 08/16/2010 1500
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		80 - 129	
Toluene-d8 (Surr)	104	%		80 - 115	
4-Bromofluorobenzene (Surr)	91	%		80 - 115	
Dibromofluoromethane	101	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-9 DUP
 Lab Sample ID: 500-27304-25

Date Sampled: 08/16/2010 1500
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/23/2010 1605			
Prep Method: 5030B		Date Prepared: 08/23/2010 1605			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	83	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-9 DUP
 Lab Sample ID: 500-27304-25

Date Sampled: 08/16/2010 1500
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	99	%		80 - 129	
Toluene-d8 (Surr)	104	%		80 - 115	
4-Bromofluorobenzene (Surr)	96	%		80 - 115	
Dibromofluoromethane	101	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-10
 Lab Sample ID: 500-27304-26

Date Sampled: 08/16/2010 1630
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/23/2010 1630			
Prep Method: 5030B		Date Prepared: 08/23/2010 1630			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	1.6	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-10
 Lab Sample ID: 500-27304-26

Date Sampled: 08/16/2010 1600
 Date Received: 08/19/2010 1015
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromofom	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		80 - 129	
Toluene-d8 (Surr)	106	%		80 - 115	
4-Bromofluorobenzene (Surr)	98	%		80 - 115	
Dibromofluoromethane	99	%		80 - 124	

DATA REPORTING QUALIFIERS

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

<u>Lab Section</u>	<u>Qualifier</u>	<u>Description</u>
GC/MS VOA	J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

QUALITY CONTROL RESULTS

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

QC Association Summary

Lab Sample ID	Client Sample ID	Report Basis	Client Matrix	Method	Prep Batch
GC/MS VOA					
Analysis Batch:500-92273					
LCS 500-92273/5	Lab Control Sample	T	Water	8260B	
MB 500-92273/4	Method Blank	T	Water	8260B	
500-27304-1	RFW-1A	T	Water	8260B	
500-27304-2	RFW-1B	T	Water	8260B	
500-27304-3	RFW-2A	T	Water	8260B	
500-27304-4	RFW-2B	T	Water	8260B	
500-27304-5	RFW-3B	T	Water	8260B	
500-27304-6	RFW-4A	T	Water	8260B	
500-27304-7FD	RFW-4A DUP	T	Water	8260B	
500-27304-8	RFW-4B	T	Water	8260B	
500-27304-9	RFW-6	T	Water	8260B	
500-27304-10	RFW-7	T	Water	8260B	
500-27304-11	RFW-9	T	Water	8260B	
500-27304-12	RFW-11B	T	Water	8260B	
500-27304-13	RFW-12B	T	Water	8260B	
500-27304-13DL	RFW-12B	T	Water	8260B	
500-27304-14	RFW-13	T	Water	8260B	
500-27304-14MS	Matrix Spike	T	Water	8260B	
500-27304-14MSD	Matrix Spike Duplicate	T	Water	8260B	
Analysis Batch:500-92396					
LCS 500-92396/7	Lab Control Sample	T	Water	8260B	
MB 500-92396/6	Method Blank	T	Water	8260B	
500-27304-15	RFW-17	T	Water	8260B	
500-27304-16TB	TRIP BLANK	T	Water	8260B	
500-27304-17	EW-2	T	Water	8260B	
500-27304-17DL	EW-2	T	Water	8260B	
500-27304-18	EW-3	T	Water	8260B	
500-27304-19	EW-4	T	Water	8260B	
500-27304-19DL	EW-4	T	Water	8260B	
500-27304-20	EW-5	T	Water	8260B	
500-27304-20DL	EW-5	T	Water	8260B	
500-27304-21	EW-6	T	Water	8260B	
500-27304-22	EW-7	T	Water	8260B	
500-27304-23	EW-8	T	Water	8260B	
500-27304-24	EW-9	T	Water	8260B	
500-27304-25FD	EW-9 DUP	T	Water	8260B	
500-27304-26	EW-10	T	Water	8260B	

Report Basis

T = Total

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Surrogate Recovery Report

8260B VOC

Client Matrix: Water

Lab Sample ID	Client Sample ID	DCA %Rec	TOL %Rec	BFB %Rec	DBFM %Rec
500-27304-1	RFW-1A	93	102	95	90
500-27304-2	RFW-1B	98	102	96	94
500-27304-3	RFW-2A	99	104	95	92
500-27304-4	RFW-2B	98	103	98	95
500-27304-5	RFW-3B	98	100	93	95
500-27304-6	RFW-4A	98	100	90	93
500-27304-7	RFW-4A DUP	96	97	92	92
500-27304-8	RFW-4B	97	103	92	94
500-27304-9	RFW-6	98	97	96	98
500-27304-10	RFW-7	98	102	91	95
500-27304-11	RFW-9	99	101	91	97
500-27304-12	RFW-11B	97	104	92	98
500-27304-13	RFW-12B	101	101	92	102
500-27304-13 DL	RFW-12B DL	102	104	92	102
500-27304-14	RFW-13	96	103	91	96
500-27304-15	RFW-17	100	100	96	93
500-27304-16	TRIP BLANK	99	103	93	96
500-27304-17	EW-2	103	107	105	100
500-27304-17 DL	EW-2 DL	100	106	97	97
500-27304-18	EW-3	98	104	96	96
500-27304-19	EW-4	100	104	96	98
500-27304-19 DL	EW-4 DL	101	105	99	100
500-27304-20	EW-5	102	103	99	100
500-27304-20 DL	EW-5 DL	102	104	99	98
500-27304-21	EW-6	92	93	86	86
500-27304-22	EW-7	93	99	90	93
500-27304-23	EW-8	102	103	98	101
500-27304-24	EW-9	102	104	91	101
500-27304-25	EW-9 DUP	99	104	96	101

Surrogate	Acceptance Limits
DCA = 1,2-Dichloroethane-d4 (Surr)	80-129
TOL = Toluene-d8 (Surr)	80-115
BFB = 4-Bromofluorobenzene (Surr)	80-115
DBFM = Dibromofluoromethane	80-124

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Surrogate Recovery Report

8260B VOC

Client Matrix: Water

Lab Sample ID	Client Sample ID	DCA %Rec	TOL %Rec	BFB %Rec	DBFM %Rec
500-27304-26	EW-10	101	106	98	99
MB 500-92273/4		88	93	90	86
MB 500-92396/6		106	113	105	102
LCS 500-92273/5		91	96	93	92
LCS 500-92396/7		95	102	100	94
500-27304-14 MS	RFW-13 MS	101	105	102	105
500-27304-14 MSD	RFW-13 MSD	98	103	96	104

Surrogate	Acceptance Limits
DCA = 1,2-Dichloroethane-d4 (Surr)	80-129
TOL = Toluene-d8 (Surr)	80-115
BFB = 4-Bromofluorobenzene (Surr)	80-115
DBFM = Dibromofluoromethane	80-124

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Method Blank - Batch: 500-92273

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-92273/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/21/2010 0944
Date Prepared: 08/21/2010 0944

Analysis Batch: 500-92273
Prep Batch: N/A
Units: ug/L

Instrument ID: CMS02
Lab File ID: 2M0821.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.17	1.0
Dichlorodifluoromethane	<1.0		0.31	1.0
Chloromethane	<1.0		0.24	1.0
Vinyl chloride	<1.0		0.20	1.0
Bromomethane	<1.0		0.38	1.0
Chloroethane	<1.0		0.36	1.0
Trichlorofluoromethane	<1.0		0.20	1.0
1,1-Dichloroethene	<1.0		0.19	1.0
Carbon disulfide	<5.0		0.55	5.0
Acetone	<5.0		1.6	5.0
Methylene Chloride	<2.0		0.67	2.0
trans-1,2-Dichloroethene	<1.0		0.32	1.0
1,1-Dichloroethane	<1.0		0.25	1.0
2,2-Dichloropropane	<1.0		0.24	1.0
cis-1,2-Dichloroethene	<1.0		0.27	1.0
Methyl Ethyl Ketone	<5.0		2.3	5.0
Bromochloromethane	<1.0		0.35	1.0
Chloroform	<1.0		0.15	1.0
1,1,1-Trichloroethane	<1.0		0.18	1.0
1,1-Dichloropropene	<1.0		0.16	1.0
Carbon tetrachloride	<1.0		0.25	1.0
1,2-Dichloroethane	<1.0		0.24	1.0
Trichloroethene	<1.0		0.24	1.0
1,2-Dichloropropane	<1.0		0.21	1.0
Dibromomethane	<1.0		0.30	1.0
Bromodichloromethane	<1.0		0.19	1.0
cis-1,3-Dichloropropene	<1.0		0.17	1.0
methyl isobutyl ketone	<5.0		0.84	5.0
Toluene	<1.0		0.19	1.0
trans-1,3-Dichloropropene	<1.0		0.24	1.0
1,1,2-Trichloroethane	<1.0		0.26	1.0
Tetrachloroethene	<1.0		0.22	1.0
1,3-Dichloropropane	<1.0		0.17	1.0
2-Hexanone	<5.0		0.80	5.0
Dibromochloromethane	<1.0		0.25	1.0
1,2-Dibromoethane	<1.0		0.37	1.0
Chlorobenzene	<1.0		0.17	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.19	1.0
Ethylbenzene	<1.0		0.18	1.0
m&p-Xylene	<2.0		0.32	2.0
o-Xylene	<1.0		0.38	1.0
Styrene	<1.0		0.15	1.0
Bromoform	<1.0		0.42	1.0

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Method Blank - Batch: 500-92273

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-92273/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/21/2010 0944
Date Prepared: 08/21/2010 0944

Analysis Batch: 500-92273
Prep Batch: N/A
Units: ug/L

Instrument ID: CMS02
Lab File ID: 2M0821.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Isopropylbenzene	<1.0		0.20	1.0
Bromobenzene	<1.0		0.21	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.29	1.0
1,2,3-Trichloropropane	<1.0		0.48	1.0
N-Propylbenzene	<1.0		0.19	1.0
2-Chlorotoluene	<1.0		0.18	1.0
1,3,5-Trimethylbenzene	<1.0		0.18	1.0
4-Chlorotoluene	<1.0		0.21	1.0
tert-Butylbenzene	<1.0		0.16	1.0
1,2,4-Trimethylbenzene	<1.0		0.14	1.0
sec-Butylbenzene	<1.0		0.16	1.0
1,3-Dichlorobenzene	<1.0		0.24	1.0
p-Isopropyltoluene	<1.0		0.16	1.0
1,4-Dichlorobenzene	<1.0		0.21	1.0
n-Butylbenzene	<1.0		0.18	1.0
1,2-Dichlorobenzene	<1.0		0.17	1.0
1,2-Dibromo-3-Chloropropane	<2.0		0.96	2.0
1,2,4-Trichlorobenzene	<1.0		0.24	1.0
Hexachlorobutadiene	<1.0		0.26	1.0
Naphthalene	<1.0		0.44	1.0
1,2,3-Trichlorobenzene	<1.0		0.24	1.0

Surrogate	% Rec	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	88	80 - 129
Toluene-d8 (Surr)	93	80 - 115
4-Bromofluorobenzene (Surr)	90	80 - 115
Dibromofluoromethane	86	80 - 124

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Lab Control Sample - Batch: 500-92273

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-92273/5
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/21/2010 1008
Date Prepared: 08/21/2010 1008

Analysis Batch: 500-92273
Prep Batch: N/A
Units: ug/L

Instrument ID: CMS02
Lab File ID: 2S0821.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	25.0	23.2	93	73 - 117	
Dichlorodifluoromethane	25.0	18.6	75	46 - 182	
Chloromethane	25.0	21.3	85	51 - 151	
Vinyl chloride	25.0	22.0	88	56 - 128	
Bromomethane	25.0	22.7	91	35 - 181	
Chloroethane	25.0	21.9	88	52 - 150	
Trichlorofluoromethane	25.0	24.9	100	69 - 142	
1,1-Dichloroethene	25.0	22.1	88	55 - 127	
Carbon disulfide	25.0	17.1	68	38 - 123	
Acetone	25.0	23.4	93	42 - 149	
Methylene Chloride	25.0	22.4	90	62 - 127	
trans-1,2-Dichloroethene	25.0	23.2	93	67 - 125	
1,1-Dichloroethane	25.0	23.1	93	67 - 122	
2,2-Dichloropropane	25.0	22.9	92	62 - 135	
cis-1,2-Dichloroethene	25.0	21.8	87	65 - 115	
Methyl Ethyl Ketone	25.0	24.9	100	52 - 148	
Bromochloromethane	25.0	24.3	97	70 - 122	
Chloroform	25.0	22.6	91	74 - 121	
1,1,1-Trichloroethane	25.0	23.4	94	76 - 127	
1,1-Dichloropropene	25.0	23.4	94	69 - 122	
Carbon tetrachloride	25.0	22.8	91	66 - 138	
1,2-Dichloroethane	25.0	23.2	93	71 - 124	
Trichloroethene	25.0	23.2	93	77 - 118	
1,2-Dichloropropane	25.0	23.8	95	75 - 120	
Dibromomethane	25.0	22.5	90	76 - 121	
Bromodichloromethane	25.0	23.7	95	79 - 124	
cis-1,3-Dichloropropene	26.9	24.4	91	66 - 122	
methyl isobutyl ketone	25.0	23.2	93	58 - 134	
Toluene	25.0	23.1	92	76 - 119	
trans-1,3-Dichloropropene	24.3	20.7	85	66 - 110	
1,1,2-Trichloroethane	25.0	22.9	92	70 - 127	
Tetrachloroethene	25.0	22.9	92	76 - 116	
1,3-Dichloropropane	25.0	23.1	92	74 - 119	
2-Hexanone	25.0	23.1	92	54 - 140	
Dibromochloromethane	25.0	23.5	94	68 - 122	
1,2-Dibromoethane	25.0	23.1	92	77 - 123	
Chlorobenzene	25.0	23.1	93	78 - 113	
1,1,1,2-Tetrachloroethane	25.0	23.7	95	80 - 126	
Ethylbenzene	25.0	23.2	93	80 - 116	
m&p-Xylene	50.0	46.9	94	79 - 120	
o-Xylene	25.0	23.2	93	80 - 117	
Styrene	25.0	23.4	94	80 - 120	
Bromoform	25.0	23.2	93	59 - 122	

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Lab Control Sample - Batch: 500-92273

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-92273/5
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/21/2010 1008
Date Prepared: 08/21/2010 1008

Analysis Batch: 500-92273
Prep Batch: N/A
Units: ug/L

Instrument ID: CMS02
Lab File ID: 2S0821.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Isopropylbenzene	25.0	20.6	83	66 - 107	
Bromobenzene	25.0	22.6	90	78 - 119	
1,1,2,2-Tetrachloroethane	25.0	22.7	91	70 - 123	
1,2,3-Trichloropropane	25.0	22.9	92	76 - 121	
N-Propylbenzene	25.0	23.2	93	74 - 124	
2-Chlorotoluene	25.0	23.1	92	75 - 121	
1,3,5-Trimethylbenzene	25.0	23.3	93	77 - 123	
4-Chlorotoluene	25.0	22.7	91	74 - 119	
tert-Butylbenzene	25.0	23.5	94	78 - 121	
1,2,4-Trimethylbenzene	25.0	23.5	94	78 - 122	
sec-Butylbenzene	25.0	24.0	96	80 - 123	
1,3-Dichlorobenzene	25.0	22.9	91	80 - 114	
p-Isopropyltoluene	25.0	23.7	95	77 - 118	
1,4-Dichlorobenzene	25.0	22.8	91	79 - 113	
n-Butylbenzene	25.0	25.1	101	75 - 129	
1,2-Dichlorobenzene	25.0	23.8	95	80 - 116	
1,2-Dibromo-3-Chloropropane	25.0	21.8	87	55 - 126	
1,2,4-Trichlorobenzene	25.0	25.3	101	68 - 119	
Hexachlorobutadiene	25.0	26.1	105	69 - 125	
Naphthalene	25.0	24.9	100	57 - 130	
1,2,3-Trichlorobenzene	25.0	25.9	104	69 - 123	

Surrogate	% Rec	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	91	80 - 129
Toluene-d8 (Surr)	96	80 - 115
4-Bromofluorobenzene (Surr)	93	80 - 115
Dibromofluoromethane	92	80 - 124

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

**Matrix Spike/
Matrix Spike Duplicate Recovery Report - Batch: 500-92273**

**Method: 8260B
Preparation: 5030B**

MS Lab Sample ID: 500-27304-14
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/21/2010 2000
Date Prepared: 08/21/2010 2000

Analysis Batch: 500-92273
Prep Batch: N/A

Instrument ID: CMS02
Lab File ID: 7304-14S.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

MSD Lab Sample ID: 500-27304-14
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/21/2010 2025
Date Prepared: 08/21/2010 2025

Analysis Batch: 500-92273
Prep Batch: N/A

Instrument ID: CMS02
Lab File ID: 7304-14T.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	MS Qual	MSD Qual
	MS	MSD					
Benzene	100	95	73 - 117	5	20		
Dichlorodifluoromethane	70	65	46 - 182	7	20		
Chloromethane	84	81	51 - 151	4	20		
Vinyl chloride	85	83	56 - 128	2	20		
Bromomethane	89	105	35 - 181	17	20		
Chloroethane	103	100	52 - 150	3	20		
Trichlorofluoromethane	96	99	69 - 142	3	20		
1,1-Dichloroethene	97	91	55 - 127	6	20		
Carbon disulfide	76	73	38 - 123	5	20		
Acetone	97	90	42 - 149	8	20		
Methylene Chloride	103	100	62 - 127	3	20		
trans-1,2-Dichloroethene	105	101	67 - 125	4	20		
1,1-Dichloroethane	104	101	67 - 122	3	20		
2,2-Dichloropropane	97	92	62 - 135	6	20		
cis-1,2-Dichloroethene	98	93	65 - 115	5	20		
Methyl Ethyl Ketone	105	109	52 - 148	4	20		
Bromochloromethane	119	112	70 - 122	7	20		
Chloroform	101	97	74 - 121	4	20		
1,1,1-Trichloroethane	103	100	76 - 127	3	20		
1,1-Dichloropropene	100	98	69 - 122	2	20		
Carbon tetrachloride	100	95	66 - 138	5	20		
1,2-Dichloroethane	99	95	71 - 124	4	20		
Trichloroethene	98	91	77 - 118	6	20		
1,2-Dichloropropane	100	97	75 - 120	3	20		
Dibromomethane	97	93	76 - 121	4	20		
Bromodichloromethane	100	98	79 - 124	2	20		
cis-1,3-Dichloropropene	94	92	66 - 122	2	20		
methyl isobutyl ketone	103	99	58 - 134	4	20		
Toluene	98	96	76 - 119	2	20		
trans-1,3-Dichloropropene	90	89	66 - 110	2	20		

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

**Matrix Spike/
Matrix Spike Duplicate Recovery Report - Batch: 500-92273**

**Method: 8260B
Preparation: 5030B**

MS Lab Sample ID: 500-27304-14
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/21/2010 2000
Date Prepared: 08/21/2010 2000

Analysis Batch: 500-92273
Prep Batch: N/A

Instrument ID: CMS02
Lab File ID: 7304-14S.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

MSD Lab Sample ID: 500-27304-14
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/21/2010 2025
Date Prepared: 08/21/2010 2025

Analysis Batch: 500-92273
Prep Batch: N/A

Instrument ID: CMS02
Lab File ID: 7304-14T.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	MS Qual	MSD Qual
	MS	MSD					
1,1,2-Trichloroethane	99	100	70 - 127	1	20		
Tetrachloroethene	90	85	76 - 116	4	20		
1,3-Dichloropropane	98	93	74 - 119	5	20		
2-Hexanone	100	91	54 - 140	10	20		
Dibromochloromethane	96	93	68 - 122	4	20		
1,2-Dibromoethane	99	99	77 - 123	1	20		
Chlorobenzene	97	92	78 - 113	5	20		
1,1,1,2-Tetrachloroethane	103	96	80 - 126	7	20		
Ethylbenzene	98	94	80 - 116	5	20		
m&p-Xylene	98	93	79 - 120	4	20		
o-Xylene	98	93	80 - 117	5	20		
Styrene	99	94	80 - 120	5	20		
Bromoform	100	94	59 - 122	6	20		
Isopropylbenzene	87	86	66 - 107	1	20		
Bromobenzene	97	96	78 - 119	1	20		
1,1,2,2-Tetrachloroethane	96	95	70 - 123	2	20		
1,2,3-Trichloropropane	96	97	76 - 121	1	20		
N-Propylbenzene	96	94	74 - 124	3	20		
2-Chlorotoluene	98	96	75 - 121	2	20		
1,3,5-Trimethylbenzene	99	96	77 - 123	3	20		
4-Chlorotoluene	97	95	74 - 119	2	20		
tert-Butylbenzene	98	96	78 - 121	2	20		
1,2,4-Trimethylbenzene	99	96	78 - 122	3	20		
sec-Butylbenzene	101	98	80 - 123	2	20		
1,3-Dichlorobenzene	97	96	80 - 114	1	20		
p-Isopropyltoluene	98	94	77 - 118	4	20		
1,4-Dichlorobenzene	96	93	79 - 113	3	20		
n-Butylbenzene	102	97	75 - 129	6	20		
1,2-Dichlorobenzene	102	98	80 - 116	4	20		
1,2-Dibromo-3-Chloropropane	90	95	55 - 126	6	20		

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

**Matrix Spike/
Matrix Spike Duplicate Recovery Report - Batch: 500-92273**

**Method: 8260B
Preparation: 5030B**

MS Lab Sample ID: 500-27304-14
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/21/2010 2000
Date Prepared: 08/21/2010 2000

Analysis Batch: 500-92273
Prep Batch: N/A

Instrument ID: CMS02
Lab File ID: 7304-14S.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

MSD Lab Sample ID: 500-27304-14
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/21/2010 2025
Date Prepared: 08/21/2010 2025

Analysis Batch: 500-92273
Prep Batch: N/A

Instrument ID: CMS02
Lab File ID: 7304-14T.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	MS Qual	MSD Qual
	MS	MSD					
1,2,4-Trichlorobenzene	95	92	68 - 119	3	20		
Hexachlorobutadiene	101	96	69 - 125	6	20		
Naphthalene	96	97	57 - 130	0	20		
1,2,3-Trichlorobenzene	96	97	69 - 123	2	20		
Surrogate	MS % Rec		MSD % Rec		Acceptance Limits		
1,2-Dichloroethane-d4 (Surr)	101		98		80 - 129		
Toluene-d8 (Surr)	105		103		80 - 115		
4-Bromofluorobenzene (Surr)	102		96		80 - 115		
Dibromofluoromethane	105		104		80 - 124		

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Method Blank - Batch: 500-92396

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-92396/6
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/23/2010 0958
Date Prepared: 08/23/2010 0958

Analysis Batch: 500-92396
Prep Batch: N/A
Units: ug/L

Instrument ID: CMS02
Lab File ID: 2M0823.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.17	1.0
Dichlorodifluoromethane	<1.0		0.31	1.0
Chloromethane	<1.0		0.24	1.0
Vinyl chloride	<1.0		0.20	1.0
Bromomethane	<1.0		0.38	1.0
Chloroethane	<1.0		0.36	1.0
Trichlorofluoromethane	<1.0		0.20	1.0
1,1-Dichloroethene	<1.0		0.19	1.0
Carbon disulfide	<5.0		0.55	5.0
Acetone	<5.0		1.6	5.0
Methylene Chloride	<2.0		0.67	2.0
trans-1,2-Dichloroethene	<1.0		0.32	1.0
1,1-Dichloroethane	<1.0		0.25	1.0
2,2-Dichloropropane	<1.0		0.24	1.0
cis-1,2-Dichloroethene	<1.0		0.27	1.0
Methyl Ethyl Ketone	<5.0		2.3	5.0
Bromochloromethane	<1.0		0.35	1.0
Chloroform	<1.0		0.15	1.0
1,1,1-Trichloroethane	<1.0		0.18	1.0
1,1-Dichloropropene	<1.0		0.16	1.0
Carbon tetrachloride	<1.0		0.25	1.0
1,2-Dichloroethane	<1.0		0.24	1.0
Trichloroethene	<1.0		0.24	1.0
1,2-Dichloropropane	<1.0		0.21	1.0
Dibromomethane	<1.0		0.30	1.0
Bromodichloromethane	<1.0		0.19	1.0
cis-1,3-Dichloropropene	<1.0		0.17	1.0
methyl isobutyl ketone	<5.0		0.84	5.0
Toluene	<1.0		0.19	1.0
trans-1,3-Dichloropropene	<1.0		0.24	1.0
1,1,2-Trichloroethane	<1.0		0.26	1.0
Tetrachloroethene	<1.0		0.22	1.0
1,3-Dichloropropane	<1.0		0.17	1.0
2-Hexanone	<5.0		0.80	5.0
Dibromochloromethane	<1.0		0.25	1.0
1,2-Dibromoethane	<1.0		0.37	1.0
Chlorobenzene	<1.0		0.17	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.19	1.0
Ethylbenzene	<1.0		0.18	1.0
m&p-Xylene	<2.0		0.32	2.0
o-Xylene	<1.0		0.38	1.0
Styrene	<1.0		0.15	1.0
Bromoform	<1.0		0.42	1.0

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Method Blank - Batch: 500-92396

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-92396/6
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/23/2010 0958
Date Prepared: 08/23/2010 0958

Analysis Batch: 500-92396
Prep Batch: N/A
Units: ug/L

Instrument ID: CMS02
Lab File ID: 2M0823.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Isopropylbenzene	<1.0		0.20	1.0
Bromobenzene	<1.0		0.21	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.29	1.0
1,2,3-Trichloropropane	<1.0		0.48	1.0
N-Propylbenzene	<1.0		0.19	1.0
2-Chlorotoluene	<1.0		0.18	1.0
1,3,5-Trimethylbenzene	<1.0		0.18	1.0
4-Chlorotoluene	<1.0		0.21	1.0
tert-Butylbenzene	<1.0		0.16	1.0
1,2,4-Trimethylbenzene	<1.0		0.14	1.0
sec-Butylbenzene	<1.0		0.16	1.0
1,3-Dichlorobenzene	<1.0		0.24	1.0
p-Isopropyltoluene	<1.0		0.16	1.0
1,4-Dichlorobenzene	<1.0		0.21	1.0
n-Butylbenzene	<1.0		0.18	1.0
1,2-Dichlorobenzene	<1.0		0.17	1.0
1,2-Dibromo-3-Chloropropane	<2.0		0.96	2.0
1,2,4-Trichlorobenzene	<1.0		0.24	1.0
Hexachlorobutadiene	<1.0		0.26	1.0
Naphthalene	<1.0		0.44	1.0
1,2,3-Trichlorobenzene	<1.0		0.24	1.0

Surrogate	% Rec	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	106	80 - 129
Toluene-d8 (Surr)	113	80 - 115
4-Bromofluorobenzene (Surr)	105	80 - 115
Dibromofluoromethane	102	80 - 124

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Lab Control Sample - Batch: 500-92396

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-92396/7
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/23/2010 1022
Date Prepared: 08/23/2010 1022

Analysis Batch: 500-92396
Prep Batch: N/A
Units: ug/L

Instrument ID: CMS02
Lab File ID: 2S0823.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	25.0	22.7	91	73 - 117	
Dichlorodifluoromethane	25.0	42.3	169	46 - 182	
Chloromethane	25.0	33.5	134	51 - 151	
Vinyl chloride	25.0	31.2	125	56 - 128	
Bromomethane	25.0	33.3	133	35 - 181	
Chloroethane	25.0	29.4	118	52 - 150	
Trichlorofluoromethane	25.0	30.9	123	69 - 142	
1,1-Dichloroethene	25.0	19.5	78	55 - 127	
Carbon disulfide	25.0	15.7	63	38 - 123	
Acetone	25.0	23.9	96	42 - 149	
Methylene Chloride	25.0	20.8	83	62 - 127	
trans-1,2-Dichloroethene	25.0	22.2	89	67 - 125	
1,1-Dichloroethane	25.0	22.4	90	67 - 122	
2,2-Dichloropropane	25.0	22.4	90	62 - 135	
cis-1,2-Dichloroethene	25.0	20.9	84	65 - 115	
Methyl Ethyl Ketone	25.0	23.1	93	52 - 148	
Bromochloromethane	25.0	23.5	94	70 - 122	
Chloroform	25.0	22.1	88	74 - 121	
1,1,1-Trichloroethane	25.0	23.1	92	76 - 127	
1,1-Dichloropropene	25.0	22.5	90	69 - 122	
Carbon tetrachloride	25.0	23.1	92	66 - 138	
1,2-Dichloroethane	25.0	22.6	90	71 - 124	
Trichloroethene	25.0	23.3	93	77 - 118	
1,2-Dichloropropane	25.0	23.4	93	75 - 120	
Dibromomethane	25.0	21.5	86	76 - 121	
Bromodichloromethane	25.0	23.2	93	79 - 124	
cis-1,3-Dichloropropene	26.9	23.1	86	66 - 122	
methyl isobutyl ketone	25.0	21.7	87	58 - 134	
Toluene	25.0	22.8	91	76 - 119	
trans-1,3-Dichloropropene	24.3	20.3	83	66 - 110	
1,1,2-Trichloroethane	25.0	21.3	85	70 - 127	
Tetrachloroethene	25.0	22.9	91	76 - 116	
1,3-Dichloropropane	25.0	22.2	89	74 - 119	
2-Hexanone	25.0	22.9	92	54 - 140	
Dibromochloromethane	25.0	22.9	92	68 - 122	
1,2-Dibromoethane	25.0	21.9	88	77 - 123	
Chlorobenzene	25.0	22.8	91	78 - 113	
1,1,1,2-Tetrachloroethane	25.0	24.0	96	80 - 126	
Ethylbenzene	25.0	23.6	95	80 - 116	
m&p-Xylene	50.0	46.9	94	79 - 120	
o-Xylene	25.0	23.4	94	80 - 117	
Styrene	25.0	23.3	93	80 - 120	
Bromoform	25.0	22.3	89	59 - 122	

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Lab Control Sample - Batch: 500-92396

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-92396/7
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/23/2010 1022
Date Prepared: 08/23/2010 1022

Analysis Batch: 500-92396
Prep Batch: N/A
Units: ug/L

Instrument ID: CMS02
Lab File ID: 2S0823.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Isopropylbenzene	25.0	20.0	80	66 - 107	
Bromobenzene	25.0	22.3	89	78 - 119	
1,1,2,2-Tetrachloroethane	25.0	21.0	84	70 - 123	
1,2,3-Trichloropropane	25.0	21.1	84	76 - 121	
N-Propylbenzene	25.0	22.4	89	74 - 124	
2-Chlorotoluene	25.0	22.4	89	75 - 121	
1,3,5-Trimethylbenzene	25.0	22.7	91	77 - 123	
4-Chlorotoluene	25.0	22.2	89	74 - 119	
tert-Butylbenzene	25.0	22.7	91	78 - 121	
1,2,4-Trimethylbenzene	25.0	22.8	91	78 - 122	
sec-Butylbenzene	25.0	23.5	94	80 - 123	
1,3-Dichlorobenzene	25.0	22.4	90	80 - 114	
p-Isopropyltoluene	25.0	22.9	92	77 - 118	
1,4-Dichlorobenzene	25.0	21.8	87	79 - 113	
n-Butylbenzene	25.0	24.2	97	75 - 129	
1,2-Dichlorobenzene	25.0	22.7	91	80 - 116	
1,2-Dibromo-3-Chloropropane	25.0	20.3	81	55 - 126	
1,2,4-Trichlorobenzene	25.0	23.3	93	68 - 119	
Hexachlorobutadiene	25.0	25.5	102	69 - 125	
Naphthalene	25.0	22.6	90	57 - 130	
1,2,3-Trichlorobenzene	25.0	23.6	94	69 - 123	
Surrogate		% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)		95		80 - 129	
Toluene-d8 (Surr)		102		80 - 115	
4-Bromofluorobenzene (Surr)		100		80 - 115	
Dibromofluoromethane		94		80 - 124	

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

2417 Bond Street, University Park, IL 60484
Phone: 708.534.5200 Fax: 708.534.5211

Report To (optional)
Contact: _____
Company: _____
Address: _____
Address: _____
Phone: _____
Fax: _____
E-Mail: _____

Bill To (optional)
Contact: _____
Company: _____
Address: _____
Address: _____
Phone: _____
Fax: _____
PO#/Reference#: _____

Chain of Custody Record

Lab Job #: 500-27304
Chain of Custody Number: _____
Page 1 of 3
Temperature °C of Cooler: 2.5

Client		Client Project #		Preservative												
Western Black + Decker		02501.004.004.0700		HCl												
Project Name		Lab Project #		Parameter												
Black + Decker																
Project Location/State		Lab PM		VOC												
Hampstead, MD		Dick Wright														
Sampler		Sampling		# of Containers	Matrix											
Greg Florkowski		Date	Time													
Lab ID	MS/MSD	Sample ID	Date	Time	# of Containers	Matrix										
1		RFW-1A	8/16/10	1010	3	W										
2		RFW-1B	8/16	1745												
3		RFW-2A	8/16	1100												
4		RFW-2B	8/16	1110												
5		RFW-3B	8/17	730												
6		RFW-4A	8/17	840												
7		RFW-4A DUP	8/17	840												
8		RFW-4B	8/17	1010												
9		RFW-6	8/16/10	0700												
10		RFW-7	8/16/10	1255												

- Preservative Key
1. HCL, Cool to 4°
 2. H2SO4, Cool to 4°
 3. HNO3, Cool to 4°
 4. NaOH, Cool to 4°
 5. NaOH/Zn, Cool to 4°
 6. NaHSO4
 7. Cool to 4°
 8. None
 9. Other

Turnaround Time Required (Business Days)

1 Day 2 Days 5 Days 7 Days 10 Days 15 Days Other

Sample Disposal

Return to Client

Disposal by Lab

Archive for _____ Months

(A fee may be assessed if samples are retained longer than 1 month)

Requested Due Date

Requisitioned By <i>[Signature]</i>	Company Western	Date 8/18/10	Time 1600	Received By <i>[Signature]</i>	Company TA	Date 8/19/10	Time 1015
Requisitioned By	Company	Date	Time	Received By	Company	Date	Time
Requisitioned By	Company	Date	Time	Received By	Company	Date	Time

Lab Courier

Shipped FK

Hand Delivered

Matrix Key
WW - Wastewater
W - Water
S - Soil
SL - Sludge
MS - Miscellaneous
OL - Oil
A - Air

SE - Sediment

SO - Soil

L - Leachate

WI - Wipe

DW - Drinking Water

O - Other

Client Comments

Lab Comments:

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

2417 Bond Street, University Park, IL 60484
 Phone: 708.534.5200 Fax: 708.534.5211

Report To _____ (optional)
 Contact: _____
 Company: _____
 Address: _____
 Address: _____
 Phone: _____
 Fax: _____
 E-Mail: _____

Bill To _____ (optional)
 Contact: _____
 Company: _____
 Address: _____
 Address: _____
 Phone: _____
 Fax: _____
 PO#/Reference# _____

Chain of Custody Record

Lab Job #: 500-27304
 Chain of Custody Number: _____
 Page 2 of 3
 Temperature °C of Cooler: _____

Client		Client Project #		Preservative		Parameter		Matrix		Preservative Key	Comments
Project Name		Project Location/State		Lab Project #		Sampler		Lab PM			
Black + Decker		Hampstead MD		HCL		COOL				1. HCL, Cool to 4° 2. H2SO4, Cool to 4° 3. HNO3, Cool to 4° 4. NaOH, Cool to 4° 5. NaOH/Zn, Cool to 4° 6. NaHSO4 7. Cool to 4° 8. None 9. Other	
Project Name		Project Location/State		Lab Project #		Sampler		Lab PM			
Lab ID	MSMSD	Sample ID	Date	Time	# of Containers	Matrix					
11		RFW-9	8/17/10	1255	3	W					
12		RFW-11B	8/17/10	1400	1						
13		RFW-12B	8/17/10	745	1						
14		RFW-13	8/16/10	1540	1						
15		RFW-17	8/16/10	1200	1						
16		Trip Blank	8/16/10	700	1						

Turnaround Time Required (Business Days)
 ___ 1 Day ___ 2 Days ___ 3 Days ___ 7 Days ___ 10 Days ___ 15 Days ___ Other
 Requested Due Date: _____

Sample Disposal
 Return to Client Disposal by Lab Archive for ___ Months (A fee may be assessed if samples are retained longer than 1 month)

Relinquished By: <u>[Signature]</u> Company: <u>Weston</u> Date: <u>8/18/10</u> Time: <u>1600</u>	Received By: <u>[Signature]</u> Company: <u>TA</u> Date: <u>8/19/10</u> Time: <u>1015</u>
Relinquished By: _____ Company: _____ Date: _____ Time: _____	Received By: _____ Company: _____ Date: _____ Time: _____
Relinquished By: _____ Company: _____ Date: _____ Time: _____	Received By: _____ Company: _____ Date: _____ Time: _____

Lab Courier: _____
 Shipped: FX
 Hand Delivered: _____

Matrix Key
 WW - Wastewater SE - Sediment
 W - Water SO - Soil
 S - Soil L - Leachate
 SL - Sludge WI - Wipe
 MS - Miscellaneous DW - Drinking Water
 OL - Oil O - Other
 A - Air

Client Comments: _____
 Lab Comments: _____

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

2417 Bond Street, University Park, IL 60484
 Phone: 708.534.5200 Fax: 708.534.5211

Report To _____ (optional)
 Contact: _____
 Company: _____
 Address: _____
 Address: _____
 Phone: _____
 Fax: _____
 E-Mail: _____

Bill To _____ (optional)
 Contact: _____
 Company: _____
 Address: _____
 Address: _____
 Phone: _____
 Fax: _____
 PO#/Reference# _____

Chain of Custody Record

Lab Job #: 500-27304
 Chain of Custody Number: _____
 Page 3 of 3
 Temperature °C of Cooler: _____

Client		Client Project #		Preservative		Parameter		Project Location/State		Lab Project #		Sampler		Lab PM		Preservative Key	
Black + Decker		02501.004.004.0700		HCl		VOC		Hampstead, MD				Greg Flusyski				1. HCL, Cool to 4° 2. H2SO4, Cool to 4° 3. HNO3, Cool to 4° 4. NaOH, Cool to 4° 5. NaOH/Zn, Cool to 4° 6. NaHSO4 7. Cool to 4° 8. None 9. Other	
Lab ID	MS/MSY	Sample ID		Sampling		# of Containers	Mark	Comments									
		Date	Time														
17		8/17/10	1300	3	W												
18		8/17/10	1310														
19		8/17/10	1115														
20		8/16/10	945														
21		8/16/10	1525														
22		8/16/10	1515														
23		8/16/10	1510														
24		8/16/10	1500														
25		8/16/10	1500														
26		8/16/10	1600														

Turnaround Time Required (Business Days) _____
 1 Day 2 Days 3 Days 7 Days 10 Days 15 Days Other _____
 Requested Due Date _____
 Sample Disposal: Return to Client Disposal by Lab Archive for _____ Months (A fee may be assessed if samples are retained longer than 1 month)

Relinquished By: <u>[Signature]</u> Company: <u>Weston</u> Date: <u>8/18/10</u> Time: <u>1600</u>	Received By: <u>[Signature]</u> Company: <u>JA</u> Date: <u>8/19/10</u> Time: <u>1015</u>
Relinquished By: _____ Company: _____ Date: _____ Time: _____	Received By: _____ Company: _____ Date: _____ Time: _____
Relinquished By: _____ Company: _____ Date: _____ Time: _____	Received By: _____ Company: _____ Date: _____ Time: _____

Lab Courier: _____
 Shipped: FK
 Hand Delivered: _____

- Matrix Key
- WW - Wastewater
 - W - Water
 - S - Soil
 - SL - Sludge
 - MS - Miscellaneous
 - OL - Oil
 - A - Air
 - SE - Sediment
 - SO - Soil
 - L - Leachate
 - WI - Wipi
 - DW - Drinking Water
 - O - Other

Client Comments: _____
 Lab Comments: _____

Login Sample Receipt Check List

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Login Number: 27304

List Source: TestAmerica Chicago

Creator: Lunt, Jeff T

List Number: 1

Question	T / F / NA	Comment
Radioactivity either was not measured or, if measured, is at or below background	True	
The cooler's custody seal, if present, is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	2.5
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	True	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	

ANALYTICAL REPORT

Job Number: 680-60513-1

Job Description: Black & Decker

For:


Weston Solutions, Inc.

1400 Weston Way

PO BOX 2653

West Chester, PA 19380

Attention: Mr. Tom Cornuet



Approved for release.
Abbie G Yant
Project Manager I
8/29/2010 10:34 AM

Abbie G Yant

Project Manager I

abbie.yant@testamericainc.com

08/29/2010

The test results in this report meet NELAP requirements for parameters for which accreditation is required or available. Any exceptions to the NELAP requirements are noted. Results pertain only to samples listed in this report. This report may not be reproduced, except in full, without the written approval of the laboratory. Questions should be directed to the person who signed this report.

Savannah Certifications and ID #s: A2LA: 0399.01; AL: 41450; ARDEQ: 88-0692; ARDOH; CA: 03217CA; CO; CT: PH0161; DE; FL: E87052; GA: 803; Guam; HI; IL: 200022; IN; IA: 353; KS: E-10322; KY EPPC: 90084; KY UST; LA DEQ: 30690; LA DHH: LA080008; ME: 2008022; MD: 250; MA: M-GA006; MI: 9925; MS; NFESC: 249; NV: GA00006; NJ: GA769; NM; NY: 10842; NC DWQ: 269; NC DHHS: 13701; PA: 68-00474; PR: GA00006; RI: LAO00244; SC: 98001001; TN: TN0296; TX: T104704185; USEPA: GA00006; VT: VT-87052; VA: 00302; WA; WV DEP: 094; WV DHHR: 9950 C; WI DNR: 999819810; WY/EPAR8: 8TMS-Q

TestAmerica Laboratories, Inc.

TestAmerica Savannah 5102 LaRoche Avenue, Savannah, GA 31404

Tel (912) 354-7858 Fax (912) 352-0165 www.testamericainc.com



METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 680-60513-1

Description		Lab Location	Method	Preparation Method
Matrix	Water			
Volatile Organic Compounds (GC/MS)		TAL SAV	EPA-DW 524.2	

Lab References:

TAL SAV = TestAmerica Savannah

Method References:

EPA-DW = "Methods For The Determination Of Organic Compounds In Drinking Water", EPA/600/4-88/039, December 1988 And Its Supplements.

SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 680-60513-1

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
680-60513-1	RFW-20	Water	08/16/2010 1730	08/19/2010 0953
680-60513-2	RFW-21	Water	08/16/2010 0800	08/19/2010 0953
680-60513-3	Trip Blank	Water	08/16/2010 0700	08/19/2010 0953

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-60513-1

Client Sample ID: RFW-20

Lab Sample ID: 680-60513-1

Date Sampled: 08/16/2010 1730

Client Matrix: Water

Date Received: 08/19/2010 0953

524.2 Volatile Organic Compounds (GC/MS)

Method: 524.2
Preparation: N/A
Dilution: 1.0
Date Analyzed: 08/24/2010 1647
Date Prepared:

Analysis Batch: 680-178226

Instrument ID: MSS
Lab File ID: s0586.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		5.0	10
Benzene	<0.50		0.18	0.50
Bromobenzene	<0.50		0.42	0.50
Bromoform	<0.50		0.39	0.50
Bromomethane	<1.0		0.45	1.0
Carbon tetrachloride	<0.50		0.22	0.50
Chlorobenzene	<0.50		0.27	0.50
Chlorobromomethane	<0.50		0.30	0.50
Chlorodibromomethane	<0.50		0.43	0.50
Chloroethane	<1.0		0.33	1.0
Chloroform	<0.50		0.29	0.50
Chloromethane	<0.50		0.32	0.50
2-Chlorotoluene	<0.50		0.17	0.50
4-Chlorotoluene	<0.50		0.16	0.50
cis-1,2-Dichloroethene	<0.50		0.37	0.50
cis-1,3-Dichloropropene	<0.50		0.32	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.30	0.50
Dibromomethane	<0.50		0.38	0.50
1,2-Dichlorobenzene	<0.50		0.17	0.50
1,3-Dichlorobenzene	<0.50		0.14	0.50
1,4-Dichlorobenzene	<0.50		0.18	0.50
Dichlorobromomethane	<1.0		0.54	1.0
Dichlorodifluoromethane	<0.50		0.34	0.50
1,1-Dichloroethane	<0.50		0.39	0.50
1,2-Dichloroethane	<0.50		0.17	0.50
1,1-Dichloroethene	<0.50		0.32	0.50
1,2-Dichloropropane	<0.50		0.45	0.50
1,3-Dichloropropane	<0.50		0.43	0.50
2,2-Dichloropropane	<0.50		0.31	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.32	0.50
Diisopropyl ether	<0.50		0.28	0.50
Ethylbenzene	<0.50		0.12	0.50
Ethylene Dibromide	<0.50		0.20	0.50
Freon 113	<0.50		0.15	0.50
Hexachlorobutadiene	<0.50		0.26	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.21	0.50
Methylene Chloride	<0.50		0.36	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.42	0.50
Naphthalene	<1.0		0.43	1.0
n-Butylbenzene	<0.50		0.17	0.50
N-Propylbenzene	<0.50		0.17	0.50

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-60513-1

Client Sample ID: RFW-20

Lab Sample ID: 680-60513-1

Date Sampled: 08/16/2010 1730

Client Matrix: Water

Date Received: 08/19/2010 0953

524.2 Volatile Organic Compounds (GC/MS)

Method:	524.2	Analysis Batch: 680-178226	Instrument ID:	MSS
Preparation:	N/A		Lab File ID:	s0586.d
Dilution:	1.0		Initial Weight/Volume:	5 mL
Date Analyzed:	08/24/2010 1647		Final Weight/Volume:	5 mL
Date Prepared:				

Analyte	Result (ug/L)	Qualifier	MDL	RL
o-Xylene	<0.50		0.27	0.50
sec-Butylbenzene	<0.50		0.14	0.50
Styrene	<0.50		0.28	0.50
Tert-amyl methyl ether	<0.50		0.20	0.50
tert-Butyl alcohol	<2.0		1.6	2.0
tert-Butylbenzene	<0.50		0.14	0.50
Tert-butyl ethyl ether	<0.50		0.26	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.16	0.50
1,1,1,2,2-Tetrachloroethane	<0.50		0.18	0.50
Tetrachloroethene	<0.50		0.30	0.50
Toluene	<0.50		0.23	0.50
trans-1,2-Dichloroethene	<0.50		0.24	0.50
trans-1,3-Dichloropropene	<0.50		0.48	0.50
1,2,3-Trichlorobenzene	<0.50		0.14	0.50
1,2,4-Trichlorobenzene	<0.50		0.18	0.50
1,1,1-Trichloroethane	<0.50		0.27	0.50
1,1,2-Trichloroethane	<0.50		0.22	0.50
Trichloroethene	<0.50		0.37	0.50
Trichlorofluoromethane	<0.50		0.23	0.50
1,2,3-Trichloropropane	<0.50		0.18	0.50
Trihalomethanes, Total	<0.50		0.29	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.16	0.50
Vinyl chloride	<0.50		0.33	0.50
Xylenes, Total	<0.50		0.27	0.50

Surrogate	%Rec	Qualifier	Acceptance Limits
4-Bromofluorobenzene	87		70 - 130
1,2-Dichlorobenzene-d4	87		70 - 130

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-60513-1

Client Sample ID: RFW-21

Lab Sample ID: 680-60513-2

Date Sampled: 08/16/2010 0800

Client Matrix: Water

Date Received: 08/19/2010 0953

524.2 Volatile Organic Compounds (GC/MS)

Method: 524.2
Preparation: N/A
Dilution: 1.0
Date Analyzed: 08/24/2010 1712
Date Prepared:

Analysis Batch: 680-178226

Instrument ID: MSS
Lab File ID: s0587.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		5.0	10
Benzene	<0.50		0.18	0.50
Bromobenzene	<0.50		0.42	0.50
Bromoform	<0.50		0.39	0.50
Bromomethane	<1.0		0.45	1.0
Carbon tetrachloride	<0.50		0.22	0.50
Chlorobenzene	<0.50		0.27	0.50
Chlorobromomethane	<0.50		0.30	0.50
Chlorodibromomethane	<0.50		0.43	0.50
Chloroethane	<1.0		0.33	1.0
Chloroform	<0.50		0.29	0.50
Chloromethane	<0.50		0.32	0.50
2-Chlorotoluene	<0.50		0.17	0.50
4-Chlorotoluene	<0.50		0.16	0.50
cis-1,2-Dichloroethene	<0.50		0.37	0.50
cis-1,3-Dichloropropene	<0.50		0.32	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.30	0.50
Dibromomethane	<0.50		0.38	0.50
1,2-Dichlorobenzene	<0.50		0.17	0.50
1,3-Dichlorobenzene	<0.50		0.14	0.50
1,4-Dichlorobenzene	<0.50		0.18	0.50
Dichlorobromomethane	<1.0		0.54	1.0
Dichlorodifluoromethane	<0.50		0.34	0.50
1,1-Dichloroethane	<0.50		0.39	0.50
1,2-Dichloroethane	<0.50		0.17	0.50
1,1-Dichloroethene	<0.50		0.32	0.50
1,2-Dichloropropane	<0.50		0.45	0.50
1,3-Dichloropropane	<0.50		0.43	0.50
2,2-Dichloropropane	<0.50		0.31	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.32	0.50
Diisopropyl ether	<0.50		0.28	0.50
Ethylbenzene	<0.50		0.12	0.50
Ethylene Dibromide	<0.50		0.20	0.50
Freon 113	<0.50		0.15	0.50
Hexachlorobutadiene	<0.50		0.26	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.21	0.50
Methylene Chloride	<0.50		0.36	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.42	0.50
Naphthalene	<1.0		0.43	1.0
n-Butylbenzene	<0.50		0.17	0.50
N-Propylbenzene	<0.50		0.17	0.50

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-60513-1

Client Sample ID: RFW-21

Lab Sample ID: 680-60513-2

Date Sampled: 08/16/2010 0800

Client Matrix: Water

Date Received: 08/19/2010 0953

524.2 Volatile Organic Compounds (GC/MS)

Method:	524.2	Analysis Batch: 680-178226	Instrument ID:	MSS
Preparation:	N/A		Lab File ID:	s0587.d
Dilution:	1.0		Initial Weight/Volume:	5 mL
Date Analyzed:	08/24/2010 1712		Final Weight/Volume:	5 mL
Date Prepared:				

Analyte	Result (ug/L)	Qualifier	MDL	RL
o-Xylene	<0.50		0.27	0.50
sec-Butylbenzene	<0.50		0.14	0.50
Styrene	<0.50		0.28	0.50
Tert-amyl methyl ether	<0.50		0.20	0.50
tert-Butyl alcohol	<2.0		1.6	2.0
tert-Butylbenzene	<0.50		0.14	0.50
Tert-butyl ethyl ether	<0.50		0.26	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.16	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.18	0.50
Tetrachloroethene	<0.50		0.30	0.50
Toluene	<0.50		0.23	0.50
trans-1,2-Dichloroethene	<0.50		0.24	0.50
trans-1,3-Dichloropropene	<0.50		0.48	0.50
1,2,3-Trichlorobenzene	<0.50		0.14	0.50
1,2,4-Trichlorobenzene	<0.50		0.18	0.50
1,1,1-Trichloroethane	<0.50		0.27	0.50
1,1,2-Trichloroethane	<0.50		0.22	0.50
Trichloroethene	<0.50		0.37	0.50
Trichlorofluoromethane	<0.50		0.23	0.50
1,2,3-Trichloropropane	<0.50		0.18	0.50
Trihalomethanes, Total	<0.50		0.29	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.16	0.50
Vinyl chloride	<0.50		0.33	0.50
Xylenes, Total	<0.50		0.27	0.50

Surrogate	%Rec	Qualifier	Acceptance Limits
4-Bromofluorobenzene	86		70 - 130
1,2-Dichlorobenzene-d4	87		70 - 130

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-60513-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-60513-3

Date Sampled: 08/16/2010 0700

Client Matrix: Water

Date Received: 08/19/2010 0953

524.2 Volatile Organic Compounds (GC/MS)

Method:	524.2	Analysis Batch: 680-178226	Instrument ID:	MSS
Preparation:	N/A		Lab File ID:	s0588.d
Dilution:	1.0		Initial Weight/Volume:	5 mL
Date Analyzed:	08/24/2010 1737		Final Weight/Volume:	5 mL
Date Prepared:				

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		5.0	10
Benzene	<0.50		0.18	0.50
Bromobenzene	<0.50		0.42	0.50
Bromoform	<0.50		0.39	0.50
Bromomethane	<1.0		0.45	1.0
Carbon tetrachloride	<0.50		0.22	0.50
Chlorobenzene	<0.50		0.27	0.50
Chlorobromomethane	<0.50		0.30	0.50
Chlorodibromomethane	<0.50		0.43	0.50
Chloroethane	<1.0		0.33	1.0
Chloroform	<0.50		0.29	0.50
Chloromethane	<0.50		0.32	0.50
2-Chlorotoluene	<0.50		0.17	0.50
4-Chlorotoluene	<0.50		0.16	0.50
cis-1,2-Dichloroethene	<0.50		0.37	0.50
cis-1,3-Dichloropropene	<0.50		0.32	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.30	0.50
Dibromomethane	<0.50		0.38	0.50
1,2-Dichlorobenzene	<0.50		0.17	0.50
1,3-Dichlorobenzene	<0.50		0.14	0.50
1,4-Dichlorobenzene	<0.50		0.18	0.50
Dichlorobromomethane	<1.0		0.54	1.0
Dichlorodifluoromethane	<0.50		0.34	0.50
1,1-Dichloroethane	<0.50		0.39	0.50
1,2-Dichloroethane	<0.50		0.17	0.50
1,1-Dichloroethene	<0.50		0.32	0.50
1,2-Dichloropropane	<0.50		0.45	0.50
1,3-Dichloropropane	<0.50		0.43	0.50
2,2-Dichloropropane	<0.50		0.31	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.32	0.50
Diisopropyl ether	<0.50		0.28	0.50
Ethylbenzene	<0.50		0.12	0.50
Ethylene Dibromide	<0.50		0.20	0.50
Freon 113	<0.50		0.15	0.50
Hexachlorobutadiene	<0.50		0.26	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.21	0.50
Methylene Chloride	<0.50		0.36	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.42	0.50
Naphthalene	<1.0		0.43	1.0
n-Butylbenzene	<0.50		0.17	0.50
N-Propylbenzene	<0.50		0.17	0.50

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-60513-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-60513-3

Date Sampled: 08/16/2010 0700

Client Matrix: Water

Date Received: 08/19/2010 0953

524.2 Volatile Organic Compounds (GC/MS)

Method:	524.2	Analysis Batch: 680-178226	Instrument ID:	MSS
Preparation:	N/A		Lab File ID:	s0588.d
Dilution:	1.0		Initial Weight/Volume:	5 mL
Date Analyzed:	08/24/2010 1737		Final Weight/Volume:	5 mL
Date Prepared:				

Analyte	Result (ug/L)	Qualifier	MDL	RL
o-Xylene	<0.50		0.27	0.50
sec-Butylbenzene	<0.50		0.14	0.50
Styrene	<0.50		0.28	0.50
Tert-amyl methyl ether	<0.50		0.20	0.50
tert-Butyl alcohol	<2.0		1.6	2.0
tert-Butylbenzene	<0.50		0.14	0.50
Tert-butyl ethyl ether	<0.50		0.26	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.16	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.18	0.50
Tetrachloroethene	<0.50		0.30	0.50
Toluene	<0.50		0.23	0.50
trans-1,2-Dichloroethene	<0.50		0.24	0.50
trans-1,3-Dichloropropene	<0.50		0.48	0.50
1,2,3-Trichlorobenzene	<0.50		0.14	0.50
1,2,4-Trichlorobenzene	<0.50		0.18	0.50
1,1,1-Trichloroethane	<0.50		0.27	0.50
1,1,2-Trichloroethane	<0.50		0.22	0.50
Trichloroethene	<0.50		0.37	0.50
Trichlorofluoromethane	<0.50		0.23	0.50
1,2,3-Trichloropropane	<0.50		0.18	0.50
Trihalomethanes, Total	<0.50		0.29	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.16	0.50
Vinyl chloride	<0.50		0.33	0.50
Xylenes, Total	<0.50		0.27	0.50

Surrogate	%Rec	Qualifier	Acceptance Limits
4-Bromofluorobenzene	87		70 - 130
1,2-Dichlorobenzene-d4	85		70 - 130

DATA REPORTING QUALIFIERS

Lab Section	Qualifier	Description
--------------------	------------------	--------------------

Client: Weston Solutions, Inc.

Job Number: 680-60513-1

Surrogate Recovery Report**524.2 Volatile Organic Compounds (GC/MS)****Client Matrix: Water**

Lab Sample ID	Client Sample ID	BFB %Rec	DCZ %Rec
680-60513-1	RFW-20	87	87
680-60513-2	RFW-21	86	87
680-60513-3	Trip Blank	87	85
MB 680-178226/21		87	85
LCS 680-178226/18		96	108
LCSD 680-178226/19		101	108

SurrogateAcceptance LimitsBFB = 4-Bromofluorobenzene
DCZ = 1,2-Dichlorobenzene-d470-130
70-130

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-60513-1

Method Blank - Batch: 680-178226

Method: 524.2

Preparation: N/A

Lab Sample ID: MB 680-178226/21
 Client Matrix: Water
 Dilution: 1.0
 Date Analyzed: 08/24/2010 1204
 Date Prepared: N/A

Analysis Batch: 680-178226
 Prep Batch: N/A
 Units: ug/L

Instrument ID: MSS
 Lab File ID: sq393.d
 Initial Weight/Volume: 5 mL
 Final Weight/Volume: 5 mL

Analyte	Result	Qual	MDL	RL
Acetone	<10		5.0	10
Benzene	<0.50		0.18	0.50
Bromobenzene	<0.50		0.42	0.50
Bromoform	<0.50		0.39	0.50
Bromomethane	<1.0		0.45	1.0
Carbon tetrachloride	<0.50		0.22	0.50
Chlorobenzene	<0.50		0.27	0.50
Chlorobromomethane	<0.50		0.30	0.50
Chlorodibromomethane	<0.50		0.43	0.50
Chloroethane	<1.0		0.33	1.0
Chloroform	<0.50		0.29	0.50
Chloromethane	<0.50		0.32	0.50
2-Chlorotoluene	<0.50		0.17	0.50
4-Chlorotoluene	<0.50		0.16	0.50
cis-1,2-Dichloroethene	<0.50		0.37	0.50
cis-1,3-Dichloropropene	<0.50		0.32	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.30	0.50
Dibromomethane	<0.50		0.38	0.50
1,2-Dichlorobenzene	<0.50		0.17	0.50
1,3-Dichlorobenzene	<0.50		0.14	0.50
1,4-Dichlorobenzene	<0.50		0.18	0.50
Dichlorobromomethane	<1.0		0.54	1.0
Dichlorodifluoromethane	<0.50		0.34	0.50
1,1-Dichloroethane	<0.50		0.39	0.50
1,2-Dichloroethane	<0.50		0.17	0.50
1,1-Dichloroethene	<0.50		0.32	0.50
1,2-Dichloropropane	<0.50		0.45	0.50
1,3-Dichloropropane	<0.50		0.43	0.50
2,2-Dichloropropane	<0.50		0.31	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.32	0.50
Diisopropyl ether	<0.50		0.28	0.50
Ethylbenzene	<0.50		0.12	0.50
Ethylene Dibromide	<0.50		0.20	0.50
Freon 113	<0.50		0.15	0.50
Hexachlorobutadiene	<0.50		0.26	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.21	0.50
Methylene Chloride	<0.50		0.36	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.42	0.50

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-60513-1

Method Blank - Batch: 680-178226

Method: 524.2
Preparation: N/A

Lab Sample ID: MB 680-178226/21
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/24/2010 1204
Date Prepared: N/A

Analysis Batch: 680-178226
Prep Batch: N/A
Units: ug/L

Instrument ID: MSS
Lab File ID: sq393.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	Result	Qual	MDL	RL
Naphthalene	<1.0		0.43	1.0
n-Butylbenzene	<0.50		0.17	0.50
N-Propylbenzene	<0.50		0.17	0.50
o-Xylene	<0.50		0.27	0.50
sec-Butylbenzene	<0.50		0.14	0.50
Styrene	<0.50		0.28	0.50
Tert-amyl methyl ether	<0.50		0.20	0.50
tert-Butyl alcohol	<2.0		1.6	2.0
tert-Butylbenzene	<0.50		0.14	0.50
Tert-butyl ethyl ether	<0.50		0.26	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.16	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.18	0.50
Tetrachloroethene	<0.50		0.30	0.50
Toluene	<0.50		0.23	0.50
trans-1,2-Dichloroethene	<0.50		0.24	0.50
trans-1,3-Dichloropropene	<0.50		0.48	0.50
1,2,3-Trichlorobenzene	<0.50		0.14	0.50
1,2,4-Trichlorobenzene	<0.50		0.18	0.50
1,1,1-Trichloroethane	<0.50		0.27	0.50
1,1,2-Trichloroethane	<0.50		0.22	0.50
Trichloroethene	<0.50		0.37	0.50
Trichlorofluoromethane	<0.50		0.23	0.50
1,2,3-Trichloropropane	<0.50		0.18	0.50
Trihalomethanes, Total	<0.50		0.29	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.16	0.50
Vinyl chloride	<0.50		0.33	0.50
Xylenes, Total	<0.50		0.27	0.50

Surrogate	% Rec	Acceptance Limits
4-Bromofluorobenzene	87	70 - 130
1,2-Dichlorobenzene-d4	85	70 - 130

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-60513-1

Lab Control Sample/
Lab Control Sample Duplicate Recovery Report - Batch: 680-178226

Method: 524.2
Preparation: N/A

LCS Lab Sample ID: LCS 680-178226/18
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/24/2010 1023
Date Prepared: N/A

Analysis Batch: 680-178226
Prep Batch: N/A
Units: ug/L

Instrument ID: MSS
Lab File ID: sq389.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

LCSD Lab Sample ID: LCSD 680-178226/19
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/24/2010 1048
Date Prepared: N/A

Analysis Batch: 680-178226
Prep Batch: N/A
Units: ug/L

Instrument ID: MSS
Lab File ID: sq390.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	LCS Qual	LCSD Qual
	LCS	LCSD					
Acetone	86	87	70 - 130	1	30		
Benzene	99	99	70 - 130	0	30		
Bromobenzene	109	110	70 - 130	1	30		
Bromoform	112	111	70 - 130	2	30		
Bromomethane	106	111	70 - 130	5	30		
Carbon tetrachloride	113	112	70 - 130	1	30		
Chlorobenzene	100	101	70 - 130	0	30		
Chlorobromomethane	94	93	70 - 130	1	30		
Chlorodibromomethane	105	106	70 - 130	1	30		
Chloroethane	107	90	70 - 130	17	30		
Chloroform	91	92	70 - 130	1	30		
Chloromethane	102	102	70 - 130	0	30		
2-Chlorotoluene	106	107	70 - 130	1	30		
4-Chlorotoluene	109	111	70 - 130	2	30		
cis-1,2-Dichloroethene	98	101	70 - 130	3	30		
cis-1,3-Dichloropropene	97	97	70 - 130	1	30		
1,2-Dibromo-3-Chloropropane	100	96	70 - 130	3	30		
Dibromomethane	97	98	70 - 130	1	30		
1,2-Dichlorobenzene	111	114	70 - 130	2	30		
1,3-Dichlorobenzene	113	116	70 - 130	3	30		
1,4-Dichlorobenzene	111	114	70 - 130	3	30		
Dichlorobromomethane	100	99	70 - 130	0	30		
Dichlorodifluoromethane	115	105	70 - 130	9	30		
1,1-Dichloroethane	98	97	70 - 130	1	30		
1,2-Dichloroethane	89	90	70 - 130	1	30		
1,1-Dichloroethene	89	89	70 - 130	0	30		
1,2-Dichloropropane	97	99	70 - 130	2	30		
1,3-Dichloropropane	98	99	70 - 130	0	30		
2,2-Dichloropropane	93	92	70 - 130	1	30		
1,1-Dichloropropene	96	96	70 - 130	0	30		
1,3-Dichloropropene, Total	96	95	70 - 130	0	30		
Diisopropyl ether	95	97	70 - 130	2	30		
Ethylbenzene	105	108	70 - 130	2	30		

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-60513-1

Lab Control Sample/
Lab Control Sample Duplicate Recovery Report - Batch: 680-178226

Method: 524.2
Preparation: N/A

LCS Lab Sample ID: LCS 680-178226/18
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/24/2010 1023
Date Prepared: N/A

Analysis Batch: 680-178226
Prep Batch: N/A
Units: ug/L

Instrument ID: MSS
Lab File ID: sq389.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

LCSD Lab Sample ID: LCSD 680-178226/19
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/24/2010 1048
Date Prepared: N/A

Analysis Batch: 680-178226
Prep Batch: N/A
Units: ug/L

Instrument ID: MSS
Lab File ID: sq390.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	LCS Qual	LCSD Qual
	LCS	LCSD					
Ethylene Dibromide	103	103	70 - 130	0	30		
Freon 113	97	97	70 - 130	0	30		
Hexachlorobutadiene	113	113	70 - 130	0	30		
2-Hexanone	105	99	70 - 130	7	30		
Isopropylbenzene	108	110	70 - 130	2	30		
4-Isopropyltoluene	96	97	70 - 130	2	30		
Methylene Chloride	95	95	70 - 130	0	30		
2-Butanone (MEK)	102	101	70 - 130	0	30		
4-Methyl-2-pentanone (MIBK)	103	102	70 - 130	1	30		
m-Xylene & p-Xylene	95	97	70 - 130	2	30		
Naphthalene	93	94	70 - 130	1	30		
n-Butylbenzene	96	97	70 - 130	1	30		
N-Propylbenzene	108	109	70 - 130	0	30		
o-Xylene	108	111	70 - 130	2	30		
sec-Butylbenzene	98	99	70 - 130	1	30		
Styrene	109	110	70 - 130	1	30		
Tert-amyl methyl ether	92	92	70 - 130	0	30		
tert-Butyl alcohol	93	90	70 - 130	2	30		
tert-Butylbenzene	113	114	70 - 130	1	30		
Tert-butyl ethyl ether	96	98	70 - 130	1	30		
1,1,1,2-Tetrachloroethane	115	115	70 - 130	0	30		
1,1,2,2-Tetrachloroethane	106	106	70 - 130	0	30		
Tetrachloroethene	102	104	70 - 130	2	30		
Toluene	104	105	70 - 130	1	30		
trans-1,2-Dichloroethene	91	93	70 - 130	2	30		
trans-1,3-Dichloropropene	96	95	70 - 130	2	30		
1,2,3-Trichlorobenzene	110	111	70 - 130	1	30		
1,2,4-Trichlorobenzene	106	109	70 - 130	3	30		
1,1,1-Trichloroethane	97	97	70 - 130	0	30		
1,1,2-Trichloroethane	100	100	70 - 130	0	30		
Trichloroethene	97	97	70 - 130	0	30		
Trichlorofluoromethane	101	101	70 - 130	0	30		
1,2,3-Trichloropropane	103	103	70 - 130	0	30		

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-60513-1

**Lab Control Sample/
Lab Control Sample Duplicate Recovery Report - Batch: 680-178226**

**Method: 524.2
Preparation: N/A**

LCS Lab Sample ID: LCS 680-178226/18
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/24/2010 1023
Date Prepared: N/A

Analysis Batch: 680-178226
Prep Batch: N/A
Units: ug/L

Instrument ID: MSS
Lab File ID: sq389.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

LCSD Lab Sample ID: LCSD 680-178226/19
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/24/2010 1048
Date Prepared: N/A

Analysis Batch: 680-178226
Prep Batch: N/A
Units: ug/L

Instrument ID: MSS
Lab File ID: sq390.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	LCS Qual	LCSD Qual
	LCS	LCSD					
1,2,4-Trimethylbenzene	96	97	70 - 130	1	30		
1,3,5-Trimethylbenzene	95	97	70 - 130	2	30		
Vinyl chloride	103	110	70 - 130	7	30		
Xylenes, Total	99	101	70 - 130	2	30		
Surrogate	LCS % Rec		LCSD % Rec	Acceptance Limits			
4-Bromofluorobenzene	96		101	70 - 130			
1,2-Dichlorobenzene-d4	108		108	70 - 130			

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD

TestAmerica Savannah
5102 LaRoche Avenue
Savannah, GA 31404

Website: www.testamericainc.com
Phone: (912) 354-7858
Fax: (912) 352-0165

Alternate Laboratory Name/Location

Phone:
Fax:

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

PROJECT REFERENCE Black + Necker	PROJECT NO. 02501.004.004.0700	PROJECT LOCATION (STATE) MD	MATRIX TYPE	REQUIRED ANALYSIS	PAGE	OF	
TAL (LAB) PROJECT MANAGER Abbie Yant	P.O. NUMBER	CONTRACT NO.	COMPOSITE (C) OR GRAB (G) INDICATE AQUEOUS (WATER) SOLID OR SEMISOLID AIR NONAQUEOUS LIQUID (OIL, SOLVENT, ...) 5242 (Voc)	PRESERVATIVE	STANDARD REPORT DELIVERY	<input type="radio"/>	
CLIENT (SITE) PM Tom Cornuet	CLIENT PHONE 610.701.3779	CLIENT FAX			DATE DUE	EXPEDITED REPORT DELIVERY (SURCHARGE)	<input type="radio"/>
CLIENT NAME Weston Black + Necker	CLIENT E-MAIL				DATE DUE	NUMBER OF COOLERS SUBMITTED PER SHIPMENT:	
CLIENT ADDRESS							
COMPANY CONTRACTING THIS WORK (if applicable) Weston Solutions							

Page	SAMPLE		SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	SOLID OR SEMISOLID	AIR	NONAQUEOUS LIQUID (OIL, SOLVENT, ...)	NUMBER OF CONTAINERS SUBMITTED										REMARKS			
	DATE	TIME							1	2	3	4	5	6	7	8	9	10		11	12	
8	8/16/10	1730	RFW-20		3				✓													
1		810	RFW-21		3				✓													
1		700	Trip Blank		2				✓													

RELINQUISHED BY: (SIGNATURE) <i>[Signature]</i>	DATE 8/18/10	TIME 1600	RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RELINQUISHED BY: (SIGNATURE)	DATE	TIME
RECEIVED BY: (SIGNATURE) <i>[Signature]</i>	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE) Beth A Daugherty	DATE 8/19/10	TIME 0953	CUSTODY INTACT YES <input type="radio"/> NO <input type="radio"/>	CUSTODY SEAL NO.	SAVANNAH LOG NO. 680-60513	LABORATORY REMARKS Temp 60
--	------------------------	---------------------	---	------------------	--------------------------------------	--------------------------------------



Weston Solutions, Inc.
1400 Weston Way
P.O. Box 2653
West Chester, Pennsylvania 19380
610-701-3000 • Fax 610-701-3186
www.westonsolutions.com

28 October 2010

Mr. Charlie Zeleski
Carroll County Health Department
Bureau of Environmental Health
P.O. Box 845
290 S. Center St.
Westminster, MD 21158

Re: Black & Decker Hampstead Facility

Dear Mr. Zeleski:

On behalf of our client, Black & Decker (U.S.) Inc. (Black & Decker), Weston Solutions, Inc. (WESTON®) provides enclosed with this letter a copy of the Quarterly Groundwater Monitoring Report for the period of July through September 2010.

If you have any questions regarding the enclosure, please contact me at (610) 701-3776.

Very truly yours,

WESTON SOLUTIONS, INC.

A handwritten signature in black ink, appearing to read "Thomas Cornuet".

Thomas Cornuet, P.G.
Project Manager

Enclosure

cc: L. Biagioni, B&D
E. Fernandes, B&D
T. Lynch III, M&S
L. Bove, WESTON (w/o encl.)





Weston Solutions, Inc.
1400 Weston Way
P.O. Box 2653
West Chester, Pennsylvania 19380
610-701-3000 • Fax 610-701-3186
www.westonsolutions.com

28 October 2010

Mr. Arthur O'Connell
Waste Management Administration
Maryland Department of the Environment
1800 Washington Blvd
Baltimore, MD 21230

Re: Black & Decker Hampstead Facility

Dear Mr. O'Connell

On behalf of our client, Black & Decker (U.S.) Inc. (Black & Decker), Weston Solutions, Inc. (WESTON®) provides enclosed with this letter two copies of the Quarterly Groundwater Monitoring Report for the period of July through September 2010. This report has been drafted for your review pursuant to the Administrative Consent Order of 13 April 1995.

If you have any questions regarding the enclosure, please contact me at (610) 701-3776.

Very truly yours,

WESTON SOLUTIONS, INC.

A handwritten signature in black ink, appearing to read "Thomas Cornuet".

Thomas Cornuet, P.G.
Project Manager

Enclosure

cc: L. Biagioni, B&D
E. Fernandes, B&D
T. Lynch III, M&S
K. Decker, Town of Hampstead
L. Bove, WESTON (w/o encl.)
B. Dietz, MDE (w/o encl.)

an employee-owned company

H:\Folders.A-FB&D-Hampstead 2006-2010\07 Reports\2010\3rdQ_2010gwmr\OConnell.doc

