

Quarterly Groundwater Monitoring Report

Prepared for

Black & Decker (U.S.) Inc.

Hampstead, Maryland

October 2015

Prepared by

WESTON SOLUTIONS, INC.

West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 3rd Quarter 2015	2-2
Table 2-2 Groundwater Elevation Data – 3rd Quarter 2015.....	2-3
Table 2-3 Effluent Characteristics Summary – 3rd Quarter 2015.....	2-4
Table 2-4 Summary of Groundwater Analytical Results - August 2015.....	2-5
Table 3-1 Treatment System Maintenance Activities – 3rd Quarter 2015	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of July through September 2015.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of July through September 2015, the extraction wells were pumping at an average combined rate of approximately 168 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of July through September 2015 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of July through September 2015, approximately 11.18 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (70.9 %) and tetrachloroethene (PCE) (29.1 %). Analytical results of the groundwater collected from the air stripper for the period of July through September 2015 are included in Appendix C.

A summary of the analytical results from the third quarter (August 2015) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

How was this calculated?

Table 2-1
Treatment System Pumping Records - 3rd Quarter 2015
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
July 2015	7,493,698
August 2015	7,294,872
September 2015	6,774,554

Table 2-2
Groundwater Elevation Data - 3rd Quarter 2015
Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV.	TOTAL DEPTH	7/25/2015		8/26/2015		9/19/2015	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NC	DRY	NC	DRY	NC
EW-2	849.21	110	81.95	767.26	82.89	766.32	82.42	766.79
EW-3	846.64	118	85.26	761.38	86.33	760.31	85.86	760.78
EW-4	858.01	97.5	PC	NC	PC	NC	PC	NC
EW-5	864.17	98	91.57	772.60	92.56	771.61	92.67	771.50
EW-6	831.98	115	103.00	728.98	103.00	728.98	103.00	728.98
EW-7	818.38	78	86.30	732.08	86.25	732.13	86.84	731.54
EW-8	811.13	98	91.09	720.04	91.45	719.68	91.50	719.63
EW-9	811.35	141	103.00	708.35	103.00	708.35	102.50	708.85
EW-10	807.74	INA	54.96	752.78	55.26	752.48	57.17	750.57
RFW-1A	864.37	78	51.26	813.11	51.43	812.94	51.22	813.15
RFW-1B	864.23	200	51.29	812.94	51.45	812.78	51.18	813.05
RFW-2A	857.41	35	16.89	840.52	17.67	839.74	17.43	839.98
RFW-2B	857.73	75	17.15	840.58	18.28	839.45	18.24	839.49
RFW-3B	839.21	153	33.86	805.35	34.44	804.77	33.95	805.26
RFW-4A	830.37	62	36.52	793.85	37.56	792.81	37.24	793.13
RFW-4B	830.37	120	36.49	793.88	37.42	792.95	37.11	793.26
RFW-5A	817.50	30	DRY	NC	DRY	NC	DRY	NC
RFW-6	785.04	120	3.56	781.48	3.46	781.58	3.29	781.75
RFW-7	805.14	29	7.35	797.79	6.59	798.55	6.24	798.90
RFW-8	860.07	56	DRY	NC	DRY	NC	DRY	NC
RFW-9	862.02	49	26.59	835.43	27.81	834.21	27.43	834.59
RFW-10	852.06	58	DRY	NC	DRY	NC	DRY	NC
RFW-11A	849.32	72	Damaged	NC	Damaged	NC	Damaged	NC
RFW-11B	849.62	116	62.32	787.30	63.52	786.10	62.59	787.03
RFW-12B	844.87	264	49.98	794.89	50.22	794.65	50.29	794.58
RFW-13	849.11	150	63.57	785.54	63.90	785.21	63.81	785.30
RFW-14B	812.39	281	52.81	759.58	52.98	759.41	53.46	758.93
RFW-16	856.14	41	DRY	NC	DRY	NC	DRY	NC
RFW-17	834.66	60.5	24.86	809.80	25.86	808.80	25.42	809.24
RFW-20	842.49	142	34.56	807.93	34.80	807.69	34.91	807.58
RFW-21	832.65	102	21.99	810.66	22.48	810.17	22.56	810.09
PH-7	805.94	89	29.61	776.33	29.65	776.29	30.45	775.49
PH-9	814.94	98	50.56	764.38	51.24	763.70	44.75	770.19
PH-11	820.68	78	51.48	769.20	52.09	768.59	47.26	773.42
PH-12	828.35	87	49.58	778.77	50.86	777.49	49.28	779.07
B-3	803.02	83	10.11	792.91	10.05	792.97	10.49	792.53
Amoco	842.29	INA	NA	NC	NA	NC	NA	NC
Hamp. Town #22	804.96	INA	1.19	803.77	1.24	803.72	1.19	803.77
Pembroke #1	INA	INA	10.89	NC	11.02	NC	10.56	NC
Pembroke #2	INA	INA	Damaged	NC	Damaged	NC	Damaged	NC
N. Houcks. Rd.	INA	INA	10.56	NC	10.95	NC	10.73	NC
E. Century St.	INA	INA	19.27	NC	19.24	NC	19.24	NC
Lwr. Beckleys. Rd.	INA	INA	54.86	NC	55.42	NC	55.51	NC

NA - Not Available/Not Accessible

NC - Not Calculable

INA - Information not available

PC - Pump Cycles

**Table 2-3
Effluent Characteristics Summary - 3rd Quarter 2015
Black & Decker
Hampstead, Maryland**

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				July 2015	August 2015	September 2015	
001	FLOW	average	MGD	NA	0.225	0.122	0.193
		maximum	MGD	NA	0.772	0.439	0.831
	1,1,1-Trichloroethane		ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene		ug/l	5	< 1	< 1	< 1
	Trichloroethylene		ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	91	< 5	< 5
		monthly average	mg/l	10	91	< 5	< 5
	pH	minimum	STD	6.0	7.1	7.1	7.2
		maximum	STD	8.5	8.0	8.0	7.6
BOD		mg/l	15	9.0	4.0	0	
TSS	maximum	mg/l	30	0	10	10	
	monthly average	mg/l	20	0	10	10	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.129	0.120	0.058
		maximum	MGD	NA	0.194	0.246	0.298
	Fecal Coliform		MPN/100ml	200	101	1.0	1.0
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.234
		maximum	MGD	NA	NR	NR	0.289
	1,1,1-Trichloroethane		ug/l	NA	NR	NR	< 1
	Tetrachloroethylene		ug/l	NA	NR	NR	< 1
	Trichloroethylene		ug/l	NA	NR	NR	< 1

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

Table 2-4
Summary of Groundwater Analytical Results - August 2015
Black & Decker
Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1.2	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	5 U	8.3	9.1	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	0.9 J	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	1.6	3.9	1 U	1 U	4.5	26	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	0.34 J	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	160	28	320	85	5	2.8	6.5	0.5 J	0.5	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	52	1.2	9.3	1.9	10	7.4	72	94	99	1.5
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	0.5	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value

NS = Not Sampled

Table 2-4
Summary of Groundwater Analytical Results - August 2015
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	2 U	2 U	2 U	2 U	2 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5.7	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	0.6 J	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	0.6 J	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	1.4	1 U	1 U	3.1	NS	1 U	1 U	NS	14	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	20	20	29	NS	0.9	1.5	NS	7.8	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	13	13	56	NS	1 U	1 U	NS	4.2	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicate sample U = Compound was analyzed for but not detected Value shown is the method detection limit for quantification.
NS = Not sampled J = Indicates an estimated value.

Table 2-4
Summary of Groundwater Analytical Results - August 2015
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	USEPA drinking water method 524.2				
												RFW-20	RFW-21	Town #22	Town #23	Trip Blank
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	1 U	2 U	2 U	NS	2 U	ABD	ABD	ABD	2 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	NA	NA	NA	NA	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	1.3	0.9 J	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.3 J	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trichloroethene	ug/L	NS	2.4	34	2.4	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	0.6	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	1 U	6.9	14	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.3 J	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division. Samples from all of the other wells are analyzed with USEPA Method 8260.
NS = Not sampled
U = Compound was analyzed but not detected
ABD = Well has been abandoned
RFW -20 was not sampled because it was damaged. The well is now repaired and will be sampled during the 4th quarter.

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells EW-2 and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from wells RFW-4B & EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (July through September 2015) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 3rd Quarter 2015
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Sep-15	A temporary power outage at the facility caused the system to shut down. System was restarted, all wells back on line.
Sep-15	EW-10 was off due to flooding caused by heavy rain. Well was reset and is back on line.

4. RECOMMENDATIONS

For the reporting period of July through September 2015, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

(Is A GW contour map supposed to be included in this rpt. ?)

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(JULY – SEPTEMBER 2015)

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group (MD0001881)
Address: 627 Hanover Pike, Hamstead Maryland
Additional Op's & cert # - Anthony Phillips 3001 Ryan Thomas 0781, Keith white 4609, Chris Dallas 6202, Dorrance Jones 0763

Superintendent: Earle Villarrea Certification # 1017

Month: July
Year: 2015

Date	Appearance	Discharge MGD	pH	Cl2 mg/l	Final Effluent outfall 001										Outfall 101					Outfall 201			Operator					
					Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	TKN mg/l	N+N mg/l	TP mg/l	TN mg/l	O&G mg/l	eColi mpn	Flow MGD	eColi mpn	Basin inches	Alum Gpd	Hypochlorite Opd	Pos Cl2 mg/l	Tetrachloroethylene ug/l		1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	Discharge mgd		
1	Clear	0.18800														0.156000		0"	5.0	1.0	5.0					0.255211	KW	
2	Clear	0.14100	7.97	0.00												0.138000		0"	5.0	1.0	5.0					0.219807	CD	
3	Clear	0.14600	7.42	0.00												0.045000		0"	5.0	1.0	5.0					0.245108	CD	
4	Clear	0.13800														0.194000		0"	5.0	1.0	5.0					0.249132	RT	
5	Clear	0.17900														0.159000		0"	5.0	1.0	5.0					0.234529	RT	
6	Clear	0.15600														0.171000		0"	5.0	1.0	5.0					0.261785	RT	
7	Clear	0.59100	7.84	0.00												0.139000	<1	0"	5.0	1.0	5.0					0.243127	RT	
8	Clear	0.16100														0.132000		0"	5.0	1.0	5.0					0.235494	KW	
9	Clear	0.23400	7.07	0.00												0.138000		0"	5.0	1.0	5.0					0.244141	KW	
10	Clear	0.52100														0.149000		0"	5.0	1.0	5.0					0.244984	KW	
11	Clear	0.15800														0.133000		0"	5.0	1.0	5.0					0.251431	DJ	
12	Clear	0.12400														0.117000		0"	5.0	1.0	5.0					0.239914	DJ	
13	Clear	0.10200														0.099000		0"	5.0	1.0	5.0					0.201444	KW	
14	Clear	0.17100	7.33	0.00	<1	<1	<1	9.00	<4	0.886	0.712	0.0634	1.6	91.0	<1	0.119000	101.30	0"	5.0	1.0	5.0	<1	<1	<1		0.276582	KW	
15	Clear	0.32400	7.20	0.00												0.120000		0"	5.0	1.0	5.0					0.223803	KW	
16	Clear	0.77200														0.167000		0"	5.0	1.0	5.0					0.259010	CD	
17	Clear	0.49200														0.013900		0"	5.0	1.0	5.0					0.204078	KW	
18	Clear	0.14000														0.176000		0"	5.0	1.0	5.0					0.269730	KW	
19	Clear	0.19300														0.136000		0"	5.0	1.0	5.0					0.235010	KW	
20	Clear	0.16300	7.14	0.00												0.128000		0"	5.0	1.0	5.0					0.248246	AP	
21	Clear	0.11200	7.22	0.00												0.109000	<1	0"	5.0	1.0	5.0					0.230595	AP	
22	Clear	0.14600														0.126000		0"	5.0	1.0	5.0					0.252922	KW	
23	Clear	0.11000														0.139000		0"	5.0	1.0	5.0					0.234938	KW	
24	Clear	0.11200														0.145000		0"	5.0	1.0	5.0					0.248993	KW	
25	Clear	0.09800														0.126000		0"	5.0	1.0	5.0					0.235839	RT	
26	Clear	0.12000														0.124000		0"	5.0	1.0	5.0					0.236064	RT	
27	Clear	0.41700														0.119000		0"	5.0	1.0	5.0					0.247594	AP	
28	Clear	0.17200	7.52	0.00												0.125000	<1	0"	5.0	1.0	5.0					0.245850	AP	
29	Clear	0.12300	7.45	0.00												0.106000		0"	5.0	1.0	5.0					0.239831	AP	
30	Clear	0.13800														0.117000		0"	5.0	1.0	5.0					0.237695	RT	
31	Clear	0.31700														0.133000		0"	5.0	1.0	5.0					0.240811	RT	
Total		6.95900														3.998900											7.493698	
Average		0.22448		<0.10	0	0	0	9	0	1	1	0	2	91	1	0.128997	3.2	0.0	5.0	1.0	5.0	0.0	0.0	0.0		0.241732		
Minimum		0.09800	7.1	0.00	0	0	0	9	0	1	1	0	2	91		0.013900	0.0	0.0	5.0	1.0	5.0	0.0	0.0	0.0		0.201444	MOR	
Maximum		0.77200	8.0	<0.10	0	0	0	9	0	1	1	0	2	91		0.194000	101	0.0	5.0	1.0	5.0	0.0	0.0	0.0		0.276582	8/20/2015	

**APPENDIX B
DISCHARGE MONITORING REPORTS
(JULY - SEPTEMBER 2015)**

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 Name BTR Hampstead, Inc
 Address c/o BTR Captial Group Management
 222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)

MD0001881 001
 PERMIT NUMBER DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires

Facility Groundwater Remediation and WWTP
 Location 626 Hanover Pike
 Attn.

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
FROM 15	07	01	TO	15	07	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form

State Discharge Permit
 07-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	9	(19)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/MONTH	GRAB
pH 00400 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	7.1	*****	8.0	(12)	0	TWICE/WEEK	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	DAILY MN	*****	8.5 DAILY MX	SU		TWICE/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	SAMPLE MEASUREMENT	*****	0	Lbs/day	*****	0	0	(19)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/MONTH	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 1 0	SAMPLE MEASUREMENT	*****	0	Lbs/mo	*****	*****	*****	****	0	ONCE/MONTH	Calculated
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/MONTH	Calculated
SOLIDS, TOTAL SUSPENDED 00530 1 2 0	SAMPLE MEASUREMENT	*****	2,612	Lbs/yr	*****	*****	*****	****	0	ONCE/MONTH	Calculated
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/MONTH	Calculated
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	91	91	(19)	2	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10 30DA AVG	15 DAILY MX	MG/L		ONCE/MONTH	GRAB
NITROGEN, TOTAL (AS N) 00600 1 0 0	SAMPLE MEASUREMENT	*****	2	Lbs/day	*****	2	2	(19)	0	ONCE/MONTH	COMP -8
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	Req. Mon. DAILY MX	MG/L		ONCE/MONTH	COMP -8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUES IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 881001 AND 33 U.S.C. 881319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
Nicole Finneyfrack Property Manager TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN	410 AREA CODE	729-8350 NUMBER	15 YEAR	08 MONTH

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDE

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name BTR Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address c/o BTR Captial Group Management

MD0001881

001

Approval expires

222 Courthouse Ct., Suite 300, Towson MD 21204

PERMIT NUMBER

DISCHARGE NUMBER

*** NO DISCHARGE ***

Facility Groundwater Remediation and WWTP

MONITORING PERIOD

NOTE: Read instructions before completing this form

Location 626 Hanover Pike

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	15	07	01		15	07	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

07-DP-0022

Attn:

PARAMETER (32-37)		QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)			
NITROGEN, TOTAL (AS N) 00600 1 1 0	SAMPLE MEASUREMENT	*****	93	Lbs/mo	*****	*****	*****	0	ONCE/ MONTH	Calculated
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****		ONCE/ MONTH	Calculated
NITROGEN, TOTAL (AS N) 00600 1 2 0	SAMPLE MEASUREMENT	*****	1,197	Lbs/yr	*****	*****	*****	0	ONCE/ MONTH	Calculated
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****		ONCE/ MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 0 0	SAMPLE MEASUREMENT	*****	0	Lbs/day	*****	0	0	0	ONCE/ MONTH	COMP -8
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	DAILY MX		ONCE/ MONTH	COMP -8
PHOSPHOROUS, TOTAL (AS P) 00665 1 1 0	SAMPLE MEASUREMENT	*****	3	Lbs/mo	*****	*****	*****	0	ONCE/ MONTH	Calculated
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****		ONCE/ MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 2 0	SAMPLE MEASUREMENT	*****	23	Lbs/yr	*****	*****	*****	0	ONCE/ MONTH	Calculated
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****		ONCE/ MONTH	Calculated
TETRACHLOROETHYLE 34475 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5		ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5		ONCE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Nicole Finneyrock Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410	729-8350	15	08	20
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 Name BTR Hampstead, Inc.
 Address c/o BTR Capital Group Management
 222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)

MD0001881 001
 PERMIT NUMBER DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires

*** NO DISCHARGE ***

Facility Groundwater Remediation and WWTP
 Location 626 Hanover Pike
 Attn:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 15	07	01	TO 15	07	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form
 State Discharge Permit
 07-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.2245	0.7720	(03)	*****	*****	*****	****	0	ONCE/MONTH	Measured
50050 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	MGD	*****	*****	*****	****		ONCE/MONTH	Measured
EFFLUENT GROSS VALUE											
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/MONTH	GRAB
50060 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	0.011	0.019	MG/L		ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE						30DA AVG	DAILY MX				
E. COLI, MPN	SAMPLE MEASUREMENT	*****	*****	****	*****	1	*****	(30)	0	ONCE/MONTH	GRAB
51040 1 0 1	PERMIT REQUIREMENT	*****	*****	****	*****	Req. Mon. GEO MEAN	*****	MPN		ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE											
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
78391 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L		ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE							DAILY MX				
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TI Nicole Finneyrock Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			410	729-8350	15	08	20
			AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 Name BTR Hampstead, Inc
 Address c/o BTR Captial Group Management
 222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)

MD0001881	101
PERMIT NUMBER	DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Groundwater Remediation and WWTP
 Location 626 Hanover Pike
 Attn:

State Discharge Permit
 07-DP-0022

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 15	07	01	TO 15	07	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (54-61)	MAXIMUM	UNITS	MINIMUM (54-61)	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	128,997	194,000	(07)	*****	*****	*****	****	0	ONCE/WEEK	Measured/Recorded
50050 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/MONTH	Measured/Recorded
E.COLI, MPN	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	101	(30)	0	ONCE/WEEK	GRAB
51040 1 0 1	PERMIT REQUIREMENT	*****	*****	****	*****	*****	126	MPN		ONCE/WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §§1001 AND 33 U.S.C. §§ 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
Nicole Finneyfrock Property Manager TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	410	729-8350	15	08
		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name **BTR Hampstead, Inc**

Address **c/o BTR Captial Group Management**

222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility **Groundwater Remediation and WWTP**

Location **626 Hanover Pike**

Attn:

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	15	08	01		15	08	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

07-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	4	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	****	7.1	*****	8.0	(12)	0	TWICE/ WEEK	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****		*****	8.5 DAILY MX	SU		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	SAMPLE MEASUREMENT	*****	15	Lbs/day	*****	10	10	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 1 0	SAMPLE MEASUREMENT	*****	329	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
SOLIDS, TOTAL SUSPENDED 00530 1 2 0	SAMPLE MEASUREMENT	*****	2,941	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10 30DA AVG	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
NITROGEN, TOTAL (AS N) 00600 1 0 0	SAMPLE MEASUREMENT	*****	5	Lbs/day	*****	3	3	(19)	0	ONCE/ MONTH	COMP -8
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	Req. Mon. DAILY MX	MG/L		ONCE/ MONTH	COMP -8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Nicole Finneyrock Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	410	729-8350	15	09
		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name BTR Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address c/o BTR Captial Group Management

MD0001881

001

Approval expires

222 Courthouse Ct., Suite 300, Towson MD 21204

PERMIT NUMBER

DISCHARGE NUMBER

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

State Discharge Permit

Attn.

07-DP-0022

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
15	08	01	15	08	31
FROM		TO			
(20-21)		(22-23)		(24-25)	
		(26-27)		(28-29)	
				(30-31)	

PARAMETER (32-37)		QUANTITY OR LOADING (54-61)			QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (46-53)	AVERAGE (54-61)	MAXIMUM (54-61)			
NITROGEN, TOTAL (AS N) 00600 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	103	Lbs/mo	*****	*****	*****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****	ONCE/ MONTH	Calculated
NITROGEN, TOTAL (AS N) 00600 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	1,300	Lbs/yr	*****	*****	*****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****	ONCE/ MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/day	*****	0	0	(19)	ONCE/ MONTH	COMP -8
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	DAILY MX	MG/L	ONCE/ MONTH	COMP -8
PHOSPHOROUS, TOTAL (AS P) 00665 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	4	Lbs/mo	*****	*****	*****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****	ONCE/ MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	27	Lbs/yr	*****	*****	*****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****	ONCE/ MONTH	Calculated
TETRACHLOROETHYLE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L	ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L	ONCE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Nicole Finneyfrock Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUES IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 351001 AND 33 U.S.C. 35 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410	729-8350	15	09	21
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 Name BTR Hampstead, Inc
 Address c/o BTR Capital Group Management
222 Courthouse Cl. Suite 300 Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)

MD0001881	001
PERMIT NUMBER	DISCHARGE NUMBER


Form Approved.
 OMB No.
 Approval expires

*** NO DISCHARGE ***

Facility Groundwater Remediation and WWTP
 Location 626 Hanover Pike
 Attn:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
15	08	01	15	08	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form
 State Discharge Permit
 07-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (38-45)				NO. EX (52-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0.1223	0.4390	(03)	*****	*****	*****	****	0	ONCE/ MONTH	Measured	
	PERMIT REQUIREMENT	REPORT	REPORT	MGD	*****	*****	*****	****		ONCE/ MONTH	Measured	
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L		ONCE/ MONTH	GRAB	
E.COLI, MPN 51040 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	8	*****	(30)	0	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	Req. Mon. GEO MEAN	*****	MPN		ONCE/ MONTH	GRAB	
TRICHLOROETHENE 78391 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TI	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 881001 AND 33 U.S.C. 881319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)							TELEPHONE		DATE		
Nicole Finneyrock Property Manager								410	729-8350	15	09	21
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MONTH	DAY

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name BTR Hampstead, Inc

Address c/o BTR Captial Group Management

222 Courthouse Ct., Suite 300, Towson MD 21204

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881
PERMIT NUMBER

101
DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 15	08	01	TO	15	08	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit
07-DP-0022

PARAMETER (32-37)		(3 Card Only)			(4 Card Only)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		QUANTITY OR LOADING (46-53)	QUANTITY OR LOADING (54-61)	UNITS	QUALITY OR CONCENTRATION (38-45)	QUALITY OR CONCENTRATION (46-53)	QUALITY OR CONCENTRATION (54-61)				
		AVERAGE	MAXIMUM		MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	119,742	246,000	(07)	*****	*****	*****	****	0	ONCE/WEEK	Measured/Recorded
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/MONTH	Measured/Recorded
E. COLI, MPN 51040 1 0 1	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/WEEK	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	126 DAILY MX	MPN		ONCE/WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §§1001 AND 33 U.S.C. §§ 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND/OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
Nicole Finneyfrock Property Manager		410	729-8350	15	09	21
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN	AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 Name BTR Hampstead, Inc
 Address c/o BTR Capital Group Management
 222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16)
 MD0001881
 PERMIT NUMBER
 001
 DISCHARGE NUMBER

Facility Groundwater Remediation and WWTP
 Location 626 Hanover Pike
 Altir

MONITORING PERIOD
 YEAR MO DAY YEAR MO DAY
 FROM 15 09 01 TO 15 09 30
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

Form Approved.
 OMB No.
 Approval expires
 State Discharge Permit
 07-DP-0022

PARAMETER (32-37)	QUANTITY OR LOADING (45-53)			QUALITY OR CONCENTRATION (46-53)			NO. EX (52-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE (45-53)	MAXIMUM (54-61)	MINIMUM (58-65)	AVERAGE (46-53)	MAXIMUM (54-61)	MINIMUM (58-65)			
BOD, 5-DAY (20 DEG. C)	MEASUREMENT	*****	*****	*****	0	(-9)	0	ONCE/ MONTH	GRAB
00310 1 0 0	PERMIT	*****	*****	*****	15	DAILY MX		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	MEASUREMENT	*****	*****	*****	7.6	(12)	0	TWICE/ WEEK	GRAB
pH	PERMIT	*****	*****	*****	8.5	SU	0	TWICE/ WEEK	GRAB
00400 1 0 0	MEASUREMENT	*****	*****	*****	10	(13)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT	*****	*****	*****	30	DAILY MX		ONCE/ MONTH	GRAB
SOLIDS, TOTAL	MEASUREMENT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
SUSPENDED	PERMIT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
00530 1 0 0	MEASUREMENT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
EFFLUENT GROSS VALUE	PERMIT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
SOLIDS, TOTAL	MEASUREMENT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
SUSPENDED	PERMIT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
00530 1 1 0	MEASUREMENT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
EFFLUENT GROSS VALUE	PERMIT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
SOLIDS, TOTAL	MEASUREMENT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
SUSPENDED	PERMIT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
00530 1 2 0	MEASUREMENT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
EFFLUENT GROSS VALUE	PERMIT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
OIL AND GREASE	MEASUREMENT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	GRAB
TOTAL RECOVERABLE	PERMIT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	GRAB
70030 1 0 0	MEASUREMENT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	COMP -8
NITROGEN	MEASUREMENT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	COMP -8
TOTAL (AS N)	PERMIT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	COMP -8
00600 1 0 0	MEASUREMENT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	COMP -8
EFFLUENT GROSS VALUE	PERMIT	*****	*****	*****	*****	*****	0	ONCE/ MONTH	COMP -8

TELEPHONE
 AREA CODE NUMBER YEAR MONTH DAY
 410 729-8350 15 10 23

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER
 OFFICER OR AUTHORIZED AGENT

PERMITTEE NAME/ADDRESS (include Facility Name/Location if different)

Name: BTR Hampstead, Inc.
 Address: c/o BTR Capital Group Management
 222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Form Approved.
 OMB No. 07-DP-0022
 Approval expires

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

Facility: Groundwater Remediation and WWTP
 Location: 526 Hanover Pike
 Attn:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
15	09	01	15	09	30

State Discharge Permit
 07-DP-0022

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

PARAMETER (32-37)	3 Card Only (45-53)		4 Card Only (54-61)		QUANTITY OR LOADING (54-61)		QUALITY OR CONCENTRATION (45-53)		MAXIMUM (54-61)	UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	MINIMUM	MAXIMUM	AVERAGE	MINIMUM							
NITROGEN, TOTAL (AS N)	MEASUREMENT	94	Lbs/mo						*****	****	0	ONCE/ MONTH	Calculated
00600 1 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	Req. Mon. MO TOTAL							*****	*****		ONCE/ MONTH	Calculated
NITROGEN, TOTAL (AS N)	MEASUREMENT	1,394	Lbs/yr						*****	*****	0	ONCE/ MONTH	Calculated
00600 1 2 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	Req. Mon. CUM TOTAL							*****	*****		ONCE/ MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P)	MEASUREMENT	0	Lbs/day						*****	(19)	0	ONCE/ MONTH	COMP -8
00655 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	Req. Mon. MO MAX							*****	MG/L		ONCE/ MONTH	COMP -8
PHOSPHOROUS, TOTAL (AS P)	MEASUREMENT	0	Lbs/mo						*****	*****	0	ONCE/ MONTH	Calculated
00665 1 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	Req. Mon. MO TOTAL							*****	*****		ONCE/ MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P)	MEASUREMENT	27	Lbs/yr						*****	*****	0	ONCE/ MONTH	Calculated
00665 1 2 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	Req. Mon. CUM TOTAL							*****	*****		ONCE/ MONTH	Calculated
TETRACHLOROETHYLE	MEASUREMENT								*****	(28)	0	ONCE/ MONTH	GRAB
34475 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT								*****	UG/L		ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE	MEASUREMENT								*****	(28)	0	ONCE/ MONTH	GRAB
34506 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT								*****	UG/L		ONCE/ MONTH	GRAB

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN

NAME/TITLE: Nicole Finneyfrock
 Property Manager
 TYPED OR PRINTED

410
 AREA CODE

729-8350
 NUMBER

15
 YEAR

10
 MONTH

23
 DAY

TELEPHONE

DATE

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PREVIOUS EDITIONS MAY BE USED.

REPLACES EPA FORM 1-40 WHICH MAY NOT BE USED.

PERMITTEE NAME/ADDRESS (Include Facility Name if location is different)
 Name BTR Hampstead, Inc
 Address c/o BTR Capital Group Management
 222 Courthouse Cl., Suite 300, Towson, MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 (17-1-3)
 MD0007881 PERMIT NUMBER
 001 DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires

*** NO DISCHARGE ***

Facility Groundwater Remediation and WWTP
 Location 626 Hanover Pike
 Aftn:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
15	09	01	15	09	30
FROM (20-21) (22-23) (24-25)			TO (26-27) (28-29) (30-31)		

NOTE: Read instructions before completing this form
 State Discharge Permit
 07-DP-0022

PARAMETER (32-37)	QUANTITY OR LOADING (46-53)		QUALITY OR CONCENTRATION (46-53)		UNITS (54-61)	MAXIMUM (54-61)	NO. EX (62-63)	FREQUENCY OF ANALYSIS (54-68)	SAMPLE TYPE (69-70)
	AVERAGE (46-53)	MAXIMUM (46-53)	AVERAGE (46-53)	MINIMUM (38-41)					
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0.1932	0.8310	REPORT	REPORT	(03)	MGD	0	ONCE/ MONTH	Measured
EFFLUENT GROSS VALUE	REPORT	REPORT	REPORT	REPORT	REPORT	REPORT	0	ONCE/ MONTH	Measured
CHLORINE, TOTAL RESIDUAL	*****	*****	*****	*****	*****	<0.1	0	ONCE/ MONTH	GRAB
50060 1 0 0	*****	*****	*****	*****	*****	0.019	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	*****	*****	30DA AVG	DAILY MX	*****	MG/L	0	ONCE/ MONTH	GRAB
E. COLI, MPN	*****	*****	3	*****	*****	(30)	0	ONCE/ MONTH	GRAB
51040 1 0 1	*****	*****	Req. Mon. GEO MEAN	*****	*****	MPN	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	0	0	ONCE/ MONTH	GRAB
TRICHLOROETHENE	*****	*****	*****	*****	*****	(28)	0	ONCE/ MONTH	GRAB
78381 1 0 0	*****	*****	*****	*****	*****	5	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	*****	*****	DAILY MX	DAILY MX	*****	UG/L	0	ONCE/ MONTH	GRAB
SAMPLE MEASUREMENT PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****	*****	*****
SAMPLE MEASUREMENT PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****	*****	*****
SAMPLE MEASUREMENT PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****	*****	*****
SAMPLE MEASUREMENT PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****	*****	*****
SAMPLE MEASUREMENT PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****	*****	*****
SAMPLE MEASUREMENT PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****	*****	*****
SAMPLE MEASUREMENT PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****	*****	*****
SAMPLE MEASUREMENT PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****	*****	*****
NAME/TI	Nicole Finneyfrock		PROPERTY OF PRINCIPAL EXECUTIVE		TELEPHONE		DATE		
	Property Manager		OFFICER OR AUTHORIZED AGEN		410 729-8350		15 10 23		
	TYPED OR PRINTED				AREA CODE NUMBER YEAR MONTH DAY				

33 U.S.C. 1319 (b)(1) (B) PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$19,000 AND/OR IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.
 COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 (REPLACES EPA FORM 3320-1 (Rev. 8/95) Previous editions may be used.)
 EPA Form 3320-1 (Rev. 8/95) (REPLACES EPA FORM 3320-1 WHICH MAY NOT BE USED.) PAGE 3 OF 3

PERMITTEE NAME/ADDRESS (include facility Name/Location if different)
 Name BTR Hampslead, Inc
 Address c/o BTR Capital Group Management
 222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16)

MD0001881
PERMIT NUMBER

201
 DISCHARGE NUMBER

Facility Groundwater Remediation and WWTP
 Location 626 Hanover Pike
 Atn:

MONITORING PERIOD			
YEAR	MO	DAY	TO
15	07	01	15 09 30

Form Approved, OMS No. Approval expires
 State Discharge Permit
 07-DP-0022

PARAMETER (32-37)	QUANTITY OR LOADING (46-53)		UNITS		QUALITY OR CONCENTRATION (46-53)		AVERAGE (46-53)	MINIMUM (38-41)	MAXIMUM (54-61)	UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE (46-53)	MAXIMUM (54-61)	MINIMUM (38-41)	MAXIMUM (54-61)									
TETRACHLOROETHYLENE	MEASUREMENT	*****	*****	*****	*****	*****	0	*****	0	(28)	0	One/Quarter	Grab
34475 1 0 0	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	REPORT	*****	REPORT	UG/L	0	One/Quarter	Grab
EFFLUENT GROSS VALUE	MEASUREMENT	*****	*****	*****	*****	*****	0	*****	0	(28)	0	One/Quarter	Grab
1,1,1-TRICHLOROETHANE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	REPORT	*****	REPORT	UG/L	0	One/Quarter	Grab
34506 1 0 0	MEASUREMENT	*****	*****	*****	*****	*****	0	*****	0	(28)	0	One/Quarter	Grab
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	REPORT	*****	REPORT	UG/L	0	One/Quarter	Grab
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MEASUREMENT	234,382	288,659	(07)	*****	*****	*****	*****	*****	*****	0	Measured	Record
50050 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	*****	*****	*****	0	Measured	Record
EFFLUENT GROSS VALUE	MEASUREMENT	*****	*****	*****	*****	*****	0	*****	0	(28)	0	One/Quarter	Grab
Total Volatile Organics (VOC)	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	REPORT	*****	REPORT	UG/L	0	One/Quarter	Grab
51415 1 0 0	MEASUREMENT	*****	*****	*****	*****	*****	0	*****	0	(28)	0	One/Quarter	Grab
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	REPORT	*****	REPORT	UG/L	0	One/Quarter	Grab
TRICHLOROETHENE	MEASUREMENT	*****	*****	*****	*****	*****	0	*****	0	(28)	0	One/Quarter	Grab
78391 1 0 0	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	REPORT	*****	REPORT	UG/L	0	One/Quarter	Grab
EFFLUENT GROSS VALUE	MEASUREMENT	*****	*****	*****	*****	*****	0	*****	0	(28)	0	One/Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	REPORT	*****	REPORT	UG/L	0	One/Quarter	Grab
	MEASUREMENT	*****	*****	*****	*****	*****	0	*****	0	(28)	0	One/Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	REPORT	*****	REPORT	UG/L	0	One/Quarter	Grab

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN
 410 AREA CODE
 729-6350 NUMBER
 15 YEAR
 10 MONTH
 23 DAY

1. CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY OWN KNOWLEDGE AND BELIEFS, I AM RESPONSIBLE FOR THE ACCURACY AND COMPLETENESS OF THE INFORMATION. SIGNATURE PENALTIES FOR SUBMITTING FALSE INFORMATION: (1) FINE UP TO \$10,000 AND/OR IMPRISONMENT UP TO 3 YEARS; (2) FINE UP TO \$10,000 AND/OR IMPRISONMENT OF BETWEEN 6 MONTHS AND 3 YEARS.

COMMENT AND EXPANDED ANY VIOLATIONS (Reference all attachments here):

PREVIOUS EDITIONS MAY BE USED. (REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PAGE 1 OF 1

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(JULY - SEPTEMBER 2015)

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE B
 259 NAJOLLES ROAD
 RE: BTR HAMPSTEAD WWTP
 MILLERSVILLE, MD 21108

Order Number: L5653508
 Project Name: BTR HAMPSTEAD WWTP
 Receive Date: 07-14-2015
 Client Code: MES_A
 Project Location: BTR HAMPSTEAD WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
 Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID	Sample Description	Samp. Date/Time/Temp	Sampled by
L5653508-1	BTR 001 GRAB	07/14/15 09:02am NA C	Customer

Satellite Received Temp 2.2 C Iced (Y/N): Y
 Received Date/Time/Temp 07/14/15 04:30pm 2.9 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
GENERAL CHEMISTRY							
Hexane Ext. Material-HEM (oil+grease)	91.0	5.00	mg/l	1664B HEM	1		07/22/15 11:30AM JEM
Total Suspended Solids (Delaware)	ND	4.00	mg/l	SM 2540D	4		07/21/15 11:25AM MS3
Biochemical Oxygen Demand, 5 Day (DE)	9.00	3.00	mg/l	SM 5210B	3		07/15/15 10:45AM SKJ
GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES							
1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		07/21/15 05:21PM JAD
Tetrachloroethene	ND	1.00	ug/l	EPA 624	1		07/21/15 05:21PM JAD
Trichloroethene	ND	1.00	ug/l	EPA 624	1		07/21/15 05:21PM JAD

Sample ID	Sample Description	Samp. Date/Time/Temp	Sampled by
L5653508-2	BTR 001 COMP	07/14/15 09:00am NA C	Customer

Satellite Received Temp 2.2 C Iced (Y/N): Y
 Received Date/Time/Temp 07/14/15 04:30pm 2.9 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
 Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No:

Inv. No: MES_AL0341
 PWSID No:

Sample ID Sample Description
 L5653508-2 BTR 001 COMP

Samp. Date/Time/Temp Sampled by
 07/14/15 09:00am NA C Customer

Satellite Received Temp 2.2 C Iced (Y/N): Y
 Received Date/Time/Temp 07/14/15 04:30pm 2.9 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
GENERAL CHEMISTRY							
Nitrate/nitrite, total as N (Delaware)	0.712	0.500	mg/l	EPA 300.0	10		07/14/15 09:27PM SLD
Kjeldahl nitrogen, as N (Delaware)	0.886	0.200	mg/l	EPA 351.2	1		07/24/15 11:13AM ALW
Phosphorus total as P (Delaware)	0.0634	0.0500	mg/l	EPA 365.4	1		07/24/15 11:13AM ALW
Ammonia, as N (Delaware)	ND	0.200	mg/l	SM 4500NH3-G	1		07/23/15 10:40AM ALW

Sample Comments | Result Qualifiers:

L5653508-1 :

For BOD method SM5210B, the nutrient blank dissolved oxygen depletion was 0.27 mg/l, above the method criteria of <0.20 mg/l. The recovery of BOD in the laboratory control sample (122%) was outside the laboratory quality control limits (85 to 115%).



CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE A
 259 NAJOLAS ROAD
 RE: BLACK & DECKER WWTP
 MILLERSVILLE, MD 21108

Order Number: L5727629
 Project Name: BLACK & DECKER WWTP
 Receive Date: 07-14-2015
 Client Code: MES_A
 Project Location: BLACK & DECKER WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
 Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID	Sample Description			Samp. Date/Time/Temp		Sampled by	
L5727629-1	BLACK & DECKER 101			07/14/15	09:30am	NA C	Customer
	Received Date/Time	07/14/15	01:30pm				
Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY							
E. Coli, MPN Cel(Delaware)	101.3		MPN/100ml	SM 9223B			07/15/15 02:50PM SUB

Sample Comments | Result Qualifiers:

L5727629-1 :
 E. coli was analyzed by Chesapeake Environmental Lab, Inc in Stevensville, MD.



CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE B
 259 NAJOLES ROAD
 RE: BTR HAMPSTEAD WWTP
 MILLERSVILLE, MD 21108

Order Number: L5708487
 Project Name: BTR HAMPSTEAD WWTP
 Receive Date: 08-11-2015
 Client Code: MES_A
 Project Location: BTR HAMPSTEAD WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
 Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID Sample Description Samp. Date/Time/Temp Sampled by
 L5708487-1 BTR 001 GRAB 08/11/15 08:35am NA C Customer

Satellite Received Temp 3.6 C Iced (Y/N): Y
 Received Date/Time/Temp 08/11/15 04:30pm 3.0 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
GENERAL CHEMISTRY							
Hexane Ext. Material-HEM (oil+grease)	ND	5.00	mg/l	1664B HEM	1		08/14/15 02:20PM JEM
Total Suspended Solids (Delaware)	10.4	4.00	mg/l	SM 2540D	1		08/13/15 07:17PM MS3
Biochemical Oxygen Demand, 5 Day (Del.)	4.00	2.00	mg/l	SM 5210B	1.5		08/12/15 08:10AM SKJ
GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES							
1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		08/17/15 09:28PM JAD
Tetrachloroethene	ND	1.00	ug/l	EPA 624	1		08/17/15 09:28PM JAD
Trichloroethene	ND	1.00	ug/l	EPA 624	1		08/17/15 09:28PM JAD

Sample ID Sample Description Samp. Date/Time/Temp Sampled by
 L5708487-2 BTR 001 COMP 08/11/15 08:32am NA C Customer
 Received Date/Time 08/11/15 04:30pm

Satellite Received Temp 3.6 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE A
 259 NAJOLLES ROAD
 RE: BLACK & DECKER WWTP
 MILLERSVILLE, MD 21108

Order Number: L5801022
 Project Name: BLACK & DECKER WWTP
 Receive Date: 08-18-2015
 Client Code: MES_A
 Project Location: BLACK & DECKER WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
 Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID	Sample Description	Samp. Date/Time/Temp	Sampled by
L5801022-1	BLACK & DECKER 101 Received Date/Time 08/18/15 01:15pm	08/18/15 09:06am NA C	Customer

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY							
E. Coli, MPN Cel(Delaware)	<1.0		MPN/100ml	SM 9223B			08/18/15 02:16PM SUB

Sample Comments | Result Qualifiers:

L5801022-1 :
 E. coli was analyzed by Chesapeake Environmental Lab, Inc in Stevensville, MD.



CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE B
 259 NAJOLAS ROAD
 RE: BTR HAMPSTEAD WWTP
 MILLERSVILLE, MD 21108

Order Number: L5410993
 Project Name: BTR HAMPSTEAD WWTP
 Receive Date: 09-01-2015
 Client Code: MES_A
 Project Location: BTR HAMPSTEAD WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
 Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID L5410993-1 Sample Description BTR 001 GRAB Samp. Date/Time/Temp 09/01/15 08:50am NA C Sampled by Customer

Satellite Received Temp 2.0 C Iced (Y/N): Y
 Received Date/Time/Temp 09/01/15 04:45pm 2.5 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
GENERAL CHEMISTRY							
Hexane Ext. Material-HEM (oil+grease)	ND	5.00	mg/l	1664B HEM	1		09/02/15 03:10PM JEM
Total Suspended Solids (Delaware)	9.50	5.00	mg/l	SM 2540D	1		09/04/15 10:10AM SRC
Biochemical Oxygen Demand, 5 Day (Del.)	ND	2.00	mg/l	SM 5210B	0		09/03/15 08:10AM SKJ
GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES							
1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		09/03/15 02:19PM JAD
Tetrachloroethene	ND	1.00	ug/l	EPA 624	1		09/03/15 02:19PM JAD
Trichloroethene	ND	1.00	ug/l	EPA 624	1		09/03/15 02:19PM JAD

Sample ID L5410993-2 Sample Description BTR 001 COMP Received Date/Time 09/01/15 04:45pm Samp. Date/Time/Temp 09/01/15 08:50am NA C Sampled by Customer

Satellite Received Temp 2.0 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE B
 259 NAJOLAS ROAD
 RE: BTR HAMPSTEAD WWTP
 MILLERSVILLE, MD 21108

Order Number: L5706005
 Project Name: BTR HAMPSTEAD WWTP
 Receive Date: 07-14-2015
 Client Code: MES_A
 Project Location: BTR HAMPSTEAD WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
 Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID Sample Description Samp. Date/Time/Temp Sampled by
 L5706005-1 BTR-201 #7 07/14/15 08:30am NA C Customer

Satellite Received Temp 2.2 C Iced (Y/N): Y
 Received Date/Time/Temp 07/14/15 04:30pm 2.9 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES							
1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
1,1,2,2-Tetrachloroethane	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
1,1,2-Trichloroethane	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
1,1-Dichloroethane	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
1,1-Dichloroethene	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
1,2-Dichlorobenzene	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
1,2-Dichloroethane	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
1,2-Dichloropropane	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
1,3-Dichlorobenzene	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
1,4-Dichlorobenzene	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
2-Chloroethyl vinyl ether	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Benzene	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Bromodichloromethane	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Bromoform	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Bromomethane	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Carbon tetrachloride	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Chlorobenzene	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Chloroethane	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Chloroform	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Chloromethane	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
cis-1,3-Dichloropropene	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Dibromochloromethane	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Ethylbenzene	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Methylene chloride	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Tetrachloroethene	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Toluene	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
trans-1,2-Dichloroethene	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
trans-1,3-Dichloropropene	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Trichloroethene	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD

PIN: 17237

Serial Number: 4859786

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample ID Sample Description
L5706005-1 BTR-201 #7

Samp. Date/Time/Temp Sampled by
07/14/15 08:30am NA C Customer

Satellite Received Temp 2.2 C Iced (Y/N): Y
Received Date/Time/Temp 07/14/15 04:30pm 2.9 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES continued							
Trichlorofluoromethane	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD
Vinyl chloride	ND	1.00	ug/l	EPA 624	1		07/21/15 04:25PM JAD



CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE B
 259 NAJOLES ROAD
 RE: BTR HAMPSTEAD WWTP
 MILLERSVILLE, MD 21108

Order Number: L5835284
 Project Name: BTR HAMPSTEAD WWTP
 Receive Date: 09-22-2015
 Client Code: MES_A
 Project Location: BTR HAMPSTEAD WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
 Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID	Sample Description			Samp. Date/Time/Temp		Sampled by	
L5835284-1	BTR OUTFALL 101			09/22/15 09:08am NA C		Customer	
Received Date/Time 09/22/15 01:33pm							
Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY							
E. Coli, MPN Cel(Delaware)	<1.0		MPN/100ml	SM 9223B			09/22/15 02:14PM SUB

Sample Comments | Result Qualifiers:

L5835284-1 :
 E. coli was analyzed by Chesapeake Environmental Lab, Inc in Stevensville, MD.



**APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(AUGUST 2015)**

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.
TestAmerica Chicago
2417 Bond Street
University Park, IL 60484
Tel: (708)534-5200

TestAmerica Job ID: 500-100546-1
Client Project/Site: Black and Decker

For:
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, Pennsylvania 19380

Attn: Mr. Tom Cornuet

Jodie Bracken

Authorized for release by:
9/3/2015 4:43:53 PM
Jodie Bracken, Project Management Assistant II
jodie.bracken@testamericainc.com

Designee for
Richard Wright, Senior Project Manager
(708)534-5200
richard.wright@testamericainc.com

LINKS

Review your project
results through
Total Access

Have a Question?

**Ask
The
Expert**

Visit us at:
www.testamericainc.com

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters. exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.




Table of Contents

Cover Page	1
Table of Contents	2
Case Narrative	3
Detection Summary	4
Method Summary	7
Sample Summary	8
Client Sample Results	9
Definitions	61
QC Association	62
Surrogate Summary	63
QC Sample Results	64
Chronicle	77
Certification Summary	82
Chain of Custody	83
Receipt Checklists	86



Case Narrative

TestAmerica Job ID: 500-100546-1

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

Job ID: 500-100546-1

Laboratory: TestAmerica Chicago

Narrative

Job Narrative
500-100546-1

Comments

No additional comments.

Receipt

The samples were received on 8/28/2015 10:05 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 0.7° C.

GC/MS VOA

Method(s) 8260B: The laboratory control sample (LCS) for 302681 recovered outside control limits for the following analytes: 1,2,4-Trichlorobenzene and 1,2,3-Trichlorobenzene. These analytes were biased high in the LCS and were not detected in the associated samples; therefore, the data has been reported.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.



Detection Summary

TestAmerica Job ID: 500-100546-1

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

Client Sample ID: RFW-1A

No Detections.

Lab Sample ID: 500-100546-1

Client Sample ID: RFW-1B

No Detections.

Lab Sample ID: 500-100546-2

Client Sample ID: RFW-2A

No Detections.

Lab Sample ID: 500-100546-3

Client Sample ID: RFW-2B

No Detections.

Lab Sample ID: 500-100546-4

Client Sample ID: RFW-3B

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Acetone	5.7		5.0	1.3	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	1.4		1.0	0.12	ug/L	1		8260B	Total/NA

Lab Sample ID: 500-100546-5

Client Sample ID: RFW-4A

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	20		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	13		1.0	0.17	ug/L	1		8260B	Total/NA

Lab Sample ID: 500-100546-6

Client Sample ID: RFW-4A DUP

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	20		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	13		1.0	0.17	ug/L	1		8260B	Total/NA

Lab Sample ID: 500-100546-7

Client Sample ID: RFW-4B

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	3.1		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	29		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	56		1.0	0.17	ug/L	1		8260B	Total/NA

Lab Sample ID: 500-100546-8

Client Sample ID: RFW-6

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.92		0.50	0.19	ug/L	1		8260B	Total/NA

Lab Sample ID: 500-100546-9

Client Sample ID: RFW-7

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	1.5		0.50	0.19	ug/L	1		8260B	Total/NA

Lab Sample ID: 500-100546-10

Client Sample ID: EW-2

Lab Sample ID: 500-100546-11

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-2 (Continued)

Lab Sample ID: 500-100546-11

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	160		0.50	0.19	ug/L	1		8260B	Total/NA
Bromodichloromethane	0.34	J	1.0	0.17	ug/L	1		8260B	Total/NA
Tetrachloroethene	52		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-3

Lab Sample ID: 500-100546-12

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Acetone	8.3		5.0	1.3	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	1.6		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	28		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	1.2		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-4

Lab Sample ID: 500-100546-13

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloromethane	1.2		1.0	0.18	ug/L	1		8260B	Total/NA
Acetone	9.1		5.0	1.3	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	3.9		1.0	0.12	ug/L	1		8260B	Total/NA
Methyl Ethyl Ketone	95		5.0	1.5	ug/L	1		8260B	Total/NA
Toluene	0.50		0.50	0.11	ug/L	1		8260B	Total/NA
Tetrachloroethene	9.3		1.0	0.17	ug/L	1		8260B	Total/NA
Trichloroethene - DL	320		5.0	1.9	ug/L	10		8260B	Total/NA

Client Sample ID: EW-5

Lab Sample ID: 500-100546-14

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	85		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	1.9		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-6

Lab Sample ID: 500-100546-15

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	5.0		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	10		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-7

Lab Sample ID: 500-100546-16

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	4.5		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	2.8		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	7.4		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-8

Lab Sample ID: 500-100546-17

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethane	0.88	J	1.0	0.19	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	26		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	6.5		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	72		1.0	0.17	ug/L	1		8260B	Total/NA

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-9

Lab Sample ID: 500-100546-18

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.46	J	0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	94		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-9 DUP

Lab Sample ID: 500-100546-19

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.52		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	99		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-10

Lab Sample ID: 500-100546-20

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Tetrachloroethene	1.5		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-9

Lab Sample ID: 500-100546-21

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethene	0.64	J	1.0	0.31	ug/L	1		8260B	Total/NA
1,1-Dichloroethane	0.55	J	1.0	0.19	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	14		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	7.8		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	4.2		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-11B

Lab Sample ID: 500-100546-22

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	2.4		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-12B

Lab Sample ID: 500-100546-23

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	1.3		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	34		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	6.9		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-13

Lab Sample ID: 500-100546-24

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.87	J	1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	2.4		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	14		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-17

Lab Sample ID: 500-100546-25

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Benzene	0.55		0.50	0.074	ug/L	1		8260B	Total/NA

Client Sample ID: Trip Blank

Lab Sample ID: 500-100546-26

No Detections.

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Method Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Method	Method Description	Protocol	Laboratory
8260B	VOC	SW846	TAL CHI

Protocol References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200

Sample Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
500-100546-1	RFW-1A	Water	08/26/15 09:45	08/28/15 10:05
500-100546-2	RFW-1B	Water	08/26/15 17:30	08/28/15 10:05
500-100546-3	RFW-2A	Water	08/26/15 11:10	08/28/15 10:05
500-100546-4	RFW-2B	Water	08/26/15 11:05	08/28/15 10:05
500-100546-5	RFW-3B	Water	08/26/15 15:50	08/28/15 10:05
500-100546-6	RFW-4A	Water	08/27/15 09:30	08/28/15 10:05
500-100546-7	RFW-4A DUP	Water	08/27/15 09:30	08/28/15 10:05
500-100546-8	RFW-4B	Water	08/27/15 08:40	08/28/15 10:05
500-100546-9	RFW-6	Water	08/26/15 13:40	08/28/15 10:05
500-100546-10	RFW-7	Water	08/26/15 12:15	08/28/15 10:05
500-100546-11	EW-2	Water	08/27/15 11:30	08/28/15 10:05
500-100546-12	EW-3	Water	08/27/15 10:50	08/28/15 10:05
500-100546-13	EW-4	Water	08/27/15 10:40	08/28/15 10:05
500-100546-14	EW-5	Water	08/27/15 10:20	08/28/15 10:05
500-100546-15	EW-6	Water	08/26/15 14:30	08/28/15 10:05
500-100546-16	EW-7	Water	08/26/15 14:20	08/28/15 10:05
500-100546-17	EW-8	Water	08/26/15 14:15	08/28/15 10:05
500-100546-18	EW-9	Water	08/26/15 14:05	08/28/15 10:05
500-100546-19	EW-9 DUP	Water	08/26/15 14:05	08/28/15 10:05
500-100546-20	EW-10	Water	08/26/15 14:00	08/28/15 10:05
500-100546-21	RFW-9	Water	08/26/15 17:00	08/28/15 10:05
500-100546-22	RFW-11B	Water	08/27/15 11:00	08/28/15 10:05
500-100546-23	RFW-12B	Water	08/27/15 12:00	08/28/15 10:05
500-100546-24	RFW-13	Water	08/27/15 07:15	08/28/15 10:05
500-100546-25	RFW-17	Water	08/27/15 12:50	08/28/15 10:05
500-100546-26	Trip Blank	Water	08/26/15 07:00	08/28/15 10:05

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-100546-1

Date Collected: 08/26/15 09:45

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/03/15 04:32	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/03/15 04:32	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/03/15 04:32	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/03/15 04:32	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/03/15 04:32	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/03/15 04:32	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/03/15 04:32	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/03/15 04:32	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/03/15 04:32	1
Acetone	<5.0		5.0	1.3	ug/L			09/03/15 04:32	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/03/15 04:32	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/03/15 04:32	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/03/15 04:32	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/03/15 04:32	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/03/15 04:32	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/03/15 04:32	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/03/15 04:32	1
Chloroform	<1.0		1.0	0.20	ug/L			09/03/15 04:32	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/03/15 04:32	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/03/15 04:32	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/03/15 04:32	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/03/15 04:32	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/03/15 04:32	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/03/15 04:32	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/03/15 04:32	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/03/15 04:32	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/03/15 04:32	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/03/15 04:32	1
Toluene	<0.50		0.50	0.11	ug/L			09/03/15 04:32	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/03/15 04:32	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/03/15 04:32	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/03/15 04:32	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/03/15 04:32	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/03/15 04:32	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/03/15 04:32	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/03/15 04:32	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/03/15 04:32	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/03/15 04:32	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/03/15 04:32	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/03/15 04:32	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/03/15 04:32	1
Styrene	<1.0		1.0	0.10	ug/L			09/03/15 04:32	1
Bromoform	<1.0		1.0	0.28	ug/L			09/03/15 04:32	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 04:32	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/03/15 04:32	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/03/15 04:32	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/03/15 04:32	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/03/15 04:32	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/03/15 04:32	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-100546-1

Date Collected: 08/26/15 09:45

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/03/15 04:32	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/03/15 04:32	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 04:32	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 04:32	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/03/15 04:32	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/15 04:32	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/03/15 04:32	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/15 04:32	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/03/15 04:32	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/03/15 04:32	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/03/15 04:32	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/03/15 04:32	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/03/15 04:32	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/03/15 04:32	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/03/15 04:32	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	95		75 - 125		09/03/15 04:32	1
Toluene-d8 (Surr)	90		75 - 120		09/03/15 04:32	1
4-Bromofluorobenzene (Surr)	97		75 - 120		09/03/15 04:32	1
Dibromofluoromethane	90		75 - 120		09/03/15 04:32	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-100546-2

Date Collected: 08/26/15 17:30

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil	Fac
Benzene	<0.50		0.50	0.074	ug/L			09/03/15 04:58	1	
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/03/15 04:58	1	
Chloromethane	<1.0		1.0	0.18	ug/L			09/03/15 04:58	1	
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/03/15 04:58	1	
Bromomethane	<1.0		1.0	0.31	ug/L			09/03/15 04:58	1	
Chloroethane	<1.0		1.0	0.34	ug/L			09/03/15 04:58	1	
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/03/15 04:58	1	
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/03/15 04:58	1	
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/03/15 04:58	1	
Acetone	<5.0		5.0	1.3	ug/L			09/03/15 04:58	1	
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/03/15 04:58	1	
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/03/15 04:58	1	
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/03/15 04:58	1	
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/03/15 04:58	1	
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/03/15 04:58	1	
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/03/15 04:58	1	
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/03/15 04:58	1	
Chloroform	<1.0		1.0	0.20	ug/L			09/03/15 04:58	1	
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/03/15 04:58	1	
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/03/15 04:58	1	
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/03/15 04:58	1	
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/03/15 04:58	1	
Trichloroethene	<0.50		0.50	0.19	ug/L			09/03/15 04:58	1	
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/03/15 04:58	1	
Dibromomethane	<1.0		1.0	0.33	ug/L			09/03/15 04:58	1	
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/03/15 04:58	1	
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/03/15 04:58	1	
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/03/15 04:58	1	
Toluene	<0.50		0.50	0.11	ug/L			09/03/15 04:58	1	
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/03/15 04:58	1	
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/03/15 04:58	1	
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/03/15 04:58	1	
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/03/15 04:58	1	
2-Hexanone	<5.0		5.0	0.56	ug/L			09/03/15 04:58	1	
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/03/15 04:58	1	
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/03/15 04:58	1	
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/03/15 04:58	1	
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/03/15 04:58	1	
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/03/15 04:58	1	
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/03/15 04:58	1	
o-Xylene	<0.50		0.50	0.068	ug/L			09/03/15 04:58	1	
Styrene	<1.0		1.0	0.10	ug/L			09/03/15 04:58	1	
Bromoform	<1.0		1.0	0.28	ug/L			09/03/15 04:58	1	
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 04:58	1	
Bromobenzene	<1.0		1.0	0.25	ug/L			09/03/15 04:58	1	
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/03/15 04:58	1	
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/03/15 04:58	1	
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/03/15 04:58	1	
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/03/15 04:58	1	

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-100546-2

Date Collected: 08/26/15 17:30

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/03/15 04:58	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/03/15 04:58	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 04:58	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 04:58	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/03/15 04:58	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/15 04:58	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/03/15 04:58	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/15 04:58	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/03/15 04:58	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/03/15 04:58	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/03/15 04:58	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/03/15 04:58	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/03/15 04:58	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/03/15 04:58	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/03/15 04:58	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	96		75 - 125		09/03/15 04:58	1
Toluene-d8 (Surr)	91		75 - 120		09/03/15 04:58	1
4-Bromofluorobenzene (Surr)	93		75 - 120		09/03/15 04:58	1
Dibromofluoromethane	91		75 - 120		09/03/15 04:58	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-100546-3

Date Collected: 08/26/15 11:10

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 12:12	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 12:12	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 12:12	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 12:12	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 12:12	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 12:12	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 12:12	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 12:12	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 12:12	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 12:12	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 12:12	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 12:12	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 12:12	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 12:12	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/02/15 12:12	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 12:12	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 12:12	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 12:12	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 12:12	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 12:12	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 12:12	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 12:12	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/02/15 12:12	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 12:12	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 12:12	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 12:12	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 12:12	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 12:12	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 12:12	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 12:12	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 12:12	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/02/15 12:12	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 12:12	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 12:12	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 12:12	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 12:12	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 12:12	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 12:12	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 12:12	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 12:12	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 12:12	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 12:12	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 12:12	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 12:12	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 12:12	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 12:12	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 12:12	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 12:12	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 12:12	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-100546-3

Date Collected: 08/26/15 11:10

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 12:12	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 12:12	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 12:12	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 12:12	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 12:12	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 12:12	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 12:12	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 12:12	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 12:12	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 12:12	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 12:12	1
1,2,4-Trichlorobenzene	<1.0	*	1.0	0.31	ug/L			09/02/15 12:12	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 12:12	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 12:12	1
1,2,3-Trichlorobenzene	<1.0	*	1.0	0.24	ug/L			09/02/15 12:12	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	98		75 - 125		09/02/15 12:12	1
Toluene-d8 (Surr)	103		75 - 120		09/02/15 12:12	1
4-Bromofluorobenzene (Surr)	100		75 - 120		09/02/15 12:12	1
Dibromofluoromethane	87		75 - 120		09/02/15 12:12	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-100546-4

Date Collected: 08/26/15 11:05

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 12:38	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 12:38	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 12:38	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 12:38	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 12:38	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 12:38	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 12:38	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 12:38	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 12:38	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 12:38	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 12:38	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 12:38	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 12:38	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 12:38	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/02/15 12:38	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 12:38	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 12:38	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 12:38	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 12:38	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 12:38	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 12:38	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 12:38	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/02/15 12:38	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 12:38	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 12:38	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 12:38	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 12:38	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 12:38	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 12:38	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 12:38	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 12:38	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/02/15 12:38	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 12:38	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 12:38	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 12:38	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 12:38	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 12:38	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 12:38	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 12:38	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 12:38	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 12:38	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 12:38	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 12:38	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 12:38	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 12:38	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 12:38	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 12:38	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 12:38	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 12:38	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-100546-4

Date Collected: 08/26/15 11:05

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 12:38	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 12:38	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 12:38	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 12:38	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 12:38	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 12:38	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 12:38	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 12:38	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 12:38	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 12:38	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 12:38	1
1,2,4-Trichlorobenzene	<1.0	*	1.0	0.31	ug/L			09/02/15 12:38	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 12:38	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 12:38	1
1,2,3-Trichlorobenzene	<1.0	*	1.0	0.24	ug/L			09/02/15 12:38	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	98		75 - 125					09/02/15 12:38	1
Toluene-d8 (Surr)	101		75 - 120					09/02/15 12:38	1
4-Bromofluorobenzene (Surr)	95		75 - 120					09/02/15 12:38	1
Dibromofluoromethane	88		75 - 120					09/02/15 12:38	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-100546-5

Date Collected: 08/26/15 15:50

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 13:05	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 13:05	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 13:05	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 13:05	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 13:05	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 13:05	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 13:05	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 13:05	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 13:05	1
Acetone	5.7		5.0	1.3	ug/L			09/02/15 13:05	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 13:05	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 13:05	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 13:05	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 13:05	1
cis-1,2-Dichloroethene	1.4		1.0	0.12	ug/L			09/02/15 13:05	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 13:05	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 13:05	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 13:05	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 13:05	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 13:05	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 13:05	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 13:05	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/02/15 13:05	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 13:05	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 13:05	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 13:05	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 13:05	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 13:05	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 13:05	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 13:05	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 13:05	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/02/15 13:05	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 13:05	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 13:05	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 13:05	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 13:05	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 13:05	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 13:05	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 13:05	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 13:05	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 13:05	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 13:05	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 13:05	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 13:05	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 13:05	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 13:05	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 13:05	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 13:05	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 13:05	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-100546-5

Date Collected: 08/26/15 15:50

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 13:05	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 13:05	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 13:05	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 13:05	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 13:05	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 13:05	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 13:05	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 13:05	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 13:05	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 13:05	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 13:05	1
1,2,4-Trichlorobenzene	<1.0	*	1.0	0.31	ug/L			09/02/15 13:05	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 13:05	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 13:05	1
1,2,3-Trichlorobenzene	<1.0	*	1.0	0.24	ug/L			09/02/15 13:05	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	98		75 - 125		09/02/15 13:05	1
Toluene-d8 (Surr)	103		75 - 120		09/02/15 13:05	1
4-Bromofluorobenzene (Surr)	101		75 - 120		09/02/15 13:05	1
Dibromofluoromethane	87		75 - 120		09/02/15 13:05	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-4A

Lab Sample ID: 500-100546-6

Date Collected: 08/27/15 09:30

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 13:32	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 13:32	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 13:32	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 13:32	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 13:32	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 13:32	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 13:32	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 13:32	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 13:32	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 13:32	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 13:32	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 13:32	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 13:32	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 13:32	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/02/15 13:32	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 13:32	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 13:32	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 13:32	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 13:32	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 13:32	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 13:32	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 13:32	1
Trichloroethene	20		0.50	0.19	ug/L			09/02/15 13:32	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 13:32	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 13:32	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 13:32	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 13:32	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 13:32	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 13:32	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 13:32	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 13:32	1
Tetrachloroethene	13		1.0	0.17	ug/L			09/02/15 13:32	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 13:32	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 13:32	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 13:32	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 13:32	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 13:32	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 13:32	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 13:32	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 13:32	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 13:32	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 13:32	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 13:32	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 13:32	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 13:32	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 13:32	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 13:32	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 13:32	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 13:32	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-4A

Lab Sample ID: 500-100546-6

Date Collected: 08/27/15 09:30

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 13:32	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 13:32	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 13:32	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 13:32	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 13:32	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 13:32	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 13:32	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 13:32	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 13:32	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 13:32	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 13:32	1
1,2,4-Trichlorobenzene	<1.0	*	1.0	0.31	ug/L			09/02/15 13:32	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 13:32	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 13:32	1
1,2,3-Trichlorobenzene	<1.0	*	1.0	0.24	ug/L			09/02/15 13:32	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	100		75 - 125		09/02/15 13:32	1
Toluene-d8 (Surr)	101		75 - 120		09/02/15 13:32	1
4-Bromofluorobenzene (Surr)	98		75 - 120		09/02/15 13:32	1
Dibromofluoromethane	89		75 - 120		09/02/15 13:32	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-4A DUP

Lab Sample ID: 500-100546-7

Date Collected: 08/27/15 09:30

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 13:58	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 13:58	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 13:58	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 13:58	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 13:58	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 13:58	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 13:58	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 13:58	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 13:58	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 13:58	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 13:58	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 13:58	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 13:58	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 13:58	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/02/15 13:58	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 13:58	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 13:58	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 13:58	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 13:58	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 13:58	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 13:58	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 13:58	1
Trichloroethene	20		0.50	0.19	ug/L			09/02/15 13:58	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 13:58	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 13:58	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 13:58	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 13:58	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 13:58	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 13:58	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 13:58	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 13:58	1
Tetrachloroethene	13		1.0	0.17	ug/L			09/02/15 13:58	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 13:58	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 13:58	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 13:58	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 13:58	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 13:58	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 13:58	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 13:58	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 13:58	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 13:58	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 13:58	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 13:58	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 13:58	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 13:58	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 13:58	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 13:58	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 13:58	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 13:58	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-4A DUP

Lab Sample ID: 500-100546-7

Date Collected: 08/27/15 09:30

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 13:58	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 13:58	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 13:58	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 13:58	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 13:58	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 13:58	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 13:58	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 13:58	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 13:58	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 13:58	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 13:58	1
1,2,4-Trichlorobenzene	<1.0	*	1.0	0.31	ug/L			09/02/15 13:58	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 13:58	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 13:58	1
1,2,3-Trichlorobenzene	<1.0	*	1.0	0.24	ug/L			09/02/15 13:58	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		75 - 125		09/02/15 13:58	1
Toluene-d8 (Surr)	100		75 - 120		09/02/15 13:58	1
4-Bromofluorobenzene (Surr)	100		75 - 120		09/02/15 13:58	1
Dibromofluoromethane	90		75 - 120		09/02/15 13:58	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-4B

Lab Sample ID: 500-100546-8

Date Collected: 08/27/15 08:40

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil	Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 14:24		1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 14:24		1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 14:24		1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 14:24		1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 14:24		1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 14:24		1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 14:24		1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 14:24		1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 14:24		1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 14:24		1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 14:24		1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 14:24		1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 14:24		1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 14:24		1
cis-1,2-Dichloroethene	3.1		1.0	0.12	ug/L			09/02/15 14:24		1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 14:24		1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 14:24		1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 14:24		1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 14:24		1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 14:24		1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 14:24		1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 14:24		1
Trichloroethene	29		0.50	0.19	ug/L			09/02/15 14:24		1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 14:24		1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 14:24		1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 14:24		1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 14:24		1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 14:24		1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 14:24		1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 14:24		1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 14:24		1
Tetrachloroethene	56		1.0	0.17	ug/L			09/02/15 14:24		1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 14:24		1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 14:24		1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 14:24		1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 14:24		1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 14:24		1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 14:24		1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 14:24		1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 14:24		1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 14:24		1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 14:24		1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 14:24		1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 14:24		1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 14:24		1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 14:24		1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 14:24		1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 14:24		1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 14:24		1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-4B

Lab Sample ID: 500-100546-8

Date Collected: 08/27/15 08:40

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 14:24	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 14:24	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 14:24	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 14:24	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 14:24	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 14:24	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 14:24	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 14:24	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 14:24	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 14:24	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 14:24	1
1,2,4-Trichlorobenzene	<1.0	*	1.0	0.31	ug/L			09/02/15 14:24	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 14:24	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 14:24	1
1,2,3-Trichlorobenzene	<1.0	*	1.0	0.24	ug/L			09/02/15 14:24	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	101		75 - 125					09/02/15 14:24	1
Toluene-d8 (Surr)	100		75 - 120					09/02/15 14:24	1
4-Bromofluorobenzene (Surr)	102		75 - 120					09/02/15 14:24	1
Dibromofluoromethane	89		75 - 120					09/02/15 14:24	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-6

Date Collected: 08/26/15 13:40

Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-9

Matrix: Water

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 14:50	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 14:50	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 14:50	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 14:50	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 14:50	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 14:50	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 14:50	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 14:50	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 14:50	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 14:50	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 14:50	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 14:50	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 14:50	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 14:50	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/02/15 14:50	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 14:50	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 14:50	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 14:50	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 14:50	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 14:50	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 14:50	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 14:50	1
Trichloroethene	0.92		0.50	0.19	ug/L			09/02/15 14:50	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 14:50	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 14:50	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 14:50	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 14:50	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 14:50	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 14:50	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 14:50	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 14:50	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/02/15 14:50	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 14:50	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 14:50	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 14:50	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 14:50	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 14:50	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 14:50	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 14:50	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 14:50	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 14:50	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 14:50	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 14:50	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 14:50	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 14:50	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 14:50	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 14:50	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 14:50	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 14:50	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-6

Lab Sample ID: 500-100546-9

Date Collected: 08/26/15 13:40

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 14:50	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 14:50	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 14:50	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 14:50	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 14:50	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 14:50	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 14:50	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 14:50	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 14:50	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 14:50	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 14:50	1
1,2,4-Trichlorobenzene	<1.0	*	1.0	0.31	ug/L			09/02/15 14:50	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 14:50	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 14:50	1
1,2,3-Trichlorobenzene	<1.0	*	1.0	0.24	ug/L			09/02/15 14:50	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	100		75 - 125		09/02/15 14:50	1
Toluene-d8 (Surr)	100		75 - 120		09/02/15 14:50	1
4-Bromofluorobenzene (Surr)	102		75 - 120		09/02/15 14:50	1
Dibromofluoromethane	90		75 - 120		09/02/15 14:50	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-7
Date Collected: 08/26/15 12:15
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-10
Matrix: Water

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 15:17	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 15:17	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 15:17	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 15:17	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 15:17	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 15:17	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 15:17	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 15:17	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 15:17	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 15:17	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 15:17	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 15:17	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 15:17	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 15:17	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/02/15 15:17	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 15:17	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 15:17	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 15:17	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 15:17	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 15:17	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 15:17	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 15:17	1
Trichloroethene	1.5		0.50	0.19	ug/L			09/02/15 15:17	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 15:17	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 15:17	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 15:17	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 15:17	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 15:17	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 15:17	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 15:17	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 15:17	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/02/15 15:17	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 15:17	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 15:17	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 15:17	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 15:17	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 15:17	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 15:17	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 15:17	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 15:17	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 15:17	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 15:17	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 15:17	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 15:17	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 15:17	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 15:17	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 15:17	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 15:17	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 15:17	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-7
Date Collected: 08/26/15 12:15
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-10
Matrix: Water

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 15:17	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 15:17	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 15:17	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 15:17	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 15:17	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 15:17	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 15:17	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 15:17	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 15:17	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 15:17	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 15:17	1
1,2,4-Trichlorobenzene	<1.0	*	1.0	0.31	ug/L			09/02/15 15:17	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 15:17	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 15:17	1
1,2,3-Trichlorobenzene	<1.0	*	1.0	0.24	ug/L			09/02/15 15:17	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	103		75 - 125		09/02/15 15:17	1
Toluene-d8 (Surr)	102		75 - 120		09/02/15 15:17	1
4-Bromofluorobenzene (Surr)	101		75 - 120		09/02/15 15:17	1
Dibromofluoromethane	90		75 - 120		09/02/15 15:17	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-2
Date Collected: 08/27/15 11:30
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-11
Matrix: Water

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil	Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 15:44		1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 15:44		1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 15:44		1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 15:44		1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 15:44		1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 15:44		1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 15:44		1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 15:44		1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 15:44		1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 15:44		1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 15:44		1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 15:44		1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 15:44		1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 15:44		1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/02/15 15:44		1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 15:44		1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 15:44		1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 15:44		1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 15:44		1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 15:44		1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 15:44		1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 15:44		1
Trichloroethene	160		0.50	0.19	ug/L			09/02/15 15:44		1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 15:44		1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 15:44		1
Bromodichloromethane	0.34	J	1.0	0.17	ug/L			09/02/15 15:44		1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 15:44		1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 15:44		1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 15:44		1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 15:44		1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 15:44		1
Tetrachloroethene	52		1.0	0.17	ug/L			09/02/15 15:44		1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 15:44		1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 15:44		1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 15:44		1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 15:44		1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 15:44		1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 15:44		1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 15:44		1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 15:44		1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 15:44		1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 15:44		1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 15:44		1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 15:44		1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 15:44		1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 15:44		1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 15:44		1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 15:44		1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 15:44		1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-2

Lab Sample ID: 500-100546-11

Date Collected: 08/27/15 11:30

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 15:44	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 15:44	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 15:44	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 15:44	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 15:44	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 15:44	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 15:44	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 15:44	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 15:44	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 15:44	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 15:44	1
1,2,4-Trichlorobenzene	<1.0	*	1.0	0.31	ug/L			09/02/15 15:44	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 15:44	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 15:44	1
1,2,3-Trichlorobenzene	<1.0	*	1.0	0.24	ug/L			09/02/15 15:44	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		75 - 125		09/02/15 15:44	1
Toluene-d8 (Surr)	100		75 - 120		09/02/15 15:44	1
4-Bromofluorobenzene (Surr)	101		75 - 120		09/02/15 15:44	1
Dibromofluoromethane	87		75 - 120		09/02/15 15:44	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-3

Lab Sample ID: 500-100546-12

Date Collected: 08/27/15 10:50

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 16:37	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 16:37	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 16:37	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 16:37	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 16:37	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 16:37	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 16:37	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 16:37	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 16:37	1
Acetone	8.3		5.0	1.3	ug/L			09/02/15 16:37	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 16:37	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 16:37	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 16:37	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 16:37	1
cis-1,2-Dichloroethene	1.6		1.0	0.12	ug/L			09/02/15 16:37	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 16:37	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 16:37	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 16:37	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 16:37	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 16:37	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 16:37	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 16:37	1
Trichloroethene	28		0.50	0.19	ug/L			09/02/15 16:37	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 16:37	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 16:37	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 16:37	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 16:37	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 16:37	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 16:37	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 16:37	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 16:37	1
Tetrachloroethene	1.2		1.0	0.17	ug/L			09/02/15 16:37	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 16:37	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 16:37	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 16:37	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 16:37	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 16:37	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 16:37	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 16:37	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 16:37	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 16:37	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 16:37	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 16:37	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 16:37	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 16:37	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 16:37	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 16:37	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 16:37	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 16:37	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-3

Lab Sample ID: 500-100546-12

Date Collected: 08/27/15 10:50

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 16:37	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 16:37	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 16:37	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 16:37	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 16:37	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 16:37	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 16:37	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 16:37	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 16:37	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 16:37	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 16:37	1
1,2,4-Trichlorobenzene	<1.0	*	1.0	0.31	ug/L			09/02/15 16:37	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 16:37	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 16:37	1
1,2,3-Trichlorobenzene	<1.0	*	1.0	0.24	ug/L			09/02/15 16:37	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	100		75 - 125		09/02/15 16:37	1
Toluene-d8 (Surr)	102		75 - 120		09/02/15 16:37	1
4-Bromofluorobenzene (Surr)	101		75 - 120		09/02/15 16:37	1
Dibromofluoromethane	90		75 - 120		09/02/15 16:37	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-4

Lab Sample ID: 500-100546-13

Date Collected: 08/27/15 10:40

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 17:03	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 17:03	1
Chloromethane	1.2		1.0	0.18	ug/L			09/02/15 17:03	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 17:03	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 17:03	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 17:03	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 17:03	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 17:03	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 17:03	1
Acetone	9.1		5.0	1.3	ug/L			09/02/15 17:03	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 17:03	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 17:03	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 17:03	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 17:03	1
cis-1,2-Dichloroethene	3.9		1.0	0.12	ug/L			09/02/15 17:03	1
Methyl Ethyl Ketone	95		5.0	1.5	ug/L			09/02/15 17:03	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 17:03	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 17:03	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 17:03	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 17:03	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 17:03	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 17:03	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 17:03	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 17:03	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 17:03	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 17:03	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 17:03	1
Toluene	0.50		0.50	0.11	ug/L			09/02/15 17:03	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 17:03	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 17:03	1
Tetrachloroethene	9.3		1.0	0.17	ug/L			09/02/15 17:03	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 17:03	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 17:03	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 17:03	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 17:03	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:03	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 17:03	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 17:03	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 17:03	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 17:03	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 17:03	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 17:03	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:03	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 17:03	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 17:03	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 17:03	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 17:03	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 17:03	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 17:03	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-4

Lab Sample ID: 500-100546-13

Date Collected: 08/27/15 10:40

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil	Fac
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 17:03	1	
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:03	1	
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:03	1	
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 17:03	1	
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 17:03	1	
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 17:03	1	
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 17:03	1	
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 17:03	1	
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 17:03	1	
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 17:03	1	
1,2,4-Trichlorobenzene	<1.0 *		1.0	0.31	ug/L			09/02/15 17:03	1	
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 17:03	1	
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 17:03	1	
1,2,3-Trichlorobenzene	<1.0 *		1.0	0.24	ug/L			09/02/15 17:03	1	

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil	Fac
1,2-Dichloroethane-d4 (Surr)	101		75 - 125		09/02/15 17:03	1	
Toluene-d8 (Surr)	103		75 - 120		09/02/15 17:03	1	
4-Bromofluorobenzene (Surr)	100		75 - 120		09/02/15 17:03	1	
Dibromofluoromethane	91		75 - 120		09/02/15 17:03	1	

Method: 8260B - VOC - DL

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil	Fac
Trichloroethene	320		5.0	1.9	ug/L			09/02/15 17:30	10	

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil	Fac
1,2-Dichloroethane-d4 (Surr)	102		75 - 125		09/02/15 17:30	10	
Toluene-d8 (Surr)	100		75 - 120		09/02/15 17:30	10	
4-Bromofluorobenzene (Surr)	99		75 - 120		09/02/15 17:30	10	
Dibromofluoromethane	89		75 - 120		09/02/15 17:30	10	

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-5
Date Collected: 08/27/15 10:20
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-14
Matrix: Water

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 17:57	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 17:57	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 17:57	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 17:57	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 17:57	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 17:57	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 17:57	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 17:57	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 17:57	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 17:57	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 17:57	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 17:57	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 17:57	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 17:57	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/02/15 17:57	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 17:57	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 17:57	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 17:57	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 17:57	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 17:57	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 17:57	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 17:57	1
Trichloroethene	85		0.50	0.19	ug/L			09/02/15 17:57	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 17:57	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 17:57	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 17:57	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 17:57	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 17:57	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 17:57	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 17:57	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 17:57	1
Tetrachloroethene	1.9		1.0	0.17	ug/L			09/02/15 17:57	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 17:57	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 17:57	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 17:57	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 17:57	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:57	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 17:57	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 17:57	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 17:57	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 17:57	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 17:57	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 17:57	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:57	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 17:57	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 17:57	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 17:57	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 17:57	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 17:57	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-5
Date Collected: 08/27/15 10:20
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-14
Matrix: Water

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 17:57	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 17:57	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:57	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:57	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 17:57	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 17:57	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 17:57	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 17:57	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 17:57	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 17:57	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 17:57	1
1,2,4-Trichlorobenzene	<1.0	*	1.0	0.31	ug/L			09/02/15 17:57	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 17:57	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 17:57	1
1,2,3-Trichlorobenzene	<1.0	*	1.0	0.24	ug/L			09/02/15 17:57	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		75 - 125		09/02/15 17:57	1
Toluene-d8 (Surr)	102		75 - 120		09/02/15 17:57	1
4-Bromofluorobenzene (Surr)	102		75 - 120		09/02/15 17:57	1
Dibromofluoromethane	89		75 - 120		09/02/15 17:57	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-6

Lab Sample ID: 500-100546-15

Date Collected: 08/26/15 14:30

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 18:23	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 18:23	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 18:23	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 18:23	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 18:23	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 18:23	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 18:23	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 18:23	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 18:23	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 18:23	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 18:23	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 18:23	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 18:23	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 18:23	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/02/15 18:23	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 18:23	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 18:23	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 18:23	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 18:23	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 18:23	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 18:23	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 18:23	1
Trichloroethene	5.0		0.50	0.19	ug/L			09/02/15 18:23	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 18:23	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 18:23	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 18:23	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 18:23	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 18:23	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 18:23	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 18:23	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 18:23	1
Tetrachloroethene	10		1.0	0.17	ug/L			09/02/15 18:23	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 18:23	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 18:23	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 18:23	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 18:23	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 18:23	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 18:23	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 18:23	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 18:23	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 18:23	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 18:23	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 18:23	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 18:23	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 18:23	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 18:23	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 18:23	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 18:23	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 18:23	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-6

Lab Sample ID: 500-100546-15

Date Collected: 08/26/15 14:30

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 18:23	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 18:23	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 18:23	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 18:23	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 18:23	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 18:23	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 18:23	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 18:23	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 18:23	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 18:23	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 18:23	1
1,2,4-Trichlorobenzene	<1.0 *		1.0	0.31	ug/L			09/02/15 18:23	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 18:23	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 18:23	1
1,2,3-Trichlorobenzene	<1.0 *		1.0	0.24	ug/L			09/02/15 18:23	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	103		75 - 125					09/02/15 18:23	1
Toluene-d8 (Surr)	101		75 - 120					09/02/15 18:23	1
4-Bromofluorobenzene (Surr)	97		75 - 120					09/02/15 18:23	1
Dibromofluoromethane	88		75 - 120					09/02/15 18:23	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-7
Date Collected: 08/26/15 14:20
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-16
Matrix: Water

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 18:49	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 18:49	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 18:49	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 18:49	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 18:49	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 18:49	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 18:49	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 18:49	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 18:49	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 18:49	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 18:49	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 18:49	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 18:49	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 18:49	1
cis-1,2-Dichloroethene	4.5		1.0	0.12	ug/L			09/02/15 18:49	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 18:49	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 18:49	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 18:49	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 18:49	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 18:49	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 18:49	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 18:49	1
Trichloroethene	2.8		0.50	0.19	ug/L			09/02/15 18:49	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 18:49	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 18:49	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 18:49	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 18:49	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 18:49	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 18:49	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 18:49	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 18:49	1
Tetrachloroethene	7.4		1.0	0.17	ug/L			09/02/15 18:49	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 18:49	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 18:49	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 18:49	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 18:49	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 18:49	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 18:49	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 18:49	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 18:49	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 18:49	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 18:49	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 18:49	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 18:49	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 18:49	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 18:49	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 18:49	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 18:49	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 18:49	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-7

Lab Sample ID: 500-100546-16

Date Collected: 08/26/15 14:20

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 18:49	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 18:49	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 18:49	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 18:49	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 18:49	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 18:49	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 18:49	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 18:49	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 18:49	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 18:49	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 18:49	1
1,2,4-Trichlorobenzene	<1.0	*	1.0	0.31	ug/L			09/02/15 18:49	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 18:49	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 18:49	1
1,2,3-Trichlorobenzene	<1.0	*	1.0	0.24	ug/L			09/02/15 18:49	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	101		75 - 125					09/02/15 18:49	1
Toluene-d8 (Surr)	101		75 - 120					09/02/15 18:49	1
4-Bromofluorobenzene (Surr)	101		75 - 120					09/02/15 18:49	1
Dibromofluoromethane	90		75 - 120					09/02/15 18:49	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-8
Date Collected: 08/26/15 14:15
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-17
Matrix: Water

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 19:15	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 19:15	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 19:15	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 19:15	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 19:15	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 19:15	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 19:15	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 19:15	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 19:15	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 19:15	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 19:15	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 19:15	1
1,1-Dichloroethane	0.88	J	1.0	0.19	ug/L			09/02/15 19:15	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 19:15	1
cis-1,2-Dichloroethene	26		1.0	0.12	ug/L			09/02/15 19:15	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 19:15	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 19:15	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 19:15	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 19:15	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 19:15	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 19:15	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 19:15	1
Trichloroethene	6.5		0.50	0.19	ug/L			09/02/15 19:15	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 19:15	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 19:15	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 19:15	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 19:15	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 19:15	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 19:15	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 19:15	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 19:15	1
Tetrachloroethene	72		1.0	0.17	ug/L			09/02/15 19:15	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 19:15	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 19:15	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 19:15	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 19:15	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 19:15	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 19:15	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 19:15	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 19:15	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 19:15	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 19:15	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 19:15	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 19:15	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 19:15	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 19:15	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 19:15	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 19:15	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 19:15	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-8

Lab Sample ID: 500-100546-17

Date Collected: 08/26/15 14:15

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 19:15	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 19:15	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 19:15	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 19:15	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 19:15	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 19:15	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 19:15	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 19:15	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 19:15	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 19:15	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 19:15	1
1,2,4-Trichlorobenzene	<1.0	F1 *	1.0	0.31	ug/L			09/02/15 19:15	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 19:15	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 19:15	1
1,2,3-Trichlorobenzene	<1.0	F1 *	1.0	0.24	ug/L			09/02/15 19:15	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	99		75 - 125					09/02/15 19:15	1
Toluene-d8 (Surr)	103		75 - 120					09/02/15 19:15	1
4-Bromofluorobenzene (Surr)	101		75 - 120					09/02/15 19:15	1
Dibromofluoromethane	89		75 - 120					09/02/15 19:15	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-9

Lab Sample ID: 500-100546-18

Date Collected: 08/26/15 14:05

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 17:00	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 17:00	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 17:00	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 17:00	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 17:00	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 17:00	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 17:00	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 17:00	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 17:00	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 17:00	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 17:00	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 17:00	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 17:00	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 17:00	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/02/15 17:00	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 17:00	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 17:00	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 17:00	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 17:00	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 17:00	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 17:00	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 17:00	1
Trichloroethene	0.46	J	0.50	0.19	ug/L			09/02/15 17:00	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 17:00	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 17:00	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 17:00	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 17:00	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 17:00	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 17:00	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 17:00	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 17:00	1
Tetrachloroethene	94		1.0	0.17	ug/L			09/02/15 17:00	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 17:00	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 17:00	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 17:00	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 17:00	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:00	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 17:00	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 17:00	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 17:00	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 17:00	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 17:00	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 17:00	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:00	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 17:00	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 17:00	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 17:00	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 17:00	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 17:00	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-9

Lab Sample ID: 500-100546-18

Date Collected: 08/26/15 14:05

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 17:00	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 17:00	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:00	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:00	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 17:00	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 17:00	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 17:00	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 17:00	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 17:00	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 17:00	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 17:00	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/02/15 17:00	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 17:00	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 17:00	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/02/15 17:00	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	99		75 - 125		09/02/15 17:00	1
Toluene-d8 (Surr)	106		75 - 120		09/02/15 17:00	1
4-Bromofluorobenzene (Surr)	93		75 - 120		09/02/15 17:00	1
Dibromofluoromethane	106		75 - 120		09/02/15 17:00	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-9 DUP

Lab Sample ID: 500-100546-19

Date Collected: 08/26/15 14:05

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 17:27	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 17:27	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 17:27	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 17:27	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 17:27	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 17:27	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 17:27	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 17:27	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 17:27	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 17:27	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 17:27	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 17:27	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 17:27	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 17:27	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/02/15 17:27	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 17:27	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 17:27	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 17:27	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 17:27	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 17:27	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 17:27	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 17:27	1
Trichloroethene	0.52		0.50	0.19	ug/L			09/02/15 17:27	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 17:27	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 17:27	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 17:27	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 17:27	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 17:27	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 17:27	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 17:27	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 17:27	1
Tetrachloroethene	99		1.0	0.17	ug/L			09/02/15 17:27	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 17:27	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 17:27	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 17:27	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 17:27	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:27	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 17:27	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 17:27	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 17:27	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 17:27	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 17:27	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 17:27	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:27	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 17:27	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 17:27	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 17:27	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 17:27	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 17:27	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-9 DUP

Lab Sample ID: 500-100546-19

Date Collected: 08/26/15 14:05

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 17:27	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 17:27	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:27	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:27	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 17:27	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 17:27	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 17:27	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 17:27	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 17:27	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 17:27	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 17:27	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/02/15 17:27	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 17:27	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 17:27	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/02/15 17:27	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		75 - 125		09/02/15 17:27	1
Toluene-d8 (Surr)	104		75 - 120		09/02/15 17:27	1
4-Bromofluorobenzene (Surr)	90		75 - 120		09/02/15 17:27	1
Dibromofluoromethane	107		75 - 120		09/02/15 17:27	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-10

Lab Sample ID: 500-100546-20

Date Collected: 08/26/15 14:00

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 17:55	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 17:55	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 17:55	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 17:55	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 17:55	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 17:55	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 17:55	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 17:55	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 17:55	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 17:55	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 17:55	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 17:55	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 17:55	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 17:55	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/02/15 17:55	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 17:55	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 17:55	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 17:55	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 17:55	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 17:55	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 17:55	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 17:55	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/02/15 17:55	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 17:55	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 17:55	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 17:55	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 17:55	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 17:55	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 17:55	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 17:55	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 17:55	1
Tetrachloroethene	1.5		1.0	0.17	ug/L			09/02/15 17:55	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 17:55	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 17:55	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 17:55	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 17:55	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:55	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 17:55	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 17:55	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 17:55	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 17:55	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 17:55	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 17:55	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:55	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 17:55	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 17:55	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 17:55	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 17:55	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 17:55	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-10

Lab Sample ID: 500-100546-20

Date Collected: 08/26/15 14:00

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 17:55	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 17:55	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:55	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 17:55	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 17:55	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 17:55	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 17:55	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 17:55	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 17:55	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 17:55	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 17:55	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/02/15 17:55	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 17:55	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 17:55	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/02/15 17:55	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	99		75 - 125		09/02/15 17:55	1
Toluene-d8 (Surr)	105		75 - 120		09/02/15 17:55	1
4-Bromofluorobenzene (Surr)	91		75 - 120		09/02/15 17:55	1
Dibromofluoromethane	107		75 - 120		09/02/15 17:55	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-9

Lab Sample ID: 500-100546-21

Date Collected: 08/26/15 17:00

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 18:23	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 18:23	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 18:23	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 18:23	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 18:23	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 18:23	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 18:23	1
1,1-Dichloroethene	0.64	J	1.0	0.31	ug/L			09/02/15 18:23	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 18:23	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 18:23	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 18:23	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 18:23	1
1,1-Dichloroethane	0.55	J	1.0	0.19	ug/L			09/02/15 18:23	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 18:23	1
cis-1,2-Dichloroethene	14		1.0	0.12	ug/L			09/02/15 18:23	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 18:23	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 18:23	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 18:23	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 18:23	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 18:23	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 18:23	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 18:23	1
Trichloroethene	7.8		0.50	0.19	ug/L			09/02/15 18:23	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 18:23	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 18:23	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 18:23	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 18:23	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 18:23	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 18:23	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 18:23	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 18:23	1
Tetrachloroethene	4.2		1.0	0.17	ug/L			09/02/15 18:23	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 18:23	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 18:23	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 18:23	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 18:23	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 18:23	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 18:23	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 18:23	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 18:23	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 18:23	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 18:23	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 18:23	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 18:23	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 18:23	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 18:23	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 18:23	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 18:23	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 18:23	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-9

Lab Sample ID: 500-100546-21

Date Collected: 08/26/15 17:00

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 18:23	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 18:23	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 18:23	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 18:23	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 18:23	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 18:23	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 18:23	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 18:23	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 18:23	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 18:23	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 18:23	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/02/15 18:23	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 18:23	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 18:23	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/02/15 18:23	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	99		75 - 125		09/02/15 18:23	1
Toluene-d8 (Surr)	105		75 - 120		09/02/15 18:23	1
4-Bromofluorobenzene (Surr)	89		75 - 120		09/02/15 18:23	1
Dibromofluoromethane	106		75 - 120		09/02/15 18:23	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-11B

Lab Sample ID: 500-100546-22

Date Collected: 08/27/15 11:00

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/03/15 03:17	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/03/15 03:17	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/03/15 03:17	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/03/15 03:17	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/03/15 03:17	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/03/15 03:17	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/03/15 03:17	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/03/15 03:17	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/03/15 03:17	1
Acetone	<5.0		5.0	1.3	ug/L			09/03/15 03:17	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/03/15 03:17	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/03/15 03:17	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/03/15 03:17	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/03/15 03:17	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/03/15 03:17	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/03/15 03:17	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/03/15 03:17	1
Chloroform	<1.0		1.0	0.20	ug/L			09/03/15 03:17	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/03/15 03:17	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/03/15 03:17	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/03/15 03:17	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/03/15 03:17	1
Trichloroethene	2.4		0.50	0.19	ug/L			09/03/15 03:17	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/03/15 03:17	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/03/15 03:17	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/03/15 03:17	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/03/15 03:17	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/03/15 03:17	1
Toluene	<0.50		0.50	0.11	ug/L			09/03/15 03:17	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/03/15 03:17	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/03/15 03:17	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/03/15 03:17	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/03/15 03:17	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/03/15 03:17	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/03/15 03:17	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/03/15 03:17	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/03/15 03:17	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/03/15 03:17	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/03/15 03:17	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/03/15 03:17	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/03/15 03:17	1
Styrene	<1.0		1.0	0.10	ug/L			09/03/15 03:17	1
Bromoform	<1.0		1.0	0.28	ug/L			09/03/15 03:17	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 03:17	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/03/15 03:17	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/03/15 03:17	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/03/15 03:17	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/03/15 03:17	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/03/15 03:17	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-11B

Lab Sample ID: 500-100546-22

Date Collected: 08/27/15 11:00

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/03/15 03:17	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/03/15 03:17	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 03:17	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 03:17	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/03/15 03:17	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/15 03:17	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/03/15 03:17	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/15 03:17	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/03/15 03:17	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/03/15 03:17	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/03/15 03:17	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/03/15 03:17	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/03/15 03:17	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/03/15 03:17	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/03/15 03:17	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	100		75 - 125		09/03/15 03:17	1
Toluene-d8 (Surr)	92		75 - 120		09/03/15 03:17	1
4-Bromofluorobenzene (Surr)	100		75 - 120		09/03/15 03:17	1
Dibromofluoromethane	91		75 - 120		09/03/15 03:17	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-12B

Lab Sample ID: 500-100546-23

Date Collected: 08/27/15 12:00

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil	Fac
Benzene	<0.50		0.50	0.074	ug/L			09/03/15 03:42		1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/03/15 03:42		1
Chloromethane	<1.0		1.0	0.18	ug/L			09/03/15 03:42		1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/03/15 03:42		1
Bromomethane	<1.0		1.0	0.31	ug/L			09/03/15 03:42		1
Chloroethane	<1.0		1.0	0.34	ug/L			09/03/15 03:42		1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/03/15 03:42		1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/03/15 03:42		1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/03/15 03:42		1
Acetone	<5.0		5.0	1.3	ug/L			09/03/15 03:42		1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/03/15 03:42		1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/03/15 03:42		1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/03/15 03:42		1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/03/15 03:42		1
cis-1,2-Dichloroethene	1.3		1.0	0.12	ug/L			09/03/15 03:42		1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/03/15 03:42		1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/03/15 03:42		1
Chloroform	<1.0		1.0	0.20	ug/L			09/03/15 03:42		1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/03/15 03:42		1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/03/15 03:42		1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/03/15 03:42		1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/03/15 03:42		1
Trichloroethene	34		0.50	0.19	ug/L			09/03/15 03:42		1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/03/15 03:42		1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/03/15 03:42		1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/03/15 03:42		1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/03/15 03:42		1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/03/15 03:42		1
Toluene	<0.50		0.50	0.11	ug/L			09/03/15 03:42		1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/03/15 03:42		1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/03/15 03:42		1
Tetrachloroethene	6.9		1.0	0.17	ug/L			09/03/15 03:42		1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/03/15 03:42		1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/03/15 03:42		1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/03/15 03:42		1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/03/15 03:42		1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/03/15 03:42		1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/03/15 03:42		1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/03/15 03:42		1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/03/15 03:42		1
o-Xylene	<0.50		0.50	0.068	ug/L			09/03/15 03:42		1
Styrene	<1.0		1.0	0.10	ug/L			09/03/15 03:42		1
Bromoform	<1.0		1.0	0.28	ug/L			09/03/15 03:42		1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 03:42		1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/03/15 03:42		1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/03/15 03:42		1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/03/15 03:42		1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/03/15 03:42		1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/03/15 03:42		1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-12B

Lab Sample ID: 500-100546-23

Date Collected: 08/27/15 12:00

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/03/15 03:42	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/03/15 03:42	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 03:42	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 03:42	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/03/15 03:42	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/15 03:42	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/03/15 03:42	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/15 03:42	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/03/15 03:42	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/03/15 03:42	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/03/15 03:42	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/03/15 03:42	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/03/15 03:42	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/03/15 03:42	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/03/15 03:42	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	101		75 - 125		09/03/15 03:42	1
Toluene-d8 (Surr)	92		75 - 120		09/03/15 03:42	1
4-Bromofluorobenzene (Surr)	101		75 - 120		09/03/15 03:42	1
Dibromofluoromethane	90		75 - 120		09/03/15 03:42	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-13

Lab Sample ID: 500-100546-24

Date Collected: 08/27/15 07:15

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/03/15 04:07	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/03/15 04:07	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/03/15 04:07	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/03/15 04:07	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/03/15 04:07	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/03/15 04:07	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/03/15 04:07	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/03/15 04:07	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/03/15 04:07	1
Acetone	<5.0		5.0	1.3	ug/L			09/03/15 04:07	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/03/15 04:07	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/03/15 04:07	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/03/15 04:07	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/03/15 04:07	1
cis-1,2-Dichloroethene	0.87	J	1.0	0.12	ug/L			09/03/15 04:07	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/03/15 04:07	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/03/15 04:07	1
Chloroform	<1.0		1.0	0.20	ug/L			09/03/15 04:07	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/03/15 04:07	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/03/15 04:07	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/03/15 04:07	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/03/15 04:07	1
Trichloroethene	2.4		0.50	0.19	ug/L			09/03/15 04:07	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/03/15 04:07	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/03/15 04:07	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/03/15 04:07	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/03/15 04:07	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/03/15 04:07	1
Toluene	<0.50		0.50	0.11	ug/L			09/03/15 04:07	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/03/15 04:07	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/03/15 04:07	1
Tetrachloroethene	14		1.0	0.17	ug/L			09/03/15 04:07	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/03/15 04:07	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/03/15 04:07	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/03/15 04:07	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/03/15 04:07	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/03/15 04:07	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/03/15 04:07	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/03/15 04:07	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/03/15 04:07	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/03/15 04:07	1
Styrene	<1.0		1.0	0.10	ug/L			09/03/15 04:07	1
Bromoform	<1.0		1.0	0.28	ug/L			09/03/15 04:07	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 04:07	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/03/15 04:07	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/03/15 04:07	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/03/15 04:07	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/03/15 04:07	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/03/15 04:07	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-13

Lab Sample ID: 500-100546-24

Date Collected: 08/27/15 07:15

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/03/15 04:07	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/03/15 04:07	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 04:07	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 04:07	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/03/15 04:07	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/15 04:07	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/03/15 04:07	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/15 04:07	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/03/15 04:07	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/03/15 04:07	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/03/15 04:07	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/03/15 04:07	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/03/15 04:07	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/03/15 04:07	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/03/15 04:07	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	100		75 - 125		09/03/15 04:07	1
Toluene-d8 (Surr)	92		75 - 120		09/03/15 04:07	1
4-Bromofluorobenzene (Surr)	103		75 - 120		09/03/15 04:07	1
Dibromofluoromethane	93		75 - 120		09/03/15 04:07	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-17

Lab Sample ID: 500-100546-25

Date Collected: 08/27/15 12:50

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	0.55		0.50	0.074	ug/L			09/03/15 05:23	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/03/15 05:23	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/03/15 05:23	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/03/15 05:23	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/03/15 05:23	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/03/15 05:23	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/03/15 05:23	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/03/15 05:23	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/03/15 05:23	1
Acetone	<5.0		5.0	1.3	ug/L			09/03/15 05:23	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/03/15 05:23	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/03/15 05:23	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/03/15 05:23	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/03/15 05:23	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/03/15 05:23	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/03/15 05:23	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/03/15 05:23	1
Chloroform	<1.0		1.0	0.20	ug/L			09/03/15 05:23	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/03/15 05:23	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/03/15 05:23	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/03/15 05:23	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/03/15 05:23	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/03/15 05:23	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/03/15 05:23	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/03/15 05:23	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/03/15 05:23	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/03/15 05:23	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/03/15 05:23	1
Toluene	<0.50		0.50	0.11	ug/L			09/03/15 05:23	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/03/15 05:23	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/03/15 05:23	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/03/15 05:23	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/03/15 05:23	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/03/15 05:23	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/03/15 05:23	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/03/15 05:23	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/03/15 05:23	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/03/15 05:23	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/03/15 05:23	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/03/15 05:23	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/03/15 05:23	1
Styrene	<1.0		1.0	0.10	ug/L			09/03/15 05:23	1
Bromoform	<1.0		1.0	0.28	ug/L			09/03/15 05:23	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 05:23	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/03/15 05:23	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/03/15 05:23	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/03/15 05:23	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/03/15 05:23	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/03/15 05:23	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-17

Lab Sample ID: 500-100546-25

Date Collected: 08/27/15 12:50

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/03/15 05:23	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/03/15 05:23	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 05:23	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 05:23	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/03/15 05:23	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/15 05:23	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/03/15 05:23	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/15 05:23	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/03/15 05:23	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/03/15 05:23	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/03/15 05:23	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/03/15 05:23	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/03/15 05:23	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/03/15 05:23	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/03/15 05:23	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	95		75 - 125		09/03/15 05:23	1
Toluene-d8 (Surr)	92		75 - 120		09/03/15 05:23	1
4-Bromofluorobenzene (Surr)	95		75 - 120		09/03/15 05:23	1
Dibromofluoromethane	88		75 - 120		09/03/15 05:23	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: Trip Blank

Lab Sample ID: 500-100546-26

Date Collected: 08/26/15 07:00

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 12:56	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 12:56	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 12:56	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 12:56	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 12:56	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 12:56	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 12:56	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 12:56	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 12:56	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 12:56	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 12:56	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 12:56	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 12:56	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 12:56	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/02/15 12:56	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 12:56	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 12:56	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 12:56	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 12:56	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 12:56	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 12:56	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 12:56	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/02/15 12:56	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 12:56	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 12:56	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 12:56	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 12:56	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 12:56	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 12:56	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 12:56	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 12:56	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/02/15 12:56	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 12:56	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 12:56	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 12:56	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 12:56	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 12:56	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 12:56	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 12:56	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 12:56	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 12:56	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 12:56	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 12:56	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 12:56	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 12:56	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 12:56	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 12:56	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 12:56	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 12:56	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: Trip Blank

Lab Sample ID: 500-100546-26

Date Collected: 08/26/15 07:00

Matrix: Water

Date Received: 08/28/15 10:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 12:56	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 12:56	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 12:56	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 12:56	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 12:56	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 12:56	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 12:56	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 12:56	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 12:56	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 12:56	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 12:56	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/02/15 12:56	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 12:56	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 12:56	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/02/15 12:56	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		75 - 125		09/02/15 12:56	1
Toluene-d8 (Surr)	106		75 - 120		09/02/15 12:56	1
4-Bromofluorobenzene (Surr)	93		75 - 120		09/02/15 12:56	1
Dibromofluoromethane	109		75 - 120		09/02/15 12:56	1

Definitions/Glossary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Qualifiers

GC/MS VOA

Qualifier	Qualifier Description
*	LCS or LCSD is outside acceptance limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
F1	MS and/or MSD Recovery is outside acceptance limits.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
▫	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CNF	Contains no Free Liquid
DER	Duplicate error ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision level concentration
MDA	Minimum detectable activity
EDL	Estimated Detection Limit
MDC	Minimum detectable concentration
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
NC	Not Calculated
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative error ratio
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

QC Association Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

GC/MS VOA

Analysis Batch: 302681

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-100546-3	RFW-2A	Total/NA	Water	8260B	
500-100546-4	RFW-2B	Total/NA	Water	8260B	
500-100546-5	RFW-3B	Total/NA	Water	8260B	
500-100546-6	RFW-4A	Total/NA	Water	8260B	
500-100546-7	RFW-4A DUP	Total/NA	Water	8260B	
500-100546-8	RFW-4B	Total/NA	Water	8260B	
500-100546-9	RFW-6	Total/NA	Water	8260B	
500-100546-10	RFW-7	Total/NA	Water	8260B	
500-100546-11	EW-2	Total/NA	Water	8260B	
500-100546-12	EW-3	Total/NA	Water	8260B	
500-100546-13	EW-4	Total/NA	Water	8260B	
500-100546-13 - DL	EW-4	Total/NA	Water	8260B	
500-100546-14	EW-5	Total/NA	Water	8260B	
500-100546-15	EW-6	Total/NA	Water	8260B	
500-100546-16	EW-7	Total/NA	Water	8260B	
500-100546-17	EW-8	Total/NA	Water	8260B	
500-100546-17 MS	EW-8	Total/NA	Water	8260B	
500-100546-17 MSD	EW-8	Total/NA	Water	8260B	
LCS 500-302681/4	Lab Control Sample	Total/NA	Water	8260B	
MB 500-302681/29	Method Blank	Total/NA	Water	8260B	

Analysis Batch: 302682

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-100546-18	EW-9	Total/NA	Water	8260B	
500-100546-19	EW-9 DUP	Total/NA	Water	8260B	
500-100546-20	EW-10	Total/NA	Water	8260B	
500-100546-21	RFW-9	Total/NA	Water	8260B	
500-100546-26	Trip Blank	Total/NA	Water	8260B	
LCS 500-302682/4	Lab Control Sample	Total/NA	Water	8260B	
MB 500-302682/29	Method Blank	Total/NA	Water	8260B	

Analysis Batch: 302848

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-100546-1	RFW-1A	Total/NA	Water	8260B	
500-100546-2	RFW-1B	Total/NA	Water	8260B	
500-100546-22	RFW-11B	Total/NA	Water	8260B	
500-100546-23	RFW-12B	Total/NA	Water	8260B	
500-100546-24	RFW-13	Total/NA	Water	8260B	
500-100546-25	RFW-17	Total/NA	Water	8260B	
LCS 500-302848/4	Lab Control Sample	Total/NA	Water	8260B	
MB 500-302848/6	Method Blank	Total/NA	Water	8260B	

Surrogate Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Method: 8260B - VOC

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	12DCE	TOL	BFB	DBFM
		(75-125)	(75-120)	(75-120)	(75-120)
500-100546-1	RFW-1A	95	90	97	90
500-100546-2	RFW-1B	96	91	93	91
500-100546-3	RFW-2A	98	103	100	87
500-100546-4	RFW-2B	98	101	95	88
500-100546-5	RFW-3B	98	103	101	87
500-100546-6	RFW-4A	100	101	98	89
500-100546-7	RFW-4A DUP	102	100	100	90
500-100546-8	RFW-4B	101	100	102	89
500-100546-9	RFW-6	100	100	102	90
500-100546-10	RFW-7	103	102	101	90
500-100546-11	EW-2	102	100	101	87
500-100546-12	EW-3	100	102	101	90
500-100546-13	EW-4	101	103	100	91
500-100546-13 - DL	EW-4	102	100	99	89
500-100546-14	EW-5	102	102	102	89
500-100546-15	EW-6	103	101	97	88
500-100546-16	EW-7	101	101	101	90
500-100546-17	EW-8	99	103	101	89
500-100546-17 MS	EW-8	99	100	100	94
500-100546-17 MSD	EW-8	101	105	102	96
500-100546-18	EW-9	99	106	93	106
500-100546-19	EW-9 DUP	102	104	90	107
500-100546-20	EW-10	99	105	91	107
500-100546-21	RFW-9	99	105	89	106
500-100546-22	RFW-11B	100	92	100	91
500-100546-23	RFW-12B	101	92	101	90
500-100546-24	RFW-13	100	92	103	93
500-100546-25	RFW-17	95	92	95	88
500-100546-26	Trip Blank	102	106	93	109
LCS 500-302681/4	Lab Control Sample	92	103	99	94
LCS 500-302682/4	Lab Control Sample	90	105	104	98
LCS 500-302848/4	Lab Control Sample	94	95	91	86
MB 500-302681/29	Method Blank	94	101	100	87
MB 500-302682/29	Method Blank	97	106	92	104
MB 500-302848/6	Method Blank	98	93	94	89

Surrogate Legend

12DCE = 1,2-Dichloroethane-d4 (Surr)
TOL = Toluene-d8 (Surr)
BFB = 4-Bromofluorobenzene (Surr)
DBFM = Dibromofluoromethane

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Method: 8260B - VOC

Lab Sample ID: MB 500-302681/29
Matrix: Water
Analysis Batch: 302681

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 11:45	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 11:45	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 11:45	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 11:45	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 11:45	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 11:45	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 11:45	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 11:45	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 11:45	1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 11:45	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 11:45	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 11:45	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 11:45	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 11:45	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/02/15 11:45	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 11:45	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 11:45	1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 11:45	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 11:45	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 11:45	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 11:45	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 11:45	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/02/15 11:45	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 11:45	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 11:45	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 11:45	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 11:45	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 11:45	1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 11:45	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 11:45	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 11:45	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/02/15 11:45	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 11:45	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 11:45	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 11:45	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 11:45	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 11:45	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 11:45	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 11:45	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 11:45	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 11:45	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 11:45	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 11:45	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 11:45	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 11:45	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 11:45	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 11:45	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 11:45	1

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Method: 8260B - VOC (Continued)

Lab Sample ID: MB 500-302681/29
Matrix: Water
Analysis Batch: 302681

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 11:45	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 11:45	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 11:45	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 11:45	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 11:45	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 11:45	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 11:45	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 11:45	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 11:45	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 11:45	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 11:45	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 11:45	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/02/15 11:45	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 11:45	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 11:45	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/02/15 11:45	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
1,2-Dichloroethane-d4 (Surr)	94		75 - 125		09/02/15 11:45	1
Toluene-d8 (Surr)	101		75 - 120		09/02/15 11:45	1
4-Bromofluorobenzene (Surr)	100		75 - 120		09/02/15 11:45	1
Dibromofluoromethane	87		75 - 120		09/02/15 11:45	1

Lab Sample ID: LCS 500-302681/4
Matrix: Water
Analysis Batch: 302681

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS		Unit	D	%Rec	%Rec. Limits
		Result	Qualifier				
Benzene	50.0	50.6		ug/L		101	70 - 120
Dichlorodifluoromethane	50.0	49.8		ug/L		100	30 - 150
Chloromethane	50.0	69.2		ug/L		138	45 - 140
Vinyl chloride	50.0	60.1		ug/L		120	63 - 127
Bromomethane	50.0	54.5		ug/L		109	30 - 170
Chloroethane	50.0	44.0		ug/L		88	40 - 150
Trichlorofluoromethane	50.0	48.0		ug/L		96	65 - 134
1,1-Dichloroethene	50.0	50.8		ug/L		102	68 - 121
Carbon disulfide	50.0	53.8		ug/L		108	61 - 120
Acetone	50.0	50.4		ug/L		101	47 - 131
Methylene Chloride	50.0	50.9		ug/L		102	70 - 120
trans-1,2-Dichloroethene	50.0	52.7		ug/L		105	70 - 120
1,1-Dichloroethane	50.0	55.8		ug/L		112	70 - 127
2,2-Dichloropropane	50.0	58.3		ug/L		117	68 - 120
cis-1,2-Dichloroethene	50.0	52.8		ug/L		106	70 - 120
Methyl Ethyl Ketone	50.0	49.2		ug/L		98	51 - 134
Bromochloromethane	50.0	47.7		ug/L		95	70 - 121
Chloroform	50.0	51.4		ug/L		103	70 - 120
1,1,1-Trichloroethane	50.0	54.0		ug/L		108	70 - 125
1,1-Dichloropropene	50.0	51.5		ug/L		103	70 - 126

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-302681/4
Matrix: Water
Analysis Batch: 302681

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Carbon tetrachloride	50.0	51.3		ug/L		103	70 - 136
1,2-Dichloroethane	50.0	52.0		ug/L		104	66 - 132
Trichloroethene	50.0	47.8		ug/L		96	70 - 122
1,2-Dichloropropane	50.0	57.7		ug/L		115	70 - 127
Dibromomethane	50.0	51.3		ug/L		103	70 - 120
Bromodichloromethane	50.0	52.1		ug/L		104	70 - 127
cis-1,3-Dichloropropene	50.0	55.3		ug/L		111	70 - 122
methyl isobutyl ketone	50.0	56.9		ug/L		114	53 - 135
Toluene	50.0	55.4		ug/L		111	70 - 120
trans-1,3-Dichloropropene	50.0	57.8		ug/L		116	70 - 123
1,1,2-Trichloroethane	50.0	56.0		ug/L		112	70 - 125
Tetrachloroethene	50.0	54.6		ug/L		109	70 - 129
1,3-Dichloropropane	50.0	54.9		ug/L		110	70 - 127
2-Hexanone	50.0	58.1		ug/L		116	53 - 140
Dibromochloromethane	50.0	53.1		ug/L		106	70 - 120
1,2-Dibromoethane	50.0	55.2		ug/L		110	70 - 124
Chlorobenzene	50.0	53.8		ug/L		108	70 - 120
1,1,1,2-Tetrachloroethane	50.0	53.9		ug/L		108	70 - 124
Ethylbenzene	50.0	54.4		ug/L		109	70 - 125
m&p-Xylene	50.0	54.3		ug/L		109	70 - 120
o-Xylene	50.0	54.6		ug/L		109	70 - 120
Styrene	50.0	57.5		ug/L		115	70 - 120
Bromoform	50.0	57.7		ug/L		115	70 - 135
Isopropylbenzene	50.0	53.3		ug/L		107	70 - 132
Bromobenzene	50.0	55.5		ug/L		111	70 - 129
1,1,2,2-Tetrachloroethane	50.0	55.8		ug/L		112	68 - 133
1,2,3-Trichloropropane	50.0	52.7		ug/L		105	53 - 139
N-Propylbenzene	50.0	54.7		ug/L		109	70 - 132
2-Chlorotoluene	50.0	53.5		ug/L		107	70 - 128
1,3,5-Trimethylbenzene	50.0	53.0		ug/L		106	70 - 129
4-Chlorotoluene	50.0	53.9		ug/L		108	70 - 127
tert-Butylbenzene	50.0	51.3		ug/L		103	70 - 137
1,2,4-Trimethylbenzene	50.0	53.9		ug/L		108	70 - 127
sec-Butylbenzene	50.0	53.8		ug/L		108	70 - 134
1,3-Dichlorobenzene	50.0	54.2		ug/L		108	70 - 122
p-Isopropyltoluene	50.0	52.1		ug/L		104	70 - 133
1,4-Dichlorobenzene	50.0	52.9		ug/L		106	70 - 120
n-Butylbenzene	50.0	55.5		ug/L		111	70 - 129
1,2-Dichlorobenzene	50.0	53.4		ug/L		107	70 - 123
1,2-Dibromo-3-Chloropropane	50.0	54.5		ug/L		109	59 - 139
1,2,4-Trichlorobenzene	50.0	63.1	*	ug/L		126	70 - 125
Hexachlorobutadiene	50.0	63.7		ug/L		127	70 - 138
Naphthalene	50.0	58.6		ug/L		117	59 - 143
1,2,3-Trichlorobenzene	50.0	70.1	*	ug/L		140	70 - 133

Surrogate	LCS %Recovery	LCS Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	92		75 - 125
Toluene-d8 (Surr)	103		75 - 120

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-302681/4

Matrix: Water

Analysis Batch: 302681

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Surrogate	LCS %Recovery	LCS Qualifier	Limits
4-Bromofluorobenzene (Surr)	99		75 - 120
Dibromofluoromethane	94		75 - 120

Lab Sample ID: 500-100546-17 MS

Matrix: Water

Analysis Batch: 302681

Client Sample ID: EW-8

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Benzene	<0.50		50.0	53.3		ug/L		107	70 - 120
Dichlorodifluoromethane	<1.0		50.0	46.3		ug/L		93	30 - 150
Chloromethane	<1.0		50.0	68.8		ug/L		138	45 - 140
Vinyl chloride	<0.50		50.0	59.8		ug/L		120	63 - 127
Bromomethane	<1.0		50.0	56.3		ug/L		113	30 - 170
Chloroethane	<1.0		50.0	48.0		ug/L		96	40 - 150
Trichlorofluoromethane	<1.0		50.0	51.3		ug/L		103	65 - 134
1,1-Dichloroethene	<1.0		50.0	49.8		ug/L		100	68 - 121
Carbon disulfide	<5.0		50.0	49.7		ug/L		99	61 - 120
Acetone	<5.0		50.0	46.5		ug/L		93	47 - 131
Methylene Chloride	<5.0		50.0	54.2		ug/L		108	70 - 120
trans-1,2-Dichloroethene	<1.0		50.0	52.2		ug/L		104	70 - 120
1,1-Dichloroethane	0.88	J	50.0	57.8		ug/L		114	70 - 127
2,2-Dichloropropane	<1.0		50.0	53.2		ug/L		106	68 - 120
cis-1,2-Dichloroethene	26		50.0	82.5		ug/L		112	70 - 120
Methyl Ethyl Ketone	<5.0		50.0	53.7		ug/L		107	51 - 134
Bromochloromethane	<1.0		50.0	52.5		ug/L		105	70 - 121
Chloroform	<1.0		50.0	53.6		ug/L		107	70 - 120
1,1,1-Trichloroethane	<1.0		50.0	53.3		ug/L		107	70 - 125
1,1-Dichloropropene	<1.0		50.0	51.0		ug/L		102	70 - 126
Carbon tetrachloride	<1.0		50.0	49.7		ug/L		99	70 - 136
1,2-Dichloroethane	<1.0		50.0	56.3		ug/L		113	66 - 132
Trichloroethene	6.5		50.0	55.0		ug/L		97	70 - 122
1,2-Dichloropropane	<1.0		50.0	60.2		ug/L		120	70 - 127
Dibromomethane	<1.0		50.0	55.3		ug/L		111	70 - 120
Bromodichloromethane	<1.0		50.0	53.6		ug/L		107	70 - 127
cis-1,3-Dichloropropene	<1.0		50.0	54.6		ug/L		109	70 - 122
methyl isobutyl ketone	<5.0		50.0	56.8		ug/L		114	53 - 135
Toluene	<0.50		50.0	55.4		ug/L		111	70 - 120
trans-1,3-Dichloropropene	<1.0		50.0	58.7		ug/L		117	70 - 123
1,1,2-Trichloroethane	<1.0		50.0	57.8		ug/L		116	70 - 125
Tetrachloroethene	72		50.0	127		ug/L		109	70 - 129
1,3-Dichloropropane	<1.0		50.0	56.5		ug/L		113	70 - 127
2-Hexanone	<5.0		50.0	57.6		ug/L		115	53 - 140
Dibromochloromethane	<1.0		50.0	53.0		ug/L		106	70 - 120
1,2-Dibromoethane	<1.0		50.0	55.4		ug/L		111	70 - 124
Chlorobenzene	<1.0		50.0	53.6		ug/L		107	70 - 120
1,1,1,2-Tetrachloroethane	<1.0		50.0	55.1		ug/L		110	70 - 124
Ethylbenzene	<0.50		50.0	52.9		ug/L		106	70 - 125
m&p-Xylene	<1.0		50.0	53.4		ug/L		107	70 - 120

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Method: 8260B - VOC (Continued)

Lab Sample ID: 500-100546-17 MS
Matrix: Water
Analysis Batch: 302681

Client Sample ID: EW-8
Prep Type: Total/NA

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec.	Limits
	Result	Qualifier	Added	Result	Qualifier					
o-Xylene	<0.50		50.0	54.5		ug/L		109	70 - 120	
Styrene	<1.0		50.0	57.5		ug/L		115	70 - 120	
Bromoform	<1.0		50.0	56.8		ug/L		114	70 - 135	
Isopropylbenzene	<1.0		50.0	53.2		ug/L		106	70 - 132	
Bromobenzene	<1.0		50.0	57.7		ug/L		115	70 - 129	
1,1,2,2-Tetrachloroethane	<1.0		50.0	61.2		ug/L		122	68 - 133	
1,2,3-Trichloropropane	<1.0		50.0	56.4		ug/L		113	53 - 139	
N-Propylbenzene	<1.0		50.0	54.0		ug/L		108	70 - 132	
2-Chlorotoluene	<1.0		50.0	54.5		ug/L		109	70 - 128	
1,3,5-Trimethylbenzene	<1.0		50.0	54.0		ug/L		108	70 - 129	
4-Chlorotoluene	<1.0		50.0	53.8		ug/L		108	70 - 127	
tert-Butylbenzene	<1.0		50.0	52.3		ug/L		105	70 - 137	
1,2,4-Trimethylbenzene	<1.0		50.0	54.5		ug/L		109	70 - 127	
sec-Butylbenzene	<1.0		50.0	54.4		ug/L		109	70 - 134	
1,3-Dichlorobenzene	<1.0		50.0	55.9		ug/L		112	70 - 122	
p-Isopropyltoluene	<1.0		50.0	52.3		ug/L		105	70 - 133	
1,4-Dichlorobenzene	<1.0		50.0	54.7		ug/L		109	70 - 120	
n-Butylbenzene	<1.0		50.0	54.5		ug/L		109	70 - 129	
1,2-Dichlorobenzene	<1.0		50.0	57.9		ug/L		116	70 - 123	
1,2-Dibromo-3-Chloropropane	<2.0		50.0	61.7		ug/L		123	59 - 139	
1,2,4-Trichlorobenzene	<1.0	F1 *	50.0	66.3	F1	ug/L		133	70 - 125	
Hexachlorobutadiene	<1.0		50.0	66.2		ug/L		132	70 - 138	
Naphthalene	<1.0		50.0	63.6		ug/L		127	59 - 143	
1,2,3-Trichlorobenzene	<1.0	F1 *	50.0	75.4	F1	ug/L		151	70 - 133	

Surrogate	MS	MS	Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	99		75 - 125
Toluene-d8 (Surr)	100		75 - 120
4-Bromofluorobenzene (Surr)	100		75 - 120
Dibromofluoromethane	94		75 - 120

Lab Sample ID: 500-100546-17 MSD
Matrix: Water
Analysis Batch: 302681

Client Sample ID: EW-8
Prep Type: Total/NA

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec.	Limits	RPD	RPD	Limit
	Result	Qualifier	Added	Result	Qualifier								
Benzene	<0.50		50.0	49.2		ug/L		98	70 - 120	8	20		
Dichlorodifluoromethane	<1.0		50.0	48.3		ug/L		97	30 - 150	4	20		
Chloromethane	<1.0		50.0	67.3		ug/L		135	45 - 140	2	20		
Vinyl chloride	<0.50		50.0	58.7		ug/L		117	63 - 127	2	20		
Bromomethane	<1.0		50.0	52.0		ug/L		104	30 - 170	8	20		
Chloroethane	<1.0		50.0	41.9		ug/L		84	40 - 150	14	20		
Trichlorofluoromethane	<1.0		50.0	50.8		ug/L		102	65 - 134	1	20		
1,1-Dichloroethene	<1.0		50.0	46.3		ug/L		93	68 - 121	7	20		
Carbon disulfide	<5.0		50.0	47.1		ug/L		94	61 - 120	5	20		
Acetone	<5.0		50.0	47.0		ug/L		94	47 - 131	1	20		
Methylene Chloride	<5.0		50.0	48.6		ug/L		97	70 - 120	11	20		
trans-1,2-Dichloroethene	<1.0		50.0	47.9		ug/L		96	70 - 120	9	20		

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Method: 8260B - VOC (Continued)

Lab Sample ID: 500-100546-17 MSD

Matrix: Water

Analysis Batch: 302681

Client Sample ID: EW-8

Prep Type: Total/NA

Analyte	Sample	Sample	Spike	MSD		Unit	D	%Rec	%Rec.	RPD	RPD	Limit
	Result	Qualifier	Added	Result	Qualifier				Limits		Limit	
1,1-Dichloroethane	0.88	J	50.0	52.3		ug/L		103	70 - 127	10	20	
2,2-Dichloropropane	<1.0		50.0	47.7		ug/L		95	68 - 120	11	20	
cis-1,2-Dichloroethene	26		50.0	76.4		ug/L		100	70 - 120	8	20	
Methyl Ethyl Ketone	<5.0		50.0	55.1		ug/L		110	51 - 134	3	20	
Bromochloromethane	<1.0		50.0	48.3		ug/L		97	70 - 121	8	20	
Chloroform	<1.0		50.0	49.3		ug/L		99	70 - 120	8	20	
1,1,1-Trichloroethane	<1.0		50.0	49.3		ug/L		99	70 - 125	8	20	
1,1-Dichloropropene	<1.0		50.0	47.9		ug/L		96	70 - 126	6	20	
Carbon tetrachloride	<1.0		50.0	46.3		ug/L		93	70 - 136	7	20	
1,2-Dichloroethane	<1.0		50.0	53.4		ug/L		107	66 - 132	5	20	
Trichloroethene	6.5		50.0	51.2		ug/L		89	70 - 122	7	20	
1,2-Dichloropropane	<1.0		50.0	57.1		ug/L		114	70 - 127	5	20	
Dibromomethane	<1.0		50.0	52.9		ug/L		106	70 - 120	4	20	
Bromodichloromethane	<1.0		50.0	51.3		ug/L		103	70 - 127	5	20	
cis-1,3-Dichloropropene	<1.0		50.0	53.6		ug/L		107	70 - 122	2	20	
methyl isobutyl ketone	<5.0		50.0	60.5		ug/L		121	53 - 135	6	20	
Toluene	<0.50		50.0	53.1		ug/L		106	70 - 120	4	20	
trans-1,3-Dichloropropene	<1.0		50.0	56.9		ug/L		114	70 - 123	3	20	
1,1,2-Trichloroethane	<1.0		50.0	54.5		ug/L		109	70 - 125	6	20	
Tetrachloroethene	72		50.0	119		ug/L		94	70 - 129	6	20	
1,3-Dichloropropane	<1.0		50.0	55.0		ug/L		110	70 - 127	3	20	
2-Hexanone	<5.0		50.0	60.3		ug/L		121	53 - 140	5	20	
Dibromochloromethane	<1.0		50.0	52.0		ug/L		104	70 - 120	2	20	
1,2-Dibromoethane	<1.0		50.0	55.1		ug/L		110	70 - 124	1	20	
Chlorobenzene	<1.0		50.0	50.4		ug/L		101	70 - 120	6	20	
1,1,1,2-Tetrachloroethane	<1.0		50.0	51.3		ug/L		103	70 - 124	7	20	
Ethylbenzene	<0.50		50.0	49.3		ug/L		99	70 - 125	7	20	
m&p-Xylene	<1.0		50.0	49.1		ug/L		98	70 - 120	8	20	
o-Xylene	<0.50		50.0	50.9		ug/L		102	70 - 120	7	20	
Styrene	<1.0		50.0	54.6		ug/L		109	70 - 120	5	20	
Bromoform	<1.0		50.0	54.0		ug/L		108	70 - 135	5	20	
Isopropylbenzene	<1.0		50.0	49.2		ug/L		98	70 - 132	8	20	
Bromobenzene	<1.0		50.0	53.4		ug/L		107	70 - 129	8	20	
1,1,2,2-Tetrachloroethane	<1.0		50.0	55.0		ug/L		110	68 - 133	11	20	
1,2,3-Trichloropropane	<1.0		50.0	54.4		ug/L		109	53 - 139	4	20	
N-Propylbenzene	<1.0		50.0	50.2		ug/L		100	70 - 132	7	20	
2-Chlorotoluene	<1.0		50.0	50.9		ug/L		102	70 - 128	7	20	
1,3,5-Trimethylbenzene	<1.0		50.0	49.9		ug/L		100	70 - 129	8	20	
4-Chlorotoluene	<1.0		50.0	49.6		ug/L		99	70 - 127	8	20	
tert-Butylbenzene	<1.0		50.0	47.9		ug/L		96	70 - 137	9	20	
1,2,4-Trimethylbenzene	<1.0		50.0	50.6		ug/L		101	70 - 127	7	20	
sec-Butylbenzene	<1.0		50.0	50.1		ug/L		100	70 - 134	8	20	
1,3-Dichlorobenzene	<1.0		50.0	50.8		ug/L		102	70 - 122	10	20	
p-Isopropyltoluene	<1.0		50.0	47.8		ug/L		96	70 - 133	9	20	
1,4-Dichlorobenzene	<1.0		50.0	50.1		ug/L		100	70 - 120	9	20	
n-Butylbenzene	<1.0		50.0	49.7		ug/L		99	70 - 129	9	20	
1,2-Dichlorobenzene	<1.0		50.0	52.5		ug/L		105	70 - 123	10	20	
1,2-Dibromo-3-Chloropropane	<2.0		50.0	55.0		ug/L		110	59 - 139	11	20	

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Method: 8260B - VOC (Continued)

Lab Sample ID: 500-100546-17 MSD

Matrix: Water

Analysis Batch: 302681

Client Sample ID: EW-8

Prep Type: Total/NA

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec.	RPD	RPD	Limit
	Result	Qualifier	Added	Result	Qualifier				Limits			
1,2,4-Trichlorobenzene	<1.0	F1 *	50.0	58.2		ug/L		116	70 - 125	13	20	
Hexachlorobutadiene	<1.0		50.0	60.3		ug/L		121	70 - 138	9	20	
Naphthalene	<1.0		50.0	55.6		ug/L		111	59 - 143	13	20	
1,2,3-Trichlorobenzene	<1.0	F1 *	50.0	66.9	F1	ug/L		134	70 - 133	12	20	

Surrogate	MSD	MSD	Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	101		75 - 125
Toluene-d8 (Surr)	105		75 - 120
4-Bromofluorobenzene (Surr)	102		75 - 120
Dibromofluoromethane	96		75 - 120

Lab Sample ID: MB 500-302682/29

Matrix: Water

Analysis Batch: 302682

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil	Fac
	Result	Qualifier								
Benzene	<0.50		0.50	0.074	ug/L			09/02/15 11:53		1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/02/15 11:53		1
Chloromethane	<1.0		1.0	0.18	ug/L			09/02/15 11:53		1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/02/15 11:53		1
Bromomethane	<1.0		1.0	0.31	ug/L			09/02/15 11:53		1
Chloroethane	<1.0		1.0	0.34	ug/L			09/02/15 11:53		1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/02/15 11:53		1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/02/15 11:53		1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/02/15 11:53		1
Acetone	<5.0		5.0	1.3	ug/L			09/02/15 11:53		1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/02/15 11:53		1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/02/15 11:53		1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/02/15 11:53		1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/02/15 11:53		1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/02/15 11:53		1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/02/15 11:53		1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/02/15 11:53		1
Chloroform	<1.0		1.0	0.20	ug/L			09/02/15 11:53		1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/02/15 11:53		1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/02/15 11:53		1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/02/15 11:53		1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 11:53		1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/02/15 11:53		1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/02/15 11:53		1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/02/15 11:53		1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/02/15 11:53		1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/02/15 11:53		1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/02/15 11:53		1
Toluene	<0.50		0.50	0.11	ug/L			09/02/15 11:53		1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/02/15 11:53		1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/02/15 11:53		1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/02/15 11:53		1

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Method: 8260B - VOC (Continued)

Lab Sample ID: MB 500-302682/29
Matrix: Water
Analysis Batch: 302682

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/02/15 11:53	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/02/15 11:53	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/02/15 11:53	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/02/15 11:53	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/02/15 11:53	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/02/15 11:53	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/02/15 11:53	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/02/15 11:53	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/02/15 11:53	1
Styrene	<1.0		1.0	0.10	ug/L			09/02/15 11:53	1
Bromoform	<1.0		1.0	0.28	ug/L			09/02/15 11:53	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 11:53	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/02/15 11:53	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/02/15 11:53	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/02/15 11:53	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 11:53	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/02/15 11:53	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/02/15 11:53	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/02/15 11:53	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 11:53	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/02/15 11:53	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/02/15 11:53	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 11:53	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/02/15 11:53	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/02/15 11:53	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/02/15 11:53	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/02/15 11:53	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/02/15 11:53	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/02/15 11:53	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/02/15 11:53	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/02/15 11:53	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/02/15 11:53	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	97		75 - 125		09/02/15 11:53	1
Toluene-d8 (Surr)	106		75 - 120		09/02/15 11:53	1
4-Bromofluorobenzene (Surr)	92		75 - 120		09/02/15 11:53	1
Dibromofluoromethane	104		75 - 120		09/02/15 11:53	1

Lab Sample ID: LCS 500-302682/4
Matrix: Water
Analysis Batch: 302682

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Benzene	50.0	53.9		ug/L		108	70 - 120
Dichlorodifluoromethane	50.0	57.3		ug/L		115	30 - 150
Chloromethane	50.0	57.3		ug/L		115	45 - 140
Vinyl chloride	50.0	57.1		ug/L		114	63 - 127

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-302682/4
Matrix: Water
Analysis Batch: 302682

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Bromomethane	50.0	37.1		ug/L		74	30 - 170
Chloroethane	50.0	50.9		ug/L		102	40 - 150
Trichlorofluoromethane	50.0	45.6		ug/L		91	65 - 134
1,1-Dichloroethene	50.0	52.7		ug/L		105	68 - 121
Carbon disulfide	50.0	54.7		ug/L		109	61 - 120
Acetone	50.0	56.6		ug/L		113	47 - 131
Methylene Chloride	50.0	53.7		ug/L		107	70 - 120
trans-1,2-Dichloroethene	50.0	52.2		ug/L		104	70 - 120
1,1-Dichloroethane	50.0	50.8		ug/L		102	70 - 127
2,2-Dichloropropane	50.0	48.6		ug/L		97	68 - 120
cis-1,2-Dichloroethene	50.0	52.9		ug/L		106	70 - 120
Methyl Ethyl Ketone	50.0	41.6		ug/L		83	51 - 134
Bromochloromethane	50.0	52.2		ug/L		104	70 - 121
Chloroform	50.0	48.1		ug/L		96	70 - 120
1,1,1-Trichloroethane	50.0	48.6		ug/L		97	70 - 125
1,1-Dichloropropene	50.0	54.5		ug/L		109	70 - 126
Carbon tetrachloride	50.0	49.2		ug/L		98	70 - 136
1,2-Dichloroethane	50.0	45.6		ug/L		91	66 - 132
Trichloroethene	50.0	54.4		ug/L		109	70 - 122
1,2-Dichloropropane	50.0	52.9		ug/L		106	70 - 127
Dibromomethane	50.0	48.0		ug/L		96	70 - 120
Bromodichloromethane	50.0	48.4		ug/L		97	70 - 127
cis-1,3-Dichloropropene	50.0	54.1		ug/L		108	70 - 122
methyl isobutyl ketone	50.0	41.4		ug/L		83	53 - 135
Toluene	50.0	56.7		ug/L		113	70 - 120
trans-1,3-Dichloropropene	50.0	54.3		ug/L		109	70 - 123
1,1,2-Trichloroethane	50.0	54.7		ug/L		109	70 - 125
Tetrachloroethene	50.0	52.1		ug/L		104	70 - 129
1,3-Dichloropropane	50.0	54.7		ug/L		109	70 - 127
2-Hexanone	50.0	42.4		ug/L		85	53 - 140
Dibromochloromethane	50.0	52.5		ug/L		105	70 - 120
1,2-Dibromoethane	50.0	53.1		ug/L		106	70 - 124
Chlorobenzene	50.0	53.0		ug/L		106	70 - 120
1,1,1,2-Tetrachloroethane	50.0	52.9		ug/L		106	70 - 124
Ethylbenzene	50.0	57.8		ug/L		116	70 - 125
m&p-Xylene	50.0	59.3		ug/L		119	70 - 120
o-Xylene	50.0	59.1		ug/L		118	70 - 120
Styrene	50.0	60.0		ug/L		120	70 - 120
Bromoform	50.0	54.2		ug/L		108	70 - 135
Isopropylbenzene	50.0	59.8		ug/L		120	70 - 132
Bromobenzene	50.0	54.7		ug/L		109	70 - 129
1,1,1,2,2-Tetrachloroethane	50.0	57.2		ug/L		114	68 - 133
1,2,3-Trichloropropane	50.0	56.4		ug/L		113	53 - 139
N-Propylbenzene	50.0	60.4		ug/L		121	70 - 132
2-Chlorotoluene	50.0	58.4		ug/L		117	70 - 128
1,3,5-Trimethylbenzene	50.0	60.5		ug/L		121	70 - 129
4-Chlorotoluene	50.0	57.8		ug/L		116	70 - 127
tert-Butylbenzene	50.0	61.2		ug/L		122	70 - 137

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-302682/4

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 302682

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
1,2,4-Trimethylbenzene	50.0	60.4		ug/L		121	70 - 127
sec-Butylbenzene	50.0	60.8		ug/L		122	70 - 134
1,3-Dichlorobenzene	50.0	54.6		ug/L		109	70 - 122
p-Isopropyltoluene	50.0	60.1		ug/L		120	70 - 133
1,4-Dichlorobenzene	50.0	53.8		ug/L		108	70 - 120
n-Butylbenzene	50.0	59.9		ug/L		120	70 - 129
1,2-Dichlorobenzene	50.0	54.3		ug/L		109	70 - 123
1,2-Dibromo-3-Chloropropane	50.0	53.6		ug/L		107	59 - 139
1,2,4-Trichlorobenzene	50.0	54.8		ug/L		110	70 - 125
Hexachlorobutadiene	50.0	56.2		ug/L		112	70 - 138
Naphthalene	50.0	57.1		ug/L		114	59 - 143
1,2,3-Trichlorobenzene	50.0	58.6		ug/L		117	70 - 133

Surrogate	LCS LCS		Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	90		75 - 125
Toluene-d8 (Surr)	105		75 - 120
4-Bromofluorobenzene (Surr)	104		75 - 120
Dibromofluoromethane	98		75 - 120

Lab Sample ID: MB 500-302848/6

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 302848

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Benzene	<0.50		0.50	0.074	ug/L			09/03/15 02:39	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/03/15 02:39	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/03/15 02:39	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/03/15 02:39	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/03/15 02:39	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/03/15 02:39	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/03/15 02:39	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/03/15 02:39	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/03/15 02:39	1
Acetone	<5.0		5.0	1.3	ug/L			09/03/15 02:39	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/03/15 02:39	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/03/15 02:39	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/03/15 02:39	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/03/15 02:39	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/03/15 02:39	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/03/15 02:39	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/03/15 02:39	1
Chloroform	<1.0		1.0	0.20	ug/L			09/03/15 02:39	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/03/15 02:39	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/03/15 02:39	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/03/15 02:39	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/03/15 02:39	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/03/15 02:39	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/03/15 02:39	1

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Method: 8260B - VOC (Continued)

Lab Sample ID: MB 500-302848/6
Matrix: Water
Analysis Batch: 302848

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Dibromomethane	<1.0		1.0	0.33	ug/L			09/03/15 02:39	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/03/15 02:39	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/03/15 02:39	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/03/15 02:39	1
Toluene	<0.50		0.50	0.11	ug/L			09/03/15 02:39	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/03/15 02:39	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/03/15 02:39	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/03/15 02:39	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/03/15 02:39	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/03/15 02:39	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/03/15 02:39	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/03/15 02:39	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/03/15 02:39	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/03/15 02:39	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/03/15 02:39	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/03/15 02:39	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/03/15 02:39	1
Styrene	<1.0		1.0	0.10	ug/L			09/03/15 02:39	1
Bromoform	<1.0		1.0	0.28	ug/L			09/03/15 02:39	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 02:39	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/03/15 02:39	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/03/15 02:39	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/03/15 02:39	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/03/15 02:39	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/03/15 02:39	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/03/15 02:39	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/03/15 02:39	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 02:39	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/03/15 02:39	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/03/15 02:39	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/15 02:39	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/03/15 02:39	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/15 02:39	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/03/15 02:39	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/03/15 02:39	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/03/15 02:39	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/03/15 02:39	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/03/15 02:39	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/03/15 02:39	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/03/15 02:39	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
1,2-Dichloroethane-d4 (Surr)	98		75 - 125		09/03/15 02:39	1
Toluene-d8 (Surr)	93		75 - 120		09/03/15 02:39	1
4-Bromofluorobenzene (Surr)	94		75 - 120		09/03/15 02:39	1
Dibromofluoromethane	89		75 - 120		09/03/15 02:39	1

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-302848/4
Matrix: Water
Analysis Batch: 302848

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D %Rec	%Rec. Limits
Benzene	50.0	43.9		ug/L	88	70 - 120
Dichlorodifluoromethane	50.0	40.2		ug/L	80	30 - 150
Chloromethane	50.0	53.7		ug/L	107	45 - 140
Vinyl chloride	50.0	45.2		ug/L	90	63 - 127
Bromomethane	50.0	30.1		ug/L	60	30 - 170
Chloroethane	50.0	30.6		ug/L	61	40 - 150
Trichlorofluoromethane	50.0	41.9		ug/L	84	65 - 134
1,1-Dichloroethene	50.0	41.5		ug/L	83	68 - 121
Carbon disulfide	50.0	39.9		ug/L	80	61 - 120
Acetone	50.0	30.9		ug/L	62	47 - 131
Methylene Chloride	50.0	37.4		ug/L	75	70 - 120
trans-1,2-Dichloroethene	50.0	42.7		ug/L	85	70 - 120
1,1-Dichloroethane	50.0	47.7		ug/L	95	70 - 127
2,2-Dichloropropane	50.0	36.5		ug/L	73	68 - 120
cis-1,2-Dichloroethene	50.0	44.7		ug/L	89	70 - 120
Methyl Ethyl Ketone	50.0	40.0		ug/L	80	51 - 134
Bromochloromethane	50.0	43.8		ug/L	88	70 - 121
Chloroform	50.0	43.7		ug/L	87	70 - 120
1,1,1-Trichloroethane	50.0	40.8		ug/L	82	70 - 125
1,1-Dichloropropene	50.0	44.7		ug/L	89	70 - 126
Carbon tetrachloride	50.0	41.9		ug/L	84	70 - 136
1,2-Dichloroethane	50.0	48.5		ug/L	97	66 - 132
Trichloroethene	50.0	47.2		ug/L	94	70 - 122
1,2-Dichloropropane	50.0	52.3		ug/L	105	70 - 127
Dibromomethane	50.0	46.8		ug/L	94	70 - 120
Bromodichloromethane	50.0	47.4		ug/L	95	70 - 127
cis-1,3-Dichloropropene	50.0	51.3		ug/L	103	70 - 122
methyl isobutyl ketone	50.0	41.2		ug/L	82	53 - 135
Toluene	50.0	49.9		ug/L	100	70 - 120
trans-1,3-Dichloropropene	50.0	53.0		ug/L	106	70 - 123
1,1,2-Trichloroethane	50.0	53.6		ug/L	107	70 - 125
Tetrachloroethene	50.0	50.5		ug/L	101	70 - 129
1,3-Dichloropropane	50.0	50.4		ug/L	101	70 - 127
2-Hexanone	50.0	43.9		ug/L	88	53 - 140
Dibromochloromethane	50.0	53.3		ug/L	107	70 - 120
1,2-Dibromoethane	50.0	52.0		ug/L	104	70 - 124
Chlorobenzene	50.0	50.4		ug/L	101	70 - 120
1,1,1,2-Tetrachloroethane	50.0	48.7		ug/L	97	70 - 124
Ethylbenzene	50.0	50.5		ug/L	101	70 - 125
m&p-Xylene	50.0	50.1		ug/L	100	70 - 120
o-Xylene	50.0	49.0		ug/L	98	70 - 120
Styrene	50.0	51.8		ug/L	104	70 - 120
Bromoform	50.0	56.8		ug/L	114	70 - 135
Isopropylbenzene	50.0	49.7		ug/L	99	70 - 132
Bromobenzene	50.0	49.6		ug/L	99	70 - 129
1,1,2,2-Tetrachloroethane	50.0	52.0		ug/L	104	68 - 133
1,2,3-Trichloropropane	50.0	51.2		ug/L	102	53 - 139
N-Propylbenzene	50.0	49.3		ug/L	99	70 - 132

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-302848/4
Matrix: Water
Analysis Batch: 302848

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
2-Chlorotoluene	50.0	49.1		ug/L		98	70 - 128
1,3,5-Trimethylbenzene	50.0	50.4		ug/L		101	70 - 129
4-Chlorotoluene	50.0	49.5		ug/L		99	70 - 127
tert-Butylbenzene	50.0	49.6		ug/L		99	70 - 137
1,2,4-Trimethylbenzene	50.0	49.3		ug/L		99	70 - 127
sec-Butylbenzene	50.0	49.5		ug/L		99	70 - 134
1,3-Dichlorobenzene	50.0	49.3		ug/L		99	70 - 122
p-Isopropyltoluene	50.0	50.0		ug/L		100	70 - 133
1,4-Dichlorobenzene	50.0	49.2		ug/L		98	70 - 120
n-Butylbenzene	50.0	48.3		ug/L		97	70 - 129
1,2-Dichlorobenzene	50.0	49.8		ug/L		100	70 - 123
1,2-Dibromo-3-Chloropropane	50.0	47.0		ug/L		94	59 - 139
1,2,4-Trichlorobenzene	50.0	50.8		ug/L		102	70 - 125
Hexachlorobutadiene	50.0	49.5		ug/L		99	70 - 138
Naphthalene	50.0	49.8		ug/L		100	59 - 143
1,2,3-Trichlorobenzene	50.0	54.0		ug/L		108	70 - 133

Surrogate	LCS %Recovery	LCS Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	94		75 - 125
Toluene-d8 (Surr)	95		75 - 120
4-Bromofluorobenzene (Surr)	91		75 - 120
Dibromofluoromethane	86		75 - 120

Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-1A

Date Collected: 08/26/15 09:45

Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-1

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302848	09/03/15 04:32	PMF	TAL CHI

Client Sample ID: RFW-1B

Date Collected: 08/26/15 17:30

Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-2

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302848	09/03/15 04:58	PMF	TAL CHI

Client Sample ID: RFW-2A

Date Collected: 08/26/15 11:10

Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-3

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302681	09/02/15 12:12	EMA	TAL CHI

Client Sample ID: RFW-2B

Date Collected: 08/26/15 11:05

Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-4

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302681	09/02/15 12:38	EMA	TAL CHI

Client Sample ID: RFW-3B

Date Collected: 08/26/15 15:50

Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-5

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302681	09/02/15 13:05	EMA	TAL CHI

Client Sample ID: RFW-4A

Date Collected: 08/27/15 09:30

Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-6

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302681	09/02/15 13:32	EMA	TAL CHI

Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-4A DUP

Date Collected: 08/27/15 09:30

Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-7

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302681	09/02/15 13:58	EMA	TAL CHI

Client Sample ID: RFW-4B

Date Collected: 08/27/15 08:40

Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-8

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302681	09/02/15 14:24	EMA	TAL CHI

Client Sample ID: RFW-6

Date Collected: 08/26/15 13:40

Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-9

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302681	09/02/15 14:50	EMA	TAL CHI

Client Sample ID: RFW-7

Date Collected: 08/26/15 12:15

Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-10

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302681	09/02/15 15:17	EMA	TAL CHI

Client Sample ID: EW-2

Date Collected: 08/27/15 11:30

Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-11

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302681	09/02/15 15:44	EMA	TAL CHI

Client Sample ID: EW-3

Date Collected: 08/27/15 10:50

Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-12

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302681	09/02/15 16:37	EMA	TAL CHI

TestAmerica Chicago

Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-4
Date Collected: 08/27/15 10:40
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-13
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302681	09/02/15 17:03	EMA	TAL CHI
Total/NA	Analysis	8260B	DL	10	302681	09/02/15 17:30	EMA	TAL CHI

Client Sample ID: EW-5
Date Collected: 08/27/15 10:20
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-14
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302681	09/02/15 17:57	EMA	TAL CHI

Client Sample ID: EW-6
Date Collected: 08/26/15 14:30
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-15
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302681	09/02/15 18:23	EMA	TAL CHI

Client Sample ID: EW-7
Date Collected: 08/26/15 14:20
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-16
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302681	09/02/15 18:49	EMA	TAL CHI

Client Sample ID: EW-8
Date Collected: 08/26/15 14:15
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-17
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302681	09/02/15 19:15	EMA	TAL CHI

Client Sample ID: EW-9
Date Collected: 08/26/15 14:05
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-18
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302682	09/02/15 17:00	EMA	TAL CHI

TestAmerica Chicago

Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: EW-9 DUP

Date Collected: 08/26/15 14:05
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-19

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302682	09/02/15 17:27	EMA	TAL CHI

Client Sample ID: EW-10

Date Collected: 08/26/15 14:00
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-20

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302682	09/02/15 17:55	EMA	TAL CHI

Client Sample ID: RFW-9

Date Collected: 08/26/15 17:00
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-21

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302682	09/02/15 18:23	EMA	TAL CHI

Client Sample ID: RFW-11B

Date Collected: 08/27/15 11:00
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-22

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302848	09/03/15 03:17	PMF	TAL CHI

Client Sample ID: RFW-12B

Date Collected: 08/27/15 12:00
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-23

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302848	09/03/15 03:42	PMF	TAL CHI

Client Sample ID: RFW-13

Date Collected: 08/27/15 07:15
Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-24

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302848	09/03/15 04:07	PMF	TAL CHI

TestAmerica Chicago

Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Client Sample ID: RFW-17

Date Collected: 08/27/15 12:50

Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-25

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302848	09/03/15 05:23	PMF	TAL CHI

Client Sample ID: Trip Blank

Date Collected: 08/26/15 07:00

Date Received: 08/28/15 10:05

Lab Sample ID: 500-100546-26

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	302682	09/02/15 12:56	EMA	TAL CHI

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200



Certification Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-100546-1

Laboratory: TestAmerica Chicago

All certifications held by this laboratory are listed. Not all certifications are applicable to this report.

Authority	Program	EPA Region	Certification ID	Expiration Date
Alabama	State Program	4	40461	04-30-16
California	State Program	9	2903	04-30-16
Georgia	State Program	4	N/A	04-30-16
Georgia	State Program	4	939	04-30-16
Hawaii	State Program	9	N/A	04-30-16
Illinois	NELAP	5	100201	04-30-16
Indiana	State Program	5	C-IL-02	04-30-16
Iowa	State Program	7	82	05-01-16
Kansas	NELAP	7	E-10161	10-31-15 *
Kentucky (UST)	State Program	4	66	04-30-16
Kentucky (WW)	State Program	4	KY90023	12-31-15
Massachusetts	State Program	1	M-IL035	06-30-16
Mississippi	State Program	4	N/A	04-30-16
New York	NELAP	2	IL00035	04-01-16
North Carolina (WW/SW)	State Program	4	291	12-31-15 *
North Dakota	State Program	8	R-194	04-30-16
Oklahoma	State Program	6	8908	08-31-16
South Carolina	State Program	4	77001	04-30-16
USDA	Federal		P330-15-00038	02-11-18
Wisconsin	State Program	5	999580010	08-31-16
Wyoming	State Program	8	8TMS-Q	04-30-16

* Certification renewal pending - certification considered valid.

TestAmerica Chicago

TestAmerica

THE LEADER IN ENVIRONMENT/

2417 Bond Street, University Park, IL
Phone: 708.534.5200 Fax: 708.5



500-100546 COC

Report To _____ (optional)
Contact: _____
Company: _____
Address: _____
Address: _____
Phone: _____
Fax: _____
E-Mail: _____

Bill To _____ (optional)
Contact: _____
Company: _____
Address: _____
Address: _____
Phone: _____
Fax: _____
PO#/Reference# _____

Chain of Custody Record

Lab Job #: 500-100546
Chain of Custody Number: _____
Page _____ of _____
Temperature °C of Cooler: 0.7

Client		Client Project #		Preservative		Parameter		Matrix		Preservative Key
Weston Solutions				HCl				VOA		
Project Name		Project Location/State		Lab Project #		Sampler		Matrix		Comments
Black + Decker		Hamstead, MD				Greg Flamski		Dick Wright		
Lab ID	MS/MSD	Sample ID	Sampling		# of Containers	Matrix				
			Date	Time						
1		RFW 1A	8/26/15	945	3	W				
2		RFW 1B		1730	3					
3		RFW 2A		1110	3					
4		RFW 2B		1105	3					
5		RFW 3B		1550	3					
6		RFW-4A	8/27/15	930	3					
7		RFW-4A Dup		930	3					
8		RFW-4B		840	3					
9		RFW-6	8/26/15	1340	3					
10		RFW-7		1215	3					

- Preservative Key
1. HCL, Cool to 4°
 2. H2SO4, Cool to 4°
 3. HNO3, Cool to 4°
 4. NaOH, Cool to 4°
 5. NaOH/Zn, Cool to 4°
 6. NaHSO4
 7. Cool to 4°
 8. None
 9. Other

Turnaround Time Required (Business Days)

1 Day 2 Days 5 Days 7 Days 10 Days 15 Days Other

Requested Due Date

Sample Disposal

Return to Client

Disposal by Lab

Archive for _____ Months

(A fee may be assessed if samples are retained longer than 1 month)

Relinquished By: <u>[Signature]</u> Company: <u>Weston</u> Date: <u>8/27/15</u> Time: <u>1600</u>	Received By: <u>[Signature]</u> Company: <u>Fed Ex</u> Date: <u>8/28/15</u> Time: <u>1005</u>
Relinquished By: _____ Company: _____ Date: _____ Time: _____	Received By: <u>[Signature]</u> Company: <u>TA-ERT</u> Date: <u>8/28/15</u> Time: _____
Relinquished By: _____ Company: _____ Date: _____ Time: _____	Received By: _____ Company: _____ Date: _____ Time: _____

Lab Courier: _____
Shipped: FedEx
Hand Delivered: _____

- Matrix Key
- WW - Wastewater
 - W - Water
 - S - Soil
 - SL - Sludge
 - MS - Miscellaneous
 - OL - Oil
 - A - Air
 - SE - Sediment
 - SO - Soil
 - L - Leachate
 - WI - Wipe
 - DW - Drinking Water
 - O - Other

Client Comments: _____

Lab Comments: _____

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

2417 Bond Street, University Park, IL 60484
 Phone: 708.534.5200 Fax: 708.534.5211

Report To: _____ (optional)
 Contact: _____
 Company: _____
 Address: _____
 Address: _____
 Phone: _____
 Fax: _____
 E-Mail: _____

Bill To: _____ (optional)
 Contact: _____
 Company: _____
 Address: _____
 Address: _____
 Phone: _____
 Fax: _____
 PO#/Reference#: _____

Chain of Custody Record

Lab Job #: 500-100544
 Chain of Custody Number: _____
 Page _____ of _____
 Temperature °C of Cooler: _____

Client		Client Project #		Preservative		Parameter		Matrix		Preservative Key 1. HCL, Cool to 4° 2. H2SO4, Cool to 4° 3. HNO3, Cool to 4° 4. NaOH, Cool to 4° 5. NaOH/Zn, Cool to 4° 6. NaHSO4 7. Cool to 4° 8. None 9. Other
Project Name		Lab Project #		Date		Time		# of Containers	Matrix	
Project Location/State		Sampler		Date		Time				
Westan Solutions				HCL						Comments
Black + Decker				VOA						
Hampstead, MD		Dick Wright								
Lab ID	MS/MSQ	Sample ID	Date	Time	# of Containers	Matrix				
11		EW-2	8/27/15	1130	3	W				
12		EW-3		1050						
13		EW-4		1040						
14		EW-5		1020						
15		EW-6	8/26/15	1430						
16		EW-7		1420						
17		EW-8		1415						
18		EW-9		1405						
19		EW-9 Dup		1405						
20		EW-10		1400						

Turnaround Time Required (Business Days)

1-Day _____ 2-Days _____ 6-Days _____ 7-Days _____ 10-Days _____ 15-Days _____ Other _____

Sample Disposal

Return to Client Disposal-by-Lab Archive for _____ Months (A fee may be assessed if samples are retained longer than 1 month)

Requested Due Date

Requested By: <u>[Signature]</u>	Company: <u>Westan</u>	Date: <u>8/27/15</u>	Time: <u>1600</u>	Received By: <u>Feed Ex</u>	Company: <u>TA-CH</u>	Date: <u>8/28/15</u>	Time: <u>1005</u>
Relinquished By: <u>[Signature]</u>	Company: <u>Westan</u>	Date: <u>8/27/15</u>	Time: <u>1600</u>	Received By: <u>[Signature]</u>	Company: <u>TA-CH</u>	Date: <u>8/28/15</u>	Time: <u>1005</u>
Relinquished By: _____	Company: _____	Date: _____	Time: _____	Received By: _____	Company: _____	Date: _____	Time: _____

Lab Courier: J
 Shipped: Feed Ex
 Hand Delivered: _____

- Matrix Key
- WW - Wastewater
 - W - Water
 - S - Soil
 - SL - Sludge
 - MS - Miscellaneous
 - OL - Oil
 - A - Air
 - SE - Sediment
 - SO - Soil
 - L - Leachate
 - WI - Wipe
 - DW - Drinking Water
 - O - Other

Client Comments

Lab Comments:

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

2417 Bond Street, University Park, IL 60484
Phone: 708.534.5200 Fax: 708.534.5211

Report To: _____ (optional)
Contact: _____
Company: _____
Address: _____
Address: _____
Phone: _____
Fax: _____
E-Mail: _____

Bill To: _____ (optional)
Contact: _____
Company: _____
Address: _____
Address: _____
Phone: _____
Fax: _____
PO#/Reference#: _____

Chain of Custody Record

Lab Job #: 500-100546

Chain of Custody Number: _____

Page _____ of _____

Temperature °C of Cooler: _____

Client		Client Project #		Preservative		Parameter		Matrix		Preservative Key 1. HCL, Cool to 4° 2. H2SO4, Cool to 4° 3. HNO3, Cool to 4° 4. NaOH, Cool to 4° 5. NaOH/Zn, Cool to 4° 6. NaHSO4 7. Cool to 4° 8. None 9. Other
Weston Solutions				HCl				VOA		
Project Name Black + Decker		Lab Project #								
Project Location/State Hampstead, MD		Lab Project #								Comments
Sampler Greg Flamski		Lab PM Dick Wright								
Lab ID	MS/MSD	Sample ID	Date	Time	# of Containers	Matrix				
21		RFW-9	8/26/15	1700	3	W				
22		RFW-11B	8/27/15	1100	3	W				
23		RFW-12B	8/27/15	1200	3	W				
24		RFW-13	8/27/15	715	3	W				
25		RFW-17	8/27/15	1250	3	W				
26		Trip Blank	8/26/15	700	2	W				

14

Turnaround Time Required (Business Days)

1 Day 2 Days 5 Days 7 Days 10 Days 15 Days Other

Sample Disposal

Return to Client Disposal by Lab Archive for _____ Months (A fee may be assessed if samples are retained longer than 1 month)

Requested By: <u>[Signature]</u>	Company: <u>Weston</u>	Date: <u>8/27/15</u>	Time: <u>1600</u>	Received By: <u>Fed Ex</u>	Company: <u>Fed Ex</u>	Date: <u>8/28/15</u>	Time: <u>1005</u>
Requested By: _____	Company: _____	Date: _____	Time: _____	Received By: <u>Shawn Scott</u>	Company: <u>TA-CRT</u>	Date: <u>8/28/15</u>	Time: <u>1005</u>
Requested By: _____	Company: _____	Date: _____	Time: _____	Received By: _____	Company: _____	Date: _____	Time: _____

Lab Courier: _____
Shipped: Fed Ex
Hand Delivered: _____

Matrix Key

WW - Wastewater	SE - Sediment
W - Water	SO - Soil
S - Soil	L - Leachate
SL - Sludge	WI - Wipe
MS - Miscellaneous	DW - Drinking Water
OL - Oil	O - Other
A - Air	

Client Comments: _____

Lab Comments: _____

Login Sample Receipt Checklist

Client: Weston Solutions, Inc.

Job Number: 500-100546-1

Login Number: 100546

List Number: 1

Creator: Scott, Sherri L

List Source: TestAmerica Chicago

Question	Answer	Comment
Radioactivity wasn't checked or is <=/ background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	0.7
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	



TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.
TestAmerica Savannah
5102 LaRoche Avenue
Savannah, GA 31404
Tel: (912)354-7858

TestAmerica Job ID: 680-116159-1
Client Project/Site: Black & Decker

For:
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, Pennsylvania 19380

Attn: Greg Flasiniski



Authorized for release by:
9/11/2015 12:33:45 PM

Lisa Harvey, Project Manager II
(912)354-7858 e.3221
lisa.harvey@testamericainc.com

LINKS

Review your project
results through

Total Access

Have a Question?

**Ask
The
Expert**


Visit us at:

www.testamericainc.com

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters. exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.



Case Narrative

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Job ID: 680-116159-1

Laboratory: TestAmerica Savannah

Narrative

CASE NARRATIVE
Client: Weston Solutions, Inc.
Project: Black & Decker
Report Number: 680-116159-1

With the exceptions noted as flags or footnotes, standard analytical protocols were followed in the analysis of the samples and no problems were encountered or anomalies observed. In addition all laboratory quality control samples were within established control limits, with any exceptions noted below. Each sample was analyzed to achieve the lowest possible reporting limit within the constraints of the method. In the event of interference or analytes present at high concentrations, samples may be diluted. For diluted samples, the reporting limits are adjusted relative to the dilution required.

RECEIPT

The samples were received on 08/28/2015; the samples arrived in good condition, properly preserved and on ice. The temperature of the coolers at receipt was 4.2 C.

VOLATILE ORGANIC COMPOUNDS (GC-MS)

Samples RFW-20 (680-116159-1), RFW-21 (680-116159-2), HAMP-22 (680-116159-3), HAMP-23 (680-116159-4) and Trip Blank (680-116159-5) were analyzed for Volatile organic Compounds (GC-MS) in accordance with EPA Method 524.2. The samples were analyzed on 09/01/2015 and 09/10/2015.

Method(s) 524.2: Insufficient sample volume was available to perform a matrix spike/matrix spike duplicate (MS/MSD) associated with analytical batch 680-398947.

Method(s) 524.2: The laboratory control sample (LCS) for batch analytical batch 680-400213 recovered outside control limits for Bromomethane. This analyte was biased high in the LCS and was not detected in the associated samples; therefore, the data have been reported.

Method(s) 524.2: Insufficient sample volume was available to perform a matrix spike/matrix spike duplicate (MS/MSD) associated with analytical batch 680-400213.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.



Sample Summary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
680-116159-1	RFW-20	Water	08/26/15 08:35	08/28/15 09:20
680-116159-2	RFW-21	Water	08/26/15 07:45	08/28/15 09:20
680-116159-3	HAMP-22	Water	08/27/15 09:15	08/28/15 09:20
680-116159-4	HAMP-23	Water	08/27/15 09:20	08/28/15 09:20
680-116159-5	Trip Blank	Water	08/26/15 07:00	08/28/15 09:20



Method Summary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Method	Method Description	Protocol	Laboratory
524.2	Volatile Organic Compounds (GC/MS)	EPA-DW	TAL SAV

Protocol References:

EPA-DW = "Methods For The Determination Of Organic Compounds In Drinking Water". EPA/600/4-88/039, December 1988 And Its Supplements.

Laboratory References:

TAL SAV = TestAmerica Savannah, 5102 LaRoche Avenue, Savannah, GA 31404, TEL (912)354-7858

Definitions/Glossary

TestAmerica Job ID: 680-116159-1

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

Qualifiers

GC/MS VOA

Qualifier	Qualifier Description
*	LCS or LCSD is outside acceptance limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
▫	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CNF	Contains no Free Liquid
DER	Duplicate error ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision level concentration
MDA	Minimum detectable activity
EDL	Estimated Detection Limit
MDC	Minimum detectable concentration
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
NC	Not Calculated
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative error ratio
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Client Sample ID: RFW-20

Lab Sample ID: 680-116159-1

Date Collected: 08/26/15 08:35

Matrix: Water

Date Received: 08/28/15 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			09/01/15 17:18	1
Benzene	<0.50		0.50	0.082	ug/L			09/01/15 17:18	1
Bromobenzene	<0.50		0.50	0.091	ug/L			09/01/15 17:18	1
Bromoform	<0.50		0.50	0.17	ug/L			09/01/15 17:18	1
Bromomethane	<1.0		1.0	0.20	ug/L			09/01/15 17:18	1
Carbon tetrachloride	<0.50		0.50	0.11	ug/L			09/01/15 17:18	1
Chlorobenzene	<0.50		0.50	0.14	ug/L			09/01/15 17:18	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/01/15 17:18	1
Chlorodibromomethane	<0.50		0.50	0.13	ug/L			09/01/15 17:18	1
Chloroethane	<1.0		1.0	0.22	ug/L			09/01/15 17:18	1
Chloroform	<0.50		0.50	0.20	ug/L			09/01/15 17:18	1
Chloromethane	<0.50		0.50	0.15	ug/L			09/01/15 17:18	1
2-Chlorotoluene	<0.50		0.50	0.11	ug/L			09/01/15 17:18	1
4-Chlorotoluene	<0.50		0.50	0.13	ug/L			09/01/15 17:18	1
cis-1,2-Dichloroethene	<0.50		0.50	0.090	ug/L			09/01/15 17:18	1
cis-1,3-Dichloropropene	<0.50		0.50	0.081	ug/L			09/01/15 17:18	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/01/15 17:18	1
Dibromomethane	<0.50		0.50	0.16	ug/L			09/01/15 17:18	1
1,2-Dichlorobenzene	<0.50		0.50	0.16	ug/L			09/01/15 17:18	1
1,3-Dichlorobenzene	<0.50		0.50	0.11	ug/L			09/01/15 17:18	1
1,4-Dichlorobenzene	<0.50		0.50	0.13	ug/L			09/01/15 17:18	1
Dichlorobromomethane	<0.50		0.50	0.079	ug/L			09/01/15 17:18	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/01/15 17:18	1
1,1-Dichloroethane	<0.50		0.50	0.078	ug/L			09/01/15 17:18	1
1,2-Dichloroethane	<0.50		0.50	0.086	ug/L			09/01/15 17:18	1
1,1-Dichloroethene	<0.50		0.50	0.15	ug/L			09/01/15 17:18	1
1,2-Dichloropropane	<0.50		0.50	0.096	ug/L			09/01/15 17:18	1
1,3-Dichloropropane	<0.50		0.50	0.10	ug/L			09/01/15 17:18	1
2,2-Dichloropropane	<0.50		0.50	0.20	ug/L			09/01/15 17:18	1
1,1-Dichloropropene	<0.50		0.50	0.095	ug/L			09/01/15 17:18	1
1,3-Dichloropropene, Total	<0.50		0.50	0.081	ug/L			09/01/15 17:18	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/01/15 17:18	1
Ethylbenzene	<0.50		0.50	0.099	ug/L			09/01/15 17:18	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/01/15 17:18	1
Freon 113	<0.50		0.50	0.15	ug/L			09/01/15 17:18	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/01/15 17:18	1
2-Hexanone	<10		10	5.0	ug/L			09/01/15 17:18	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/01/15 17:18	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/01/15 17:18	1
Methylene Chloride	<0.50		0.50	0.20	ug/L			09/01/15 17:18	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/01/15 17:18	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/01/15 17:18	1
m-Xylene & p-Xylene	<0.50		0.50	0.15	ug/L			09/01/15 17:18	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/01/15 17:18	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/01/15 17:18	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/01/15 17:18	1
o-Xylene	<0.50		0.50	0.086	ug/L			09/01/15 17:18	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/01/15 17:18	1
Styrene	<0.50		0.50	0.089	ug/L			09/01/15 17:18	1

TestAmerica Savannah

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Client Sample ID: RFW-20

Lab Sample ID: 680-116159-1

Date Collected: 08/26/15 08:35

Matrix: Water

Date Received: 08/28/15 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/01/15 17:18	1
tert-Butyl alcohol	<10		10	1.6	ug/L			09/01/15 17:18	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/01/15 17:18	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/01/15 17:18	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.24	ug/L			09/01/15 17:18	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.13	ug/L			09/01/15 17:18	1
Tetrachloroethene	<0.50		0.50	0.18	ug/L			09/01/15 17:18	1
Toluene	<0.50		0.50	0.086	ug/L			09/01/15 17:18	1
trans-1,2-Dichloroethene	<0.50		0.50	0.090	ug/L			09/01/15 17:18	1
trans-1,3-Dichloropropene	<0.50		0.50	0.11	ug/L			09/01/15 17:18	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/01/15 17:18	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.12	ug/L			09/01/15 17:18	1
1,1,1-Trichloroethane	<0.50		0.50	0.15	ug/L			09/01/15 17:18	1
1,1,2-Trichloroethane	<0.50		0.50	0.16	ug/L			09/01/15 17:18	1
Trichloroethene	<0.50		0.50	0.13	ug/L			09/01/15 17:18	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/01/15 17:18	1
1,2,3-Trichloropropane	<0.50		0.50	0.17	ug/L			09/01/15 17:18	1
Trihalomethanes, Total	<0.50		0.50	0.079	ug/L			09/01/15 17:18	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/01/15 17:18	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/01/15 17:18	1
Vinyl chloride	<0.50		0.50	0.16	ug/L			09/01/15 17:18	1
Xylenes, Total	<0.50		0.50	0.086	ug/L			09/01/15 17:18	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	96		70 - 130		09/01/15 17:18	1
1,2-Dichlorobenzene-d4	90		70 - 130		09/01/15 17:18	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Client Sample ID: RFW-21

Lab Sample ID: 680-116159-2

Date Collected: 08/26/15 07:45

Matrix: Water

Date Received: 08/28/15 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			09/01/15 17:39	1
Benzene	<0.50		0.50	0.082	ug/L			09/01/15 17:39	1
Bromobenzene	<0.50		0.50	0.091	ug/L			09/01/15 17:39	1
Bromoform	<0.50		0.50	0.17	ug/L			09/01/15 17:39	1
Bromomethane	<1.0		1.0	0.20	ug/L			09/01/15 17:39	1
Carbon tetrachloride	<0.50		0.50	0.11	ug/L			09/01/15 17:39	1
Chlorobenzene	<0.50		0.50	0.14	ug/L			09/01/15 17:39	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/01/15 17:39	1
Chlorodibromomethane	<0.50		0.50	0.13	ug/L			09/01/15 17:39	1
Chloroethane	<1.0		1.0	0.22	ug/L			09/01/15 17:39	1
Chloroform	<0.50		0.50	0.20	ug/L			09/01/15 17:39	1
Chloromethane	<0.50		0.50	0.15	ug/L			09/01/15 17:39	1
2-Chlorotoluene	<0.50		0.50	0.11	ug/L			09/01/15 17:39	1
4-Chlorotoluene	<0.50		0.50	0.13	ug/L			09/01/15 17:39	1
cis-1,2-Dichloroethene	<0.50		0.50	0.090	ug/L			09/01/15 17:39	1
cis-1,3-Dichloropropene	<0.50		0.50	0.081	ug/L			09/01/15 17:39	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/01/15 17:39	1
Dibromomethane	<0.50		0.50	0.16	ug/L			09/01/15 17:39	1
1,2-Dichlorobenzene	<0.50		0.50	0.16	ug/L			09/01/15 17:39	1
1,3-Dichlorobenzene	<0.50		0.50	0.11	ug/L			09/01/15 17:39	1
1,4-Dichlorobenzene	<0.50		0.50	0.13	ug/L			09/01/15 17:39	1
Dichlorobromomethane	<0.50		0.50	0.079	ug/L			09/01/15 17:39	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/01/15 17:39	1
1,1-Dichloroethane	<0.50		0.50	0.078	ug/L			09/01/15 17:39	1
1,2-Dichloroethane	<0.50		0.50	0.086	ug/L			09/01/15 17:39	1
1,1-Dichloroethene	<0.50		0.50	0.15	ug/L			09/01/15 17:39	1
1,2-Dichloropropane	<0.50		0.50	0.096	ug/L			09/01/15 17:39	1
1,3-Dichloropropane	<0.50		0.50	0.10	ug/L			09/01/15 17:39	1
2,2-Dichloropropane	<0.50		0.50	0.20	ug/L			09/01/15 17:39	1
1,1-Dichloropropene	<0.50		0.50	0.095	ug/L			09/01/15 17:39	1
1,3-Dichloropropene, Total	<0.50		0.50	0.081	ug/L			09/01/15 17:39	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/01/15 17:39	1
Ethylbenzene	<0.50		0.50	0.099	ug/L			09/01/15 17:39	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/01/15 17:39	1
Freon 113	<0.50		0.50	0.15	ug/L			09/01/15 17:39	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/01/15 17:39	1
2-Hexanone	<10		10	5.0	ug/L			09/01/15 17:39	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/01/15 17:39	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/01/15 17:39	1
Methylene Chloride	<0.50		0.50	0.20	ug/L			09/01/15 17:39	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/01/15 17:39	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/01/15 17:39	1
m-Xylene & p-Xylene	<0.50		0.50	0.15	ug/L			09/01/15 17:39	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/01/15 17:39	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/01/15 17:39	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/01/15 17:39	1
o-Xylene	<0.50		0.50	0.086	ug/L			09/01/15 17:39	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/01/15 17:39	1
Styrene	<0.50		0.50	0.089	ug/L			09/01/15 17:39	1

TestAmerica Savannah

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Client Sample ID: RFW-21

Lab Sample ID: 680-116159-2

Date Collected: 08/26/15 07:45

Matrix: Water

Date Received: 08/28/15 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/01/15 17:39	1
tert-Butyl alcohol	<10		10	1.6	ug/L			09/01/15 17:39	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/01/15 17:39	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/01/15 17:39	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.24	ug/L			09/01/15 17:39	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.13	ug/L			09/01/15 17:39	1
Tetrachloroethene	<0.50		0.50	0.18	ug/L			09/01/15 17:39	1
Toluene	<0.50		0.50	0.086	ug/L			09/01/15 17:39	1
trans-1,2-Dichloroethene	<0.50		0.50	0.090	ug/L			09/01/15 17:39	1
trans-1,3-Dichloropropene	<0.50		0.50	0.11	ug/L			09/01/15 17:39	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/01/15 17:39	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.12	ug/L			09/01/15 17:39	1
1,1,1-Trichloroethane	<0.50		0.50	0.15	ug/L			09/01/15 17:39	1
1,1,2-Trichloroethane	<0.50		0.50	0.16	ug/L			09/01/15 17:39	1
Trichloroethene	<0.50		0.50	0.13	ug/L			09/01/15 17:39	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/01/15 17:39	1
1,2,3-Trichloropropane	<0.50		0.50	0.17	ug/L			09/01/15 17:39	1
Trihalomethanes, Total	<0.50		0.50	0.079	ug/L			09/01/15 17:39	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/01/15 17:39	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/01/15 17:39	1
Vinyl chloride	<0.50		0.50	0.16	ug/L			09/01/15 17:39	1
Xylenes, Total	<0.50		0.50	0.086	ug/L			09/01/15 17:39	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	94		70 - 130		09/01/15 17:39	1
1,2-Dichlorobenzene-d4	91		70 - 130		09/01/15 17:39	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Client Sample ID: HAMP-22

Lab Sample ID: 680-116159-3

Date Collected: 08/27/15 09:15

Matrix: Water

Date Received: 08/28/15 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			09/10/15 00:11	1
Benzene	<0.50		0.50	0.082	ug/L			09/10/15 00:11	1
Bromobenzene	<0.50		0.50	0.091	ug/L			09/10/15 00:11	1
Bromoform	<0.50		0.50	0.17	ug/L			09/10/15 00:11	1
Bromomethane	<1.0 *		1.0	0.20	ug/L			09/10/15 00:11	1
Carbon tetrachloride	<0.50		0.50	0.11	ug/L			09/10/15 00:11	1
Chlorobenzene	<0.50		0.50	0.14	ug/L			09/10/15 00:11	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/10/15 00:11	1
Chlorodibromomethane	<0.50		0.50	0.13	ug/L			09/10/15 00:11	1
Chloroethane	<1.0		1.0	0.22	ug/L			09/10/15 00:11	1
Chloroform	<0.50		0.50	0.20	ug/L			09/10/15 00:11	1
Chloromethane	<0.50		0.50	0.15	ug/L			09/10/15 00:11	1
2-Chlorotoluene	<0.50		0.50	0.11	ug/L			09/10/15 00:11	1
4-Chlorotoluene	<0.50		0.50	0.13	ug/L			09/10/15 00:11	1
cis-1,2-Dichloroethene	<0.50		0.50	0.090	ug/L			09/10/15 00:11	1
cis-1,3-Dichloropropene	<0.50		0.50	0.081	ug/L			09/10/15 00:11	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/10/15 00:11	1
Dibromomethane	<0.50		0.50	0.16	ug/L			09/10/15 00:11	1
1,2-Dichlorobenzene	<0.50		0.50	0.16	ug/L			09/10/15 00:11	1
1,3-Dichlorobenzene	<0.50		0.50	0.11	ug/L			09/10/15 00:11	1
1,4-Dichlorobenzene	<0.50		0.50	0.13	ug/L			09/10/15 00:11	1
Dichlorobromomethane	<0.50		0.50	0.079	ug/L			09/10/15 00:11	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/10/15 00:11	1
1,1-Dichloroethane	<0.50		0.50	0.078	ug/L			09/10/15 00:11	1
1,2-Dichloroethane	<0.50		0.50	0.086	ug/L			09/10/15 00:11	1
1,1-Dichloroethene	<0.50		0.50	0.15	ug/L			09/10/15 00:11	1
1,2-Dichloropropane	<0.50		0.50	0.096	ug/L			09/10/15 00:11	1
1,3-Dichloropropane	<0.50		0.50	0.10	ug/L			09/10/15 00:11	1
2,2-Dichloropropane	<0.50		0.50	0.20	ug/L			09/10/15 00:11	1
1,1-Dichloropropene	<0.50		0.50	0.095	ug/L			09/10/15 00:11	1
1,3-Dichloropropene, Total	<0.50		0.50	0.081	ug/L			09/10/15 00:11	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/10/15 00:11	1
Ethylbenzene	<0.50		0.50	0.099	ug/L			09/10/15 00:11	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/10/15 00:11	1
Freon 113	<0.50		0.50	0.15	ug/L			09/10/15 00:11	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/10/15 00:11	1
2-Hexanone	<10		10	5.0	ug/L			09/10/15 00:11	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/10/15 00:11	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/10/15 00:11	1
Methylene Chloride	<0.50		0.50	0.20	ug/L			09/10/15 00:11	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/10/15 00:11	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/10/15 00:11	1
m-Xylene & p-Xylene	<0.50		0.50	0.15	ug/L			09/10/15 00:11	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/10/15 00:11	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/10/15 00:11	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/10/15 00:11	1
o-Xylene	<0.50		0.50	0.086	ug/L			09/10/15 00:11	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/10/15 00:11	1
Styrene	<0.50		0.50	0.089	ug/L			09/10/15 00:11	1

TestAmerica Savannah

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Client Sample ID: HAMP-22

Lab Sample ID: 680-116159-3

Date Collected: 08/27/15 09:15

Matrix: Water

Date Received: 08/28/15 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/10/15 00:11	1
tert-Butyl alcohol	<10		10	1.6	ug/L			09/10/15 00:11	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/10/15 00:11	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/10/15 00:11	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.24	ug/L			09/10/15 00:11	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.13	ug/L			09/10/15 00:11	1
Tetrachloroethene	<0.50		0.50	0.18	ug/L			09/10/15 00:11	1
Toluene	<0.50		0.50	0.086	ug/L			09/10/15 00:11	1
trans-1,2-Dichloroethene	<0.50		0.50	0.090	ug/L			09/10/15 00:11	1
trans-1,3-Dichloropropene	<0.50		0.50	0.11	ug/L			09/10/15 00:11	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/10/15 00:11	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.12	ug/L			09/10/15 00:11	1
1,1,1-Trichloroethane	<0.50		0.50	0.15	ug/L			09/10/15 00:11	1
1,1,2-Trichloroethane	<0.50		0.50	0.16	ug/L			09/10/15 00:11	1
Trichloroethene	<0.50		0.50	0.13	ug/L			09/10/15 00:11	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/10/15 00:11	1
1,2,3-Trichloropropane	<0.50		0.50	0.17	ug/L			09/10/15 00:11	1
Trihalomethanes, Total	<0.50		0.50	0.079	ug/L			09/10/15 00:11	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/10/15 00:11	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/10/15 00:11	1
Vinyl chloride	<0.50		0.50	0.16	ug/L			09/10/15 00:11	1
Xylenes, Total	<0.50		0.50	0.086	ug/L			09/10/15 00:11	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	97		70 - 130		09/10/15 00:11	1
1,2-Dichlorobenzene-d4	97		70 - 130		09/10/15 00:11	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Client Sample ID: HAMP-23

Lab Sample ID: 680-116159-4

Date Collected: 08/27/15 09:20

Matrix: Water

Date Received: 08/28/15 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			09/10/15 00:32	1
Benzene	<0.50		0.50	0.082	ug/L			09/10/15 00:32	1
Bromobenzene	<0.50		0.50	0.091	ug/L			09/10/15 00:32	1
Bromoform	<0.50		0.50	0.17	ug/L			09/10/15 00:32	1
Bromomethane	<1.0	*	1.0	0.20	ug/L			09/10/15 00:32	1
Carbon tetrachloride	<0.50		0.50	0.11	ug/L			09/10/15 00:32	1
Chlorobenzene	<0.50		0.50	0.14	ug/L			09/10/15 00:32	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/10/15 00:32	1
Chlorodibromomethane	<0.50		0.50	0.13	ug/L			09/10/15 00:32	1
Chloroethane	<1.0		1.0	0.22	ug/L			09/10/15 00:32	1
Chloroform	0.34	J	0.50	0.20	ug/L			09/10/15 00:32	1
Chloromethane	<0.50		0.50	0.15	ug/L			09/10/15 00:32	1
2-Chlorotoluene	<0.50		0.50	0.11	ug/L			09/10/15 00:32	1
4-Chlorotoluene	<0.50		0.50	0.13	ug/L			09/10/15 00:32	1
cis-1,2-Dichloroethene	<0.50		0.50	0.090	ug/L			09/10/15 00:32	1
cis-1,3-Dichloropropene	<0.50		0.50	0.081	ug/L			09/10/15 00:32	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/10/15 00:32	1
Dibromomethane	<0.50		0.50	0.16	ug/L			09/10/15 00:32	1
1,2-Dichlorobenzene	<0.50		0.50	0.16	ug/L			09/10/15 00:32	1
1,3-Dichlorobenzene	<0.50		0.50	0.11	ug/L			09/10/15 00:32	1
1,4-Dichlorobenzene	<0.50		0.50	0.13	ug/L			09/10/15 00:32	1
Dichlorobromomethane	<0.50		0.50	0.079	ug/L			09/10/15 00:32	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/10/15 00:32	1
1,1-Dichloroethane	<0.50		0.50	0.078	ug/L			09/10/15 00:32	1
1,2-Dichloroethane	<0.50		0.50	0.086	ug/L			09/10/15 00:32	1
1,1-Dichloroethene	<0.50		0.50	0.15	ug/L			09/10/15 00:32	1
1,2-Dichloropropane	<0.50		0.50	0.096	ug/L			09/10/15 00:32	1
1,3-Dichloropropane	<0.50		0.50	0.10	ug/L			09/10/15 00:32	1
2,2-Dichloropropane	<0.50		0.50	0.20	ug/L			09/10/15 00:32	1
1,1-Dichloropropene	<0.50		0.50	0.095	ug/L			09/10/15 00:32	1
1,3-Dichloropropene, Total	<0.50		0.50	0.081	ug/L			09/10/15 00:32	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/10/15 00:32	1
Ethylbenzene	<0.50		0.50	0.099	ug/L			09/10/15 00:32	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/10/15 00:32	1
Freon 113	<0.50		0.50	0.15	ug/L			09/10/15 00:32	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/10/15 00:32	1
2-Hexanone	<10		10	5.0	ug/L			09/10/15 00:32	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/10/15 00:32	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/10/15 00:32	1
Methylene Chloride	<0.50		0.50	0.20	ug/L			09/10/15 00:32	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/10/15 00:32	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/10/15 00:32	1
m-Xylene & p-Xylene	<0.50		0.50	0.15	ug/L			09/10/15 00:32	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/10/15 00:32	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/10/15 00:32	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/10/15 00:32	1
o-Xylene	<0.50		0.50	0.086	ug/L			09/10/15 00:32	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/10/15 00:32	1
Styrene	<0.50		0.50	0.089	ug/L			09/10/15 00:32	1

TestAmerica Savannah

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Client Sample ID: HAMP-23

Lab Sample ID: 680-116159-4

Date Collected: 08/27/15 09:20

Matrix: Water

Date Received: 08/28/15 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/10/15 00:32	1
tert-Butyl alcohol	<10		10	1.6	ug/L			09/10/15 00:32	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/10/15 00:32	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/10/15 00:32	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.24	ug/L			09/10/15 00:32	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.13	ug/L			09/10/15 00:32	1
Tetrachloroethene	0.34	J	0.50	0.18	ug/L			09/10/15 00:32	1
Toluene	<0.50		0.50	0.086	ug/L			09/10/15 00:32	1
trans-1,2-Dichloroethene	<0.50		0.50	0.090	ug/L			09/10/15 00:32	1
trans-1,3-Dichloropropene	<0.50		0.50	0.11	ug/L			09/10/15 00:32	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/10/15 00:32	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.12	ug/L			09/10/15 00:32	1
1,1,1-Trichloroethane	<0.50		0.50	0.15	ug/L			09/10/15 00:32	1
1,1,2-Trichloroethane	<0.50		0.50	0.16	ug/L			09/10/15 00:32	1
Trichloroethene	<0.50		0.50	0.13	ug/L			09/10/15 00:32	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/10/15 00:32	1
1,2,3-Trichloropropane	<0.50		0.50	0.17	ug/L			09/10/15 00:32	1
Trihalomethanes, Total	0.34	J	0.50	0.079	ug/L			09/10/15 00:32	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/10/15 00:32	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/10/15 00:32	1
Vinyl chloride	<0.50		0.50	0.16	ug/L			09/10/15 00:32	1
Xylenes, Total	<0.50		0.50	0.086	ug/L			09/10/15 00:32	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	101		70 - 130					09/10/15 00:32	1
1,2-Dichlorobenzene-d4	100		70 - 130					09/10/15 00:32	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Client Sample ID: Trip Blank

Date Collected: 08/26/15 07:00

Date Received: 08/28/15 09:20

Lab Sample ID: 680-116159-5

Matrix: Water

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			09/01/15 12:00	1
Benzene	<0.50		0.50	0.082	ug/L			09/01/15 12:00	1
Bromobenzene	<0.50		0.50	0.091	ug/L			09/01/15 12:00	1
Bromoform	<0.50		0.50	0.17	ug/L			09/01/15 12:00	1
Bromomethane	<1.0		1.0	0.20	ug/L			09/01/15 12:00	1
Carbon tetrachloride	<0.50		0.50	0.11	ug/L			09/01/15 12:00	1
Chlorobenzene	<0.50		0.50	0.14	ug/L			09/01/15 12:00	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/01/15 12:00	1
Chlorodibromomethane	<0.50		0.50	0.13	ug/L			09/01/15 12:00	1
Chloroethane	<1.0		1.0	0.22	ug/L			09/01/15 12:00	1
Chloroform	<0.50		0.50	0.20	ug/L			09/01/15 12:00	1
Chloromethane	<0.50		0.50	0.15	ug/L			09/01/15 12:00	1
2-Chlorotoluene	<0.50		0.50	0.11	ug/L			09/01/15 12:00	1
4-Chlorotoluene	<0.50		0.50	0.13	ug/L			09/01/15 12:00	1
cis-1,2-Dichloroethene	<0.50		0.50	0.090	ug/L			09/01/15 12:00	1
cis-1,3-Dichloropropene	<0.50		0.50	0.081	ug/L			09/01/15 12:00	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/01/15 12:00	1
Dibromomethane	<0.50		0.50	0.16	ug/L			09/01/15 12:00	1
1,2-Dichlorobenzene	<0.50		0.50	0.16	ug/L			09/01/15 12:00	1
1,3-Dichlorobenzene	<0.50		0.50	0.11	ug/L			09/01/15 12:00	1
1,4-Dichlorobenzene	<0.50		0.50	0.13	ug/L			09/01/15 12:00	1
Dichlorobromomethane	<0.50		0.50	0.079	ug/L			09/01/15 12:00	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/01/15 12:00	1
1,1-Dichloroethane	<0.50		0.50	0.078	ug/L			09/01/15 12:00	1
1,2-Dichloroethane	<0.50		0.50	0.086	ug/L			09/01/15 12:00	1
1,1-Dichloroethene	<0.50		0.50	0.15	ug/L			09/01/15 12:00	1
1,2-Dichloropropane	<0.50		0.50	0.096	ug/L			09/01/15 12:00	1
1,3-Dichloropropane	<0.50		0.50	0.10	ug/L			09/01/15 12:00	1
2,2-Dichloropropane	<0.50		0.50	0.20	ug/L			09/01/15 12:00	1
1,1-Dichloropropene	<0.50		0.50	0.095	ug/L			09/01/15 12:00	1
1,3-Dichloropropene, Total	<0.50		0.50	0.081	ug/L			09/01/15 12:00	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/01/15 12:00	1
Ethylbenzene	<0.50		0.50	0.099	ug/L			09/01/15 12:00	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/01/15 12:00	1
Freon 113	<0.50		0.50	0.15	ug/L			09/01/15 12:00	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/01/15 12:00	1
2-Hexanone	<10		10	5.0	ug/L			09/01/15 12:00	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/01/15 12:00	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/01/15 12:00	1
Methylene Chloride	<0.50		0.50	0.20	ug/L			09/01/15 12:00	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/01/15 12:00	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/01/15 12:00	1
m-Xylene & p-Xylene	<0.50		0.50	0.15	ug/L			09/01/15 12:00	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/01/15 12:00	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/01/15 12:00	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/01/15 12:00	1
o-Xylene	<0.50		0.50	0.086	ug/L			09/01/15 12:00	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/01/15 12:00	1
Styrene	<0.50		0.50	0.089	ug/L			09/01/15 12:00	1

TestAmerica Savannah

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-116159-5

Date Collected: 08/26/15 07:00

Matrix: Water

Date Received: 08/28/15 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/01/15 12:00	1
tert-Butyl alcohol	<10		10	1.6	ug/L			09/01/15 12:00	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/01/15 12:00	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/01/15 12:00	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.24	ug/L			09/01/15 12:00	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.13	ug/L			09/01/15 12:00	1
Tetrachloroethene	<0.50		0.50	0.18	ug/L			09/01/15 12:00	1
Toluene	<0.50		0.50	0.086	ug/L			09/01/15 12:00	1
trans-1,2-Dichloroethene	<0.50		0.50	0.090	ug/L			09/01/15 12:00	1
trans-1,3-Dichloropropene	<0.50		0.50	0.11	ug/L			09/01/15 12:00	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/01/15 12:00	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.12	ug/L			09/01/15 12:00	1
1,1,1-Trichloroethane	<0.50		0.50	0.15	ug/L			09/01/15 12:00	1
1,1,2-Trichloroethane	<0.50		0.50	0.16	ug/L			09/01/15 12:00	1
Trichloroethene	<0.50		0.50	0.13	ug/L			09/01/15 12:00	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/01/15 12:00	1
1,2,3-Trichloropropane	<0.50		0.50	0.17	ug/L			09/01/15 12:00	1
Trihalomethanes, Total	<0.50		0.50	0.079	ug/L			09/01/15 12:00	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/01/15 12:00	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/01/15 12:00	1
Vinyl chloride	<0.50		0.50	0.16	ug/L			09/01/15 12:00	1
Xylenes, Total	<0.50		0.50	0.086	ug/L			09/01/15 12:00	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	98		70 - 130		09/01/15 12:00	1
1,2-Dichlorobenzene-d4	98		70 - 130		09/01/15 12:00	1

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Lab Sample ID: MB 680-398947/9
Matrix: Water
Analysis Batch: 398947

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			09/01/15 11:13	1
Benzene	<0.50		0.50	0.082	ug/L			09/01/15 11:13	1
Bromobenzene	<0.50		0.50	0.091	ug/L			09/01/15 11:13	1
Bromoform	<0.50		0.50	0.17	ug/L			09/01/15 11:13	1
Bromomethane	<1.0		1.0	0.20	ug/L			09/01/15 11:13	1
Carbon tetrachloride	<0.50		0.50	0.11	ug/L			09/01/15 11:13	1
Chlorobenzene	<0.50		0.50	0.14	ug/L			09/01/15 11:13	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/01/15 11:13	1
Chlorodibromomethane	<0.50		0.50	0.13	ug/L			09/01/15 11:13	1
Chloroethane	<1.0		1.0	0.22	ug/L			09/01/15 11:13	1
Chloroform	<0.50		0.50	0.20	ug/L			09/01/15 11:13	1
Chloromethane	<0.50		0.50	0.15	ug/L			09/01/15 11:13	1
2-Chlorotoluene	<0.50		0.50	0.11	ug/L			09/01/15 11:13	1
4-Chlorotoluene	<0.50		0.50	0.13	ug/L			09/01/15 11:13	1
cis-1,2-Dichloroethene	<0.50		0.50	0.090	ug/L			09/01/15 11:13	1
cis-1,3-Dichloropropene	<0.50		0.50	0.081	ug/L			09/01/15 11:13	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/01/15 11:13	1
Dibromomethane	<0.50		0.50	0.16	ug/L			09/01/15 11:13	1
1,2-Dichlorobenzene	<0.50		0.50	0.16	ug/L			09/01/15 11:13	1
1,3-Dichlorobenzene	<0.50		0.50	0.11	ug/L			09/01/15 11:13	1
1,4-Dichlorobenzene	<0.50		0.50	0.13	ug/L			09/01/15 11:13	1
Dichlorobromomethane	<0.50		0.50	0.079	ug/L			09/01/15 11:13	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/01/15 11:13	1
1,1-Dichloroethane	<0.50		0.50	0.078	ug/L			09/01/15 11:13	1
1,2-Dichloroethane	<0.50		0.50	0.086	ug/L			09/01/15 11:13	1
1,1-Dichloroethene	<0.50		0.50	0.15	ug/L			09/01/15 11:13	1
1,2-Dichloropropane	<0.50		0.50	0.096	ug/L			09/01/15 11:13	1
1,3-Dichloropropane	<0.50		0.50	0.10	ug/L			09/01/15 11:13	1
2,2-Dichloropropane	<0.50		0.50	0.20	ug/L			09/01/15 11:13	1
1,1-Dichloropropene	<0.50		0.50	0.095	ug/L			09/01/15 11:13	1
1,3-Dichloropropene, Total	<0.50		0.50	0.081	ug/L			09/01/15 11:13	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/01/15 11:13	1
Ethylbenzene	<0.50		0.50	0.099	ug/L			09/01/15 11:13	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/01/15 11:13	1
Freon 113	<0.50		0.50	0.15	ug/L			09/01/15 11:13	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/01/15 11:13	1
2-Hexanone	<10		10	5.0	ug/L			09/01/15 11:13	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/01/15 11:13	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/01/15 11:13	1
Methylene Chloride	<0.50		0.50	0.20	ug/L			09/01/15 11:13	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/01/15 11:13	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/01/15 11:13	1
m-Xylene & p-Xylene	<0.50		0.50	0.15	ug/L			09/01/15 11:13	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/01/15 11:13	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/01/15 11:13	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/01/15 11:13	1
o-Xylene	<0.50		0.50	0.086	ug/L			09/01/15 11:13	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/01/15 11:13	1

TestAmerica Savannah

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 680-398947/9
Matrix: Water
Analysis Batch: 398947

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil	Fac
	Result	Qualifier								
Styrene	<0.50		0.50	0.089	ug/L			09/01/15 11:13	1	
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/01/15 11:13	1	
tert-Butyl alcohol	<10		10	1.6	ug/L			09/01/15 11:13	1	
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/01/15 11:13	1	
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/01/15 11:13	1	
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.24	ug/L			09/01/15 11:13	1	
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.13	ug/L			09/01/15 11:13	1	
Tetrachloroethene	<0.50		0.50	0.18	ug/L			09/01/15 11:13	1	
Toluene	<0.50		0.50	0.086	ug/L			09/01/15 11:13	1	
trans-1,2-Dichloroethene	<0.50		0.50	0.090	ug/L			09/01/15 11:13	1	
trans-1,3-Dichloropropene	<0.50		0.50	0.11	ug/L			09/01/15 11:13	1	
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/01/15 11:13	1	
1,2,4-Trichlorobenzene	<0.50		0.50	0.12	ug/L			09/01/15 11:13	1	
1,1,1-Trichloroethane	<0.50		0.50	0.15	ug/L			09/01/15 11:13	1	
1,1,2-Trichloroethane	<0.50		0.50	0.16	ug/L			09/01/15 11:13	1	
Trichloroethene	<0.50		0.50	0.13	ug/L			09/01/15 11:13	1	
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/01/15 11:13	1	
1,2,3-Trichloropropane	<0.50		0.50	0.17	ug/L			09/01/15 11:13	1	
Trihalomethanes, Total	<0.50		0.50	0.079	ug/L			09/01/15 11:13	1	
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/01/15 11:13	1	
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/01/15 11:13	1	
Vinyl chloride	<0.50		0.50	0.16	ug/L			09/01/15 11:13	1	
Xylenes, Total	<0.50		0.50	0.086	ug/L			09/01/15 11:13	1	

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil	Fac
	%Recovery	Qualifier					
4-Bromofluorobenzene	99		70 - 130		09/01/15 11:13	1	
1,2-Dichlorobenzene-d4	98		70 - 130		09/01/15 11:13	1	

Lab Sample ID: LCS 680-398947/4
Matrix: Water
Analysis Batch: 398947

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Benzene	20.0	20.3		ug/L		101	70 - 130
Bromobenzene	20.0	19.4		ug/L		97	70 - 130
Bromoform	20.0	21.9		ug/L		110	70 - 130
Bromomethane	20.0	21.9		ug/L		110	70 - 130
Carbon tetrachloride	20.0	19.6		ug/L		98	70 - 130
Chlorobenzene	20.0	20.1		ug/L		101	70 - 130
Chlorobromomethane	20.0	20.3		ug/L		102	70 - 130
Chlorodibromomethane	20.0	20.2		ug/L		101	70 - 130
Chloroethane	20.0	18.3		ug/L		91	70 - 130
Chloroform	20.0	19.9		ug/L		99	70 - 130
Chloromethane	20.0	18.6		ug/L		93	70 - 130
2-Chlorotoluene	20.0	20.3		ug/L		101	70 - 130
4-Chlorotoluene	20.0	20.2		ug/L		101	70 - 130
cis-1,2-Dichloroethene	20.0	20.1		ug/L		101	70 - 130

TestAmerica Savannah

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 680-398947/4
Matrix: Water
Analysis Batch: 398947

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
cis-1,3-Dichloropropene	20.0	20.9		ug/L		105	70 - 130
1,2-Dibromo-3-Chloropropane	20.0	21.1		ug/L		105	70 - 130
Dibromomethane	20.0	19.6		ug/L		98	70 - 130
1,2-Dichlorobenzene	20.0	20.0		ug/L		100	70 - 130
1,3-Dichlorobenzene	20.0	20.0		ug/L		100	70 - 130
1,4-Dichlorobenzene	20.0	20.1		ug/L		101	70 - 130
Dichlorobromomethane	20.0	20.0		ug/L		100	70 - 130
Dichlorodifluoromethane	20.0	14.7		ug/L		74	70 - 130
1,1-Dichloroethane	20.0	19.9		ug/L		100	70 - 130
1,2-Dichloroethane	20.0	19.2		ug/L		96	70 - 130
1,1-Dichloroethene	20.0	18.6		ug/L		93	70 - 130
1,2-Dichloropropane	20.0	20.4		ug/L		102	70 - 130
1,3-Dichloropropane	20.0	20.6		ug/L		103	70 - 130
2,2-Dichloropropane	20.0	20.5		ug/L		103	70 - 130
1,1-Dichloropropene	20.0	20.4		ug/L		102	70 - 130
1,3-Dichloropropene, Total	40.0	41.9		ug/L		105	70 - 130
Diisopropyl ether	20.0	20.6		ug/L		103	70 - 130
Ethylbenzene	20.0	20.3		ug/L		101	70 - 130
Ethylene Dibromide	20.0	20.2		ug/L		101	70 - 130
Freon 113	20.0	20.2		ug/L		101	70 - 130
Hexachlorobutadiene	20.0	21.0		ug/L		105	70 - 130
2-Hexanone	100	108		ug/L		108	70 - 130
Isopropylbenzene	20.0	20.3		ug/L		101	70 - 130
4-Isopropyltoluene	20.0	21.1		ug/L		106	70 - 130
Methylene Chloride	20.0	20.4		ug/L		102	70 - 130
2-Butanone (MEK)	100	107		ug/L		107	70 - 130
4-Methyl-2-pentanone (MIBK)	100	105		ug/L		105	70 - 130
m-Xylene & p-Xylene	20.0	20.4		ug/L		102	70 - 130
Naphthalene	20.0	21.2		ug/L		106	70 - 130
n-Butylbenzene	20.0	21.3		ug/L		107	70 - 130
N-Propylbenzene	20.0	20.4		ug/L		102	70 - 130
o-Xylene	20.0	20.3		ug/L		101	70 - 130
sec-Butylbenzene	20.0	21.0		ug/L		105	70 - 130
Styrene	20.0	20.6		ug/L		103	70 - 130
Tert-amyl methyl ether	20.0	21.2		ug/L		106	70 - 130
tert-Butyl alcohol	200	203		ug/L		101	70 - 130
tert-Butylbenzene	20.0	20.3		ug/L		101	70 - 130
Tert-butyl ethyl ether	20.0	20.8		ug/L		104	70 - 130
1,1,1,2-Tetrachloroethane	20.0	20.0		ug/L		100	70 - 130
1,1,2,2-Tetrachloroethane	20.0	20.7		ug/L		103	70 - 130
Tetrachloroethene	20.0	20.3		ug/L		101	70 - 130
Toluene	20.0	20.3		ug/L		102	70 - 130
trans-1,2-Dichloroethene	20.0	19.7		ug/L		98	70 - 130
trans-1,3-Dichloropropene	20.0	21.0		ug/L		105	70 - 130
1,2,3-Trichlorobenzene	20.0	21.3		ug/L		107	70 - 130
1,2,4-Trichlorobenzene	20.0	20.8		ug/L		104	70 - 130
1,1,1-Trichloroethane	20.0	19.2		ug/L		96	70 - 130
1,1,2-Trichloroethane	20.0	20.3		ug/L		101	70 - 130

TestAmerica Savannah

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 680-398947/4
Matrix: Water
Analysis Batch: 398947

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Trichloroethene	20.0	20.2		ug/L		101	70 - 130
Trichlorofluoromethane	20.0	18.8		ug/L		94	70 - 130
1,2,3-Trichloropropane	20.0	21.4		ug/L		107	70 - 130
Trihalomethanes, Total	80.0	82.0		ug/L		103	70 - 130
1,2,4-Trimethylbenzene	20.0	20.9		ug/L		104	70 - 130
1,3,5-Trimethylbenzene	20.0	20.4		ug/L		102	70 - 130
Vinyl chloride	20.0	16.0		ug/L		80	70 - 130
Xylenes, Total	40.0	40.7		ug/L		102	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
4-Bromofluorobenzene	100		70 - 130
1,2-Dichlorobenzene-d4	104		70 - 130

Lab Sample ID: LCS 680-398947/5
Matrix: Water
Analysis Batch: 398947

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Acetone	100	105		ug/L		105	70 - 130	2	30
Benzene	20.0	20.1		ug/L		101	70 - 130	1	30
Bromobenzene	20.0	19.2		ug/L		96	70 - 130	1	30
Bromoform	20.0	20.4		ug/L		102	70 - 130	7	30
Bromomethane	20.0	22.4		ug/L		112	70 - 130	2	30
Carbon tetrachloride	20.0	19.7		ug/L		99	70 - 130	0	30
Chlorobenzene	20.0	20.1		ug/L		101	70 - 130	0	30
Chlorobromomethane	20.0	20.6		ug/L		103	70 - 130	1	30
Chlorodibromomethane	20.0	19.5		ug/L		98	70 - 130	3	30
Chloroethane	20.0	20.4		ug/L		102	70 - 130	11	30
Chloroform	20.0	19.6		ug/L		98	70 - 130	2	30
Chloromethane	20.0	20.3		ug/L		102	70 - 130	9	30
2-Chlorotoluene	20.0	19.9		ug/L		99	70 - 130	2	30
4-Chlorotoluene	20.0	19.4		ug/L		97	70 - 130	4	30
cis-1,2-Dichloroethene	20.0	19.8		ug/L		99	70 - 130	2	30
cis-1,3-Dichloropropene	20.0	20.7		ug/L		104	70 - 130	1	30
1,2-Dibromo-3-Chloropropane	20.0	19.1		ug/L		96	70 - 130	10	30
Dibromomethane	20.0	18.9		ug/L		95	70 - 130	4	30
1,2-Dichlorobenzene	20.0	18.3		ug/L		92	70 - 130	9	30
1,3-Dichlorobenzene	20.0	18.7		ug/L		94	70 - 130	7	30
1,4-Dichlorobenzene	20.0	18.9		ug/L		95	70 - 130	6	30
Dichlorobromomethane	20.0	19.8		ug/L		99	70 - 130	1	30
Dichlorodifluoromethane	20.0	15.0		ug/L		75	70 - 130	2	30
1,1-Dichloroethane	20.0	19.8		ug/L		99	70 - 130	1	30
1,2-Dichloroethane	20.0	18.6		ug/L		93	70 - 130	3	30
1,1-Dichloroethene	20.0	20.9		ug/L		104	70 - 130	12	30
1,2-Dichloropropane	20.0	20.4		ug/L		102	70 - 130	0	30
1,3-Dichloropropane	20.0	20.0		ug/L		100	70 - 130	3	30
2,2-Dichloropropane	20.0	20.2		ug/L		101	70 - 130	2	30
1,1-Dichloropropene	20.0	20.4		ug/L		102	70 - 130	0	30

TestAmerica Savannah

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 680-398947/5
Matrix: Water
Analysis Batch: 398947

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec.	RPD	RPD Limit
							Limits		
1,3-Dichloropropene, Total	40.0	41.4		ug/L		103	70 - 130	1	30
Diisopropyl ether	20.0	20.4		ug/L		102	70 - 130	1	30
Ethylbenzene	20.0	20.2		ug/L		101	70 - 130	0	30
Ethylene Dibromide	20.0	19.6		ug/L		98	70 - 130	3	30
Freon 113	20.0	20.0		ug/L		100	70 - 130	1	30
Hexachlorobutadiene	20.0	20.0		ug/L		100	70 - 130	4	30
2-Hexanone	100	103		ug/L		103	70 - 130	5	30
Isopropylbenzene	20.0	20.5		ug/L		103	70 - 130	1	30
4-Isopropyltoluene	20.0	20.4		ug/L		102	70 - 130	4	30
Methylene Chloride	20.0	20.0		ug/L		100	70 - 130	2	30
2-Butanone (MEK)	100	99.4		ug/L		99	70 - 130	7	30
4-Methyl-2-pentanone (MIBK)	100	101		ug/L		101	70 - 130	4	30
m-Xylene & p-Xylene	20.0	20.3		ug/L		101	70 - 130	1	30
Naphthalene	20.0	19.1		ug/L		96	70 - 130	11	30
n-Butylbenzene	20.0	20.0		ug/L		100	70 - 130	6	30
N-Propylbenzene	20.0	20.2		ug/L		101	70 - 130	1	30
o-Xylene	20.0	20.2		ug/L		101	70 - 130	0	30
sec-Butylbenzene	20.0	20.3		ug/L		102	70 - 130	3	30
Styrene	20.0	20.3		ug/L		101	70 - 130	2	30
Tert-amyl methyl ether	20.0	20.5		ug/L		103	70 - 130	3	30
tert-Butyl alcohol	200	206		ug/L		103	70 - 130	2	30
tert-Butylbenzene	20.0	19.9		ug/L		99	70 - 130	2	30
Tert-butyl ethyl ether	20.0	20.5		ug/L		102	70 - 130	1	30
1,1,1,2-Tetrachloroethane	20.0	19.7		ug/L		98	70 - 130	2	30
1,1,2,2-Tetrachloroethane	20.0	19.6		ug/L		98	70 - 130	5	30
Tetrachloroethene	20.0	19.8		ug/L		99	70 - 130	2	30
Toluene	20.0	20.1		ug/L		101	70 - 130	1	30
trans-1,2-Dichloroethene	20.0	20.0		ug/L		100	70 - 130	1	30
trans-1,3-Dichloropropene	20.0	20.6		ug/L		103	70 - 130	2	30
1,2,3-Trichlorobenzene	20.0	19.8		ug/L		99	70 - 130	7	30
1,2,4-Trichlorobenzene	20.0	19.3		ug/L		97	70 - 130	7	30
1,1,1-Trichloroethane	20.0	19.5		ug/L		97	70 - 130	1	30
1,1,2-Trichloroethane	20.0	19.4		ug/L		97	70 - 130	4	30
Trichloroethene	20.0	20.2		ug/L		101	70 - 130	0	30
Trichlorofluoromethane	20.0	21.8		ug/L		109	70 - 130	15	30
1,2,3-Trichloropropane	20.0	20.0		ug/L		100	70 - 130	7	30
Trihalomethanes, Total	80.0	79.3		ug/L		99	70 - 130	3	30
1,2,4-Trimethylbenzene	20.0	20.2		ug/L		101	70 - 130	3	30
1,3,5-Trimethylbenzene	20.0	19.8		ug/L		99	70 - 130	3	30
Vinyl chloride	20.0	19.8		ug/L		99	70 - 130	21	30
Xylenes, Total	40.0	40.5		ug/L		101	70 - 130	1	30

Surrogate	LCSD LCSD		Limits
	%Recovery	Qualifier	
4-Bromofluorobenzene	99		70 - 130
1,2-Dichlorobenzene-d4	95		70 - 130

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 680-400213/9
Matrix: Water
Analysis Batch: 400213

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Acetone	<10		10	5.0	ug/L			09/09/15 19:57	1
Benzene	<0.50		0.50	0.082	ug/L			09/09/15 19:57	1
Bromobenzene	<0.50		0.50	0.091	ug/L			09/09/15 19:57	1
Bromoform	<0.50		0.50	0.17	ug/L			09/09/15 19:57	1
Bromomethane	<1.0		1.0	0.20	ug/L			09/09/15 19:57	1
Carbon tetrachloride	<0.50		0.50	0.11	ug/L			09/09/15 19:57	1
Chlorobenzene	<0.50		0.50	0.14	ug/L			09/09/15 19:57	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/09/15 19:57	1
Chlorodibromomethane	<0.50		0.50	0.13	ug/L			09/09/15 19:57	1
Chloroethane	<1.0		1.0	0.22	ug/L			09/09/15 19:57	1
Chloroform	<0.50		0.50	0.20	ug/L			09/09/15 19:57	1
Chloromethane	<0.50		0.50	0.15	ug/L			09/09/15 19:57	1
2-Chlorotoluene	<0.50		0.50	0.11	ug/L			09/09/15 19:57	1
4-Chlorotoluene	<0.50		0.50	0.13	ug/L			09/09/15 19:57	1
cis-1,2-Dichloroethene	<0.50		0.50	0.090	ug/L			09/09/15 19:57	1
cis-1,3-Dichloropropene	<0.50		0.50	0.081	ug/L			09/09/15 19:57	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/09/15 19:57	1
Dibromomethane	<0.50		0.50	0.16	ug/L			09/09/15 19:57	1
1,2-Dichlorobenzene	<0.50		0.50	0.16	ug/L			09/09/15 19:57	1
1,3-Dichlorobenzene	<0.50		0.50	0.11	ug/L			09/09/15 19:57	1
1,4-Dichlorobenzene	<0.50		0.50	0.13	ug/L			09/09/15 19:57	1
Dichlorobromomethane	<0.50		0.50	0.079	ug/L			09/09/15 19:57	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/09/15 19:57	1
1,1-Dichloroethane	<0.50		0.50	0.078	ug/L			09/09/15 19:57	1
1,2-Dichloroethane	<0.50		0.50	0.086	ug/L			09/09/15 19:57	1
1,1-Dichloroethene	<0.50		0.50	0.15	ug/L			09/09/15 19:57	1
1,2-Dichloropropane	<0.50		0.50	0.096	ug/L			09/09/15 19:57	1
1,3-Dichloropropane	<0.50		0.50	0.10	ug/L			09/09/15 19:57	1
2,2-Dichloropropane	<0.50		0.50	0.20	ug/L			09/09/15 19:57	1
1,1-Dichloropropene	<0.50		0.50	0.095	ug/L			09/09/15 19:57	1
1,3-Dichloropropene, Total	<0.50		0.50	0.081	ug/L			09/09/15 19:57	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/09/15 19:57	1
Ethylbenzene	<0.50		0.50	0.099	ug/L			09/09/15 19:57	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/09/15 19:57	1
Freon 113	<0.50		0.50	0.15	ug/L			09/09/15 19:57	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/09/15 19:57	1
2-Hexanone	<10		10	5.0	ug/L			09/09/15 19:57	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/09/15 19:57	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/09/15 19:57	1
Methylene Chloride	<0.50		0.50	0.20	ug/L			09/09/15 19:57	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/09/15 19:57	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/09/15 19:57	1
m-Xylene & p-Xylene	<0.50		0.50	0.15	ug/L			09/09/15 19:57	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/09/15 19:57	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/09/15 19:57	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/09/15 19:57	1
o-Xylene	<0.50		0.50	0.086	ug/L			09/09/15 19:57	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/09/15 19:57	1

TestAmerica Savannah

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 680-400213/9
Matrix: Water
Analysis Batch: 400213

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Styrene	<0.50		0.50	0.089	ug/L			09/09/15 19:57	1
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/09/15 19:57	1
tert-Butyl alcohol	<10		10	1.6	ug/L			09/09/15 19:57	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/09/15 19:57	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/09/15 19:57	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.24	ug/L			09/09/15 19:57	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.13	ug/L			09/09/15 19:57	1
Tetrachloroethene	<0.50		0.50	0.18	ug/L			09/09/15 19:57	1
Toluene	<0.50		0.50	0.086	ug/L			09/09/15 19:57	1
trans-1,2-Dichloroethene	<0.50		0.50	0.090	ug/L			09/09/15 19:57	1
trans-1,3-Dichloropropene	<0.50		0.50	0.11	ug/L			09/09/15 19:57	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/09/15 19:57	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.12	ug/L			09/09/15 19:57	1
1,1,1-Trichloroethane	<0.50		0.50	0.15	ug/L			09/09/15 19:57	1
1,1,2-Trichloroethane	<0.50		0.50	0.16	ug/L			09/09/15 19:57	1
Trichloroethene	<0.50		0.50	0.13	ug/L			09/09/15 19:57	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/09/15 19:57	1
1,2,3-Trichloropropane	<0.50		0.50	0.17	ug/L			09/09/15 19:57	1
Trihalomethanes, Total	<0.50		0.50	0.079	ug/L			09/09/15 19:57	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/09/15 19:57	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/09/15 19:57	1
Vinyl chloride	<0.50		0.50	0.16	ug/L			09/09/15 19:57	1
Xylenes, Total	<0.50		0.50	0.086	ug/L			09/09/15 19:57	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
4-Bromofluorobenzene	98		70 - 130		09/09/15 19:57	1
1,2-Dichlorobenzene-d4	97		70 - 130		09/09/15 19:57	1

Lab Sample ID: LCS 680-400213/4
Matrix: Water
Analysis Batch: 400213

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Benzene	20.0	20.4		ug/L		102	70 - 130
Bromobenzene	20.0	19.9		ug/L		100	70 - 130
Bromoform	20.0	21.1		ug/L		105	70 - 130
Bromomethane	20.0	27.9 *		ug/L		139	70 - 130
Carbon tetrachloride	20.0	19.6		ug/L		98	70 - 130
Chlorobenzene	20.0	20.2		ug/L		101	70 - 130
Chlorobromomethane	20.0	20.4		ug/L		102	70 - 130
Chlorodibromomethane	20.0	20.0		ug/L		100	70 - 130
Chloroethane	20.0	19.7		ug/L		99	70 - 130
Chloroform	20.0	19.8		ug/L		99	70 - 130
Chloromethane	20.0	23.3		ug/L		117	70 - 130
2-Chlorotoluene	20.0	19.7		ug/L		99	70 - 130
4-Chlorotoluene	20.0	19.8		ug/L		99	70 - 130
cis-1,2-Dichloroethene	20.0	20.3		ug/L		101	70 - 130

TestAmerica Savannah

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 680-400213/4
Matrix: Water
Analysis Batch: 400213

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS		Unit	D	%Rec	%Rec. Limits
		Result	Qualifier				
cis-1,3-Dichloropropene	20.0	21.2		ug/L		106	70 - 130
1,2-Dibromo-3-Chloropropane	20.0	20.5		ug/L		102	70 - 130
Dibromomethane	20.0	19.6		ug/L		98	70 - 130
1,2-Dichlorobenzene	20.0	19.3		ug/L		97	70 - 130
1,3-Dichlorobenzene	20.0	19.5		ug/L		98	70 - 130
1,4-Dichlorobenzene	20.0	19.7		ug/L		99	70 - 130
Dichlorobromomethane	20.0	20.1		ug/L		100	70 - 130
Dichlorodifluoromethane	20.0	18.6		ug/L		93	70 - 130
1,1-Dichloroethane	20.0	19.9		ug/L		100	70 - 130
1,2-Dichloroethane	20.0	19.5		ug/L		97	70 - 130
1,1-Dichloroethene	20.0	20.1		ug/L		101	70 - 130
1,2-Dichloropropane	20.0	20.6		ug/L		103	70 - 130
1,3-Dichloropropane	20.0	20.9		ug/L		104	70 - 130
2,2-Dichloropropane	20.0	20.1		ug/L		100	70 - 130
1,1-Dichloropropene	20.0	20.4		ug/L		102	70 - 130
1,3-Dichloropropene, Total	40.0	42.4		ug/L		106	70 - 130
Diisopropyl ether	20.0	20.9		ug/L		104	70 - 130
Ethylbenzene	20.0	20.2		ug/L		101	70 - 130
Ethylene Dibromide	20.0	20.2		ug/L		101	70 - 130
Freon 113	20.0	20.0		ug/L		100	70 - 130
Hexachlorobutadiene	20.0	20.5		ug/L		103	70 - 130
2-Hexanone	100	112		ug/L		112	70 - 130
Isopropylbenzene	20.0	20.2		ug/L		101	70 - 130
4-Isopropyltoluene	20.0	20.5		ug/L		102	70 - 130
Methylene Chloride	20.0	20.7		ug/L		103	70 - 130
2-Butanone (MEK)	100	110		ug/L		110	70 - 130
4-Methyl-2-pentanone (MIBK)	100	110		ug/L		110	70 - 130
m-Xylene & p-Xylene	20.0	20.2		ug/L		101	70 - 130
Naphthalene	20.0	21.5		ug/L		107	70 - 130
n-Butylbenzene	20.0	20.5		ug/L		102	70 - 130
N-Propylbenzene	20.0	20.2		ug/L		101	70 - 130
o-Xylene	20.0	20.2		ug/L		101	70 - 130
sec-Butylbenzene	20.0	20.4		ug/L		102	70 - 130
Styrene	20.0	20.6		ug/L		103	70 - 130
Tert-amyl methyl ether	20.0	21.4		ug/L		107	70 - 130
tert-Butyl alcohol	200	220		ug/L		110	70 - 130
tert-Butylbenzene	20.0	20.3		ug/L		102	70 - 130
Tert-butyl ethyl ether	20.0	21.1		ug/L		105	70 - 130
1,1,1,2-Tetrachloroethane	20.0	19.7		ug/L		99	70 - 130
1,1,2,2-Tetrachloroethane	20.0	20.5		ug/L		103	70 - 130
Tetrachloroethene	20.0	19.9		ug/L		99	70 - 130
Toluene	20.0	20.4		ug/L		102	70 - 130
trans-1,2-Dichloroethene	20.0	19.9		ug/L		100	70 - 130
trans-1,3-Dichloropropene	20.0	21.2		ug/L		106	70 - 130
1,2,3-Trichlorobenzene	20.0	21.4		ug/L		107	70 - 130
1,2,4-Trichlorobenzene	20.0	20.3		ug/L		102	70 - 130
1,1,1-Trichloroethane	20.0	19.6		ug/L		98	70 - 130
1,1,2-Trichloroethane	20.0	20.1		ug/L		100	70 - 130

TestAmerica Savannah

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 680-400213/4
Matrix: Water
Analysis Batch: 400213

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS		Unit	D	%Rec	%Rec. Limits
		Result	Qualifier				
Trichloroethene	20.0	19.6		ug/L		98	70 - 130
Trichlorofluoromethane	20.0	19.9		ug/L		99	70 - 130
1,2,3-Trichloropropane	20.0	21.4		ug/L		107	70 - 130
Trihalomethanes, Total	80.0	81.0		ug/L		101	70 - 130
1,2,4-Trimethylbenzene	20.0	20.6		ug/L		103	70 - 130
1,3,5-Trimethylbenzene	20.0	20.2		ug/L		101	70 - 130
Vinyl chloride	20.0	21.1		ug/L		106	70 - 130
Xylenes, Total	40.0	40.5		ug/L		101	70 - 130

Surrogate	LCS		Limits
	%Recovery	Qualifier	
4-Bromofluorobenzene	100		70 - 130
1,2-Dichlorobenzene-d4	102		70 - 130

Lab Sample ID: LCSD 680-400213/5
Matrix: Water
Analysis Batch: 400213

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD		Unit	D	%Rec	%Rec. Limits	RPD	Limit
		Result	Qualifier						
Acetone	100	107		ug/L		107	70 - 130	1	30
Benzene	20.0	20.4		ug/L		102	70 - 130	0	30
Bromobenzene	20.0	19.6		ug/L		98	70 - 130	2	30
Bromoform	20.0	21.1		ug/L		105	70 - 130	0	30
Bromomethane	20.0	25.3		ug/L		126	70 - 130	10	30
Carbon tetrachloride	20.0	19.7		ug/L		98	70 - 130	0	30
Chlorobenzene	20.0	20.3		ug/L		102	70 - 130	1	30
Chlorobromomethane	20.0	19.6		ug/L		98	70 - 130	4	30
Chlorodibromomethane	20.0	19.9		ug/L		100	70 - 130	0	30
Chloroethane	20.0	20.2		ug/L		101	70 - 130	2	30
Chloroform	20.0	19.5		ug/L		98	70 - 130	1	30
Chloromethane	20.0	20.8		ug/L		104	70 - 130	12	30
2-Chlorotoluene	20.0	20.0		ug/L		100	70 - 130	1	30
4-Chlorotoluene	20.0	20.1		ug/L		101	70 - 130	2	30
cis-1,2-Dichloroethene	20.0	20.4		ug/L		102	70 - 130	0	30
cis-1,3-Dichloropropene	20.0	21.1		ug/L		106	70 - 130	0	30
1,2-Dibromo-3-Chloropropane	20.0	21.1		ug/L		106	70 - 130	3	30
Dibromomethane	20.0	19.7		ug/L		98	70 - 130	1	30
1,2-Dichlorobenzene	20.0	19.5		ug/L		97	70 - 130	1	30
1,3-Dichlorobenzene	20.0	19.6		ug/L		98	70 - 130	0	30
1,4-Dichlorobenzene	20.0	19.8		ug/L		99	70 - 130	1	30
Dichlorobromomethane	20.0	19.7		ug/L		98	70 - 130	2	30
Dichlorodifluoromethane	20.0	17.6		ug/L		88	70 - 130	5	30
1,1-Dichloroethane	20.0	20.3		ug/L		101	70 - 130	2	30
1,2-Dichloroethane	20.0	19.4		ug/L		97	70 - 130	0	30
1,1,1-Dichloroethene	20.0	20.3		ug/L		101	70 - 130	1	30
1,2-Dichloropropane	20.0	21.0		ug/L		105	70 - 130	2	30
1,3-Dichloropropane	20.0	21.0		ug/L		105	70 - 130	1	30
2,2-Dichloropropane	20.0	20.3		ug/L		102	70 - 130	1	30
1,1,1-Dichloropropene	20.0	20.3		ug/L		101	70 - 130	1	30

TestAmerica Savannah

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 680-400213/5
Matrix: Water
Analysis Batch: 400213

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD		Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
		Result	Qualifier						
1,3-Dichloropropene, Total	40.0	42.3		ug/L		106	70 - 130	0	30
Diisopropyl ether	20.0	21.2		ug/L		106	70 - 130	1	30
Ethylbenzene	20.0	20.4		ug/L		102	70 - 130	1	30
Ethylene Dibromide	20.0	20.1		ug/L		101	70 - 130	0	30
Freon 113	20.0	20.0		ug/L		100	70 - 130	0	30
Hexachlorobutadiene	20.0	20.1		ug/L		101	70 - 130	2	30
2-Hexanone	100	109		ug/L		109	70 - 130	2	30
Isopropylbenzene	20.0	20.3		ug/L		102	70 - 130	1	30
4-Isopropyltoluene	20.0	20.6		ug/L		103	70 - 130	1	30
Methylene Chloride	20.0	21.1		ug/L		106	70 - 130	2	30
2-Butanone (MEK)	100	108		ug/L		108	70 - 130	2	30
4-Methyl-2-pentanone (MIBK)	100	109		ug/L		109	70 - 130	1	30
m-Xylene & p-Xylene	20.0	20.1		ug/L		100	70 - 130	1	30
Naphthalene	20.0	21.6		ug/L		108	70 - 130	1	30
n-Butylbenzene	20.0	20.6		ug/L		103	70 - 130	1	30
N-Propylbenzene	20.0	20.3		ug/L		102	70 - 130	0	30
o-Xylene	20.0	20.3		ug/L		101	70 - 130	0	30
sec-Butylbenzene	20.0	20.5		ug/L		102	70 - 130	0	30
Styrene	20.0	20.9		ug/L		105	70 - 130	1	30
Tert-amyl methyl ether	20.0	21.4		ug/L		107	70 - 130	0	30
tert-Butyl alcohol	200	214		ug/L		107	70 - 130	3	30
tert-Butylbenzene	20.0	20.1		ug/L		101	70 - 130	1	30
Tert-butyl ethyl ether	20.0	21.3		ug/L		107	70 - 130	1	30
1,1,1,2-Tetrachloroethane	20.0	19.5		ug/L		98	70 - 130	1	30
1,1,2,2-Tetrachloroethane	20.0	20.7		ug/L		103	70 - 130	1	30
Tetrachloroethane	20.0	20.1		ug/L		101	70 - 130	1	30
Toluene	20.0	20.5		ug/L		102	70 - 130	0	30
trans-1,2-Dichloroethene	20.0	19.7		ug/L		99	70 - 130	1	30
trans-1,3-Dichloropropene	20.0	21.1		ug/L		106	70 - 130	0	30
1,2,3-Trichlorobenzene	20.0	21.1		ug/L		105	70 - 130	2	30
1,2,4-Trichlorobenzene	20.0	20.3		ug/L		102	70 - 130	0	30
1,1,1-Trichloroethane	20.0	19.7		ug/L		98	70 - 130	0	30
1,1,2-Trichloroethane	20.0	20.0		ug/L		100	70 - 130	0	30
Trichloroethene	20.0	19.9		ug/L		99	70 - 130	1	30
Trichlorofluoromethane	20.0	19.4		ug/L		97	70 - 130	2	30
1,2,3-Trichloropropane	20.0	21.7		ug/L		108	70 - 130	1	30
Trihalomethanes, Total	80.0	80.2		ug/L		100	70 - 130	1	30
1,2,4-Trimethylbenzene	20.0	20.6		ug/L		103	70 - 130	0	30
1,3,5-Trimethylbenzene	20.0	20.2		ug/L		101	70 - 130	0	30
Vinyl chloride	20.0	20.5		ug/L		103	70 - 130	3	30
Xylenes, Total	40.0	40.3		ug/L		101	70 - 130	0	30

Surrogate	LCSD		Limits
	%Recovery	Qualifier	
4-Bromofluorobenzene	100		70 - 130
1,2-Dichlorobenzene-d4	102		70 - 130

QC Association Summary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

GC/MS VOA

Analysis Batch: 398947

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
680-116159-1	RFW-20	Total/NA	Water	524.2	
680-116159-2	RFW-21	Total/NA	Water	524.2	
680-116159-5	Trip Blank	Total/NA	Water	524.2	
LCS 680-398947/4	Lab Control Sample	Total/NA	Water	524.2	
LCSD 680-398947/5	Lab Control Sample Dup	Total/NA	Water	524.2	
MB 680-398947/9	Method Blank	Total/NA	Water	524.2	

Analysis Batch: 400213

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
680-116159-3	HAMP-22	Total/NA	Water	524.2	
680-116159-4	HAMP-23	Total/NA	Water	524.2	
LCS 680-400213/4	Lab Control Sample	Total/NA	Water	524.2	
LCSD 680-400213/5	Lab Control Sample Dup	Total/NA	Water	524.2	
MB 680-400213/9	Method Blank	Total/NA	Water	524.2	

Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Client Sample ID: RFW-20

Date Collected: 08/26/15 08:35

Date Received: 08/28/15 09:20

Lab Sample ID: 680-116159-1

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	5 mL	5 mL	398947	09/01/15 17:18	DJK	TAL SAV

Instrument ID: CMSO2

Client Sample ID: RFW-21

Date Collected: 08/26/15 07:45

Date Received: 08/28/15 09:20

Lab Sample ID: 680-116159-2

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	5 mL	5 mL	398947	09/01/15 17:39	DJK	TAL SAV

Instrument ID: CMSO2

Client Sample ID: HAMP-22

Date Collected: 08/27/15 09:15

Date Received: 08/28/15 09:20

Lab Sample ID: 680-116159-3

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	5 mL	5 mL	400213	09/10/15 00:11	JLK	TAL SAV

Instrument ID: CMSO2

Client Sample ID: HAMP-23

Date Collected: 08/27/15 09:20

Date Received: 08/28/15 09:20

Lab Sample ID: 680-116159-4

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	5 mL	5 mL	400213	09/10/15 00:32	JLK	TAL SAV

Instrument ID: CMSO2

Client Sample ID: Trip Blank

Date Collected: 08/26/15 07:00

Date Received: 08/28/15 09:20

Lab Sample ID: 680-116159-5

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	5 mL	5 mL	398947	09/01/15 12:00	DJK	TAL SAV

Instrument ID: CMSO2

Laboratory References:

TAL SAV = TestAmerica Savannah, 5102 LaRoche Avenue, Savannah, GA 31404, TEL (912)354-7858

Login Sample Receipt Checklist

Client: Weston Solutions, Inc.

Job Number: 680-116159-1

Login Number: 116159

List Source: TestAmerica Savannah

List Number: 1

Creator: Kicklighter, Marilyn D

Question	Answer	Comment
Radioactivity wasn't checked or is \leq background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

Certification Summary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-116159-1

Laboratory: TestAmerica Savannah

The certifications listed below are applicable to this report

Authority	Program	EPA Region	Certification ID	Expiration Date
Maryland	State Program	3	250	12-31-15