

Quarterly Groundwater Monitoring Report

Prepared for

Black & Decker (U.S.) Inc.

Hampstead, Maryland

October 2005

Prepared by

WESTON SOLUTIONS, INC.

West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A – GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B – DISCHARGE MONITORING REPORTS

APPENDIX C – GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D – GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 3 rd Quarter 2005	2-2
Table 2-2 Groundwater Elevation Data – 3 rd Quarter 2005.....	2-3
Table 2-3 Effluent Characteristics Summary – 3 rd Quarter 2005	2-4
Table 2-4 Summary of Groundwater Analytical Results – August 2005	2-6
Table 3-1 Treatment System Maintenance Activities – 3 rd Quarter 2005	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of July through September 2005.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. At the time the water level measurements were collected, the extraction wells were pumping at an average combined rate of 166 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of July through September 2005 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of July through September 2005, approximately 41 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (70 %) and tetrachlorethene (PCE) (30 %). Analytical results of the groundwater collected at the inlet to the air stripper for the period of July through September 2005 are included in Appendix C.

Table 2-1
Treatment System Pumping Records - 3rd Quarter 2005
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
July 2005	7,238,781
August 2005	7,117,255
September 2005	6,741,037

Table 2-2
Groundwater Elevation Data - 3rd Quarter 2005
Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV.	TOTAL DEPTH	7/13/2005		8/18/2005		9/30/05	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NA	DRY	NA	DRY	NA
EW-2	849.21	110	91.42	757.79	101.30	747.91	92.84	756.37
EW-3	846.64	118	88.18	758.46	89.43	757.21	89.40	757.24
EW-4	858.01	97.5	NA	NA	NA	NA	NA	NA
EW-5	864.17	98	90.89	773.28	90.66	773.51	91.47	772.70
EW-6	831.98	115	82.11	749.87	82.72	749.26	83.67	748.31
EW-7	818.38	78	42.13	776.25	38.45	779.93	49.41	768.97
EW-8	811.13	98	43.58	767.55	44.81	766.32	47.38	763.75
EW-9	811.35	141	94.73	716.62	104.50	706.85	96.88	714.47
EW-10	807.74	NA	44.86	762.88	42.71	765.03	48.00	759.74
RFW-1A	864.37	78	50.43	813.94	49.43	814.94	51.55	812.82
RFW-1B	864.23	200	50.45	813.78	49.46	814.77	51.58	812.65
RFW-2A	857.41	35	13.07	844.34	15.71	841.70	14.11	843.30
RFW-2B	857.73	75	13.84	843.89	16.32	841.41	14.68	843.05
RFW-3B	839.21	153	27.26	811.95	30.37	808.84	29.32	809.89
RFW-4A	830.37	62	36.96	793.41	37.90	792.47	38.77	791.60
RFW-4B	830.37	120	36.84	793.53	37.76	792.61	38.70	791.67
RFW-5A	817.50	30	DRY	NA	DRY	NA	DRY	NA
RFW-6	785.04	120	2.94	782.10	3.99	781.05	4.23	780.81
RFW-7	805.14	29	7.57	797.57	7.51	797.63	8.19	796.95
RFW-8	860.07	56	DRY	NA	DRY	NA	DRY	NA
RFW-9	862.02	49	25.11	836.91	26.43	835.59	27.43	834.59
RFW-10	852.06	58	DRY	NA	DRY	NA	DRY	NA
RFW-11A	849.32	72	NA	NA	NA	NA	NA	NA
RFW-11B	849.62	116	71.11	778.51	70.14	779.48	72.46	777.16
RFW-12B	844.87	264	51.47	793.40	51.42	793.45	55.69	789.18
RFW-13	849.11	150	59.13	789.98	58.93	790.18	60.31	788.80
RFW-14B	812.39	281	33.91	778.48	34.43	777.96	34.44	777.95
RFW-16	856.14	41	DRY	NA	DRY	NA	DRY	856.14
RFW-17	834.66	60.5	25.99	808.67	27.01	807.65	27.76	806.90
RFW-20	842.49	142	33.47	809.02	34.14	808.35	34.11	808.38
RFW-21	832.65	102	21.26	811.39	21.76	810.89	22.69	809.96
PH-7	805.94	89	19.00	786.94	19.56	786.38	19.76	786.18
PH-9	814.94	98	31.17	783.77	32.90	782.04	33.13	781.81
PH-11	820.68	78	42.03	778.65	42.38	778.30	43.94	776.74
PH-12	828.35	87	42.93	785.42	43.67	784.68	44.27	784.08
B-3	803.02	83	NA	NA	NA	NA	NA	NA
Amoco	842.29	NA	NA	NA	NA	NA	NA	NA
Hamp. Town #22	804.96	NA	31.40	773.56	29.56	775.40	19.57	785.39
Pembroke #1	NA	NA	11.99	NA	12.35	NA	12.68	NA
Pembroke #2	NA	NA	NA	NA	NA	NA	NA	NA
N. Houcks. Rd.	NA	NA	10.18	NA	10.80	NA	9.89	NA
E. Century St.	NA	NA	29.11	NA	26.53	NA	27.59	NA
Lwr. Beckleys. Rd.	NA	NA	52.26	NA	NA	NA	54.26	NA

NA - Not Available/Not Accessible

Table 2-3
Effluent Characteristics Summary - 3rd Quarter 2005
Black & Decker
Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				July 2005	August 2005	September 2005	
001	FLOW	average	MGD	NA	0.338	0.113	0.057
		maximum	MGD	NA	1.141	1.141	0.064
	1,1,1-Trichloroethane	ug/l	5	< 5	< 5	< 5	
	Tetrachloroethylene	ug/l	5	< 5	< 5	< 5	
	Trichloroethylene	ug/l	5	< 5	< 5	< 5	
	Total Residual Chlorine	mg/l	< 0.1	< 0.1	< 0.1	< 0.1	
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		quarterly average	mg/l	10	NR	NR	< 5
	pH	minimum	STD	6.0	6.20	6.10	6.30
		maximum	STD	8.5	7.00	6.90	6.70
	BOD		mg/l	15	5.0	< 2	7.0
	TSS	maximum	mg/l	30	13.0	8.0	14.0
quarterly average		mg/l	20	NR	NR	12.0	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.257	0.260	0.237
		maximum	MGD	NA	0.290	0.268	0.277
	Fecal Coliform	MPN/100ml	200	< 2	< 2	< 2	
201 (Monitoring Point)	FLOW	average	MGD	NA	0.234	0.230	0.225
		maximum	MGD	NA	0.277	0.278	0.273
	1,1,1-Trichloroethane	ug/l	NA	< 5	< 5	< 5	
	Tetrachloroethylene	ug/l	NA	< 5	< 5	< 5	
	Trichloroethylene	ug/l	NA	< 5	< 5	< 5	

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

A summary of the analytical results from the third quarter (August 2005) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete analytical data package is included in Appendix D. As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater samples collected from extraction well EW-9. The remainder of VOC's present were detected at levels well below the Federal Maximum Contaminant Levels (MCL).

Table 2-4
Summary of Groundwater Analytical Results - August 2005
Black & Decker
Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-5 (DUP)	EW-6	EW-7	EW-8	EW-9	EW-10
Chloromethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Acetone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	5 U	1 J	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 J	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	4	2.4	5 U	1 U	1 U	1 U	5.3	21	1.2	1 U
Chloroform	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	740	230	950	410	390	8.8	4.4	10	2.3	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	68	5.5	27	13	13	21	6.9	63	180	10
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
 J = Indicates an estimated value.

Table 2-4
Summary of Groundwater Analytical Results - August 2005
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1.2	1 U	1 U	1 U	NS	1 U	1 U	NS	1.6	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.2	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	10	1.8	1.7	6.6	NS	1.6	1 U	NS	12	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	1.3	1.2	0.9 J	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	2	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	1.5	1 U	7.9	56	55	18	NS	9.9	11	NS	21	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	8.2	65	63	60	NS	6.8	1 U	NS	5	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicate sample
 NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
 J = Indicates an estimated value.

Table 2-4
Summary of Groundwater Analytical Results - August 2005
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	RFW-20	RFW-21	Town #22	Town #23	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	NA	NA	NA	NA	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1.1	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	6.6	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	31	550	3.1	NS	1 U	1.5	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	1 U	40	16	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division. Samples from all of the other wells are analyzed with USEPA Method 8260.

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (July through September 2005) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 3rd Quarter 2005
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Jul-05	Replaced the integrater for the flow meter in well EW-8.
Aug-05	Replaced the integrater for the flow meter in well EW-2.

4. RECOMMENDATIONS

For the reporting period of July through September 2005, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(JULY - SEPTEMBER 2005)

Month / Year

July 2005

Black & Decker
Air Stripper # 2
Operating Record

Past Month Reading

37618663

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	F	1040	37846003	↑	25938	25904
2						
3						
4	Holiday			939078		
5	T	1035	38785081	238789	25938	26000
6	W	1100	39023876	231664	25902	26000
7	T	1045	39255534	259760	25906	26000
8	F	1320	39515494	↑	26013	26000
9						
10				698558		
11	M	1245	40214052	241825	26084	26000
12	T	1325	40455877	225144	26084	26025
13	W	1240	40681021	201524	26084	26048
14	T	0920	40882545	276965	26084	26069
15	F	1335	41159510	↑	26084	26097
16						
17				679722		
18	M	1130	41839232	234951	26084	26167
19	T	1135	42074183	235961	26108	26167
20	W	1150	42310144	215928	26132	26167
21	T	1005	42526072	232012	26154	26167
22	F	0950	42758084	↑	26178	26167
23						
24				725988		
25	M	1240	43484072	197635	26253	26167
26	T	0908	43681707	264207	26253	26187
27	W	1220	43945914	234173	26253	26215
28	T	1225	44180087	211741	26253	26239
29	F	1020	44391828	↑	26253	26261
30						
31				692956		
Total				7238781		
Average				233509		

40214054

0 1 15

Month / Year

Aug. 2005

Black & Decker
Air Stripper # 2
Operating Record

Past Month Reading

44391828

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	M	1005	45084784	232348	26253	26332
2	T	1000	45317132	230874	26277	26332
3	W	0955	45548006	250766	26301	26332
4	T	1155	45798772	225543	26327	26332
5	F	1120	46024315	↑	26351	26332
6						
7				699135		
8	M	1200	46723450	223698	26423	26332
9	T	1115	46947148	219553	26423	26356
10	W	1010	47166701	237719	26423	26379
11	T	1055	4740420	225935	26423	26404
12	F	1030	47630355	↑	26423	26427
13						
14				691545		
15	M	1040	48321900	236567	26423	26499
16	T	1125	48558467	277914	26448	26499
17	W	435pm	48736381	183728	26477	26499
18	T	1155	49020109	223809	26496	26499
19	F	1120	49243918	↑	26520	26499
20						
21				675816		
22	M	1010	49919734	225639	26591	26499
23	T	0955	50145373	236097	26591	26523
24	W	1045	50381470	229356	26591	26548
25	T	1055	50610856	219593	26591	26572
26	F	1005	50830444	↑	26591	26595
27						
28				694946		
29	M	1120	51525395	212925	26591	26668
30	T	0955	51738320	235438	26591	26691
31	W	1040	51973758	228281	26591	26715
Total				7117255		
Average				229589		

Next Month Reading 52202039

Date 9-1-05

Month / Year

Sept. 2005

Black & Decker
Air Stripper # 2
Operating Record

Past Month Reading

51973758

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	T	1046	52262039	231731	26615	26715
2	F	1115	52433770	↑	26639	26715
3	S					
4	S					
5	M	0605	53064839	631069		
6	T	1100	53337593	272754	26700	26715
7	W	1315	53584705	247112	26735	26715
8	T	1125	53792649	207944	26735	26742
9	F	1225	54037848	245199	26735	26764
10	S			↑	26735	26790
11	S					
12	M	1140	54695951	658103		
13	T	1230	54929318	233367	26735	26860
14	W	1130	55143854	214536	26760	26860
15	T	1130	55368974	225120	26783	26860
16	F	0935	55574909	205935	26807	26860
17	S			↑	26829	26860
18	S					
19	M	1225	56272728	697819		
20	T	1130	56487275	214547	26904	26860
21	W	1050	56704698	217423	26904	26883
22	T	0830	56905815	201117	26904	26906
23	F	0850	57129456	223641	26904	26928
24	S			↑	26904	26952
25	S					
26	M	1055	57820838	691382		
27	T	1105	58044331	223493	26904	27027
28	W	1025	58260491	216160	26928	27027
29	T	1040	58484951	224460	26951	27027
30	F	1150	58717096	232145	26976	27027
31				225980	27101	27027
Total				6741037		
Average				224701		

Next Month Reading 52262039

**APPENDIX B
DISCHARGE MONITORING REPORTS
(JULY - SEPTEMBER 2005)**

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MD0001881	001				
PERMIT NUMBER	DISCHARGE NUMBER				
(2-16)	(17-19)				
MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2005	07	01	05	07	31

FORM APPROVED
 OMB No.2040-0004

FROM (20-21) (22-23) (24-25) TO (26-27) (28-29) (30-31) NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) (46-53) QUANTITY OR LOADING (54-61)			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-69)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW		0.338	1.141	MGD				0	Measured/Recorded	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT						Measured/Recorded	
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						5		1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						5		1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						5		1/MONTH	GRAB
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT						<0.1	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					0.011	0.019		1/MONTH	GRAB
OIL & GREASE	SAMPLE MEASUREMENT						<5	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					10	<5		1/MONTH	GRAB
pH	SAMPLE MEASUREMENT				6.20		7.00	0	2/WEEK	GRAB
	PERMIT REQUIREMENT				6.00		8.50		2/WEEK	GRAB
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREON, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1919. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)				TELEPHONE		DATE		
Michael A. Clark Principal						<i>Earl Weddle</i>		410-374-9025		05 08 02
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				AREA CODE-NUMBER		YEAR MO DAY		

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland, 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER
001
 DISCHARGE NUMBER

FORM APPROVED
 OMB No. 2040-0004

MONITORING PERIOD
 FROM YEAR **2005** MO **07** DAY **01** TO YEAR **05** MO **07** DAY **31**

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) (46-53) QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45) QUALITY OR CONCENTRATION (46-53) (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-69)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
BOD	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT							0	1/MONTH	GRAB	
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT							0	1/MONTH	GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREON AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 18 U.S.C. § 1519. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						TELEPHONE		DATE	
Michael A. Clark Principal								410-374-9025		05 08 02	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						AREA CODE-NUMBER		YEAR MO DAY	
COMMENT AND EXPLANATION OF ANY VIOLATIONS		(Reference all attachments here)									

*Averages for TSS and Oil & Grease are reported quarterly.
 EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER (2-16)

101
 DISCHARGE NUMBER (17-19)

FORM APPROVED
 OMB No. 2040-0004

MONITORING PERIOD

FROM

YEAR	MO	DAY
2005	07	01

(20-21) (22-23) (24-25)

TO

YEAR	MO	DAY
05	07	31

(26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW	SAMPLE MEASUREMENT	0.257	0.290	MGD				0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT						Cont Measure/Record	
FECAL COLIFORM	SAMPLE MEASUREMENT					<2	MPN/100ml	0	1/WEEK	GRAB
	PERMIT REQUIREMENT					200			1/WEEK	GRAB
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER

Michael A. Clark
Principal

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 21 U.S.C. § 1919. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Emil Weddle

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE DATE

410-374-8025

05 | 08 | 02

AREA CODE-NUMBER YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)


MD0001881
 PERMIT NUMBER
 201
 DISCHARGE NUMBER

FORM APPROVED
 OMB No. 2040-0004

MONITORING PERIOD
 FROM YEAR 2005 MO 07 DAY 01 TO YEAR 05 MO 07 DAY 31

PARAMETER (92-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (48-53) (22-23) (24-25)			QUALITY OR CONCENTRATION (4 Card Only) (29-27) (28-29) (30-31)				NO. EX (92-43)	FREQUENCY OF ANALYSIS (94-98)	SAMPLE TYPE (99-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	0.234	0.277	MGD					0	Cont Measure/Record		
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								
1,1,1-TRICHLOROETHANE						<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT					N/A			1/MONTH	GRAB	
TETRACHLOROETHYLENE						<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT					N/A			1/MONTH	GRAB	
TRICHLOROETHYLENE						<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT					N/A			1/MONTH	GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NOTE: Read instructions before completing this form.

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 19 U.S.C. § 1001 AND 33 U.S.C. § 1319. Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.	TELEPHONE	DATE
Michael A. Clark Principal TYPED OR PRINTED		 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	410-374-9025

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER
 (2-18)

001
 DISCHARGE NUMBER
 (17-18)

FORM APPROVED
 OMB No. 2040-0004

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2005	08	01	05	08	31

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) (46-53)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION (46-53) (54-61)			NO. EX (62-65)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS					
FLOW		0.113	1.141	MGD						0	Measured/Recorded		
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								Measured/Recorded		
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT							<5		0	1/MONTH	GRAB	
	PERMIT REQUIREMENT							5	ppb		1/MONTH	GRAB	
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT							<5		0	1/MONTH	GRAB	
	PERMIT REQUIREMENT							5	ppb		1/MONTH	GRAB	
TRICHLOROETHYLENE	SAMPLE MEASUREMENT							<5		0	1/MONTH	GRAB	
	PERMIT REQUIREMENT							5	ppb		1/MONTH	GRAB	
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT							<0.1		0	1/MONTH	GRAB	
	PERMIT REQUIREMENT							0.011	0.015		1/MONTH	GRAB	
OIL & GREASE	SAMPLE MEASUREMENT							<5		0	1/MONTH	GRAB	
	PERMIT REQUIREMENT							10	<5		1/MONTH	GRAB	
pH	SAMPLE MEASUREMENT				6.10			6.90		0	2/WEEK	GRAB	
	PERMIT REQUIREMENT				6.00			8.50	STD		2/WEEK	GRAB	
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include: Fine up to \$10,000 and/or maximum imprisonment of between 6 months and 3 years.)											
Michael A. Clark Principal		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT								TELEPHONE		DATE	
TYPED OR PRINTED		<i>Eric W. Weddle</i>								410-374-9025		05 09 06	
COMMENT AND EXPLANATION OF ANY VIOLATIONS		(Reference all attachments here)								AREA CODE-NUMBER		YEAR MO DAY	

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-99) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland, 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No. 2040-0004

MD0001881
 PERMIT NUMBER
 (2-16)

001
 DISCHARGE NUMBER
 (17-19)

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2005	08	01	05	08	31

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) (46-53)			(4 Card Only) (38-45)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-66)	SAMPLE TYPE (68-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
BOD	SAMPLE MEASUREMENT								0	1/MONTH	GRAB
	PERMIT REQUIREMENT							mg/l		1/MONTH	GRAB
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT					8.0			0	1/MONTH	GRAB
	PERMIT REQUIREMENT					20	30	mg/l		1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319 (Penalties under these statutes may include: fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)							TELEPHONE	DATE	
Michael A. Clark Principal		<i>Earl Wedder</i> SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							410-374-9025	05 08 06	
TYPED OR PRINTED									AREA CODE-NUMBER	YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER
101
 DISCHARGE NUMBER

FORM APPROVED
 OMB No. 2040-0004

MONITORING PERIOD
 FROM YEAR **2005** MO **08** DAY **01** TO YEAR **05** MO **08** DAY **31**

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.260	0.268	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								
FECAL COLIFORM	SAMPLE MEASUREMENT					<2		MPN/ 100ml	0	1/WEEK	GRAB
	PERMIT REQUIREMENT					200					
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER: **Michael A. Clark**
 Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. 33 USC § 1311 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT: *Earl Wedole*

TELEPHONE: **410-374-9025**
 DATE: **05 | 09 | 06**

COMMENT AND EXPLANATION OF ANY VIOLATIONS: _____
 (Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER
 (2-16)

201
 DISCHARGE NUMBER
 (17-18)

FORM APPROVED
 OMB No.2040-0004

MONITORING PERIOD
 FROM YEAR MO DAY TO YEAR MO DAY
2005 08 01 **05 08 31**
 (20-21) (22-23) (24-26) (28-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (46-61)			QUALITY OR CONCENTRATION (62-81)				NO. EX (82-83)	FREQUENCY OF ANALYSIS (84-88)	SAMPLE TYPE (89-92)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.230	0.278	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER

Michael A. Clark
Principal

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include: Fines up to \$10,000 and/or maximum imprisonment of between 6 months and 3 years.)

Earl Wedde
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE DATE

410-374-8025

05 | 09 | 06

AREA CODE-NUMBER

YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MD0001851
 PERMIT NUMBER
 (2-16)

001
 DISCHARGE NUMBER
 (17-18)

FORM APPROVED
 OMB No.2040-0004

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	2005	09	01		05	09	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (45-53)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
FLOW		0.057	0.064	MGD					0	Measured/Recorded		
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Measured/Recorded		
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT						5			1/MONTH	GRAB	
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT						5			1/MONTH	GRAB	
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT						5			1/MONTH	GRAB	
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT						<0.1	mg/l	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT						0.011	0.015		1/MONTH	GRAB	
OIL & GREASE	SAMPLE MEASUREMENT						<5	<5	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						10	<5		1/MONTH	GRAB	
pH	SAMPLE MEASUREMENT				6.30		6.70	STD	0	2/WEEK	GRAB	
	PERMIT REQUIREMENT				6.00		6.50			2/WEEK	GRAB	
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY KNOWLEDGE OF THESE INDIVIDUALS I AM RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 19 U.S.C. § 1001 AND 22 U.S.C. § 1219. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)							TELEPHONE		DATE	
Michael A. Clark Principal									410-374-9025		05 10 04	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							AREA CODE-NUMBER		YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 8-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**

Suite 420E
Washington, DC 20004

FACILITY: **Hampstead, Maryland, 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

(2-16)

(17-18)

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	2005	09	01		05	09	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) (48-53)			(4 Card Only) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
BOD	SAMPLE MEASUREMENT							7.0	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT							15			1/MONTH	GRAB
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT					12.0		14.0	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					20		30			1/MONTH	GRAB
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 19 U.S.C. § 1061 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						TELEPHONE		DATE		
Michael A. Clark Principal								410-374-9025		05 10 04		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						AREA CODE-NUMBER		YEAR MO DAY		

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.
 EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)


DISCHARGE MONITORING REPORT (DMR)

MD0001881 **101**
 PERMIT NUMBER DISCHARGE NUMBER
 (2-18) (17-18)

MONITORING PERIOD
 FROM YEAR MO DAY TO YEAR MO DAY
2005 09 01 05 09 30
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

FORM APPROVED
 OMB No. 20-40-0004

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (42-53)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.237	0.277	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record	
FECAL COLIFORM	SAMPLE MEASUREMENT						<2	MPN/ 100ml	0	1/WEEK GRAB	
	PERMIT REQUIREMENT						200			1/WEEK GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 23 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 3 years.)							TELEPHONE	DATE	
Michael A. Clark Principal									 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		
TYPED OR PRINTED									AREA CODE-NUMBER	YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No. 2040-0004

MD0001881 **201**
 PERMIT NUMBER DISCHARGE NUMBER

(2-10)

(17-18)

MONITORING PERIOD

FROM: YEAR **2005** MO **09** DAY **01** TO: YEAR **05** MO **09** DAY **30**
(20-21) (22-23) (24-29) (25-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) (40-53) QUANTITY OR LOADING (54-61)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-66)	SAMPLE TYPE (67-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.225	0.273	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
 Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 23 U.S.C. § 1219. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Wedder
 SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE
410-374-9025
 AREA CODE-NUMBER

DATE
05 | 10 | 04
 YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(JULY - SEPTEMBER 2005)



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 1

Client: BTR Hampstead, LLC	Client Sample ID: Air Stripper 2 (Pre)
Report No: 0507213	
Project: Hampstead-Monthly	Lab ID: 0507213-002
Matrix: WASTEWATER	Collection Date: 7/13/2005 11:18

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst: NA

Chloromethane	< 10	10	µg/L	7/15/2005 1:15
Vinyl chloride	< 10	10	µg/L	7/15/2005 1:15
Bromomethane	< 10	10	µg/L	7/15/2005 1:15
Chloroethane	< 10	10	µg/L	7/15/2005 1:15
Acrolein	< 100	100	µg/L	7/15/2005 1:15
1,1-Dichloroethene	< 5.0	5.0	µg/L	7/15/2005 1:15
Methylene chloride	< 5.0	5.0	µg/L	7/15/2005 1:15
Acrylonitrile	< 100	100	µg/L	7/15/2005 1:15
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	7/15/2005 1:15
1,1-Dichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:15
Chloroform	< 5.0	5.0	µg/L	7/15/2005 1:15
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:15
Carbon tetrachloride	< 5.0	5.0	µg/L	7/15/2005 1:15
Benzene	< 5.0	5.0	µg/L	7/15/2005 1:15
1,2-Dichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:15
Trichloroethene	180	5.0	µg/L	7/15/2005 1:15
1,2-Dichloropropane	< 5.0	5.0	µg/L	7/15/2005 1:15
Bromodichloromethane	< 5.0	5.0	µg/L	7/15/2005 1:15
2-Chloroethyl vinyl ether	< 10	10	µg/L	7/15/2005 1:15
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	7/15/2005 1:15
Toluene	< 5.0	5.0	µg/L	7/15/2005 1:15
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	7/15/2005 1:15
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:15
Tetrachloroethene	89	5.0	µg/L	7/15/2005 1:15
Dibromochloromethane	< 5.0	5.0	µg/L	7/15/2005 1:15
Chlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:15
Ethylbenzene	< 5.0	5.0	µg/L	7/15/2005 1:15
Bromoform	< 5.0	5.0	µg/L	7/15/2005 1:15
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	7/15/2005 1:15
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:15
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:15



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 2

Client: BTR Hampstead, LLC
Report No: 0507213
Project: Hampstead-Monthly
Matrix: WASTEWATER

Client Sample ID: Air Stripper 2 (Pre)
Lab ID: 0507213-002
Collection Date: 7/13/2005 11:18

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:15



Microbac

www.microbac.com

Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 3

Client: BTR Hampstead, LLC

Client Sample ID: Outfall 201 (Post)

Report No: 0507213

Project: Hampstead-Monthly

Lab ID: 0507213-003

Matrix: WASTEWATER

Collection Date: 7/13/2005 11:17

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst: NA

Chloromethane	< 10	10	µg/L	7/15/2005 1:47
Vinyl chloride	< 10	10	µg/L	7/15/2005 1:47
Bromomethane	< 10	10	µg/L	7/15/2005 1:47
Chloroethane	< 10	10	µg/L	7/15/2005 1:47
Acrolein	< 100	100	µg/L	7/15/2005 1:47
1,1-Dichloroethene	< 5.0	5.0	µg/L	7/15/2005 1:47
Methylene chloride	< 5.0	5.0	µg/L	7/15/2005 1:47
Acrylonitrile	< 100	100	µg/L	7/15/2005 1:47
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	7/15/2005 1:47
1,1-Dichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:47
Chloroform	< 5.0	5.0	µg/L	7/15/2005 1:47
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:47
Carbon tetrachloride	< 5.0	5.0	µg/L	7/15/2005 1:47
Benzene	< 5.0	5.0	µg/L	7/15/2005 1:47
1,2-Dichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:47
Trichloroethene	< 5.0	5.0	µg/L	7/15/2005 1:47
1,2-Dichloropropane	< 5.0	5.0	µg/L	7/15/2005 1:47
Bromodichloromethane	< 5.0	5.0	µg/L	7/15/2005 1:47
2-Chloroethyl vinyl ether	< 10	10	µg/L	7/15/2005 1:47
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	7/15/2005 1:47
Toluene	< 5.0	5.0	µg/L	7/15/2005 1:47
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	7/15/2005 1:47
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:47
Tetrachloroethene	< 5.0	5.0	µg/L	7/15/2005 1:47
Dibromochloromethane	< 5.0	5.0	µg/L	7/15/2005 1:47
Chlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:47
Ethylbenzene	< 5.0	5.0	µg/L	7/15/2005 1:47
Bromoform	< 5.0	5.0	µg/L	7/15/2005 1:47
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	7/15/2005 1:47
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:47
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:47



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 4

Client: BTR Hampstead, LLC
Report No: 0507213
Project: Hampstead-Monthly
Matrix: WASTEWATER

Client Sample ID: Outfall 201 (Post)
Lab ID: 0507213-003
Collection Date: 7/13/2005 11:17

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:47



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 1

Client:	BTR Hampstead, LLC	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0508125		
Project:	Hampstead-Monthly	Lab ID:	0508125-002
Matrix:	WASTEWATER	Collection Date:	8/4/2005 8:22

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
VOLATILE ORGANIC COMPOUNDS (EPA 624)				
Prep. Method: <u>NA</u>	Prep. Date: <u>NA</u>		Prep Analyst: <u>NA</u>	Analyst: MLS
Chloromethane	< 10	10	µg/L	8/9/2005 2:15
Vinyl chloride	< 10	10	µg/L	8/9/2005 2:15
Bromomethane	< 10	10	µg/L	8/9/2005 2:15
Chloroethane	< 10	10	µg/L	8/9/2005 2:15
Acrolein	< 100	100	µg/L	8/9/2005 2:15
1,1-Dichloroethene	< 5.0	5.0	µg/L	8/9/2005 2:15
Methylene chloride	< 5.0	5.0	µg/L	8/9/2005 2:15
Acrylonitrile	< 100	100	µg/L	8/9/2005 2:15
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	8/9/2005 2:15
1,1-Dichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:15
Chloroform	< 5.0	5.0	µg/L	8/9/2005 2:15
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:15
Carbon tetrachloride	< 5.0	5.0	µg/L	8/9/2005 2:15
Benzene	< 5.0	5.0	µg/L	8/9/2005 2:15
1,2-Dichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:15
Trichloroethene	130	5.0	µg/L	8/9/2005 2:15
1,2-Dichloropropane	< 5.0	5.0	µg/L	8/9/2005 2:15
Bromodichloromethane	< 5.0	5.0	µg/L	8/9/2005 2:15
2-Chloroethyl vinyl ether	< 10	10	µg/L	8/9/2005 2:15
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	8/9/2005 2:15
Toluene	< 5.0	5.0	µg/L	8/9/2005 2:15
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	8/9/2005 2:15
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:15
Tetrachloroethene	66	5.0	µg/L	8/9/2005 2:15
Dibromochloromethane	< 5.0	5.0	µg/L	8/9/2005 2:15
Chlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:15
Ethylbenzene	< 5.0	5.0	µg/L	8/9/2005 2:15
Bromoform	< 5.0	5.0	µg/L	8/9/2005 2:15
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	8/9/2005 2:15
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:15
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:15



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800
Fax: 410-633-6553
www.gascoyne.com

Test Results

Page 2

Client:	BTR Hampstead, LLC	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0508125	Lab ID:	0508125-002
Project:	Hampstead-Monthly	Collection Date:	8/4/2005 8:22
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:15



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 3

Client:	BTR Hampstead, LLC	Client Sample ID:	Outfall 201 (Post)
Report No:	0508125		
Project:	Hampstead-Monthly	Lab ID:	0508125-003
Matrix:	WASTEWATER	Collection Date:	8/4/2005 8:21

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
VOLATILE ORGANIC COMPOUNDS (EPA 624)				Analyst: MLS
Prep. Method: <u>NA</u>	Prep. Date: <u>NA</u>		Prep Analyst: <u>NA</u>	
Chloromethane	< 10	10	µg/L	8/9/2005 2:47
Vinyl chloride	< 10	10	µg/L	8/9/2005 2:47
Bromomethane	< 10	10	µg/L	8/9/2005 2:47
Chloroethane	< 10	10	µg/L	8/9/2005 2:47
Acrolein	< 100	100	µg/L	8/9/2005 2:47
1,1-Dichloroethene	< 5.0	5.0	µg/L	8/9/2005 2:47
Methylene chloride	< 5.0	5.0	µg/L	8/9/2005 2:47
Acrylonitrile	< 100	100	µg/L	8/9/2005 2:47
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	8/9/2005 2:47
1,1-Dichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:47
Chloroform	< 5.0	5.0	µg/L	8/9/2005 2:47
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:47
Carbon tetrachloride	< 5.0	5.0	µg/L	8/9/2005 2:47
Benzene	< 5.0	5.0	µg/L	8/9/2005 2:47
1,2-Dichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:47
Trichloroethene	< 5.0	5.0	µg/L	8/9/2005 2:47
1,2-Dichloropropane	< 5.0	5.0	µg/L	8/9/2005 2:47
Bromodichloromethane	< 5.0	5.0	µg/L	8/9/2005 2:47
2-Chloroethyl vinyl ether	< 10	10	µg/L	8/9/2005 2:47
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	8/9/2005 2:47
Toluene	< 5.0	5.0	µg/L	8/9/2005 2:47
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	8/9/2005 2:47
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:47
Tetrachloroethene	< 5.0	5.0	µg/L	8/9/2005 2:47
Dibromochloromethane	< 5.0	5.0	µg/L	8/9/2005 2:47
Chlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:47
Ethylbenzene	< 5.0	5.0	µg/L	8/9/2005 2:47
Bromoform	< 5.0	5.0	µg/L	8/9/2005 2:47
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	8/9/2005 2:47
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:47
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:47



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 4

Client:	BTR Hampstead, LLC	Client Sample ID:	Outfall 201 (Post)
Report No:	0508125	Lab ID:	0508125-003
Project:	Hampstead-Monthly	Collection Date:	8/4/2005 8:21
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:47



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 1

Client: BTR Hampstead, LLC Client Sample ID: Air Stripper 2 (Pre)
 Report No: 0509193
 Project: Hampstead-Monthly Lab ID: 0509193-002
 Matrix: WASTEWATER Collection Date: 9/7/2005 11:05

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst: NA

Chloromethane	< 10	10	µg/L	9/12/2005 19:18
Vinyl chloride	< 10	10	µg/L	9/12/2005 19:18
Bromomethane	< 10	10	µg/L	9/12/2005 19:18
Chloroethane	< 10	10	µg/L	9/12/2005 19:18
Acrolein	< 100	100	µg/L	9/12/2005 19:18
1,1-Dichloroethene	< 5.0	5.0	µg/L	9/12/2005 19:18
Methylene chloride	< 5.0	5.0	µg/L	9/12/2005 19:18
Acrylonitrile	< 100	100	µg/L	9/12/2005 19:18
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	9/12/2005 19:18
1,1-Dichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:18
Chloroform	< 5.0	5.0	µg/L	9/12/2005 19:18
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:18
Carbon tetrachloride	< 5.0	5.0	µg/L	9/12/2005 19:18
Benzene	< 5.0	5.0	µg/L	9/12/2005 19:18
1,2-Dichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:18
Trichloroethene	180	5.0	µg/L	9/12/2005 19:18
1,2-Dichloropropane	< 5.0	5.0	µg/L	9/12/2005 19:18
Bromodichloromethane	< 5.0	5.0	µg/L	9/12/2005 19:18
2-Chloroethyl vinyl ether	< 10	10	µg/L	9/12/2005 19:18
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	9/12/2005 19:18
Toluene	< 5.0	5.0	µg/L	9/12/2005 19:18
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	9/12/2005 19:18
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:18
Tetrachloroethene	53	5.0	µg/L	9/12/2005 19:18
Dibromochloromethane	< 5.0	5.0	µg/L	9/12/2005 19:18
Chlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:18
Ethylbenzene	< 5.0	5.0	µg/L	9/12/2005 19:18
Bromoform	< 5.0	5.0	µg/L	9/12/2005 19:18
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	9/12/2005 19:18
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:18
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:18



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800
Fax: 410-633-6553
www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 2

Client: BTR Hampstead, LLC
Report No: 0509193
Project: Hampstead-Monthly
Matrix: WASTEWATER

Client Sample ID: Air Stripper 2 (Pre)
Lab ID: 0509193-002
Collection Date: 9/7/2005 11:05

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:18



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 3

Client: BTR Hampstead, LLC
 Report No: 0509193
 Project: Hampstead-Monthly
 Matrix: WASTEWATER

Client Sample ID: Outfall 201 (Post)
 Lab ID: 0509193-003
 Collection Date: 9/7/2005 11:06

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst: NA

Chloromethane	< 10	10	µg/L	9/12/2005 19:51
Vinyl chloride	< 10	10	µg/L	9/12/2005 19:51
Bromomethane	< 10	10	µg/L	9/12/2005 19:51
Chloroethane	< 10	10	µg/L	9/12/2005 19:51
Acrolein	< 100	100	µg/L	9/12/2005 19:51
1,1-Dichloroethene	< 5.0	5.0	µg/L	9/12/2005 19:51
Methylene chloride	< 5.0	5.0	µg/L	9/12/2005 19:51
Acrylonitrile	< 100	100	µg/L	9/12/2005 19:51
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	9/12/2005 19:51
1,1-Dichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:51
Chloroform	< 5.0	5.0	µg/L	9/12/2005 19:51
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:51
Carbon tetrachloride	< 5.0	5.0	µg/L	9/12/2005 19:51
Benzene	< 5.0	5.0	µg/L	9/12/2005 19:51
1,2-Dichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:51
Trichloroethene	< 5.0	5.0	µg/L	9/12/2005 19:51
1,2-Dichloropropane	< 5.0	5.0	µg/L	9/12/2005 19:51
Bromodichloromethane	< 5.0	5.0	µg/L	9/12/2005 19:51
2-Chloroethyl vinyl ether	< 10	10	µg/L	9/12/2005 19:51
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	9/12/2005 19:51
Toluene	< 5.0	5.0	µg/L	9/12/2005 19:51
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	9/12/2005 19:51
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:51
Tetrachloroethene	< 5.0	5.0	µg/L	9/12/2005 19:51
Dibromochloromethane	< 5.0	5.0	µg/L	9/12/2005 19:51
Chlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:51
Ethylbenzene	< 5.0	5.0	µg/L	9/12/2005 19:51
Bromoform	< 5.0	5.0	µg/L	9/12/2005 19:51
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	9/12/2005 19:51
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:51
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:51



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800
Fax: 410-633-6553
www.gascoyne.com

Test Results

Page 4

Client: BTR Hampstead, LLC **Client Sample ID:** Outfall 201 (Post)
Report No: 0509193 **Lab ID:** 0509193-003
Project: Hampstead-Monthly **Collection Date:** 9/7/2005 11:06
Matrix: WASTEWATER

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:51

APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(AUGUST 2005)

STL Chicago
2417 Bond Street
University Park, IL 60466

Tel: 708 534 5200 Fax: 708 534 5211
www.stl-inc.com

SEVERN TRENT LABORATORIES
ANALYTICAL REPORT

JOB NUMBER: 239396


Prepared For:

Weston Solutions, Inc.
Building 5-2
1400 Weston Way
West Chester, PA 19380-1499

Project: Black & Decker

Attention: Tom Cornuet

Date: 09/30/2005


Signature

Name: Richard C. Wright

Title: Project Manager

E-Mail: rwright@stl-inc.com

9/30/05
Date

STL Chicago
2417 Bond Street
University Park, IL 60466

PHONE: (708) 534-5200


FAX...: (708) 534-5211

This Report Contains (113) Pages

**Severn Trent Laboratories Chicago
GC/MS Case Narrative**

Weston Solutions
Black and Decker
JOB Number: 239396
VOA DATA:

1. All of the samples were analyzed within the 14-day hold time from the date of collection.
2. All Method Blank target compounds were below reporting limits.
3. The LCS (Laboratory Control Samples) had all five-controlled spike recoveries within the in-house generated QC limits.
4. Matrix Spike/Matrix Spike Duplicate analyses were not performed on this sample set.
5. The volatile samples had all surrogate recoveries within the in-house generated QC limits.
6. The water samples were prepared using Method 5030 and analyzed following SW846 Method 8260B and 8000B. All calibration criteria are met per method or SOP (for minimum R values for certain compounds). The low point in the initial calibration verifies the base reporting limits. The target compounds were quantitated using the initial calibration.
7. The volatile samples had all internal standard areas and retention times within the SOP acceptance limits as compared to the corresponding calibration verification standard.
8. The water samples were analyzed using a 10-mL purge volume. An initial dilution was required on sample 22 due to sample matrix. Secondary dilutions for target compounds were required on samples 13, 20, 21, 22, 23, 24, and 28. The results and reporting limits were adjusted to account for the dilution performed.



Gary Rynkar
GC/MS Section Manager

9/2/5
Date

STL Chicago is part of Severn Trent Laboratories, Inc.

SAMPLE INFORMATION
Date: 09/30/2005

Job Number.: 239396
Customer....: Weston Solutions, Inc.
Attn.....: Tom Cornuet

Project Number.....: 20005711
Customer Project ID....: BLACK AND DECKER
Project Description....: Black & Decker

Laboratory Sample ID	Customer Sample ID	Sample Matrix	Date Sampled	Time Sampled	Date Received	Time Received
239396-1	RFW-1A	Water	08/18/2005	10:00	08/20/2005	09:00
239396-2	RFW-1B	Water	08/19/2005	11:00	08/20/2005	09:00
239396-3	RFW-2A	Water	08/18/2005	08:55	08/20/2005	09:00
239396-4	RFW-2B	Water	08/18/2005	09:20	08/20/2005	09:00
239396-5	RFW-3B	Water	08/19/2005	08:40	08/20/2005	09:00
239396-6	RFW-4A	Water	08/19/2005	08:45	08/20/2005	09:00
239396-7	RFW-4A DUP	Water	08/19/2005	08:45	08/20/2005	09:00
239396-8	RFW-4B	Water	08/19/2005	10:15	08/20/2005	09:00
239396-9	RFW-6	Water	08/19/2005	08:10	08/20/2005	09:00
239396-10	RFW-7	Water	08/18/2005	13:20	08/20/2005	09:00
239396-11	RFW-9	Water	08/19/2005	12:40	08/20/2005	09:00
239396-12	RFW-11B	Water	08/19/2005	12:00	08/20/2005	09:00
239396-13	RFW-12B	Water	08/19/2005	11:45	08/20/2005	09:00
239396-14	RFW-13	Water	08/18/2005	14:20	08/20/2005	09:00
239396-15	RFW-17	Water	08/18/2005	12:15	08/20/2005	09:00
239396-16	LEISTER-1	Water	08/18/2005	16:20	08/20/2005	09:00
239396-17	LEISTER-2	Water	08/18/2005	16:30	08/20/2005	09:00
239396-18	LEISTER-DAIRY	Water	08/18/2005	16:25	08/20/2005	09:00
239396-19	TRIP BLANK	Water	08/18/2005	08:00	08/20/2005	09:00
239396-20	EW-2	Water	08/19/2005	11:30	08/20/2005	09:00
239396-21	EW-3	Water	08/19/2005	10:30	08/20/2005	09:00
239396-22	EW-4	Water	08/19/2005	10:15	08/20/2005	09:00
239396-23	EW-5	Water	08/19/2005	10:45	08/20/2005	09:00
239396-24	EW-5 DUP	Water	08/19/2005	10:45	08/20/2005	09:00
239396-25	EW-6	Water	08/18/2005	13:40	08/20/2005	09:00
239396-26	EW-7	Water	08/18/2005	13:45	08/20/2005	09:00

STL Chicago is part of Severn Trent Laboratories, Inc.

SAMPLE INFORMATION
Date:

Job Number.: 239396
Customer...: Weston Solutions, Inc.
Attr.....: Tom Cornuet

Project Number.....: 20005711
Customer Project ID....: BLACK AND DECKER
Project Description....: Black & Decker

Laboratory Sample ID	Customer Sample ID	Sample Matrix	Date Sampled	Time Sampled	Date Received	Time Received
239396-27	EW-8	Water	08/18/2005	14:00	08/20/2005	09:00
239396-28	EW-9	Water	08/18/2005	14:05	08/20/2005	09:00
239396-29	EW-10	Water	08/19/2005	08:20	08/20/2005	09:00

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-1A
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 10:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-1
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics										
	Dichlorodifluoromethane	1.0	U	0.12	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Chloromethane	1.0	U	0.20	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Vinyl chloride	1.0	U	0.16	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Bromomethane	1.0	U	0.59	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Chloroethane	1.0	U	0.32	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Trichlorofluoromethane	1.0	U	0.14	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,1-Dichloroethene	1.0	U	0.25	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Carbon disulfide	5.0	U	0.15	5.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Acetone	5.0	U	1.4	5.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Methylene chloride	1.0	U	0.24	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	trans-1,2-Dichloroethene	1.0	U	0.29	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,1-Dichloroethane	1.0	U	0.15	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	2,2-Dichloropropane	1.0	U	0.17	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	cis-1,2-Dichloroethene	1.0	U	0.20	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	2-Butanone (MEK)	5.0	U	1.0	5.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Bromochloromethane	1.0	U	0.27	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Chloroform	1.0	U	0.14	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,1,1-Trichloroethane	1.0	U	0.17	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,1-Dichloropropene	1.0	U	0.38	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Carbon tetrachloride	1.0	U	0.34	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Benzene	1.0	U	0.23	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2-Dichloroethane	1.0	U	0.25	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Trichloroethene	1.0	U	0.13	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2-Dichloropropane	1.0	U	0.19	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Dibromomethane	1.0	U	0.21	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Bromodichloromethane	1.0	U	0.22	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	cis-1,3-Dichloropropene	1.0	U	0.15	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U	0.92	5.0	1.00000	ug/L	158795		08/30/05 2227	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-1A
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 10:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-1
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-1A
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 10:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-1
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0		U	0.35	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2-Dichlorobenzene	1.0		U	0.29	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2-Dibromo-3-chloropropane	1.0		U	0.41	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2,4-Trichlorobenzene	1.0		U	0.36	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Hexachlorobutadiene	1.0		U	0.36	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Naphthalene	1.0		U	0.37	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2,3-Trichlorobenzene	1.0		U	0.43	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS					Date: 09/30/2005					
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER			ATTN: Tom Cornuet						
Customer Sample ID: RFW-1B Date Sampled.....: 08/19/2005 Time Sampled.....: 11:00 Sample Matrix.....: Water			Laboratory Sample ID: 239396-2 Date Received.....: 08/20/2005 Time Received.....: 09:00									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
82608	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/30/05 2252	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-1B
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 11:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-2
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date: 09/30/2005				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: RFW-1B Date Sampled.....: 08/19/2005 Time Sampled.....: 11:00 Sample Matrix.....: Water			Laboratory Sample ID: 239396-2 Date Received.....: 08/20/2005 Time Received.....: 09:00									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Corruet

Customer Sample ID: RFW-2A
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 08:55
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-3
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Trichloroethene	1.5	U		0.13	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/30/05 2316	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-2A
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 08:55
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-3
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-2A
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 08:55
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-3
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-2B
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 09:20
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-4
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
82608	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/30/05 2340	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-2B
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 09:20
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-4
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/30/05 2340	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2340	jd

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date: 09/30/2005				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: RFW-2B				Laboratory Sample ID: 239396-4								
Date Sampled.....: 08/18/2005				Date Received.....: 08/20/2005								
Time Sampled.....: 09:20				Time Received.....: 09:00								
Sample Matrix.....: Water												
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-3B
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:40
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-5
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,1-Dichloroethane	1.2	U	H	0.25	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	trans-1,2-Dichloroethane	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	cis-1,2-Dichloroethane	10	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Trichloroethene	7.9	U		0.13	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0004	jdj

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date:09/30/2005				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER			ATTN: Tom Cornuet						
Customer Sample ID: RFW-3B Date Sampled.....: 08/19/2005 Time Sampled.....: 08:40 Sample Matrix.....: Water			Laboratory Sample ID: 239396-5 Date Received.....: 08/20/2005 Time Received.....: 09:00									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DTECTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Tetrachloroethene	8.2	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-38
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:40
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-5
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RE	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date:09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Corbett

Customer Sample ID: RFW-4A
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-6
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
82608	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	cis-1,2-Dichloroethene	1.8	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Chloroform	1.3	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Trichloroethene	56	U		0.13	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0028	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Corruet

Customer Sample ID: RFW-4A
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-6
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	Tetrachloroethene	65			0.18	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/31/05 0028	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/31/05 0028	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0028	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0028	jd

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS					Date: 09/30/2005					
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER			ATTN: Tom Cornuet						
Customer Sample ID: RFW-4A Date Sampled.....: 08/19/2005 Time Sampled.....: 08:45 Sample Matrix.....: Water			Laboratory Sample ID: 239396-6 Date Received.....: 08/20/2005 Time Received.....: 09:00									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-4A DUP
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-7
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	cis-1,2-Dichloroethene	1.7	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Chloroform	1.2	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Trichloroethene	55	U		0.13	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0053	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-4A DUP
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-7
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Tetrachloroethene	63	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-4A DUP
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-7
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	NOL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date:09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Corruet

Customer Sample ID: RFW-4B
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:15
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-8
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	cis-1,2-Dichloroethene	6.6	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Chloroform	0.94	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Trichloroethene	18	U		0.13	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0117	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-4B
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:15
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-B
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MOL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Tetrachloroethene	60			0.18	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396 Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc. PROJECT: BLACK AND DECKER ATTN: Tom Cornuet

Customer Sample ID: RFW-4B
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:15
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-8
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0117	jdh
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0117	jdh
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0117	jdh
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0117	jdh
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0117	jdh
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0117	jdh
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0117	jdh

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-6
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:10
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-9
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	cis-1,2-Dichloroethene	1.6	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Trichloroethene	9.9	U		0.13	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0141	jd

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-6
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:10
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-9
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	PDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Tetrachloroethane	6.8	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj

* In Description = Dry Wgt.

Page 28

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-6
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:10
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-9
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0		U	0.35	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,2-Dichlorobenzene	1.0		U	0.29	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,2-Dibromo-3-chloropropane	1.0		U	0.41	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,2,4-Trichlorobenzene	1.0		U	0.36	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Hexachlorobutadiene	1.0		U	0.36	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Naphthalene	1.0		U	0.37	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,2,3-Trichlorobenzene	1.0		U	0.43	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-7
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 13:20
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-10
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MOL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Trichloroethene	11	U	H	0.13	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0206	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-7
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 13:20
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-10
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RE	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/31/05 0206	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/31/05 0206	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0206	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0206	jd

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date:09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-7
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 13:20
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-10
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q-FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U	0.35	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,2-Dichlorobenzene	1.0	U	0.29	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,2-Dibromo-3-chloropropane	1.0	U	0.41	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,2,4-Trichlorobenzene	1.0	U	0.36	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Hexachlorobutadiene	1.0	U	0.36	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Naphthalene	1.0	U	0.37	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,2,3-Trichlorobenzene	1.0	U	0.43	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-9
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 12:40
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-11
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DETECTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0230	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0230	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0230	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0230	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0230	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0230	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0230	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-11B
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 12:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-12
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Trichloroethene	31	U		0.13	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0254	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Corbett

Customer Sample ID: RFW-11B
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 12:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-12
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date: 09/30/2005				
CUSTOMER: Neston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: RFW-11B Date Sampled.....: 08/19/2005 Time Sampled.....: 12:00 Sample Matrix.....: Water			Laboratory Sample ID: 239396-12 Date Received.....: 08/20/2005 Time Received.....: 09:00									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0254	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-12B
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 11:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-13
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	NDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,1-Dichloroethene	1.1	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	cis-1,2-Dichloroethene	6.6	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Trichloroethene	550	U		1.3	10	10.00000	ug/L	158795	D1	08/31/05 0342	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0318	jdj

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date:09/30/2005				
CUSTOMER: Weston Solutions, Inc.		PROJECT: BLACK AND DECKER				ATTN: Tom Cornwell						
Customer Sample ID: RFW-12B Date Sampled.....: 08/19/2005 Time Sampled.....: 11:45 Sample Matrix.....: Water		Laboratory Sample ID: 239396-13 Date Received.....: 08/20/2005 Time Received.....: 09:00										
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RI	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Tetrachloroethene	40			0.18	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-128
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 11:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-13
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0318	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-13
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 14:20
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-14
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	cis-1,2-Dichloroethene	0.96	J		0.20	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Trichloroethene	3.1	U		0.13	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0407	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-13
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 14:20
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-14
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Tetrachloroethene	16			0.18	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS												
Job Number: 239396								Date: 09/30/2005				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: RFW-13 Date Sampled.....: 08/18/2005 Time Sampled.....: 14:20 Sample Matrix.....: Water						Laboratory Sample ID: 239396-14 Date Received.....: 08/20/2005 Time Received.....: 09:00						
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0407	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-17
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 12:15
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-15
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0431	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-17
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 12:15
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-15
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U	0.18	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	trans-1,3-Dichloropropene	1.0	U	0.16	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,1,2-Trichloroethane	1.0	U	0.24	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Tetrachloroethene	1.0	U	0.18	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,3-Dichloropropane	1.0	U	0.22	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	2-Hexanone	5.0	U	0.99	5.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Dibromochloromethane	1.0	U	0.22	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,2-Dibromoethane (EDB)	1.0	U	0.33	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Chlorobenzene	1.0	U	0.15	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,1,1,2-Tetrachloroethane	1.0	U	0.33	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Ethylbenzene	1.0	U	0.21	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	m&p-Xylenes	2.0	U	0.36	2.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	o-Xylene	1.0	U	0.19	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Styrene	1.0	U	0.18	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Bromoform	1.0	U	0.32	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Isopropylbenzene	1.0	U	0.20	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Bromobenzene	1.0	U	0.22	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,1,2,2-Tetrachloroethane	1.0	U	0.34	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,2,3-Trichloropropane	1.0	U	0.35	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	n-Propylbenzene	1.0	U	0.16	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	2-Chlorotoluene	1.0	U	0.16	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,3,5-Trimethylbenzene	1.0	U	0.18	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	4-Chlorotoluene	1.0	U	0.18	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	tert-Butylbenzene	1.0	U	0.16	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,2,4-Trimethylbenzene	1.0	U	0.26	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	sec-Butylbenzene	1.0	U	0.19	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,3-Dichlorobenzene	1.0	U	0.21	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	p-Isopropyltoluene	1.0	U	0.29	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,4-Dichlorobenzene	1.0	U	0.25	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj

* In Description = Dry Wgt.

Page 46

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Corwuet

Customer Sample ID: RFW-17
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 12:15
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-15
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0431	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: LEISTER-1
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 16:20
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-16
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0455	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: LEISTER-1
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 16:20
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-16
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0		U	0.18	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	trans-1,3-Dichloropropene	1.0		U	0.16	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	1,1,2-Trichloroethane	1.0		U	0.24	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	Tetrachloroethene	1.0		U	0.18	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	1,3-Dichloropropane	1.0		U	0.22	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	2-Hexanone	5.0		U	0.99	5.0	1.00000	ug/L	158795		08/31/05 0455	jd
	Dibromochloromethane	1.0		U	0.22	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	1,2-Dibromoethane (EDB)	1.0		U	0.33	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	Chlorobenzene	1.0		U	0.15	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	1,1,1,2-Tetrachloroethane	1.0		U	0.33	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	Ethylbenzene	1.0		U	0.21	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	m&p-Xylenes	2.0		U	0.36	2.0	1.00000	ug/L	158795		08/31/05 0455	jd
	o-Xylene	1.0		U	0.19	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	Styrene	1.0		U	0.18	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	Bromoform	1.0		U	0.32	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	Isopropylbenzene	1.0		U	0.20	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	Bromobenzene	1.0		U	0.22	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	1,1,2,2-Tetrachloroethane	1.0		U	0.34	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	1,2,3-Trichloropropane	1.0		U	0.35	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	n-Propylbenzene	1.0		U	0.16	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	2-Chlorotoluene	1.0		U	0.16	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	1,3,5-Trimethylbenzene	1.0		U	0.18	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	4-Chlorotoluene	1.0		U	0.18	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	tert-Butylbenzene	1.0		U	0.16	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	1,2,4-Trimethylbenzene	1.0		U	0.26	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	sec-Butylbenzene	1.0		U	0.19	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	1,3-Dichlorobenzene	1.0		U	0.21	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	p-Isopropyltoluene	1.0		U	0.29	1.0	1.00000	ug/L	158795		08/31/05 0455	jd
	1,4-Dichlorobenzene	1.0		U	0.25	1.0	1.00000	ug/L	158795		08/31/05 0455	jd

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date:09/30/2005				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER			ATTN: Tom Cornuet						
Customer Sample ID: LEISTER-1			Laboratory Sample ID: 239396-16			Date Sampled.....: 08/18/2005			Date Received.....: 08/20/2005			
Time Sampled.....: 16:20			Time Received.....: 09:00			Sample Matrix.....: Water						
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0455	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: LEISTER-2
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 16:30
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-17
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
82608	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,1-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0519	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: LEISTER-2
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 16:30
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-17
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: LEISTER-2
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 16:30
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-17
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0519	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: LEISTER-DAIRY
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 16:25
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-18
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics										
	Dichlorodifluoromethane	1.0	U	0.12	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	Chloromethane	1.0	U	0.20	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	Vinyl chloride	1.0	U	0.16	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	Bromomethane	1.0	U	0.59	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	Chloroethane	1.0	U	0.32	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	Trichlorofluoromethane	1.0	U	0.14	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	1,1-Dichloroethene	1.0	U	0.25	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	Carbon disulfide	5.0	U	0.15	5.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	Acetone	5.0	U	1.4	5.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	Methylene chloride	1.0	U	0.24	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	trans-1,2-Dichloroethene	1.0	U	0.29	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	1,1-Dichloroethane	1.0	U	0.15	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	2,2-Dichloropropane	1.0	U	0.17	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	cis-1,2-Dichloroethene	1.0	U	0.20	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	2-Butanone (MEK)	5.0	U	1.0	5.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	Bromochloromethane	1.0	U	0.27	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	Chloroform	1.0	U	0.14	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	1,1,1-Trichloroethane	1.0	U	0.17	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	1,1-Dichloropropene	1.0	U	0.38	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	Carbon tetrachloride	1.0	U	0.34	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	Benzene	1.0	U	0.23	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	1,2-Dichloroethane	1.0	U	0.25	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	Trichloroethene	1.0	U	0.13	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	1,2-Dichloropropane	1.0	U	0.19	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	Dibromomethane	1.0	U	0.21	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	Bromodichloromethane	1.0	U	0.22	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	cis-1,3-Dichloropropene	1.0	U	0.15	1.0	1.00000	ug/L	158913		08/31/05 2155	jdh
	4-Methyl-2-pentanone (MIBK)	5.0	U	0.92	5.0	1.00000	ug/L	158913		08/31/05 2155	jdh

* In Description = Dry Wgt.

Page 54

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Corruet

Customer Sample ID: LEISTER-DAIRY
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 16:25
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-18
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DV	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date: 09/30/2005				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER			ATTN: Tom Cornuet						
Customer Sample ID: LEISTER-DAIRY			Laboratory Sample ID: 239396-18									
Date Sampled.....: 08/18/2005			Date Received.....: 08/20/2005									
Time Sampled.....: 16:25			Time Received.....: 09:00									
Sample Matrix.....: Water												
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0		U	0.35	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	1,2-Dichlorobenzene	1.0		U	0.29	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	1,2-Dibromo-3-chloropropane	1.0		U	0.41	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	1,2,4-Trichlorobenzene	1.0		U	0.36	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	Hexachlorobutadiene	1.0		U	0.36	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	Naphthalene	1.0		U	0.37	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj
	1,2,3-Trichlorobenzene	1.0		U	0.43	1.0	1.00000	ug/L	158913		08/31/05 2155	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Corbett

Customer Sample ID: TRIP BLANK
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 08:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-19
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158913		08/31/05 2219	jdj

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date: 09/30/2005				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER			ATTN: Tom Cornuet						
Customer Sample ID: TRIP BLANK Date Sampled.....: 08/18/2005 Time Sampled.....: 08:00 Sample Matrix.....: Water			Laboratory Sample ID: 239396-19 Date Received.....: 08/20/2005 Time Received.....: 09:00									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MOI	RI	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158913		08/31/05 2219	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158913		08/31/05 2219	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158913		08/31/05 2219	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158913		08/31/05 2219	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: TR1P BLANK
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 08:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-19
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158913		08/31/05 2219	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-2
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 11:30
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-20
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	cis-1,2-Dichloroethene	4.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	2-Butanone (NEK)	5.0	U		1.0	5.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Trichloroethene	740	U		1.3	10	10.00000	ug/L	158909	D1	08/31/05 1052	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158909		08/31/05 1003	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-2
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 11:30
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-20
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	Tetrachloroethene	68			0.18	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1003	jdn

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date: 09/30/2005				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER			ATTN: Tom Cornuet						
Customer Sample ID: EW-2 Date Sampled.....: 08/19/2005 Time Sampled.....: 11:30 Sample Matrix.....: Water			Laboratory Sample ID: 239396-20 Date Received.....: 08/20/2005 Time Received.....: 09:00									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158909		08/31/05 1003	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-3
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:30
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-21
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MOL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158909		08/31/05 1116	jd
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158909		08/31/05 1116	jd
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	cis-1,2-Dichloroethene	2.4	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158909		08/31/05 1116	jd
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	Trichloroethene	230	U		0.65	5.0	5.00000	ug/L	158909	D1	08/31/05 1140	jd
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1116	jd
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158909		08/31/05 1116	jd

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-3
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:30
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-21
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	Tetrachloroethane	5.5	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-3
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:30
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-21
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158909		08/31/05 1116	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date:09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-4
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:15
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-22
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	NDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	5.0	U		0.60	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Chloromethane	5.0	U		1.0	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Vinyl chloride	5.0	U		0.80	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Bromomethane	5.0	U		3.0	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Chloroethane	5.0	U		1.6	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Trichlorofluoromethane	5.0	U		0.70	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,1-Dichloroethene	5.0	U		1.2	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Carbon disulfide	25	U		0.75	25	5.00000	ug/L	158909		08/31/05 1204	jdj
	Acetone	25	U		7.0	25	5.00000	ug/L	158909		08/31/05 1204	jdj
	Methylene chloride	5.0	U		1.2	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	trans-1,2-Dichloroethene	5.0	U		1.4	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,1-Dichloroethane	5.0	U		0.75	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	2,2-Dichloropropane	5.0	U		0.85	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	cis-1,2-Dichloroethene	5.0	U		1.0	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	2-Butanone (MEK)	25	U		5.0	25	5.00000	ug/L	158909		08/31/05 1204	jdj
	Bromochloromethane	5.0	U		1.4	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Chloroform	5.0	U		0.70	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,1,1-Trichloroethane	5.0	U		0.85	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,1-Dichloropropene	5.0	U		1.9	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Carbon tetrachloride	5.0	U		1.7	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Benzene	5.0	U		1.2	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,2-Dichloroethane	5.0	U		1.2	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Trichloroethene	950	U		6.5	50	50.00000	ug/L	158909	D1	08/31/05 1229	jdj
	1,2-Dichloropropane	5.0	U		0.95	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Dibromomethane	5.0	U		1.0	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Bromodichloromethane	5.0	U		1.1	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	cis-1,3-Dichloropropene	5.0	U		0.75	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	4-Methyl-2-pentanone (MIBK)	25	U		4.6	25	5.00000	ug/L	158909		08/31/05 1204	jdj

* In Description = Dry Wgt.

Page 66

LABORATORY TEST RESULTS

Job Number: 239396

Date:09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-4
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:15
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-22
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	5.0	U		0.90	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	trans-1,3-Dichloropropene	5.0	U		0.80	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,1,2-Trichloroethane	5.0	U		1.2	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Tetrachloroethene	27			0.90	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,3-Dichloropropane	5.0	U		1.1	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	2-Hexanone	25	U		5.0	25	5.00000	ug/L	158909		08/31/05 1204	jdj
	Dibromochloromethane	5.0	U		1.1	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,2-Dibromoethane (EDB)	5.0	U		1.6	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Chlorobenzene	5.0	U		0.75	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,1,1,2-Tetrachloroethane	5.0	U		1.6	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Ethylbenzene	5.0	U		1.0	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	m&p-Xylenes	10	U		1.8	10	5.00000	ug/L	158909		08/31/05 1204	jdj
	o-Xylene	5.0	U		0.95	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Styrene	5.0	U		0.90	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Bromoform	5.0	U		1.6	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Isopropylbenzene	5.0	U		1.0	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Bromobenzene	5.0	U		1.1	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,1,2,2-Tetrachloroethane	5.0	U		1.7	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,2,3-Trichloropropane	5.0	U		1.8	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	n-Propylbenzene	5.0	U		0.80	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	2-Chlorotoluene	5.0	U		0.80	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,3,5-Trimethylbenzene	5.0	U		0.90	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	4-Chlorotoluene	5.0	U		0.90	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	tert-Butylbenzene	5.0	U		0.80	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,2,4-Trimethylbenzene	5.0	U		1.3	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	sec-Butylbenzene	5.0	U		0.95	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,3-Dichlorobenzene	5.0	U		1.0	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	p-Isopropyltoluene	5.0	U		1.4	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,4-Dichlorobenzene	5.0	U		1.2	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date: 09/30/2005				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-4 Date Sampled.....: 08/19/2005 Time Sampled.....: 10:15 Sample Matrix.....: Water			Laboratory Sample ID: 239396-22 Date Received.....: 08/20/2005 Time Received.....: 09:00									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	5.0	U		1.8	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,2-Dichlorobenzene	5.0	U		1.4	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,2-Dibromo-3-chloropropane	5.0	U		2.0	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,2,4-Trichlorobenzene	5.0	U		1.8	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Hexachlorobutadiene	5.0	U		1.8	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	Naphthalene	5.0	U		1.8	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj
	1,2,3-Trichlorobenzene	5.0	U		2.2	5.0	5.00000	ug/L	158909		08/31/05 1204	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-5
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-23
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,1-Dichloroethene	0.97	J		0.25	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Trichloroethene	410	U		1.3	10	10.00000	ug/L	158909	D1	08/31/05 1317	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158909		08/31/05 1253	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-5
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-23
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Tetrachloroethene	13	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-5
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-23
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0		U	0.35	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,2-Dichlorobenzene	1.0		U	0.29	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,2-Dibromo-3-chloropropane	1.0		U	0.41	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,2,4-Trichlorobenzene	1.0		U	0.36	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Hexachlorobutadiene	1.0		U	0.36	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	Naphthalene	1.0		U	0.37	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj
	1,2,3-Trichlorobenzene	1.0		U	0.43	1.0	1.00000	ug/L	158909		08/31/05 1253	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-5 DUP
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-24
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Trichloroethene	390	U		1.3	10	10.00000	ug/L	158909	D1	08/31/05 1415	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158909		08/31/05 1342	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-5 DUP
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-24
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Tetrachloroethene	13			0.18	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date: 09/30/2005				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-5 DUP Date Sampled.....: 08/19/2005 Time Sampled.....: 10:45 Sample Matrix.....: Water			Laboratory Sample ID: 239396-24 Date Received.....: 08/20/2005 Time Received.....: 09:00									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158909		08/31/05 1342	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-6
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 13:40
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-25
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
82608	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	Trichloroethene	8.8	U		0.13	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1440	jdn
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158909		08/31/05 1440	jdn

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-6
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 13:40
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-25
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	Tetrachloroethene	21			0.18	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj

* In Description = Dry Wgt.

Page 76

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-6
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 13:40
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-25
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158909		08/31/05 1440	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Corbett

Customer Sample ID: EW-7
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 13:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-26
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	cis-1,2-Dichloroethene	5.3	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Trichloroethene	4.4	U		0.13	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158909		08/31/05 1504	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Corvuet

Customer Sample ID: EW-7
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 13:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-26
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Tetrachloroethene	6.9	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-7
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 13:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-26
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158909		08/31/05 1504	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-8
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 14:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-27
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLABS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	1,1-Dichloroethane	0.95	J		0.15	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	cis-1,2-Dichloroethene	21	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Trichloroethene	10	U		0.13	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158909		08/31/05 1529	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-B
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 14:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-27
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	Tetrachloroethene	63			0.18	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1529	jdh

* In Description = Dry Wgt.

Page 82

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-8
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 14:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-27
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U	0.35	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	1,2-Dichlorobenzene	1.0	U	0.29	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	1,2-Dibromo-3-chloropropane	1.0	U	0.41	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	1,2,4-Trichlorobenzene	1.0	U	0.36	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Hexachlorobutadiene	1.0	U	0.36	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	Naphthalene	1.0	U	0.37	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj
	1,2,3-Trichlorobenzene	1.0	U	0.43	1.0	1.00000	ug/L	158909		08/31/05 1529	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-9
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 14:05
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-28
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	cis-1,2-Dichloroethene	1.2	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Trichloroethene	2.3	U		0.13	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158909		08/31/05 1553	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Corruet

Customer Sample ID: EW-9
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 14:05
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-28
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	Tetrachloroethene	180	U		0.90	5.0	5.00000	ug/L	158909	D1	08/31/05 1618	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158909		08/31/05 1553	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158909		08/31/05 1553	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1553	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1553	jd

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date: 09/30/2005				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-9 Date Sampled.....: 08/18/2005 Time Sampled.....: 14:05 Sample Matrix.....: Water			Laboratory Sample ID: 239396-28 Date Received.....: 08/20/2005 Time Received.....: 09:00									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158909		08/31/05 1553	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-10
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:20
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-29
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	BY	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158909		08/31/05 1642	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-10
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:20
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-29
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Tetrachloroethene	10	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-10
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:20
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-29
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDE	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0		U	0.35	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,2-Dichlorobenzene	1.0		U	0.29	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,2-Dibromo-3-chloropropane	1.0		U	0.41	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,2,4-Trichlorobenzene	1.0		U	0.36	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Hexachlorobutadiene	1.0		U	0.36	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	Naphthalene	1.0		U	0.37	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj
	1,2,3-Trichlorobenzene	1.0		U	0.43	1.0	1.00000	ug/L	158909		08/31/05 1642	jdj

* In Description = Dry Wgt.

LABORATORY CHRONICLE

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Lab ID: 239396-1	Client ID: RFW-1A	Date Recvd: 08/20/2005	Sample Date: 08/18/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/30/2005 2227	
EDD	Electronic Data Deliverable	1	159112				
8260B	Volatile Organics	1	158795	158791		08/30/2005 2227	1.00000
Lab ID: 239396-2	Client ID: RFW-1B	Date Recvd: 08/20/2005	Sample Date: 08/19/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/30/2005 2252	
8260B	Volatile Organics	1	158795	158791		08/30/2005 2252	1.00000
Lab ID: 239396-3	Client ID: RFW-2A	Date Recvd: 08/20/2005	Sample Date: 08/18/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/30/2005 2316	
8260B	Volatile Organics	1	158795	158791		08/30/2005 2316	1.00000
Lab ID: 239396-4	Client ID: RFW-2B	Date Recvd: 08/20/2005	Sample Date: 08/18/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/30/2005 2340	
8260B	Volatile Organics	1	158795	158791		08/30/2005 2340	1.00000
Lab ID: 239396-5	Client ID: RFW-3B	Date Recvd: 08/20/2005	Sample Date: 08/19/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/31/2005 0004	
8260B	Volatile Organics	1	158795	158791		08/31/2005 0004	1.00000
Lab ID: 239396-6	Client ID: RFW-4A	Date Recvd: 08/20/2005	Sample Date: 08/19/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/31/2005 0028	
8260B	Volatile Organics	1	158795	158791		08/31/2005 0028	1.00000
Lab ID: 239396-7	Client ID: RFW-4A DUP	Date Recvd: 08/20/2005	Sample Date: 08/19/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/31/2005 0053	
8260B	Volatile Organics	1	158795	158791		08/31/2005 0053	1.00000
Lab ID: 239396-8	Client ID: RFW-4B	Date Recvd: 08/20/2005	Sample Date: 08/19/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/31/2005 0117	
8260B	Volatile Organics	1	158795	158791		08/31/2005 0117	1.00000
Lab ID: 239396-9	Client ID: RFW-6	Date Recvd: 08/20/2005	Sample Date: 08/19/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/31/2005 0141	
8260B	Volatile Organics	1	158795	158791		08/31/2005 0141	1.00000
Lab ID: 239396-10	Client ID: RFW-7	Date Recvd: 08/20/2005	Sample Date: 08/18/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/31/2005 0206	
8260B	Volatile Organics	1	158795	158791		08/31/2005 0206	1.00000
Lab ID: 239396-11	Client ID: RFW-9	Date Recvd: 08/20/2005	Sample Date: 08/19/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/31/2005 0230	
8260B	Volatile Organics	1	158795	158791		08/31/2005 0230	1.00000
Lab ID: 239396-12	Client ID: RFW-11B	Date Recvd: 08/20/2005	Sample Date: 08/19/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/31/2005 0254	

Job Number: 239396		LABORATORY CHRONICLE			Date: 09/30/2005		
CUSTOMER: Weston Solutions, Inc.		PROJECT: BLACK AND DECKER			ATTN: Tom Cornuet		
Lab ID: 239396-12	Client ID: RFW-11B	Date Recvd: 08/20/2005	Sample Date: 08/19/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
8260B	Volatile Organics	1	158795	158791		08/31/2005 0254	1.00000
Lab ID: 239396-13	Client ID: RFW-12B	Date Recvd: 08/20/2005	Sample Date: 08/19/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/31/2005 0342	
5030B	5030 10 mL Purge Prep	2	158791			08/31/2005 0318	1.00000
8260B	Volatile Organics	1	158795	158791		08/31/2005 0318	1.00000
8260B	Volatile Organics	1	158795	158791		08/31/2005 0342	10.0000
Lab ID: 239396-14	Client ID: RFW-13	Date Recvd: 08/20/2005	Sample Date: 08/18/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/31/2005 0407	
8260B	Volatile Organics	1	158795	158791		08/31/2005 0407	1.00000
Lab ID: 239396-15	Client ID: RFW-17	Date Recvd: 08/20/2005	Sample Date: 08/18/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/31/2005 0431	
8260B	Volatile Organics	1	158795	158791		08/31/2005 0431	1.00000
Lab ID: 239396-16	Client ID: LEISTER-1	Date Recvd: 08/20/2005	Sample Date: 08/18/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/31/2005 0455	
8260B	Volatile Organics	1	158795	158791		08/31/2005 0455	1.00000
Lab ID: 239396-17	Client ID: LEISTER-2	Date Recvd: 08/20/2005	Sample Date: 08/18/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158791			08/31/2005 0519	
8260B	Volatile Organics	1	158795	158791		08/31/2005 0519	1.00000
Lab ID: 239396-18	Client ID: LEISTER-DAIRY	Date Recvd: 08/20/2005	Sample Date: 08/18/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158912			08/31/2005 2155	
5030B	5030 10 mL Purge Prep	2	158791			08/31/2005 0736	
8260B	Volatile Organics	1	158913	158912		08/31/2005 2155	1.00000
Lab ID: 239396-19	Client ID: TRIP BLANK	Date Recvd: 08/20/2005	Sample Date: 08/18/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158912			08/31/2005 2219	
8260B	Volatile Organics	1	158913	158912		08/31/2005 2219	1.00000
Lab ID: 239396-20	Client ID: EW-2	Date Recvd: 08/20/2005	Sample Date: 08/19/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158908			08/31/2005 1003	
5030B	5030 10 mL Purge Prep	2	158908			08/31/2005 1052	
8260B	Volatile Organics	1	158909	158908		08/31/2005 1003	1.00000
8260B	Volatile Organics	1	158909	158908		08/31/2005 1052	10.0000
Lab ID: 239396-21	Client ID: EW-3	Date Recvd: 08/20/2005	Sample Date: 08/19/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158908			08/31/2005 1140	
5030B	5030 10 mL Purge Prep	2	158908			08/31/2005 1116	
8260B	Volatile Organics	1	158909	158908		08/31/2005 1116	1.00000
8260B	Volatile Organics	1	158909	158908		08/31/2005 1140	5.00000
Lab ID: 239396-22	Client ID: EW-4	Date Recvd: 08/20/2005	Sample Date: 08/19/2005				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
5030B	5030 10 mL Purge Prep	1	158908			08/31/2005 1229	

LABORATORY CHRONICLE

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Carmuet

Lab ID:	Client ID:	Date Recvd:	Sample Date:				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
239396-22	EW-4	08/20/2005	08/19/2005				
5030B	5030 10 mL Purge Prep	2	158908			08/31/2005 1204	
8260B	Volatile Organics	1	158909	158908		08/31/2005 1204	5.00000
8260B	Volatile Organics	1	158909	158908		08/31/2005 1229	50.0000
239396-23	EW-5	08/20/2005	08/19/2005				
5030B	5030 10 mL Purge Prep	1	158908			08/31/2005 1317	
5030B	5030 10 mL Purge Prep	2	158908			08/31/2005 1253	
8260B	Volatile Organics	1	158909	158908		08/31/2005 1253	1.00000
8260B	Volatile Organics	1	158909	158908		08/31/2005 1317	10.0000
239396-24	EW-5 DUP	08/20/2005	08/19/2005				
5030B	5030 10 mL Purge Prep	1	158908			08/31/2005 1342	
5030B	5030 10 mL Purge Prep	2	158908			08/31/2005 1415	
8260B	Volatile Organics	1	158909	158908		08/31/2005 1342	1.00000
8260B	Volatile Organics	1	158909	158908		08/31/2005 1415	10.0000
239396-25	EW-6	08/20/2005	08/18/2005				
5030B	5030 10 mL Purge Prep	1	158908			08/31/2005 1440	
8260B	Volatile Organics	1	158909	158908		08/31/2005 1440	1.00000
239396-26	EW-7	08/20/2005	08/18/2005				
5030B	5030 10 mL Purge Prep	1	158908			08/31/2005 1504	
8260B	Volatile Organics	1	158909	158908		08/31/2005 1504	1.00000
239396-27	EW-8	08/20/2005	08/18/2005				
5030B	5030 10 mL Purge Prep	1	158908			08/31/2005 1529	
8260B	Volatile Organics	1	158909	158908		08/31/2005 1529	1.00000
239396-28	EW-9	08/20/2005	08/18/2005				
5030B	5030 10 mL Purge Prep	1	158908			08/31/2005 1618	
5030B	5030 10 mL Purge Prep	2	158908			08/31/2005 1553	
8260B	Volatile Organics	1	158909	158908		08/31/2005 1553	1.00000
8260B	Volatile Organics	1	158909	158908		08/31/2005 1618	5.00000
239396-29	EW-10	08/20/2005	08/19/2005				
5030B	5030 10 mL Purge Prep	1	158908			08/31/2005 1642	
8260B	Volatile Organics	1	158909	158908		08/31/2005 1642	1.00000

STL Chicago is part of Severn Trent Laboratories, Inc.

SURROGATE RECOVERIES REPORT		Report Date.: 09/30/2005
Job Number.: 239396		
CUSTOMER: Weston Solutions, Inc.	PROJECT: BLACK AND DECKER	ATTN: Tom Cornuet

Method.....: Volatile Organics	Test Matrix...: Water	Prep Batch...: 158791
Method Code...: 8260B	Batch(s).....: 158795	

Lab ID	DT	Sample ID	Date	12DCED	BRFLBE	DBRFLM	TOLD8
LCS			08/30/2005	100	106	105	99
MB			08/30/2005	107	103	107	101
239396- 1		RFW-1A	08/30/2005	106	103	113	99
239396- 2		RFW-1B	08/30/2005	101	101	105	100
239396- 3		RFW-2A	08/30/2005	103	103	106	99
239396- 4		RFW-2B	08/30/2005	101	99	105	99
239396- 5		RFW-3B	08/31/2005	101	98	106	97
239396- 6		RFW-4A	08/31/2005	102	102	108	101
239396- 7		RFW-4A DUP	08/31/2005	104	103	111	100
239396- 8		RFW-4B	08/31/2005	103	101	109	99
239396- 9		RFW-6	08/31/2005	103	102	109	99
239396- 10		RFW-7	08/31/2005	101	101	105	97
239396- 11		RFW-9	08/31/2005	102	100	107	97
239396- 12		RFW-11B	08/31/2005	101	102	108	97
239396- 13		RFW-12B	08/31/2005	99	98	108	97
239396- 13	D1	RFW-12B	08/31/2005	102	98	107	97
239396- 14		RFW-13	08/31/2005	101	101	107	96
239396- 15		RFW-17	08/31/2005	103	101	106	97
239396- 16		LEISTER-1	08/31/2005	102	103	110	99
239396- 17		LEISTER-2	08/31/2005	101	98	107	96

Test	Test Description	Limits
12DCED	1,2-Dichloroethane-d4 (surr)	62 - 127
BRFLBE	4-Bromofluorobenzene (surr)	67 - 132
DBRFLM	Dibromofluoromethane (surr)	77 - 119
TOLD8	Toluene-d8 (surr)	81 - 126

Method.....: Volatile Organics	Test Matrix...: Water	Prep Batch...: 158908
Method Code...: 8260B	Batch(s).....: 158909	

Lab ID	DT	Sample ID	Date	12DCED	BRFLBE	DBRFLM	TOLD8
LCS			08/31/2005	95	99	102	96
MB			08/31/2005	112	101	111	99
239396- 20		EW-2	08/31/2005	103	99	108	100
239396- 20	D1	EW-2	08/31/2005	99	97	107	98
239396- 21		EW-3	08/31/2005	105	99	110	99
239396- 21	D1	EW-3	08/31/2005	100	98	108	98
239396- 22		EW-4	08/31/2005	100	98	107	98
239396- 22	D1	EW-4	08/31/2005	99	99	106	98
239396- 23		EW-5	08/31/2005	99	99	109	98
239396- 23	D1	EW-5	08/31/2005	97	98	111	97
239396- 24		EW-5 DUP	08/31/2005	98	96	111	97
239396- 24	D1	EW-5 DUP	08/31/2005	107	101	114	100
239396- 25		EW-6	08/31/2005	102	99	111	98
239396- 26		EW-7	08/31/2005	103	98	108	98
239396- 27		EW-8	08/31/2005	102	98	110	99
239396- 28		EW-9	08/31/2005	103	99	110	98
239396- 28	D1	EW-9	08/31/2005	101	98	107	97
239396- 29		EW-10	08/31/2005	103	98	110	97

STL Chicago is part of Severn Trent Laboratories, Inc.

SURROGATE RECOVERIES REPORT

Job Number.: 239396 Report Date.: 09/30/2005

CUSTOMER: Weston Solutions, Inc. PROJECT: BLACK AND DECKER ATTN: Tom Cornuet

Method.....: Volatile Organics Test Matrix...: Water Prep Batch...: 158908
 Method Code...: 82608 Batch(e).....: 158909

Test	Test Description	Limits
12DCED	1,2-Dichloroethane-d4 (surr)	62 - 127
BRFLBE	4-Bromofluorobenzene (surr)	67 - 132
DBRFLM	Dibromofluoromethane (surr)	77 - 119
TOLD8	Toluene-d8 (surr)	81 - 126

Method.....: Volatile Organics Test Matrix...: Water Prep Batch...: 158912
 Method Code...: 82608 Batch(s).....: 158913

Lab ID	DT	Sample ID	Date	12DCED	BRFLBE	DBRFLM	TOLD8
LCS			08/31/2005	95	99	102	96
MB			08/31/2005	101	101	105	95
239396- 18		LEISTER-DAIRY	08/31/2005	101	101	103	96
239396- 19		TRIP BLANK	08/31/2005	102	100	105	97

Test	Test Description	Limits
12DCED	1,2-Dichloroethane-d4 (surr)	62 - 127
BRFLBE	4-Bromofluorobenzene (surr)	67 - 132
DBRFLM	Dibromofluoromethane (surr)	77 - 119
TOLD8	Toluene-d8 (surr)	81 - 126

QUALITY CONTROL RESULTS

Job Number.: 239396

Report Date.: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

Test Method.....: 8260B
Method Description.: Volatile Organics

Equipment Code....: GCL2
Batch.....: 158795

Analyst...: jdn

LCS	Laboratory Control Sample	V05H3005A	158791-002	08/30/2005	2002
-----	---------------------------	-----------	------------	------------	------

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits	F
Dichlorodifluoromethane	ug/L	34.937		25.000	1.000	U 140	% 24-171	
Chloromethane	ug/L	33.892		25.000	1.000	U 136	% 31-182	
Vinyl chloride	ug/L	29.131		25.000	1.000	U 117	% 52-134	
Bromomethane	ug/L	37.730		25.000	1.000	U 151	% 31-188	
Chloroethane	ug/L	30.202		25.000	1.000	U 121	% 58-148	
Trichlorofluoromethane	ug/L	30.421		25.000	1.000	U 122	% 54-142	
1,1-Dichloroethene	ug/L	28.654		25.000	1.000	U 115	% 51-136	
Carbon disulfide	ug/L	19.191		25.000	5.000	U 77	% 21-111	
Acetone	ug/L	29.292		25.000	5.000	U 117	% 14-177	
Methylene chloride	ug/L	30.494		25.000	1.000	U 122	% 64-127	
trans-1,2-Dichloroethene	ug/L	27.090		25.000	1.000	U 108	% 62-138	
Methyl-tert-butyl-ether (MTBE)	ug/L	28.718		25.000	1.000	U 115	% 55-142	
1,1-Dichloroethane	ug/L	28.076		25.000	1.000	U 112	% 70-124	
2,2-Dichloropropane	ug/L	28.504		25.000	1.000	U 114	% 68-127	
cis-1,2-Dichloroethene	ug/L	29.271		25.000	1.000	U 117	% 76-125	
2-Butanone (MEK)	ug/L	30.383		25.000	5.000	U 122	% 29-139	
Bromochloromethane	ug/L	29.506		25.000	1.000	U 118	% 57-116	*
Chloroform	ug/L	29.266		25.000	1.000	U 117	% 75-122	
1,1,1-Trichloroethane	ug/L	29.200		25.000	1.000	U 120	% 70-127	
1,1-Dichloropropene	ug/L	26.306		25.000	1.000	U 105	% 70-125	
Carbon tetrachloride	ug/L	28.134		25.000	1.000	U 113	% 64-132	
Benzene	ug/L	26.792		25.000	1.000	U 107	% 75-122	
1,2-Dichloroethane	ug/L	27.468		25.000	1.000	U 110	% 67-120	
Trichloroethene	ug/L	26.053		25.000	1.000	U 104	% 75-124	
1,2-Dichloropropane	ug/L	26.830		25.000	1.000	U 107	% 76-116	
Dibromomethane	ug/L	27.770		25.000	1.000	U 111	% 68-116	
Bromodichloromethane	ug/L	29.858		25.000	1.000	U 119	% 75-125	
cis-1,3-Dichloropropene	ug/L	27.156		26.000	1.000	U 104	% 72-115	
4-Methyl-2-pentanone (MIBK)	ug/L	27.275		25.000	5.000	U 109	% 39-137	
Toluene	ug/L	25.909		25.000	1.000	U 104	% 77-120	
trans-1,3-Dichloropropene	ug/L	25.286		24.000	1.000	U 105	% 68-119	
1,1,2-Trichloroethane	ug/L	30.039		25.000	1.000	U 120	% 63-127	
Tetrachloroethene	ug/L	25.524		25.000	1.000	U 102	% 70-125	
1,3-Dichloropropane	ug/L	26.751		25.000	1.000	U 107	% 72-118	
2-Hexanone	ug/L	26.962		25.000	5.000	U 108	% 36-144	
Dibromochloromethane	ug/L	29.004		25.000	1.000	U 116	% 73-116	
1,2-Dibromoethane (EDB)	ug/L	27.047		25.000	1.000	U 108	% 62-123	
Chlorobenzene	ug/L	26.321		25.000	1.000	U 105	% 76-116	
1,1,1,2-Tetrachloroethane	ug/L	29.253		25.000	1.000	U 117	% 77-120	
Ethylbenzene	ug/L	25.374		25.000	1.000	U 101	% 75-125	
m&p-Xylenes	ug/L	49.747		50.000	2.000	U 99	% 75-123	
o-Xylene	ug/L	25.586		25.000	1.000	U 102	% 76-121	
Styrene	ug/L	26.421		25.000	1.000	U 106	% 77-128	
Bromoform	ug/L	26.305		25.000	1.000	U 105	% 65-115	
Isopropylbenzene	ug/L	23.069		25.000	1.000	U 92	% 64-119	
Bromobenzene	ug/L	25.658		25.000	1.000	U 103	% 76-118	
1,1,2,2-Tetrachloroethane	ug/L	26.296		25.000	1.000	U 105	% 61-122	
1,2,3-Trichloropropane	ug/L	26.712		25.000	1.000	U 107	% 62-124	
n-Propylbenzene	ug/L	24.660		25.000	1.000	U 99	% 69-132	
2-Chlorotoluene	ug/L	24.258		25.000	1.000	U 97	% 70-127	

Job Number.: 239396

QUALITY CONTROL RESULTS

Report Date.: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND BECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

LCS	Laboratory Control Sample	V05H30DSA	158791-002		08/30/2005	2002
-----	---------------------------	-----------	------------	--	------------	------

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits	F
1,3,5-Trimethylbenzene	ug/L	23.859		25.000	1.000	U 95	% 70-132	
4-Chlorotoluene	ug/L	23.962		25.000	1.000	U 96	% 70-126	
tert-Butylbenzene	ug/L	25.202		25.000	1.000	U 101	% 70-133	
1,2,4-Trimethylbenzene	ug/L	24.683		25.000	1.000	U 99	% 71-131	
sec-Butylbenzene	ug/L	25.113		25.000	1.000	U 100	% 70-134	
1,3-Dichlorobenzene	ug/L	25.362		25.000	1.000	U 101	% 71-120	
p-Isopropyltoluene	ug/L	24.276		25.000	1.000	U 97	% 66-130	
1,4-Dichlorobenzene	ug/L	25.691		25.000	1.000	U 103	% 70-118	
n-Butylbenzene	ug/L	25.753		25.000	1.000	U 103	% 64-142	
1,2-Dichlorobenzene	ug/L	25.713		25.000	1.000	U 103	% 72-118	
1,2-Dibromo-3-chloropropane	ug/L	26.465		25.000	1.000	U 106	% 57-119	
1,2,4-Trichlorobenzene	ug/L	24.973		25.000	1.000	U 100	% 60-132	
Hexachlorobutadiene	ug/L	26.204		25.000	1.000	U 105	% 63-145	
Naphthalene	ug/L	25.756		25.000	1.000	U 103	% 57-128	
1,2,3-Trichlorobenzene	ug/L	25.030		25.000	1.000	U 100	% 66-124	

QUALITY CONTROL RESULTS

Job Number.: 239396 Report Date.: 09/30/2005

CUSTOMER: Weston Solutions, Inc. PROJECT: BLACK AND DECKER ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

Test Method.....: 8260B Equipment Code....: GCL2 Analyst....: jdn
 Method Description.: Volatile Organics Batch.....: 158795

WB	Method Blank	158791-001	08/30/2005 1937
----	--------------	------------	-----------------

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits
Dichlorodifluoromethane	ug/L	1.000	U				
Chloromethane	ug/L	1.000	U				
Vinyl chloride	ug/L	1.000	U				
Bromomethane	ug/L	1.000	U				
Chloroethane	ug/L	1.000	U				
Trichlorofluoromethane	ug/L	1.000	U				
1,1-Dichloroethene	ug/L	1.000	U				
Carbon disulfide	ug/L	5.000	U				
Acetone	ug/L	5.000	U				
Methylene chloride	ug/L	1.000	U				
trans-1,2-Dichloroethene	ug/L	1.000	U				
Methyl-tert-butyl-ether (MTBE)	ug/L	1.000	U				
1,1-Dichloroethane	ug/L	1.000	U				
2,2-Dichloropropane	ug/L	1.000	U				
cis-1,2-Dichloroethene	ug/L	1.000	U				
2-Butanone (MEK)	ug/L	5.000	U				
Bromochloromethane	ug/L	1.000	U				
Chloroform	ug/L	1.000	U				
1,1,1-Trichloroethane	ug/L	1.000	U				
1,1-Dichloropropene	ug/L	1.000	U				
Carbon tetrachloride	ug/L	1.000	U				
Benzene	ug/L	1.000	U				
1,2-Dichloroethane	ug/L	1.000	U				
Trichloroethene	ug/L	1.000	U				
1,2-Dichloropropane	ug/L	1.000	U				
Dibromomethane	ug/L	1.000	U				
Bromodichloromethane	ug/L	1.000	U				
cis-1,3-Dichloropropene	ug/L	1.000	U				
4-Methyl-2-pentanone (MIBK)	ug/L	5.000	U				
Toluene	ug/L	1.000	U				
trans-1,3-Dichloropropene	ug/L	1.000	U				
1,1,2-Trichloroethane	ug/L	1.000	U				
Tetrachloroethane	ug/L	1.000	U				
1,3-Dichloropropane	ug/L	1.000	U				
2-Hexanone	ug/L	5.000	U				
Dibromochloromethane	ug/L	1.000	U				
1,2-Dibromoethane (EDB)	ug/L	1.000	U				
Chlorobenzene	ug/L	1.000	U				
1,1,1,2-Tetrachloroethane	ug/L	1.000	U				
Ethylbenzene	ug/L	1.000	U				
m&p-Xylenes	ug/L	2.000	U				
o-Xylene	ug/L	1.000	U				
Styrene	ug/L	1.000	U				
Bromoform	ug/L	1.000	U				
Isopropylbenzene	ug/L	1.000	U				
Bromobenzene	ug/L	1.000	U				
1,1,2,2-Tetrachloroethane	ug/L	1.000	U				
1,2,3-Trichloropropane	ug/L	1.000	U				
n-Propylbenzene	ug/L	1.000	U				
2-Chlorotoluene	ug/L	1.000	U				

Job Number.: 239396

QUALITY CONTROL RESULTS

Report Date.: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
MB	Method Blank		158721-001		08/30/2005	1937

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits	F
1,3,5-Trimethylbenzene	ug/L	1.000	U					
4-Chlorotoluene	ug/L	1.000	U					
tert-Butylbenzene	ug/L	1.000	U					
1,2,4-Trimethylbenzene	ug/L	1.000	U					
sec-Butylbenzene	ug/L	1.000	U					
1,3-Dichlorobenzene	ug/L	1.000	U					
p-Isopropyltoluene	ug/L	1.000	U					
1,4-Dichlorobenzene	ug/L	1.000	U					
n-Butylbenzene	ug/L	1.000	U					
1,2-Dichlorobenzene	ug/L	1.000	U					
1,2-Dibromo-3-chloropropane	ug/L	1.000	U					
1,2,4-Trichlorobenzene	ug/L	1.000	U					
Hexachlorobutadiene	ug/L	1.000	U					
Naphthalene	ug/L	1.000	U					
1,2,3-Trichlorobenzene	ug/L	1.000	U					

QUALITY CONTROL RESULTS

Job Number.: 239396

Report Date.: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

Test Method.....: 8260B
Method Description.: Volatile Organics

Equipment Code....: GCL2
Batch.....: 158909

Analyst...: jdn

LCS	Laboratory Control Sample	V05H310SA	158908-002		08/31/2005	1027
-----	---------------------------	-----------	------------	--	------------	------

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits	F
Dichlorodifluoromethane	ug/L	29.481		25.000	1.000	U 118	% 24-171	
Chloromethane	ug/L	27.337		25.000	1.000	U 109	% 31-182	
Vinyl chloride	ug/L	23.439		25.000	1.000	U 94	% 52-134	
Bromomethane	ug/L	29.966		25.000	1.000	U 120	% 31-188	
Chloroethane	ug/L	28.975		25.000	1.000	U 116	% 58-148	
Trichlorofluoromethane	ug/L	26.665		25.000	1.000	U 107	% 54-142	
1,1-Dichloroethene	ug/L	25.601		25.000	1.000	U 102	% 51-136	
Carbon disulfide	ug/L	16.462		25.000	5.000	U 66	% 21-111	
Acetone	ug/L	22.593		25.000	5.000	U 90	% 14-177	
Methylene chloride	ug/L	26.503		25.000	1.000	U 106	% 64-127	
trans-1,2-Dichloroethene	ug/L	23.955		25.000	1.000	U 96	% 62-138	
Methyl-tert-butyl-ether (MTBE)	ug/L	25.841		25.000	1.000	U 103	% 55-142	
1,1-Dichloroethane	ug/L	23.799		25.000	1.000	U 95	% 70-124	
2,2-Dichloropropane	ug/L	25.245		25.000	1.000	U 101	% 68-127	
cis-1,2-Dichloroethene	ug/L	24.735		25.000	1.000	U 99	% 76-125	
2-Butanone (MEK)	ug/L	25.665		25.000	5.000	U 103	% 29-139	
Bromochloromethane	ug/L	27.588		25.000	1.000	U 110	% 57-116	
Chloroform	ug/L	25.347		25.000	1.000	U 101	% 75-122	
1,1,1-Trichloroethane	ug/L	26.014		25.000	1.000	U 104	% 70-127	
1,1-Dichloropropene	ug/L	23.469		25.000	1.000	U 94	% 70-125	
Carbon tetrachloride	ug/L	25.192		25.000	1.000	U 101	% 64-132	
Benzene	ug/L	22.903		25.000	1.000	U 92	% 75-122	
1,2-Dichloroethane	ug/L	23.119		25.000	1.000	U 92	% 67-120	
Trichloroethene	ug/L	22.519		25.000	1.000	U 90	% 75-124	
1,2-Dichloropropane	ug/L	22.746		25.000	1.000	U 91	% 76-116	
Dibromomethane	ug/L	23.727		25.000	1.000	U 95	% 68-116	
Bromodichloromethane	ug/L	25.923		25.000	1.000	U 104	% 75-125	
cis-1,3-Dichloropropene	ug/L	22.786		26.000	1.000	U 88	% 72-115	
4-Methyl-2-pentanone (MIBK)	ug/L	21.574		25.000	5.000	U 86	% 39-137	
Toluene	ug/L	23.175		25.000	1.000	U 93	% 77-120	
trans-1,3-Dichloropropene	ug/L	21.351		24.000	1.000	U 89	% 68-119	
1,1,2-Trichloroethane	ug/L	24.805		25.000	1.000	U 99	% 63-127	
Tetrachloroethene	ug/L	22.210		25.000	1.000	U 89	% 70-125	
1,3-Dichloropropane	ug/L	22.377		25.000	1.000	U 90	% 72-118	
2-Hexanone	ug/L	21.003		25.000	5.000	U 84	% 36-144	
Dibromochloromethane	ug/L	24.451		25.000	1.000	U 98	% 73-116	
1,2-Dibromoethane (EDB)	ug/L	22.747		25.000	1.000	U 91	% 62-123	
Chlorobenzene	ug/L	22.299		25.000	1.000	U 89	% 76-116	
1,1,1,2-Tetrachloroethane	ug/L	24.916		25.000	1.000	U 100	% 77-120	
Ethylbenzene	ug/L	21.812		25.000	1.000	U 87	% 75-125	
m&p-Xylenes	ug/L	42.582		50.000	2.000	U 85	% 75-123	
o-Xylene	ug/L	21.772		25.000	1.000	U 87	% 76-121	
Styrene	ug/L	22.390		25.000	1.000	U 90	% 77-128	
Bromoform	ug/L	21.962		25.000	1.000	U 88	% 65-115	
Isopropylbenzene	ug/L	20.265		25.000	1.000	U 81	% 64-119	
Bromobenzene	ug/L	22.102		25.000	1.000	U 88	% 76-118	
1,1,2,2-Tetrachloroethane	ug/L	21.535		25.000	1.000	U 86	% 61-122	
1,2,3-Trichloropropane	ug/L	21.265		25.000	1.000	U 85	% 62-124	
n-Propylbenzene	ug/L	21.831		25.000	1.000	U 87	% 69-132	
2-Chlorotoluene	ug/L	20.849		25.000	1.000	U 83	% 70-127	

Job Number.: Z39396

QUALITY CONTROL RESULTS

Report Date.: 09/30/2005

CUSTOMER: Weston Solutions, Inc.		PROJECT: BLACK AND DECKER		ATTN: Tom Cornuet	
QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date Time
LCS	Laboratory Control Sample	V05H31DSA	158908-002		08/31/2005 1027

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	*	Limits	F
1,3,5-Trimethylbenzene	ug/L	20.934		25.000	1.000	U 84	%	70-132	
4-Chlorotoluene	ug/L	21.015		25.000	1.000	U 84	%	70-126	
tert-Butylbenzene	ug/L	22.411		25.000	1.000	U 90	%	70-133	
1,2,4-Trimethylbenzene	ug/L	22.059		25.000	1.000	U 88	%	71-131	
sec-Butylbenzene	ug/L	22.305		25.000	1.000	U 89	%	70-134	
1,3-Dichlorobenzene	ug/L	22.356		25.000	1.000	U 89	%	71-120	
p-Isopropyltoluene	ug/L	21.895		25.000	1.000	U 88	%	66-130	
1,4-Dichlorobenzene	ug/L	22.312		25.000	1.000	U 89	%	70-118	
n-Butylbenzene	ug/L	23.385		25.000	1.000	U 94	%	64-142	
1,2-Dichlorobenzene	ug/L	22.509		25.000	1.000	U 90	%	72-118	
1,2-Dibromo-3-chloropropane	ug/L	22.038		25.000	1.000	U 88	%	57-119	
1,2,4-Trichlorobenzene	ug/L	22.700		25.000	1.000	U 91	%	60-132	
Hexachlorobutadiene	ug/L	24.984		25.000	1.000	U 100	%	63-145	
Naphthalene	ug/L	23.355		25.000	1.000	U 93	%	57-128	
1,2,3-Trichlorobenzene	ug/L	23.029		25.000	1.000	U 92	%	66-124	

QUALITY CONTROL RESULTS

Job Number.: 239396

Report Date.: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

Test Method.....: 8260B

Equipment Code.....: GCL2

Analyst....: jdn

Method Description.: Volatile Organics

Batch.....: 158909

MB	Method Blank	158908-001	08/31/2005	0914
----	--------------	------------	------------	------

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits	F
Dichlorodifluoromethane	ug/L	1.000	U					
Chloromethane	ug/L	1.000	U					
Vinyl chloride	ug/L	1.000	U					
Bromomethane	ug/L	1.000	U					
Chloroethane	ug/L	1.000	U					
Trichlorofluoromethane	ug/L	1.000	U					
1,1-Dichloroethene	ug/L	1.000	U					
Carbon disulfide	ug/L	5.000	U					
Acetone	ug/L	5.000	U					
Methylene chloride	ug/L	1.000	U					
trans-1,2-Dichloroethene	ug/L	1.000	U					
Methyl-tert-butyl-ether (MTBE)	ug/L	1.000	U					
1,1-Dichloroethane	ug/L	1.000	U					
2,2-Dichloropropane	ug/L	1.000	U					
cis-1,2-Dichloroethene	ug/L	1.000	U					
2-Butanone (MEK)	ug/L	5.000	U					
Bromochloromethane	ug/L	1.000	U					
Chloroform	ug/L	1.000	U					
1,1,1-Trichloroethane	ug/L	1.000	U					
1,1-Dichloropropene	ug/L	1.000	U					
Carbon tetrachloride	ug/L	1.000	U					
Benzene	ug/L	1.000	U					
1,2-Dichloroethane	ug/L	1.000	U					
Trichloroethene	ug/L	1.000	U					
1,2-Dichloropropane	ug/L	1.000	U					
Dibromomethane	ug/L	1.000	U					
Bromodichloromethane	ug/L	1.000	U					
cis-1,3-Dichloropropene	ug/L	1.000	U					
4-Methyl-2-pentanone (MIBK)	ug/L	5.000	U					
Toluene	ug/L	1.000	U					
trans-1,3-Dichloropropene	ug/L	1.000	U					
1,1,2-Trichloroethane	ug/L	1.000	U					
Tetrachloroethene	ug/L	1.000	U					
1,3-Dichloropropane	ug/L	1.000	U					
2-Hexanone	ug/L	5.000	U					
Dibromochloromethane	ug/L	1.000	U					
1,2-Dibromoethane (EDB)	ug/L	1.000	U					
Chlorobenzene	ug/L	1.000	U					
1,1,1,2-Tetrachloroethane	ug/L	1.000	U					
Ethylbenzene	ug/L	1.000	U					
m&p-Xylenes	ug/L	2.000	U					
o-Xylene	ug/L	1.000	U					
Styrene	ug/L	1.000	U					
Bromoform	ug/L	1.000	U					
Isopropylbenzene	ug/L	1.000	U					
Bromobenzene	ug/L	1.000	U					
1,1,2,2-Tetrachloroethane	ug/L	1.000	U					
1,2,3-Trichloropropane	ug/L	1.000	U					
n-Propylbenzene	ug/L	1.000	U					
2-Chlorotoluene	ug/L	1.000	U					

Job Number.: Z39396

QUALITY CONTROL RESULTS

Report Date.: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

NB	Method Blank		158908-001		08/31/2005	0914
----	--------------	--	------------	--	------------	------

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits	F
1,3,5-Trimethylbenzene	ug/L	1.000	U					
4-Chlorotoluene	ug/L	1.000	U					
tert-Butylbenzene	ug/L	1.000	U					
1,2,4-Trimethylbenzene	ug/L	1.000	U					
sec-Butylbenzene	ug/L	1.000	U					
1,3-Dichlorobenzene	ug/L	1.000	U					
p-Isopropyltoluene	ug/L	1.000	U					
1,4-Dichlorobenzene	ug/L	1.000	U					
n-Butylbenzene	ug/L	1.000	U					
1,2-Dichlorobenzene	ug/L	1.000	U					
1,2-Dibromo-3-chloropropane	ug/L	1.000	U					
1,2,4-Trichlorobenzene	ug/L	1.000	U					
Hexachlorobutadiene	ug/L	1.000	U					
Naphthalene	ug/L	1.000	U					
1,2,3-Trichlorobenzene	ug/L	1.000	U					

QUALITY CONTROL RESULTS

Job Number.: 239396 Report Date.: 09/30/2005

CUSTOMER: Neston Solutions, Inc. PROJECT: BLACK AND DECKER ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

Test Method.....: 8260B Equipment Code....: GCL2 Analyst...: jdn
 Method Description.: Volatile Organics Batch.....: 158913

LCS	Laboratory Control Sample	V05H310SA	158912-002		08/31/2005 2131
-----	---------------------------	-----------	------------	--	-----------------

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	*	Limits	F
Dichlorodifluoromethane	ug/L	30.042		25.000	1.000	U 120	%	24-171	
Chloromethane	ug/L	30.775		25.000	1.000	U 123	%	31-182	
Vinyl chloride	ug/L	25.724		25.000	1.000	U 103	%	52-134	
Bromomethane	ug/L	36.320		25.000	1.000	U 145	%	31-188	
Chloroethane	ug/L	31.884		25.000	1.000	U 128	%	58-148	
Trichlorofluoromethane	ug/L	28.195		25.000	1.000	U 113	%	54-142	
1,1-Dichloroethene	ug/L	25.532		25.000	1.000	U 102	%	51-136	
Carbon disulfide	ug/L	17.125		25.000	5.000	U 68	%	21-111	
Acetone	ug/L	26.007		25.000	5.000	U 104	%	14-177	
Methylene chloride	ug/L	27.988		25.000	1.000	U 112	%	64-127	
trans-1,2-Dichloroethene	ug/L	25.046		25.000	1.000	U 100	%	62-138	
Methyl-tert-butyl-ether (MTBE)	ug/L	25.685		25.000	1.000	U 103	%	55-142	
1,1-Dichloroethane	ug/L	25.933		25.000	1.000	U 104	%	70-124	
2,2-Dichloropropane	ug/L	26.005		25.000	1.000	U 104	%	68-127	
cis-1,2-Dichloroethene	ug/L	26.910		25.000	1.000	U 108	%	76-125	
2-Butanone (MEK)	ug/L	26.428		25.000	5.000	U 106	%	29-139	
Bromochloromethane	ug/L	27.282		25.000	1.000	U 109	%	57-116	
Chloroform	ug/L	27.278		25.000	1.000	U 109	%	75-122	
1,1,1-Trichloroethane	ug/L	28.294		25.000	1.000	U 113	%	70-127	
1,1-Dichloropropene	ug/L	24.504		25.000	1.000	U 98	%	70-125	
Carbon tetrachloride	ug/L	27.313		25.000	1.000	U 109	%	64-132	
Benzene	ug/L	24.851		25.000	1.000	U 99	%	75-122	
1,2-Dichloroethane	ug/L	25.478		25.000	1.000	U 102	%	67-120	
Trichloroethene	ug/L	24.427		25.000	1.000	U 98	%	75-124	
1,2-Dichloropropane	ug/L	24.958		25.000	1.000	U 100	%	76-116	
Dibromomethane	ug/L	26.398		25.000	1.000	U 106	%	68-116	
Bromodichloromethane	ug/L	27.829		25.000	1.000	U 111	%	75-125	
cis-1,3-Dichloropropene	ug/L	24.786		26.000	1.000	U 95	%	72-115	
4-Methyl-2-pentanone (MIBK)	ug/L	23.960		25.000	5.000	U 96	%	39-137	
Toluene	ug/L	24.374		25.000	1.000	U 97	%	77-120	
trans-1,3-Dichloropropene	ug/L	22.998		24.000	1.000	U 96	%	68-119	
1,1,2-Trichloroethane	ug/L	26.397		25.000	1.000	U 106	%	63-127	
Tetrachloroethene	ug/L	23.673		25.000	1.000	U 95	%	70-125	
1,3-Dichloropropane	ug/L	24.644		25.000	1.000	U 99	%	72-118	
2-Hexanone	ug/L	22.832		25.000	5.000	U 91	%	36-144	
Dibromochloromethane	ug/L	27.286		25.000	1.000	U 109	%	73-116	
1,2-Dibromoethane (EDB)	ug/L	24.630		25.000	1.000	U 99	%	62-123	
Chlorobenzene	ug/L	24.600		25.000	1.000	U 98	%	76-116	
1,1,1,2-Tetrachloroethane	ug/L	27.986		25.000	1.000	U 112	%	77-120	
Ethylbenzene	ug/L	24.199		25.000	1.000	U 97	%	75-125	
m&p-Xylenes	ug/L	47.187		50.000	2.000	U 94	%	75-123	
o-Xylene	ug/L	23.799		25.000	1.000	U 95	%	76-121	
Styrene	ug/L	24.769		25.000	1.000	U 99	%	77-128	
Bromoform	ug/L	24.401		25.000	1.000	U 98	%	65-115	
Isopropylbenzene	ug/L	21.963		25.000	1.000	U 88	%	64-119	
Bromobenzene	ug/L	24.774		25.000	1.000	U 99	%	76-118	
1,1,2,2-Tetrachloroethane	ug/L	24.576		25.000	1.000	U 98	%	61-122	
1,2,3-Trichloropropane	ug/L	25.856		25.000	1.000	U 103	%	62-124	
n-Propylbenzene	ug/L	23.383		25.000	1.000	U 94	%	69-132	
2-Chlorotoluene	ug/L	22.489		25.000	1.000	U 90	%	70-127	

QUALITY CONTROL RESULTS

Job Number.: 239396 Report Date.: 09/30/2005

CUSTOMER: Weston Solutions, Inc. PROJECT: BLACK AND DECKER ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

Test Method.....: 8260B Equipment Code....: GCL2 Analyst...: jdn
 Method Description.: Volatile Organics Batch.....: 158913

MB	Method Blank		158912-001		08/31/2005	2106
----	--------------	--	------------	--	------------	------

Parameter/Test Description	Units	QC Result	GC Result	True Value	Orig. Value	QC Calc.	* Limits
Dichlorodifluoromethane	ug/L	1.000	U				
Chloromethane	ug/L	1.000	U				
Vinyl chloride	ug/L	1.000	U				
Bromomethane	ug/L	1.000	U				
Chloroethane	ug/L	1.000	U				
Trichlorofluoromethane	ug/L	1.000	U				
1,1-Dichloroethene	ug/L	1.000	U				
Carbon disulfide	ug/L	5.000	U				
Acetone	ug/L	5.000	U				
Methylene chloride	ug/L	1.000	U				
trans-1,2-Dichloroethene	ug/L	1.000	U				
Methyl-tert-butyl-ether (MTBE)	ug/L	1.000	U				
1,1-Dichloroethane	ug/L	1.000	U				
2,2-Dichloropropane	ug/L	1.000	U				
cis-1,2-Dichloroethene	ug/L	1.000	U				
2-Butanone (MEK)	ug/L	5.000	U				
Bromochloromethane	ug/L	1.000	U				
Chloroform	ug/L	1.000	U				
1,1,1-Trichloroethane	ug/L	1.000	U				
1,1-Dichloropropene	ug/L	1.000	U				
Carbon tetrachloride	ug/L	1.000	U				
Benzene	ug/L	1.000	U				
1,2-Dichloroethane	ug/L	1.000	U				
Trichloroethene	ug/L	1.000	U				
1,2-Dichloropropane	ug/L	1.000	U				
Dibromomethane	ug/L	1.000	U				
Bromodichloromethane	ug/L	1.000	U				
cis-1,3-Dichloropropene	ug/L	1.000	U				
4-Methyl-2-pentanone (MIBK)	ug/L	5.000	U				
Toluene	ug/L	1.000	U				
trans-1,3-Dichloropropene	ug/L	1.000	U				
1,1,2-Trichloroethane	ug/L	1.000	U				
Tetrachloroethene	ug/L	1.000	U				
1,3-Dichloropropane	ug/L	1.000	U				
2-Hexanone	ug/L	5.000	U				
Dibromochloromethane	ug/L	1.000	U				
1,2-Dibromoethane (EDB)	ug/L	1.000	U				
Chlorobenzene	ug/L	1.000	U				
1,1,1,2-Tetrachloroethane	ug/L	1.000	U				
Ethylbenzene	ug/L	1.000	U				
m&p-Xylenes	ug/L	2.000	U				
o-Xylene	ug/L	1.000	U				
Styrene	ug/L	1.000	U				
Bromoform	ug/L	1.000	U				
Isopropylbenzene	ug/L	1.000	U				
Bromobenzene	ug/L	1.000	U				
1,1,2,2-Tetrachloroethane	ug/L	1.000	U				
1,2,3-Trichloropropane	ug/L	1.000	U				
n-Propylbenzene	ug/L	1.000	U				
2-Chlorotoluene	ug/L	1.000	U				

Job Number.: 239396		QUALITY CONTROL RESULTS			Report Date.: 09/30/2005	
CUSTOMER: Neston Solutions, Inc.		PROJECT: BLACK AND DECKER		ATTN: Tom Cornuet		
QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
MB	Method Blank		158912-001		08/31/2005	2106

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits	F
1,3,5-Trimethylbenzene	ug/L	1.000	U					
4-Chlorotoluene	ug/L	1.000	U					
tert-Butylbenzene	ug/L	1.000	U					
1,2,4-Trimethylbenzene	ug/L	1.000	U					
sec-Butylbenzene	ug/L	1.000	U					
1,3-Dichlorobenzene	ug/L	1.000	U					
p-Isopropyltoluene	ug/L	1.000	U					
1,4-Dichlorobenzene	ug/L	1.000	U					
n-Butylbenzene	ug/L	1.000	U					
1,2-Dichlorobenzene	ug/L	1.000	U					
1,2-Dibromo-3-chloropropane	ug/L	1.000	U					
1,2,4-Trichlorobenzene	ug/L	1.000	U					
Hexachlorobutadiene	ug/L	1.000	U					
Naphthalene	ug/L	1.000	U					
1,2,3-Trichlorobenzene	ug/L	1.000	U					

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

Report Date: 09/30/2005

REPORT COMMENTS

- 1) All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.
- 2) Soil, sediment and sludge sample results are reported on a "dry weight" basis except when analyzed for landfill disposal or incineration parameters. All other solid matrix samples are reported on an "as received" basis unless noted differently.
- 3) Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.
- 4) The test results for the noted analytical method(s) meet the requirements of NELAC. Lab Cert. ID# 100201
- 5) According to 40CFR Part 136.3, pH, Chlorine Residual and Dissolved Oxygen analyses are to be performed immediately after aqueous sample collection. When these parameters are not indicated as field (e.g. pH Field) they were not analyzed immediately, but as soon as possible on laboratory receipt.

Glossary of flags, qualifiers and abbreviations (any number of which may appear in the report)

Inorganic Qualifiers (Q-Column)

- U Analyte was not detected at or above the stated limit.
- < Not detected at or above the reporting limit.
- J Result is less than the RL, but greater than or equal to the method detection limit.
- B Result is less than the CRDL/RL, but greater than or equal to the IDL/MDL.
- S Result was determined by the Method of Standard Additions.
- F AFCEE: Result is less than the RL, but greater than or equal to the method detection limit.

Inorganic Flags (Flag Column)

- ICV,CCV,ICB,CCB,ISA,ISB,CRI,CRA,MRL: Instrument related QC exceed the upper or lower control limits.
 - * LCS, LCD, MD: Batch QC exceeds the upper or lower control limits.
 - + MSA correlation coefficient is less than 0.995.
 - 4 MS, MSD: The analyte present in the original sample is 4 times greater than the matrix spike concentration; therefore, control limits are not applicable.
 - E SD: Serial dilution exceeds the control limits.
 - H MB, EB1, EB2, EB3: Batch QC is greater than reporting limit or had a negative instrument reading lower than the absolute value of the reporting limit.
 - N MS, MSD: Spike recovery exceeds the upper or lower control limits.
 - W AS(GFAA) Post-digestion spike was outside 85-115% control limits.
- Organic Qualifiers (Q - Column)
- U Analyte was not detected at or above the stated limit.
 - ND Compound not detected.
 - J Result is an estimated value below the reporting limit or a tentatively identified compound (TIC).
 - Q Result was qualitatively confirmed, but not quantified.
 - C Pesticide identification was confirmed by GC/MS.
 - Y The chromatographic response resembles a typical fuel pattern.
 - Z The chromatographic response does not resemble a typical fuel pattern.
 - E Result exceeded calibration range, secondary dilution required.
 - F AFCEE: Result is an estimated value below the reporting limit or a tentatively identified compound (TIC)

Organic Flags (Flags Column)

- B MB: Batch QC is greater than reporting limit.
- * LCS, LCD, ELC, ELD, CV, MS, MSD, Surrogate: Batch QC exceeds the upper or lower control limits.
- EB1, EB2, EB3, MLE: Batch QC is greater than reporting limit
- A Concentration exceeds the instrument calibration range
- a Concentration is below the method Reporting Limit (RL)
- B Compound was found in the blank and sample.
- D Surrogate or matrix spike recoveries were not obtained because the extract was diluted for analysis; also compounds analyzed at a dilution will be flagged with a D.
- H Alternate peak selection upon analytical review
- I Indicates the presence of an interference, recovery is not calculated.
- M Manually integrated compound.
- P The lower of the two values is reported when the % difference between the results of two GC columns is

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

Report Date: 09/30/2005

greater than 25%.

Abbreviations

AS	Post Digestion Spike (GFAA Samples - See Note 1 below)
Batch	Designation given to identify a specific extraction, digestion, preparation set, or analysis set
CAP	Capillary Column CCB Continuing Calibration Blank
CCV	Continuing Calibration Verification
CF	Confirmation analysis of original
C1	Confirmation analysis of A1 or D1
C2	Confirmation analysis of A2 or D2
C3	Confirmation analysis of A3 or D3
CRA	Low Level Standard Check - GFAA; Mercury
CRI	Low Level Standard Check - ICP
CV	Calibration Verification Standard
Dil Fac	Dilution Factor - Secondary dilution analysis
D1	Dilution 1
D2	Dilution 2
D3	Dilution 3
DLFac	Detection Limit Factor
DSH	Distilled Standard - High Level
DSL	Distilled Standard - Low Level
DSM	Distilled Standard - Medium Level
EB1	Extraction Blank 1
EB2	Extraction Blank 2
EB3	D1 Blank
ELC	Method Extracted LCS
ELD	Method Extracted LCD
ICAL	Initial calibration
ICB	Initial Calibration Blank
ICV	Initial Calibration Verification
IDL	Instrument Detection Limit
ISA	Interference Check Sample A - ICAP
ISB	Interference Check Sample B - ICAP
Job No.	The first six digits of the sample ID which refers to a specific client, project and sample group Lab ID An 8 number unique laboratory identification
LCD	Laboratory Control Standard Duplicate
LCS	Laboratory Control Standard with reagent grade water or a matrix free from the analyte of interest
MB	Method Blank or (PB) Preparation Blank
MD	Method Duplicate
MDL	Method Detection Limit
MLE	Medium Level Extraction Blank
MRL	Method Reporting Limit Standard
MSA	Method of Standard Additions
MS	Matrix Spike
MSD	Matrix Spike Duplicate
ND	Not Detected
PREPF	Preparation factor used by the Laboratory's Information Management System (LIMS)
PDS	Post Digestion Spike (ICAP)
RA	Re-analysis of original
A1	Re-analysis of D1
A2	Re-analysis of D2
A3	Re-analysis of D3
RD	Re-extraction of dilution
RE	Re-extraction of original
RC	Re-extraction Confirmation
RL	Reporting Limit
RPD	Relative Percent Difference of duplicate (unrounded) analyses
RRF	Relative Response Factor
RT	Retention Time

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

Report Date: 09/30/2005

RTW Retention Time Window Sample ID A 9 digit number unique for each sample, the first six digits are referred as the job number
SCB Seeded Control Blank
SD Serial Dilution (Calculated when sample concentration exceeds 50 times the MDL)
UCB Unseeded Control Blank
SSV Second Source Verification Standard
SLCS Solid Laboratory Control Standard(LCS)
PHC pH Calibration Check LCSP pH Laboratory Control Sample
LCDP pH Laboratory Control Sample Duplicate
MDPH pH Sample Duplicate
MDFP Flashpoint Sample Duplicate
LCFP Flashpoint LCS
G1 Gelex Check Standard Range 0-1
G2 Gelex Check Standard Range 1-10
G3 Gelex Check Standard Range 10-100
G4 Gelex Check Standard Range 100-1000

Note 1: The Post Spike Designation on Batch QC for GFAA is designated with an "S" added to the current abbreviation used. EX. LCS S=LCS Post Spike (GFAA); MSS=MS Post Spike (GFAA)

Note 2: The MD calculates an absolute difference (A) when the sample concentration is less than 5 times the reporting limit. The control limit is represented as +/- the RL.

**SEVERN
TRENT** **STL**

STL Chicago
2417 Bond Street
University Park, IL 60466
Phone: 708-534-5200
Fax: 708-534-5211

Report To:

Contact: Tom Cornuet
Company: Waste
Address: _____
Phone: (610) 701-7360
Fax: _____
E-Mail: _____

BIR To:

Contact: _____
Company: _____
Address: _____
Phone: _____
Fax: _____
PO#: _____ Quote: _____

Shaded Areas For Internal Use Only 3 of 3

Lab Lot# 239396

Package Sealed Yes No	Samples Sealed Yes No
Revised on file Yes No	Samples Intact Yes No
Temperature °C of Cooler <u>5.0</u>	
White Field True Yes No NA	Probers Indicated Yes No NA
Oil Check OK Yes No NA	Res Cl. Check OK Yes No NA
Sample Labels and CDC Agree Yes No <u>CDC not present</u>	

Sampler Name: _____ Signature: _____

Project Name: Black + Decker

Project Number: _____

Project Location: Hampstead MD
Lab P/N: Dick Wright

Date Required: _____
Hard Copy: / /
Fax: / /

Lab No	Client Sample ID	Sampling		Matrix	Comp/Grab	Analysis														
		Date	Time			1	2	3	4	5	6	7	8	9	10					
<u>25</u>	<u>EW-6</u>	<u>8-18-05</u>	<u>1340</u>		<u>V</u>															
<u>26</u>	<u>EW-7</u>	<u> / / </u>	<u>1345</u>		<u>A</u>															
<u>27</u>	<u>EW-8</u>	<u> / / </u>	<u>1400</u>																	
<u>28</u>	<u>EW-9</u>	<u> / / </u>	<u>1405</u>																	
<u>29</u>	<u>EW-10</u>	<u>8-19-05</u>	<u>820</u>																	

Additional Analyses / Remarks

REQUISITIONED BY: [Signature] COMPANY: Waste DATE: 8/19/05 TIME: 1:00

RECEIVED BY: [Signature] COMPANY: STL DATE: 8-20-05 TIME: 0900

- Matrix Key**
- WW - Wastewater
 - W - Water
 - S - Soil
 - SL - Sludge
 - MS - Miscellaneous
 - OL - Oil
 - A - Air

- Container Key**
- SE - Sediment
 - SO - Solid
 - DS - Drum Solid
 - DL - Drum Liquid
 - L - Leachate
 - WI - Wipe
 - O - _____

- Preservative Key**
1. Plastic
 2. VOA Vial
 3. Sterile Plastic
 4. Amber Glass
 5. Wide-mouth Glass
 6. Other

- Preservative Key**
1. HCl, Cool to 4°
 2. H2SO4, Cool to 4°
 3. HNO3, Cool to 4°
 4. NaOH, Cool to 4°
 5. NaOH/Zn, Cool to 4°
 6. Cool to 4°
 7. None

COMMENTS

Date Received: / /
Counter: _____ Hand Delivered
BHI of Lading

SEVERN
TRENT

STL

STL Chicago
2417 Bond Street
University Park, IL 60466

Tel: 708 534 5200 Fax: 708 534 5211
www.stl-inc.com

SEVERN TRENT LABORATORIES
ANALYTICAL REPORT

JOB NUMBER: 239395

Prepared For:

Weston Solutions, Inc.
Building 5-2
1400 Weston Way
West Chester, PA 19380-1499

Project: Black & Decker

Attention: Tom Cornuet

Date: 09/30/2005

Signature

Name: Richard C. Wright

Title: Project Manager

E-Mail: rwright@stl-inc.com

Date

9/30/05
STL Chicago
2417 Bond Street
University Park, IL 60466

PHONE: (708) 534-5200
FAX...: (708) 534-5211

This Report Contains (20) Pages

ANALYTICAL REPORT


Job Number: 680-7314-1

Job Description: 239395 - Weston / Black & Decker

For:

Severn Trent Laboratories, Inc.
2417 Bond Street
University, IL 60466

Attention: Mr. Richard Wright



Bernard Kirkland
Project Manager I
bkirkland@stl-inc.com
09/30/2005

METHOD SUMMARY

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Description	Lab Location	Method	Preparation Method
Matrix: Water			
Purgeable Organic Compounds in Water by GC/MS	STL-SAV	EPA-DW	524.2

LAB REFERENCES:

STL-SAV = STL-Savannah

METHOD REFERENCES:

EPA-DW - "Methods For The Determination Of Organic Compounds In Drinking Water", EPA/600/4-88/039, December 1988 And Its Supplements.

SAMPLE SUMMARY

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

<u>Lab Sample ID</u>	<u>Client Sample ID</u>	<u>Client Matrix</u>	<u>Date/Time Sampled</u>	<u>Date/Time Received</u>
680-7314-1	RFW-20	Water	08/19/2005 0930	08/23/2005 0914
680-7314-2	RFW-21	Water	08/18/2005 1145	08/23/2005 0914
680-7314-3	Hamp-22	Water	08/19/2005 0910	08/23/2005 0914
680-7314-4	Hamp-23	Water	08/19/2005 0920	08/23/2005 0914

Analytical Data

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Client Sample ID: RFW-20

Lab Sample ID: 680-7314-1

Client Matrix: Water

Date Sampled: 08/19/2005 0930

Date Received: 08/23/2005 0914

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-21051

Instrument ID: GC/MS Volatiles - S

Preparation: N/A

Lab File ID: s8445.d

Dilution: 1.0

Initial Weight/Volume: mL

Date Analyzed: 09/01/2005 0835

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	RL
Acetone	<10		10
Benzene	<0.50		0.50
Bromobenzene	<0.50		0.50
Bromoform	<0.50		0.50
Bromomethane	<1.0		1.0
Carbon tetrachloride	<0.50		0.50
Chlorobenzene	<0.50		0.50
Chlorobromomethane	<0.50		0.50
Chlorodibromomethane	<0.50		0.50
Chloroethane	<1.0		1.0
Chloroform	<0.50		0.50
Chloromethane	<0.50		0.50
2-Chlorotoluene	<0.50		0.50
4-Chlorotoluene	<0.50		0.50
cis-1,2-Dichloroethene	<0.50		0.50
cis-1,3-Dichloropropene	<0.50		0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.50
Dibromomethane	<0.50		0.50
1,2-Dichlorobenzene	<0.50		0.50
1,4-Dichlorobenzene	<0.50		0.50
1,3-Dichlorobenzene	<0.50		0.50
Dichlorobromomethane	<0.50		0.50
Dichlorodifluoromethane	<0.50		0.50
1,2-Dichloroethane	<0.50		0.50
1,1-Dichloroethane	<0.50		0.50
1,1-Dichloroethene	<0.50		0.50
1,2-Dichloropropane	<0.50		0.50
1,3-Dichloropropane	<0.50		0.50
2,2-Dichloropropane	<0.50		0.50
1,1-Dichloropropene	<0.50		0.50
1,3-Dichloropropene, Total	<0.50		0.50
Diisopropyl ether	<0.50		0.50
Ethylbenzene	<0.50		0.50
Ethylene Dibromide	<0.50		0.50
Freon 113	<0.50		0.50
Hexachlorobutadiene	<0.50		0.50
2-Hexanone	<10		10
Isopropylbenzene	<0.50		0.50
4-Isopropyltoluene	<0.50		0.50
Methylene Chloride	<0.50		0.50
Methyl Ethyl Ketone	<10		10
methyl isobutyl ketone	<10		10
m-Xylene & p-Xylene	<0.50		0.50

Analytical Data

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Client Sample ID: RFW-20

Lab Sample ID: 680-7314-1

Date Sampled: 08/19/2005 0930

Client Matrix: Water

Date Received: 08/23/2005 0914

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch: 680-21051	Instrument ID: GC/MS Volatiles - S
Preparation:	N/A		Lab File ID: s8445.d
Dilution:	1.0		Initial Weight/Volume: mL
Date Analyzed:	09/01/2005 0835		Final Weight/Volume: 5 mL
Date Prepared:	N/A		

Analyte	Result (ug/L)	Qualifier	RL
Naphthalene	<1.0		1.0
n-Butylbenzene	<0.50		0.50
N-Propylbenzene	<0.50		0.50
o-Xylene	<0.50		0.50
sec-Butylbenzene	<0.50		0.50
Styrene	<0.50		0.50
Tert-amyl methyl ether	<0.50		0.50
tert-Butylbenzene	<0.50		0.50
Tert-butyl ethyl ether	<0.50		0.50
1,1,1,2-Tetrachloroethane	<0.50		0.50
1,1,2,2-Tetrachloroethane	<0.50		0.50
Tetrachloroethene	<0.50		0.50
Toluene	<0.50		0.50
trans-1,2-Dichloroethene	<0.50		0.50
trans-1,3-Dichloropropene	<0.50		0.50
1,2,4-Trichlorobenzene	<0.50		0.50
1,2,3-Trichlorobenzene	<0.50		0.50
1,1,1-Trichloroethane	<0.50		0.50
1,1,2-Trichloroethane	<0.50		0.50
Trichloroethene	1.5		0.50
Trichlorofluoromethane	<0.50		0.50
1,2,3-Trichloropropane	<0.50		0.50
1,2,4-Trimethylbenzene	<0.50		0.50
1,3,5-Trimethylbenzene	<0.50		0.50
Vinyl chloride	<0.50		0.50
Xylenes, Total	<0.50		0.50
Surrogate	%Rec		Acceptance Limits
4-Bromofluorobenzene	73		70 - 130
1,2-Dichlorobenzene-d4	71		70 - 130

Analytical Data

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Client Sample ID: RFW-21

Lab Sample ID: 680-7314-2

Client Matrix: Water

Date Sampled: 08/18/2005 1145

Date Received: 08/23/2005 0914

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-21051

Instrument ID: GC/MS Volatiles - S

Preparation: N/A

Lab File ID: s8446.d

Dilution: 1.0

Initial Weight/Volume: mL

Date Analyzed: 09/01/2005 0856

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	RL
Acetone	<10		10
Benzene	<0.50		0.50
Bromobenzene	<0.50		0.50
Bromoform	<0.50		0.50
Bromomethane	<1.0		1.0
Carbon tetrachloride	<0.50		0.50
Chlorobenzene	<0.50		0.50
Chlorobromomethane	<0.50		0.50
Chlorodibromomethane	<0.50		0.50
Chloroethane	<1.0		1.0
Chloroform	<0.50		0.50
Chloromethane	<0.50		0.50
2-Chlorotoluene	<0.50		0.50
4-Chlorotoluene	<0.50		0.50
cis-1,2-Dichloroethene	<0.50		0.50
cis-1,3-Dichloropropene	<0.50		0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.50
Dibromomethane	<0.50		0.50
1,2-Dichlorobenzene	<0.50		0.50
1,4-Dichlorobenzene	<0.50		0.50
1,3-Dichlorobenzene	<0.50		0.50
Dichlorodibromomethane	<0.50		0.50
Dichlorodifluoromethane	<0.50		0.50
1,2-Dichloroethane	<0.50		0.50
1,1-Dichloroethane	<0.50		0.50
1,1-Dichloroethene	<0.50		0.50
1,2-Dichloropropane	<0.50		0.50
1,3-Dichloropropane	<0.50		0.50
2,2-Dichloropropane	<0.50		0.50
1,1-Dichloropropene	<0.50		0.50
1,3-Dichloropropene, Total	<0.50		0.50
Diisopropyl ether	<0.50		0.50
Ethylbenzene	<0.50		0.50
Ethylene Dibromide	<0.50		0.50
Freon 113	<0.50		0.50
Hexachlorobutadiene	<0.50		0.50
2-Hexanone	<10		10
Isopropylbenzene	<0.50		0.50
4-Isopropyltoluene	<0.50		0.50
Methylene Chloride	<0.50		0.50
Methyl Ethyl Ketone	<10		10
methyl isobutyl ketone	<10		10
m-Xylene & p-Xylene	<0.50		0.50

Analytical Data

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Client Sample ID: RFW-21

Lab Sample ID: 680-7314-2

Date Sampled: 08/18/2005 1145

Client Matrix: Water

Date Received: 08/23/2005 0914

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch:	680-21051	Instrument ID:	GC/MS Volatiles - S
Preparation:	N/A			Lab File ID:	s8446.d
Dilution:	1.0			Initial Weight/Volume:	mL
Date Analyzed:	09/01/2005 0856			Final Weight/Volume:	5 mL
Date Prepared:	N/A				

Analyte	Result (ug/L)	Qualifier	RL
Naphthalene	<1.0		1.0
n-Butylbenzene	<0.50		0.50
N-Propylbenzene	<0.50		0.50
o-Xylene	<0.50		0.50
sec-Butylbenzene	<0.50		0.50
Styrene	<0.50		0.50
Tert-amyl methyl ether	<0.50		0.50
tert-Butylbenzene	<0.50		0.50
Tert-butyl ethyl ether	<0.50		0.50
1,1,1,2-Tetrachloroethane	<0.50		0.50
1,1,2,2-Tetrachloroethane	<0.50		0.50
Tetrachloroethene	<0.50		0.50
Toluene	<0.50		0.50
trans-1,2-Dichloroethene	<0.50		0.50
trans-1,3-Dichloropropene	<0.50		0.50
1,2,4-Trichlorobenzene	<0.50		0.50
1,2,3-Trichlorobenzene	<0.50		0.50
1,1,1-Trichloroethane	<0.50		0.50
1,1,2-Trichloroethane	<0.50		0.50
Trichloroethene	<0.50		0.50
Trichlorofluoromethane	<0.50		0.50
1,2,3-Trichloropropane	<0.50		0.50
1,2,4-Trimethylbenzene	<0.50		0.50
1,3,5-Trimethylbenzene	<0.50		0.50
Vinyl chloride	<0.50		0.50
Xylenes, Total	<0.50		0.50
Surrogate	%Rec	Acceptance Limits	
4-Bromofluorobenzene	74	70 - 130	
1,2-Dichlorobenzene-d4	75	70 - 130	

Analytical Data

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Client Sample ID: Hamp-22

Lab Sample ID: 680-7314-3

Date Sampled: 08/19/2005 0910

Client Matrix: Water

Date Received: 08/23/2005 0914

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch: 680-20866	Instrument ID: GC/MS Volatiles - S
Preparation:	N/A		Lab File ID: s8456.d
Dilution:	1.0		Initial Weight/Volume: mL
Date Analyzed:	09/01/2005 1512		Final Weight/Volume: 5 mL
Date Prepared:	N/A		

Analyte	Result (ug/L)	Qualifier	RL
Acetone	<10		10
Benzene	<0.50		0.50
Bromobenzene	<0.50		0.50
Bromoform	<0.50		0.50
Bromomethane	<1.0		1.0
Carbon tetrachloride	<0.50		0.50
Chlorobenzene	<0.50		0.50
Chlorobromomethane	<0.50		0.50
Chlorodibromomethane	<0.50		0.50
Chloroethane	<1.0		1.0
Chloroform	<0.50		0.50
Chloromethane	<0.50		0.50
2-Chlorotoluene	<0.50		0.50
4-Chlorotoluene	<0.50		0.50
cis-1,2-Dichloroethene	<0.50		0.50
cis-1,3-Dichloropropene	<0.50		0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.50
Dibromomethane	<0.50		0.50
1,2-Dichlorobenzene	<0.50		0.50
1,4-Dichlorobenzene	<0.50		0.50
1,3-Dichlorobenzene	<0.50		0.50
Dichlorobromomethane	<0.50		0.50
Dichlorodifluoromethane	<0.50		0.50
1,2-Dichloroethane	<0.50		0.50
1,1-Dichloroethane	<0.50		0.50
1,1-Dichloroethene	<0.50		0.50
1,2-Dichloropropane	<0.50		0.50
1,3-Dichloropropane	<0.50		0.50
2,2-Dichloropropane	<0.50		0.50
1,1-Dichloropropene	<0.50		0.50
1,3-Dichloropropene, Total	Err		0.50
Diisopropyl ether	<0.50		0.50
Ethylbenzene	<0.50		0.50
Ethylene Dibromide	<0.50		0.50
Freon 113	<0.50		0.50
Hexachlorobutadiene	<0.50		0.50
2-Hexanone	<10		10
Isopropylbenzene	<0.50		0.50
4-Isopropyltoluene	<0.50		0.50
Methylene Chloride	<0.50		0.50
Methyl Ethyl Ketone	<10		10
methyl isobutyl ketone	<10		10
m-Xylene & p-Xylene	<0.50		0.50

Analytical Data

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Client Sample ID: Hamp-22

Lab Sample ID: 680-7314-3

Date Sampled: 08/19/2005 0910

Client Matrix: Water

Date Received: 08/23/2005 0914

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch: 680-20866	Instrument ID: GC/MS Volatiles - S
Preparation:	N/A		Lab File ID: s8456.d
Dilution:	1.0		Initial Weight/Volume: mL
Date Analyzed:	09/01/2005 1512		Final Weight/Volume: 5 mL
Date Prepared:	N/A		

Analyte	Result (ug/L)	Qualifier	RL
Naphthalene	<1.0		1.0
n-Butylbenzene	<0.50		0.50
N-Propylbenzene	<0.50		0.50
o-Xylene	<0.50		0.50
sec-Butylbenzene	<0.50		0.50
Styrene	<0.50		0.50
Tert-amyl methyl ether	<0.50		0.50
tert-Butylbenzene	<0.50		0.50
Tert-butyl ethyl ether	<0.50		0.50
1,1,1,2-Tetrachloroethane	<0.50		0.50
1,1,2,2-Tetrachloroethane	<0.50		0.50
Tetrachloroethene	<0.50		0.50
Toluene	<0.50		0.50
trans-1,2-Dichloroethene	<0.50		0.50
trans-1,3-Dichloropropene	<0.50		0.50
1,2,4-Trichlorobenzene	<0.50		0.50
1,2,3-Trichlorobenzene	<0.50		0.50
1,1,1-Trichloroethane	<0.50		0.50
1,1,2-Trichloroethane	<0.50		0.50
Trichloroethene	<0.50		0.50
Trichlorofluoromethane	<0.50		0.50
1,2,3-Trichloropropane	<0.50		0.50
1,2,4-Trimethylbenzene	<0.50		0.50
1,3,5-Trimethylbenzene	<0.50		0.50
Vinyl chloride	<0.50		0.50
Xylenes, Total	<0.50		0.50

Surrogate	%Rec	Acceptance Limits
4-Bromofluorobenzene	83	70 - 130
1,2-Dichlorobenzene-d4	81	70 - 130

Analytical Data

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Client Sample ID: Hamp-23

Lab Sample ID: 680-7314-4

Date Sampled: 08/19/2005 0920

Client Matrix: Water

Date Received: 08/23/2005 0914

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-21051

Instrument ID: GC/MS Volatiles - S

Preparation: N/A

Lab File ID: s8448.d

Dilution: 1.0

Initial Weight/Volume: mL

Date Analyzed: 09/01/2005 0936

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	RL
Acetone	<10		10
Benzene	<0.50		0.50
Bromobenzene	<0.50		0.50
Bromoform	<0.50		0.50
Bromomethane	<1.0		1.0
Carbon tetrachloride	<0.50		0.50
Chlorobenzene	<0.50		0.50
Chlorobromomethane	<0.50		0.50
Chlorodibromomethane	<0.50		0.50
Chloroethane	<1.0		1.0
Chloroform	<0.50		0.50
Chloromethane	<0.50		0.50
2-Chlorotoluene	<0.50		0.50
4-Chlorotoluene	<0.50		0.50
cis-1,2-Dichloroethene	<0.50		0.50
cis-1,3-Dichloropropene	<0.50		0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.50
Dibromomethane	<0.50		0.50
1,2-Dichlorobenzene	<0.50		0.50
1,4-Dichlorobenzene	<0.50		0.50
1,3-Dichlorobenzene	<0.50		0.50
Dichlorobromomethane	<0.50		0.50
Dichlorodifluoromethane	<0.50		0.50
1,2-Dichloroethane	<0.50		0.50
1,1-Dichloroethane	<0.50		0.50
1,1-Dichloroethene	<0.50		0.50
1,2-Dichloropropane	<0.50		0.50
1,3-Dichloropropane	<0.50		0.50
2,2-Dichloropropane	<0.50		0.50
1,1-Dichloropropene	<0.50		0.50
1,3-Dichloropropene, Total	<0.50		0.50
Diisopropyl ether	<0.50		0.50
Ethylbenzene	<0.50		0.50
Ethylene Dibromide	<0.50		0.50
Freon 113	<0.50		0.50
Hexachlorobutadiene	<0.50		0.50
2-Hexanone	<10		10
Isopropylbenzene	<0.50		0.50
4-Isopropyltoluene	<0.50		0.50
Methylene Chloride	<0.50		0.50
Methyl Ethyl Ketone	<10		10
methyl isobutyl ketone	<10		10
m-Xylene & p-Xylene	<0.50		0.50

Analytical Data

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Client Sample ID: Hamp-23

Lab Sample ID: 680-7314-4

Date Sampled: 08/19/2005 0920

Client Matrix: Water

Date Received: 08/23/2005 0914

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch: 680-21051	Instrument ID: GC/MS Volatiles - S
Preparation:	N/A		Lab File ID: s8448.d
Dilution:	1.0		Initial Weight/Volume: mL
Date Analyzed:	09/01/2005 0936		Final Weight/Volume: 5 mL
Date Prepared:	N/A		

Analyte	Result (ug/L)	Qualifier	RL
Naphthalene	<1.0		1.0
n-Butylbenzene	<0.50		0.50
N-Propylbenzene	<0.50		0.50
o-Xylene	<0.50		0.50
sec-Butylbenzene	<0.50		0.50
Styrene	<0.50		0.50
Tert-amyl methyl ether	<0.50		0.50
tert-Butylbenzene	<0.50		0.50
Tert-butyl ethyl ether	<0.50		0.50
1,1,1,2-Tetrachloroethane	<0.50		0.50
1,1,2,2-Tetrachloroethane	<0.50		0.50
Tetrachloroethene	<0.50		0.50
Toluene	<0.50		0.50
trans-1,2-Dichloroethene	<0.50		0.50
trans-1,3-Dichloropropene	<0.50		0.50
1,2,4-Trichlorobenzene	<0.50		0.50
1,2,3-Trichlorobenzene	<0.50		0.50
1,1,1-Trichloroethane	<0.50		0.50
1,1,2-Trichloroethane	<0.50		0.50
Trichloroethene	<0.50		0.50
Trichlorofluoromethane	<0.50		0.50
1,2,3-Trichloropropane	<0.50		0.50
1,2,4-Trimethylbenzene	<0.50		0.50
1,3,5-Trimethylbenzene	<0.50		0.50
Vinyl chloride	<0.50		0.50
Xylenes, Total	<0.50		0.50
Surrogate	%Rec	Acceptance Limits	
4-Bromofluorobenzene	70	70 - 130	
1,2-Dichlorobenzene-d4	71	70 - 130	

DATA REPORTING QUALIFIERS

Lab Section	Qualifier	Description
-------------	-----------	-------------

Quality Control Results

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Method Blank - Batch: 680-20866

Method: 524.2
Preparation: N/A

Lab Sample ID: MB 680-20866/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/01/2005 1350
Date Prepared: N/A

Analysis Batch: 680-20866
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq589.d
Initial Weight/Volume: mL
Final Weight/Volume: 5 mL

Analyte	Result	Qual	RL
Acetone	<10		10
Benzene	<0.50		0.50
Bromobenzene	<0.50		0.50
Bromoform	<0.50		0.50
Bromomethane	<1.0		1.0
Carbon tetrachloride	<0.50		0.50
Chlorobenzene	<0.50		0.50
Chlorobromomethane	<0.50		0.50
Chlorodibromomethane	<0.50		0.50
Chloroethane	<1.0		1.0
Chloroform	<0.50		0.50
Chloromethane	<0.50		0.50
2-Chlorotoluene	<0.50		0.50
4-Chlorotoluene	<0.50		0.50
cis-1,2-Dichloroethene	<0.50		0.50
cis-1,3-Dichloropropene	<0.50		0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.50
Dibromomethane	<0.50		0.50
1,2-Dichlorobenzene	<0.50		0.50
1,4-Dichlorobenzene	<0.50		0.50
1,3-Dichlorobenzene	<0.50		0.50
Dichlorobromomethane	<0.50		0.50
Dichlorodifluoromethane	<0.50		0.50
1,2-Dichloroethane	<0.50		0.50
1,1-Dichloroethane	<0.50		0.50
1,1-Dichloroethene	<0.50		0.50
1,2-Dichloropropane	<0.50		0.50
1,3-Dichloropropane	<0.50		0.50
2,2-Dichloropropane	<0.50		0.50
1,1-Dichloropropene	<0.50		0.50
1,3-Dichloropropene, Total	Err		0.50
Diisopropyl ether	<0.50		0.50
Ethylbenzene	<0.50		0.50
Ethylene Dibromide	<0.50		0.50
Freon 113	<0.50		0.50
Hexachlorobutadiene	<0.50		0.50
2-Hexanone	<10		10
Isopropylbenzene	<0.50		0.50
4-Isopropyltoluene	<0.50		0.50
Methylene Chloride	<0.50		0.50
Methyl Ethyl Ketone	<10		10
methyl isobutyl ketone	<10		10

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Method Blank - Batch: 680-20866

Method: 524.2
Preparation: N/A

Lab Sample ID: MB 680-20866/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/01/2005 1350
Date Prepared: N/A

Analysis Batch: 680-20866
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq589.d
Initial Weight/Volume: mL
Final Weight/Volume: 5 mL

Analyte	Result	Qual	RL
m-Xylene & p-Xylene	<0.50		0.50
Naphthalene	<1.0		1.0
n-Butylbenzene	<0.50		0.50
N-Propylbenzene	<0.50		0.50
o-Xylene	<0.50		0.50
sec-Butylbenzene	<0.50		0.50
Styrene	<0.50		0.50
Tert-amyl methyl ether	<0.50		0.50
tert-Butylbenzene	<0.50		0.50
Tert-butyl ethyl ether	<0.50		0.50
1,1,1,2-Tetrachloroethane	<0.50		0.50
1,1,2,2-Tetrachloroethane	<0.50		0.50
Tetrachloroethene	<0.50		0.50
Toluene	<0.50		0.50
trans-1,2-Dichloroethene	<0.50		0.50
trans-1,3-Dichloropropene	<0.50		0.50
1,2,4-Trichlorobenzene	<0.50		0.50
1,2,3-Trichlorobenzene	<0.50		0.50
1,1,1-Trichloroethane	<0.50		0.50
1,1,2-Trichloroethane	<0.50		0.50
Trichloroethene	<0.50		0.50
Trichlorofluoromethane	<0.50		0.50
1,2,3-Trichloropropane	<0.50		0.50
1,2,4-Trimethylbenzene	<0.50		0.50
1,3,5-Trimethylbenzene	<0.50		0.50
Vinyl chloride	<0.50		0.50
Xylenes, Total	<0.50		0.50
Surrogate	% Rec	Acceptance Limits	
4-Bromofluorobenzene	80	70 - 130	
1,2-Dichlorobenzene-d4	77	70 - 130	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Laboratory Control Sample - Batch: 680-20866

Method: 524.2
Preparation: N/A

Lab Sample ID: LCS 680-20866/3
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/01/2005 1309
Date Prepared: N/A

Analysis Batch: 680-20866
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq587.d
Initial Weight/Volume: mL
Final Weight/Volume: 5 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	20.0	19	97	70 - 130	
Bromobenzene	20.0	17	85	70 - 130	
Bromoform	20.0	19	96	70 - 130	
Bromomethane	20.0	21	107	70 - 130	
Carbon tetrachloride	20.0	18	91	70 - 130	
Chlorobenzene	20.0	18	88	70 - 130	
Chlorobromomethane	20.0	21	104	70 - 130	
Chlorodibromomethane	20.0	19	94	70 - 130	
Chloroethane	20.0	15	75	70 - 130	
Chloroform	20.0	18	89	70 - 130	
Chloromethane	20.0	22	108	70 - 130	
2-Chlorotoluene	20.0	21	106	70 - 130	
4-Chlorotoluene	20.0	18	90	70 - 130	
cis-1,2-Dichloroethene	20.0	18	92	70 - 130	
cis-1,3-Dichloropropene	20.0	18	92	70 - 130	
1,2-Dibromo-3-Chloropropane	20.0	19	95	70 - 130	
Dibromomethane	20.0	19	94	70 - 130	
1,2-Dichlorobenzene	20.0	17	86	70 - 130	
1,4-Dichlorobenzene	20.0	16	82	70 - 130	
1,3-Dichlorobenzene	20.0	17	86	70 - 130	
Dichlorobromomethane	20.0	19	97	70 - 130	
Dichlorodifluoromethane	20.0	21	103	70 - 130	
1,2-Dichloroethane	20.0	18	90	70 - 130	
1,1-Dichloroethane	20.0	20	102	70 - 130	
1,1-Dichloroethene	20.0	20	102	70 - 130	
1,2-Dichloropropane	20.0	21	103	70 - 130	
1,3-Dichloropropane	20.0	19	96	70 - 130	
2,2-Dichloropropane	20.0	17	87	70 - 130	
1,1-Dichloropropene	20.0	18	92	70 - 130	
Ethylbenzene	20.0	19	96	70 - 130	
Ethylene Dibromide	20.0	18	90	70 - 130	
Hexachlorobutadiene	20.0	14	68	70 - 130	
Isopropylbenzene	20.0	19	95	70 - 130	
4-Isopropyltoluene	20.0	18	90	70 - 130	
Methylene Chloride	20.0	19	97	70 - 130	
m-Xylene & p-Xylene	40.0	38	96	70 - 130	
Naphthalene	20.0	17	85	70 - 130	
n-Butylbenzene	20.0	19	95	70 - 130	
N-Propylbenzene	20.0	19	97	70 - 130	
o-Xylene	20.0	18	91	70 - 130	
sec-Butylbenzene	20.0	19	93	70 - 130	
Styrene	20.0	19	96	70 - 130	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Laboratory Control Sample - Batch: 680-20866

Method: 524.2
Preparation: N/A

Lab Sample ID: LCS 680-20866/3
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/01/2005 1309
Date Prepared: N/A

Analysis Batch: 680-20866
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq587.d
Initial Weight/Volume: mL
Final Weight/Volume: 5 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
tert-Butylbenzene	20.0	18	89	70 - 130	
1,1,1,2-Tetrachloroethane	20.0	19	93	70 - 130	
1,1,2,2-Tetrachloroethane	20.0	20	99	70 - 130	
Tetrachloroethene	20.0	18	89	70 - 130	
Toluene	20.0	19	94	70 - 130	
trans-1,2-Dichloroethene	20.0	19	96	70 - 130	
trans-1,3-Dichloropropene	20.0	19	93	70 - 130	
1,2,4-Trichlorobenzene	20.0	16	78	70 - 130	
1,2,3-Trichlorobenzene	20.0	15	77	70 - 130	
1,1,1-Trichloroethane	20.0	18	88	70 - 130	
1,1,2-Trichloroethane	20.0	20	100	70 - 130	
Trichloroethene	20.0	18	89	70 - 130	
Trichlorofluoromethane	20.0	21	105	70 - 130	
1,2,3-Trichloropropane	20.0	18	91	70 - 130	
1,2,4-Trimethylbenzene	20.0	18	91	70 - 130	
1,3,5-Trimethylbenzene	20.0	18	91	70 - 130	
Vinyl chloride	20.0	23	113	70 - 130	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Method Blank - Batch: 680-21051

Method: 524.2
Preparation: N/A

Lab Sample ID: MB 680-21051/10
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/01/2005 0032
Date Prepared: N/A

Analysis Batch: 680-21051
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq585.d
Initial Weight/Volume: mL
Final Weight/Volume: 5 mL

Analyte	Result	Qual	RL
Acetone	<10		10
Benzene	<0.50		0.50
Bromobenzene	<0.50		0.50
Bromoform	<0.50		0.50
Bromomethane	<1.0		1.0
Carbon tetrachloride	<0.50		0.50
Chlorobenzene	<0.50		0.50
Chlorobromomethane	<0.50		0.50
Chlorodibromomethane	<0.50		0.50
Chloroethane	<1.0		1.0
Chloroform	<0.50		0.50
Chloromethane	<0.50		0.50
2-Chlorotoluene	<0.50		0.50
4-Chlorotoluene	<0.50		0.50
cis-1,2-Dichloroethene	<0.50		0.50
cis-1,3-Dichloropropene	<0.50		0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.50
Dibromomethane	<0.50		0.50
1,2-Dichlorobenzene	<0.50		0.50
1,4-Dichlorobenzene	<0.50		0.50
1,3-Dichlorobenzene	<0.50		0.50
Dichlorobromomethane	<0.50		0.50
Dichlorodifluoromethane	<0.50		0.50
1,2-Dichloroethane	<0.50		0.50
1,1-Dichloroethane	<0.50		0.50
1,1-Dichloroethene	<0.50		0.50
1,2-Dichloropropane	<0.50		0.50
1,3-Dichloropropane	<0.50		0.50
2,2-Dichloropropane	<0.50		0.50
1,1-Dichloropropene	<0.50		0.50
1,3-Dichloropropene, Total	<0.50		0.50
Diisopropyl ether	<0.50		0.50
Ethylbenzene	<0.50		0.50
Ethylene Dibromide	<0.50		0.50
Freon 113	<0.50		0.50
Hexachlorobutadiene	<0.50		0.50
2-Hexanone	<10		10
Isopropylbenzene	<0.50		0.50
4-Isopropyltoluene	<0.50		0.50
Methylene Chloride	<0.50		0.50
Methyl Ethyl Ketone	<10		10
methyl isobutyl ketone	<10		10

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Method Blank - Batch: 680-21051

Method: 524.2
Preparation: N/A

Lab Sample ID: MB 680-21051/10
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/01/2005 0032
Date Prepared: N/A

Analysis Batch: 680-21051
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq585.d
Initial Weight/Volume: mL
Final Weight/Volume: 5 mL

Analyte	Result	Qual	RL
m-Xylene & p-Xylene	<0.50		0.50
Naphthalene	<1.0		1.0
n-Butylbenzene	<0.50		0.50
N-Propylbenzene	<0.50		0.50
o-Xylene	<0.50		0.50
sec-Butylbenzene	<0.50		0.50
Styrene	<0.50		0.50
Tert-amyl methyl ether	<0.50		0.50
tert-Butylbenzene	<0.50		0.50
Tert-butyl ethyl ether	<0.50		0.50
1,1,1,2-Tetrachloroethane	<0.50		0.50
1,1,2,2-Tetrachloroethane	<0.50		0.50
Tetrachloroethene	<0.50		0.50
Toluene	<0.50		0.50
trans-1,2-Dichloroethene	<0.50		0.50
trans-1,3-Dichloropropene	<0.50		0.50
1,2,4-Trichlorobenzene	<0.50		0.50
1,2,3-Trichlorobenzene	<0.50		0.50
1,1,1-Trichloroethane	<0.50		0.50
1,1,2-Trichloroethane	<0.50		0.50
Trichloroethene	<0.50		0.50
Trichlorofluoromethane	<0.50		0.50
1,2,3-Trichloropropane	<0.50		0.50
1,2,4-Trimethylbenzene	<0.50		0.50
1,3,5-Trimethylbenzene	<0.50		0.50
Vinyl chloride	<0.50		0.50
Xylenes, Total	<0.50		0.50

Surrogate	% Rec	Acceptance Limits
4-Bromofluorobenzene	79	70 - 130
1,2-Dichlorobenzene-d4	78	70 - 130

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Laboratory Control Sample - Batch: 680-21051

Method: 524.2
Preparation: N/A

Lab Sample ID: LCS 680-21051/7
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/31/2005 2351
Date Prepared: N/A

Analysis Batch: 680-21051
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq583.d
Initial Weight/Volume: mL
Final Weight/Volume: 5 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	20.0	18	90	70 - 130	
Bromobenzene	20.0	16	80	70 - 130	
Bromoform	20.0	19	94	70 - 130	
Bromomethane	20.0	21	103	70 - 130	
Carbon tetrachloride	20.0	17	87	70 - 130	
Chlorobenzene	20.0	16	81	70 - 130	
Chlorobromomethane	20.0	19	95	70 - 130	
Chlorodibromomethane	20.0	18	90	70 - 130	
Chloroethane	20.0	19	95	70 - 130	
Chloroform	20.0	17	84	70 - 130	
Chloromethane	20.0	22	109	70 - 130	
2-Chlorotoluene	20.0	19	94	70 - 130	
4-Chlorotoluene	20.0	16	80	70 - 130	
cis-1,2-Dichloroethene	20.0	17	83	70 - 130	
cis-1,3-Dichloropropene	20.0	17	87	70 - 130	
1,2-Dibromo-3-Chloropropane	20.0	19	97	70 - 130	
Dibromomethane	20.0	18	90	70 - 130	
1,2-Dichlorobenzene	20.0	17	83	70 - 130	
1,4-Dichlorobenzene	20.0	16	78	70 - 130	
1,3-Dichlorobenzene	20.0	16	82	70 - 130	
Dichlorobromomethane	20.0	18	90	70 - 130	
Dichlorodifluoromethane	20.0	20	99	70 - 130	
1,2-Dichloroethane	20.0	17	83	70 - 130	
1,1-Dichloroethane	20.0	19	94	70 - 130	
1,1-Dichloroethene	20.0	19	95	70 - 130	
1,2-Dichloropropane	20.0	19	95	70 - 130	
1,3-Dichloropropane	20.0	18	88	70 - 130	
2,2-Dichloropropane	20.0	17	83	70 - 130	
1,1-Dichloropropene	20.0	17	84	70 - 130	
Ethylbenzene	20.0	18	89	70 - 130	
Ethylene Dibromide	20.0	17	85	70 - 130	
Hexachlorobutadiene	20.0	14	68	70 - 130	
Isopropylbenzene	20.0	18	88	70 - 130	
4-Isopropyltoluene	20.0	18	88	70 - 130	
Methylene Chloride	20.0	17	85	70 - 130	
m-Xylene & p-Xylene	40.0	36	89	70 - 130	
Naphthalene	20.0	17	87	70 - 130	
n-Butylbenzene	20.0	19	93	70 - 130	
N-Propylbenzene	20.0	18	92	70 - 130	
o-Xylene	20.0	17	85	70 - 130	
sec-Butylbenzene	20.0	18	89	70 - 130	
Styrene	20.0	18	89	70 - 130	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Severn Trent Laboratories, Inc.

Job Number: 680-7314-1

Laboratory Control Sample - Batch: 680-21051

Method: 524.2
Preparation: N/A

Lab Sample ID: LCS 680-21051/7
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/31/2005 2351
Date Prepared: N/A

Analysis Batch: 680-21051
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq583.d
Initial Weight/Volume: mL
Final Weight/Volume: 5 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
tert-Butylbenzene	20.0	17	85	70 - 130	
1,1,1,2-Tetrachloroethane	20.0	17	85	70 - 130	
1,1,1,2,2-Tetrachloroethane	20.0	20	98	70 - 130	
Tetrachloroethene	20.0	16	82	70 - 130	
Toluene	20.0	18	88	70 - 130	
trans-1,2-Dichloroethene	20.0	18	90	70 - 130	
trans-1,3-Dichloropropene	20.0	17	86	70 - 130	
1,2,4-Trichlorobenzene	20.0	15	76	70 - 130	
1,2,3-Trichlorobenzene	20.0	15	75	70 - 130	
1,1,1-Trichloroethane	20.0	17	83	70 - 130	
1,1,2-Trichloroethane	20.0	18	92	70 - 130	
Trichloroethene	20.0	17	84	70 - 130	
Trichlorofluoromethane	20.0	19	94	70 - 130	
1,2,3-Trichloropropane	20.0	18	88	70 - 130	
1,2,4-Trimethylbenzene	20.0	18	88	70 - 130	
1,3,5-Trimethylbenzene	20.0	18	88	70 - 130	
Vinyl chloride	20.0	20	102	70 - 130	

Calculations are performed before rounding to avoid round-off errors in calculated results.

