

Quarterly Groundwater Monitoring Report

Prepared for
Black & Decker (U.S.) Inc.

Hampstead, Maryland

October 2007

Prepared by

WESTON SOLUTIONS, INC.

West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 3rd Quarter 2007	2-2
Table 2-2 Groundwater Elevation Data – 3rd Quarter 2007.....	2-3
Table 2-3 Effluent Characteristics Summary – 3rd Quarter 2007.....	2-4
Table 2-4 Summary of Groundwater Analytical Results - August 2007.....	2-5
Table 3-1 Treatment System Maintenance Activities – 3rd Quarter 2007	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of July through September 2007.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of July through September 2007, the extraction wells were pumping at an average combined rate of approximately 163 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of July through September 2007 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of July through September 2007, approximately 24 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (86 %) and tetrachloroethene (PCE) (14 %). Analytical results of the groundwater collected from the air stripper for the period of January through March 2007 are included in Appendix C.

A summary of the analytical results from the first quarter (August 2007) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 3rd Quarter 2007
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
July 2007	6,777,770
August 2007	6,598,950
September 2007	6,694,100

Table 2-2
Groundwater Elevation Data - 3rd Quarter 2007
Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV.	TOTAL DEPTH	7/23/2007		8/6/2007		9/11/2007	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NA	DRY	NA	DRY	NA
EW-2	849.21	110	75.82	773.39	76.74	772.47	77.31	771.90
EW-3	846.64	118	89.13	757.51	88.47	758.17	89.50	757.14
EW-4	858.01	97.5	NA	NA	NA	NA	NA	NA
EW-5	864.17	98	64.80	799.37	66.24	797.93	66.56	797.61
EW-6	831.98	115	89.88	742.10	85.11	746.87	86.42	745.56
EW-7	818.38	78	48.53	769.85	44.13	774.25	45.81	772.57
EW-8	811.13	98	64.22	746.91	72.72	738.41	74.31	736.82
EW-9	811.35	141	103.78	707.57	102.94	708.41	103.48	707.87
EW-10	807.74	NA	56.30	751.44	56.71	751.03	57.10	750.64
RFW-1A	864.37	78	49.26	815.11	47.09	817.28	47.15	817.22
RFW-1B	864.23	200	49.31	814.92	47.12	817.11	47.19	817.04
RFW-2A	857.41	35	14.98	842.43	17.53	839.88	17.60	839.81
RFW-2B	857.73	75	15.11	842.62	18.04	839.69	18.11	839.62
RFW-3B	839.21	153	30.12	809.09	33.77	805.44	34.06	805.15
RFW-4A	830.37	62	37.78	792.59	37.12	793.25	37.80	792.57
RFW-4B	830.37	120	37.14	793.23	37.08	793.29	37.77	792.60
RFW-5A	817.50	30	DRY	NA	DRY	NA	DRY	NA
RFW-6	785.04	120	4.32	780.72	4.19	780.85	4.40	780.64
RFW-7	805.14	29	7.67	797.47	7.41	797.73	7.83	797.31
RFW-8	860.07	56	DRY	NA	DRY	NA	DRY	NA
RFW-9	862.02	49	25.61	836.41	27.77	834.25	27.74	834.28
RFW-10	852.06	58	DRY	NA	DRY	NA	DRY	NA
RFW-11A	849.32	72	NA	NA	NA	NA	NA	NA
RFW-11B	849.62	116	70.32	779.30	67.58	782.04	67.66	781.96
RFW-12B	844.87	264	54.08	790.79	49.79	795.08	50.55	794.32
RFW-13	849.11	150	61.89	787.22	59.33	789.78	60.17	788.94
RFW-14B	812.39	281	53.11	759.28	51.74	760.65	52.26	760.13
RFW-16	856.14	41	DRY	NA	DRY	NA	DRY	NA
RFW-17	834.66	60.5	27.38	807.28	27.27	807.39	28.71	805.95
RFW-20	842.49	142	35.13	807.36	35.19	807.30	35.26	807.23
RFW-21	832.65	102	24.14	808.51	22.91	809.74	23.64	809.01
PH-7	805.94	89	28.40	777.54	34.00	771.94	36.12	769.82
PH-9	814.94	98	36.31	778.63	34.88	780.06	34.83	780.11
PH-11	820.68	78	44.80	775.88	45.29	775.39	45.23	775.45
PH-12	828.35	87	47.66	780.69	47.74	780.61	47.80	780.55
B-3	803.02	83	NA	NA	8.63	794.39	8.84	794.18
Amoco	842.29	NA	NA	NA	NA	NA	NA	NA
Hamp. Town #22	804.96	NA	39.44	765.52	26.53	778.43	23.12	781.84
Pembroke #1	NA	NA	14.46	NA	14.98	NA	16.32	NA
Pembroke #2	NA	NA	NA	NA	NA	NA	NA	NA
N. Houcks. Rd.	NA	NA	9.08	NA	8.74	NA	9.53	NA
E. Century St.	NA	NA	12.81	NA	12.01	NA	12.26	NA
Lwr. Beckleys. Rd.	NA	NA	NA	NA	52.89	NA	53.44	NA

NA - Not Available/Not Accessible

Table 2-3
Effluent Characteristics Summary - 3rd Quarter 2007
Black & Decker
Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				July 2007	August 2007	September 2007	
001	FLOW	average	MGD	NA	0.120	0.090	0.160
		maximum	MGD	NA	0.195	0.129	0.209
	1,1,1-Trichloroethane		ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene		ug/l	5	< 1	< 1	< 1
	Trichloroethylene		ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	< 5	8.0
		quarterly average	mg/l	10	0	0	8.0
	pH	minimum	STD	6.0	6.80	6.60	7.10
		maximum	STD	8.5	8.20	8.20	7.70
	BOD		mg/l	15	8.0	6.0	4.0
TSS	maximum	mg/l	30	18.0	16.0	10.0	
	quarterly average	mg/l	20	18.0	16.0	10.0	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.075	0.088	0.139
		maximum	MGD	NA	0.296	0.520	0.630
	Fecal Coliform		MPN/100ml	200	1.0	4.0	13.0
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.218
		maximum	MGD	NA	NR	NR	0.256
	1,1,1-Trichloroethane		ug/l	NA	NR	NR	< 1
	Tetrachloroethylene		ug/l	NA	NR	NR	< 1
	Trichloroethylene		ug/l	NA	NR	NR	< 1

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

Table 2-4
 Summary of Groundwater Analytical Results - August 2007
 Black & Decker
 Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	2.3	2.4	1 U	1 U	1 U	5.8	19	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1.4	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	480	220	1600	210	9.2	5.5	11	1.7	1.8	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	68	5.3	31	13	21	12	82	190	220	4.6
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
 J = Indicates an estimated value.

Table 2-4
 Summary of Groundwater Analytical Results - August 2007
 Black & Decker
 Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4B	RFW-4B (DUP)	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.3	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	5.4	1	4	3.6	NS	1 U	1 U	NS	14	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	1.1	1.8	1.7	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.5	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	1	1 U	1 U	41	55	54	NS	2	5.2	NS	18	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	1.9	38	120	96	NS	2.6	1 U	NS	6.4	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicated sample
 NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
 J = Indicates an estimated value.

Table 2-4
Summary of Groundwater Analytical Results - August 2007
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	USEPA drinking water method 524.2				
												RFW-20	RFW-21	Town #22	Town #23	Trip Blank
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	1 U	1 U	1 U	NS	1.5	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	NA	NA	NA	NA	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	5.5	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trichloroethene	ug/L	NS	16	370	3.9	NS	1 U	1 U	1 U	NS	1 U	1	0.5 U	0.5 U	0.5 U	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	1 U	34	19	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division. Samples from all of the other wells are analyzed with USEPA Method 8260.

NS = Not sampled

U = Compound was analyzed but not detected.

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from wells RFW-4B and EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (July through September 2007) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 3rd Quarter 2007
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Jul-07	Micro-Tech Designs onsite for periodic calibration the of the Wet Well, Air Stripper and the Chemical feed.
Aug-07	The pumps that drain the air stripper column were cycling. The valve in the ceiling was adjusted to create a steady flow. This caused pressure to build in the system. Wells EW-3 & EW-8 were turned off temporarily to reduce the pressure. There was added demand to the system due to a 300-ton chiller used within the facility. The chiller was drawing additional water from the system. The additional demand caused the instability in the pumps that drain the air stripper column. The two wells were off for 66 hours until the pressure could be reduced in the system. All wells are running again.

4. RECOMMENDATIONS

For the reporting period of July through September 2007, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(JULY - SEPTEMBER 2007)

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 626 Hanover Pike, Hampstead Maryland

Permit Number: 02-DP-0022

Operator: Justin Myers

Month: JULY

Year: # 2007

Certification # 8406

Date	Appearance	Final Effluent outfall 001									Outfall 101					Outfall 201			Comments		
		Discharge MGD	pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l		Trichloroethene ug/l	Discharge mgd
1	clr	0.0740								0.00000		1.0	0.0	0.0	0.0				0.204465		
2	clr	0.0860								0.19100		1.0	10.0	6.0	3.3				0.224121		
3	clr	0.0760	7.2	0.00						0.29600	< 2	3.0	15.0	6.0	4.7				0.187321		
4	clr	0.0950								0.21400		6.0	15.0	7.0	3.0				0.251244		
5	cldy	0.0830	6.8	0.00						0.20300		8.0	2.0	7.0	1.7				0.215354		
6	clr	0.0880								0.00000		8.0	0.0	0.0	0.0				0.222376		
7	clr	0.0900								0.00000		9.0	0.0	0.0	0.0				0.239155		
8	clr	0.0750								0.00000		9.0	0.0	0.0	0.0				0.210498		
9	clr	0.0880								0.00000		8.0	0.0	0.0	0.0				0.227667		
10	clr	0.0850								0.00000		7.0	0.0	0.0	0.0				0.218605		
11	clr	0.0810	8.0	0.00						0.00000		7.0	0.0	0.0	0.0				0.194059		
12	clr	0.0880								0.00000		6.0	0.0	0.0	0.0				0.246741		
13	clr	0.0970	8.2	0.00						0.00000		5.0	0.0	0.0	0.0				0.210747		
14	clr	0.0840								0.00000		5.0	0.0	0.0	0.0				0.211085		
15	clr	0.0740								0.00000		5.0	0.0	0.0	0.0				0.219219		
16	clr	0.0940	8.2	0.00						0.00000		4.0	0.0	0.0	0.0				0.231934		
17	clr	0.0850								0.24400		4.0	20.0	8.0	1.5				0.228703		
18	clr	0.0780								0.22100		7.0	20.0	6.0	3.9				0.201598		
19	cldy	0.1720								0.16800		10.0	10.0	6.0	3.8				0.205881		
20	clr	0.1640	8.0	0.00						0.00000		10.0	0.0	0.0	0.0				0.205113		
21	clr	0.1630								0.00000		10.0	0.0	0.0	0.0				0.211619		
22	clr	0.1620								0.00000		9.0	0.0	0.0	0.0				0.232067		
23	clr	0.1740								0.00000		9.0	0.0	0.0	0.0				0.243585		
24	clr	0.1840	7.0	0.00						0.00000		8.0	5.0	8.0	0.0				0.212439		
25	clr	0.1660			< 1.00	< 1.00	< 1.00	8.0	18.0	< 5.0	0.25700	< 2	11.0	5.0	6.0	3.1	< 1	< 1	< 1	0.213187	
26	clr	0.1680								0.24100		14.0	5.0	5.0	3.0				0.221510		
27	clr	0.1950	6.9	0.00						0.23900		14.0	0.5	2.0	3.0				0.236898		
28	clr	0.1560								0.03600		14.0	0.0	0.0	2.8				0.203975		
29	clr	0.1560								0.00000		14.0	0.0	0.0	0.0				0.227755		
30	clr	0.1610								0.00000		14.0	0.0	0.0	0.0				0.206030		
31	clr	0.1710	7.9	0.00						0.00000		13.0	0.0	0.0	0.0				0.212820		
Total		3.7130	68.2	0.00	0.0	0.0	0.0	8	18	0	2.31000	2	253.0	107.5	67.0	33.8	0.00	0.00	0.00	6.77777	
Average		0.1198	7.6	<0.10	0.0	0.0	0.0	8	18	0	0.07452	1	8.2	3.5	2.2	1.1	0.00	0.00	0.00	0.21864	
Minimum		0.0740	6.8	0.00	0.0	0.0	0.0	8	18	0	0.00000	1	1.0	0.0	0.0	0.0	0.00	0.00	0.00	0.18732	
Maximum		0.1950	8.2	<0.10	0.0	0.0	0.0	8	18	0	0.29600	1	14.0	20.0	8.0	4.7	0.00	0.00	0.00	0.25124	MOR 3-15-07

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 626 Hanover Pike, Hampstead Maryland

Permit Number: 02-DP-0022
Operator: Justin Myers
Certification # 8406

Month: August
Year: # 2007

Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Final Effluent outfall 001					Outfall 101					Outfall 201				Comments		
					Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethylene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l		Trichloroethylene ug/l	Discharge mgd
1	clear	0.1000									0.00000		14.0	0.0	0.0	0.0				0.229486	
2	clear	0.0760									0.00000		14.0	0.0	0.0	0.0				0.196801	
3	clear	0.0960	8.2	0.00							0.00000		14.0	0.0	0.0	0.0				0.208201	
4	clear	0.0880									0.00000		14.0	0.0	0.0	0.0				0.228884	
5	clear	0.0850									0.00000		14.0	0.0	0.0	0.0				0.204506	
6	clear	0.0890									0.18300		10.0	15.0	6.0	2.3				0.209853	
7	clear	0.0890	6.7	0.00							0.19500	4	12.0	15.0	8.0	3.3				0.253401	
8	clear	0.0850			< 1.00	< 1.00	< 1.00	6.0	16.0	< 5.1	0.26800		12.0	5.0	8.0	3.4				0.230016	
9	clear	0.0870	6.6	0.00							0.25600		14.0	15.0	7.0	5.0				0.227382	
10	clear	0.0820									0.25400		14.0	20.0	6.0	2.0				0.210172	
11	clear	0.0860									0.25000		14.0	5.0	6.0	3.4				0.227367	
12	clear	0.0900									0.00000		14.0	0.0	0.0	3.7				0.256003	
13	clear	0.0900									0.00000		14.0	0.0	0.0	0.0				0.169435	
14	clear	0.0880	7.3	0.00							0.00000		14.0	0.0	0.0	0.0				0.132206	
15	clear	0.0850									0.00000		14.0	0.0	0.0	0.0				0.187270	
16	clear	0.0800	7.4	0.00							0.00000		14.0	0.0	0.0	0.0				0.218523	
17	clear	0.0970									0.00000		14.0	0.0	0.0	0.0				0.233240	
18	clear	0.0790									0.00000		14.0	0.0	0.0	0.0				0.205632	
19	clear	0.0790									0.00000		14.0	0.0	0.0	0.0				0.222005	
20	clear	0.0820									0.00000		14.0	0.0	0.0	0.0				0.229600	
21	clear	0.0760	6.6	0.00							0.00000		11.0	0.0	0.0	0.0				0.195841	
22	clear	0.0910									0.00000		10.0	0.0	0.0	0.0				0.243062	
23	clear	0.0710									0.00000		9.0	0.0	0.0	0.0				0.206983	
24	clear	0.0820	6.8	0.00							0.00000		8.0	0.0	0.0	0.0				0.203631	
25	clear	0.0730									0.00000		7.0	6.0	0.0	0.0				0.200610	
26	clear	0.0780									0.00000		6.0	0.0	0.0	0.0				0.217204	
27	clear	0.1240									0.00000		6.0	0.0	0.0	0.0				0.212340	
28	clear	0.1290	7.1	0.00							0.21600		5.0	0.0	0.0	0.0				0.213735	
29	clear	0.1130									0.27900		7.0	0.0	0.0	0.0				0.205886	
30	clear	0.1080	7.0	0.00							0.30400		10.0	0.0	0.0	0.0				0.211457	
31	clear	0.1220									0.52000		12.0	0.0	0.0	0.0				0.208218	
Total		2.8000	63.7	0.00	0.0	0.0	0.0	6	16	0	2.72500	4	363.0	81.0	41.0	23.1	0.00	0.00	0.00	6.59895	
Average		0.0903	7.1	<0.10	0.0	0.0	0.0	6	16	0	0.08790	4	11.7	2.6	1.3	0.7	#DIV/0!	#DIV/0!	#####	0.21287	
Minimum		0.0710	6.6	0.00	0.0	0.0	0.0	6	16	0	0.00000	4	5.0	0.0	0.0	0.0	0.00	0.00	0.00	0.13221	
Maximum		0.1290	8.2	<0.10	0.0	0.0	0.0	6	16	0	0.52000	4	14.0	20.0	8.0	5.0	0.00	0.00	0.00	0.25600	MOR 3-15-07

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 626 Hanover Pike, Hampstead Maryland

Permit Number: 02-DP-0022
Operator: Justin Myers
Certification # 8406

Month: Sept
Year: # 2007

006/008

MES/TECH ENG SERVICES

10/25/2007 14:31 FAX 4107298340

Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Final Effluent outfall 001						Outfall 101						Outfall 201				Comments	
					Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD, mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	Discharge mgd		
1	clear	0.1160									0.00000		12.0	0.0	0.0	0.0				0.213490		
2	clear	0.0940									0.00000		14.0	0.0	0.0	0.0				0.181319		
3	clear	0.1210									0.00000		9.0	0.0	0.0	0.0				0.233673		
4	clear	0.1090	7.3	0.00							0.00000		7.0	0.0	0.0	0.0				0.211704		
5	clear	0.1690									0.31500		4.0	5.0	4.0	3.0				0.199536		
6	clear	0.1770	7.4	0.00							0.35700	13	7.0	10.0	3.0	4.3				0.209575		
7	clear	0.1730									0.37600		10.0	10.0	6.0	2.0				0.193160		
8	clear	0.1980									0.40700		14.0	15.0	4.0	3.3				0.234268		
9	clear	0.1600									0.00000		14.0	0.0	0.0	2.1				0.196039		
10	clear	0.1780									0.00000		14.0	0.0	0.0	0.0				0.216000		
11	clear	0.2090	7.3	0.00							0.00000		11.0	0.0	0.0	0.0				0.237962		
12	clear	0.1730									0.00000		9.0	0.0	0.0	0.0				0.233729		
13	clear	0.1690	7.7	0.00							0.00000		8.0	0.0	0.0	0.0				0.251199		
14	clear	0.1750									0.00000		7.0	0.0	0.0	0.0				0.221231		
15	clear	0.1630									0.00000		6.0	0.0	0.0	0.0				0.228765		
16	clear	0.1630									0.00000		5.0	0.0	0.0	0.0				0.228785		
17	clear	0.1710									0.00000		5.0	0.0	0.0	0.0				0.245043		
18	clear	0.1610	7.4	0.00							0.24100		5.0	10.0	6.0	5.0				0.223899		
19	clear	0.1690			< 1.00	< 1.00	< 1.00	4.0	10.0	8.4	0.25000	2	7.0	15.0	6.0	5.0				0.231663		
20	clear	0.1860	7.1	0.00							0.31000		11.0	5.0	2.0	1.9				0.252853		
21	clear	0.1500									0.00000		9.0	0.0	0.0	0.0				0.195334		
22	clear	0.1610									0.00000		8.0	0.0	0.0	0.0				0.220658		
23	clear	0.1730									0.00000		8.0	0.0	0.0	0.0				0.247072		
24	clear	0.1620									0.29300		5.0	20.0	6.0	1.5				0.220646		
25	clear	0.1780	7.3	0.00							0.30500		9.0	20.0	3.0	1.7				0.239564		
26	clear	0.1600									0.33400	< 2	11.0	15.0	3.0	5.0				0.218883		
27	clear	0.1620	7.3	0.00							0.35400		14.0	25.0	6.0	2.0				0.222123		
28	clear	0.1450									0.63000		14.0	10.0	2.5	1.7				0.223136		
29	clear	0.1210									0.00000		14.0	0.0	0.0	0.0				0.223136		
30	clear	0.1630									0.00000		14.0	0.0	0.0	0.0				0.239652		
31																						
Total		4.8090	58.8	0.00	0.0	0.0	0.0	4	10	8	4.17200	16	285.0	160.0	51.5	38.5	0.00	0.00	0.00	6.69410		
Average		0.1603	7.4	<0.10	0.0	0.0	0.0	4	10	8	0.13907	5	9.5	5.3	1.7	1.3	#DIV/0!	#DIV/0!	#DIV/0!	0.22314		
Minimum		0.0940	7.1	0.00	0.0	0.0	0.0	4	10	8	0.00000	1	4.0	0.0	0.0	0.0	0.00	0.00	0.00	0.18132		
Maximum		0.2090	7.7	<0.10	0.0	0.0	0.0	4	10	8	0.63000	13	14.0	25.0	6.0	5.0	0.00	0.00	0.00	0.25285	MOR 3-15-07	



**APPENDIX B
DISCHARGE MONITORING REPORTS
(JULY - SEPTEMBER 2007)**



PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**
 ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**
 ATTN:


MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
07	07	01	TO	07	07	31	
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)	

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (46-53) (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE (3 Card Only 46-53)	MAXIMUM (3 Card Only 46-53)	UNITS (3 Card Only 46-53)	MINIMUM (4 Card Only 38-43)	AVERAGE (4 Card Only 38-43)	MAXIMUM (4 Card Only 38-43)				UNITS (4 Card Only 38-43)
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	8	(19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15	MG/L		ONE/MONTH	GRAB
pH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	6.8	*****	8.2	(12)	0	TWO/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	8.5	SU		TWO/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	18	18	(19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	20	30	MG/L		ONE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	119774	195000	(07)	*****	*****	*****		0	MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.011	0.019	MG/L		ONE/MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
410 729-8350
 AREA CODE NUMBER
 DATE
07 08 21
 YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**
 ADDRESS **626 Hanover Pike**
Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**
 ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

MD0001881
 PERMIT NUMBER


001
 DISCHARGE NUMBER

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	07	01		07	07	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING (34-61)			QUANTITY OR CONCENTRATION (46-53)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****		*****	*****	0		0	ONE/MONTH	GRAB
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONE/MONTH	GRAB
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Jim Harkins, Director MES	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE	DATE		
			410 AREA CODE	729-8350 NUMBER	07 YEAR	08 MO

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Blask and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

State Discharge Permit
02-DP-0022

MD0001881
PERMIT NUMBER

101
DISCHARGE NUMBER

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98


MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
07	07	01		07	07	31	
(20-21)		(22-23)		(24-25)		(26-27)	
				(28-29)		(30-31)	

*** NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (34-61)			QUANTITY OR CONCENTRATION (38-45)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS (38-45)	MINIMUM (46-53)	AVERAGE (54-61)	MAXIMUM (54-61)				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	74516	296000	(07)	*****	*****	*****		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	REPORT *****	REPORT *****	GPD	*****	*****	*****	****		ONE/MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	TWO/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200	MPN		TWO/WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
410 729-8350
AREA CODE NUMBER

DATE
07 08 21
YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

State Discharge Permit
02-DP-0022

MD0001881

PERMIT NUMBER

001

DISCHARGE NUMBER

Form Approved. 12345

OMB No. 2040-0004

Approval expires 05-31-98

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	07	08	01		07	08	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (46-53)			QUANTITY OR CONCENTRATION (46-53)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-65)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	6	(19)	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15	MG/L		ONE/ MONTH	GRAB
pH 00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	6.6	*****	8.2	(12)	0	TWO/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	8.5	SU		TWO/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	16	16	(19)	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	20	30	MG/L		ONE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	*****	129000	(07)	*****	*****	*****	*****		0	MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.01	0.019	MG/L		ONE/ MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	0		0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	0		0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
410 729-8350
DATE
07 09 27
AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**
 ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
 02-DP-0022

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MD0001881
 PERMIT NUMBER


001
 DISCHARGE NUMBER

Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**
 ATTN:

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	08	01		07	08	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)				UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****		*****	*****	0		0	ONE/MONTH	GRAB	
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB	
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****		*****	0	0	(19)	0	ONE/MONTH	GRAB	
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONE/MONTH	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
Jim Harkins, Director MES			410	729-8350	07	09	27
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here.)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**
Hampstead, MD 21074

FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
 02-DP-0022

MD0001881
 PERMIT NUMBER


101
 DISCHARGE NUMBER

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
07	08	01		07	08	31	
(20-21)		(22-23)		(24-25)		(26-27)	
				(28-29)		(30-31)	

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only (46-53) (54-61))			QUANTITY OR CONCENTRATION (4 Card Only (38-45) (46-53) (54-61))			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	87903	520000	(07)	*****	*****	*****		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONE/MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		*****	*****	4	(30)	0	TWO/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200	MPN		TWO/WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Jim Harkins, Director MES	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE 410 729-8350	DATE			
			AREA CODE	NUMBER	YEAR	MO
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 					

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME **AG/GFI Hampstead, Inc**
 Facility Name/Location if different
 NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
07	09	01	TO	07	09	30	
(20-21)		(22-23)		(24-25)		(26-27)	
				(28-29)		(30-31)	

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

002/008

MES/TECH ENG SERVICES


4107298340

10/25/2007 14:25 FAX

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (46-53)			QUANTITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	*****	4	(19)	0	ONE/MONTH	GRAB
pH		*****	*****	****	7.1	*****	7.7	(12)	0	TWO/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	10	10	(19)	0	ONE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE		160300	209000	(07) GPD	*****	*****	*****	****	0	MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	<0.1	<0.1	(19)	0	ONE/MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	*****	0	ug/l	0	ONE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	*****	0	ug/l	0	ONE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: **410 729-8350**
 DATE: **07 10 23**
 AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**
Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**
 ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

State Discharge Permit
02-DP-0022

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	09	01		07	09	30
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE	*****	*****		****	*****	*****	0	ug/l	0	ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0 EFFLUENT GROSS VALUE	*****	*****		****	*****	8	8	(19)	0	ONE/MONTH	GRAB
	SAMPLE MEASUREMENT							MG/L			
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

[Signature]
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
410	729-8350	07	10	23
AREA CODE	NUMBER	YEAR	MO	DAY

003/008
 MES/TECH ENG SERVICES
 4107298340
 FAX 14:26
 10/25/2007

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME **AG/GFI Hampstead, Inc**
 Facility Name/Location (if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

MD0001881

PERMIT NUMBER

101

DISCHARGE NUMBER

MONITORING PERIOD

FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
07	09	01	07	09	30
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

004/008

MES/TECH ENG SERVICES

4107298340


14:27 FAX

10/25/2007

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE		139067	630000	(07) GPD	*****	*****	*****	****	0	ONE/MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	*****	13	(30) MPN	0	TWO/WEEK	GRAB
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
410	729-8350	07	10	23
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

005/008

ADDRESS **626 Hanover Pike**
Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**
 ATTN:

MD0001881
 PERMIT NUMBER

201
 DISCHARGE NUMBER

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
07	07	01		07	09	30	
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)	

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

MES/TECH ENG SERVICES

FAX 4107298340


FAX 14:29

10/25/2007

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE		218161	256003	(07) GPD	*****	*****	*****	0	MEASURED	RECORD
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	0	0	0	ONE/ QUARTER	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	0	0	0	ONE/ QUARTER	GRAB
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	0	0	0	ONE/ QUARTER	GRAB
	SAMPLE MEASUREMENT									
	SAMPLE MEASUREMENT									
	SAMPLE MEASUREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
410	729-8350	07	10	23
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Quarterly Report!

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(JULY - SEPTEMBER 2007)

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A07071329
Project Name: Black & Decker WWTP
Receive Date: 7/25/2007
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A07071329-01 **Sample Date: 7/25/2007 10:15**

Site: Black & Decker 001
Client Sample ID:
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
BOD-5	8	mg/L	2	SM 5210 B	7/26/2007 10:00:00 AM	SKent
Total Suspended Solids	18	mg/L	5	SM 2540D	7/27/2007 11:46:00 AM	JMcGuire

Sample # A07071329-01A **Sample Date: 7/25/2007 10:15**

Site: Black & Decker 001
Client Sample ID: A
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	<5	mg/L	5	EPA 1664	7/25/2007 5:45:00 PM	SHess

Sample # A07071329-01B **Sample Date: 7/25/2007 10:15**

Site: Black & Decker 001
Client Sample ID: B
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	8/1/2007 4:41:00 PM	IMcMullen
Tetrachloroethene	<1	ug/L	1	EPA 8260B	8/1/2007 4:41:00 PM	IMcMullen
Trichloroethene	<1	ug/L	1	EPA 8260B	8/1/2007 4:41:00 PM	IMcMullen

Approved: 
Quality Assurance Manager

Reported: 8/17/2007 7:01:15 AM

RDL = Reporting Detection Limit N/A = Not Applicable
Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A07071332
Project Name: Black & Decker WWTP
Receive Date: 7/25/2007
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A07071332-01 **Sample Date: 7/25/2007 10:40**

Site: Black & Decker 201
Client Sample ID:
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	8/1/2007 5:12:00 PM	IMcMullen
Tetrachloroethene	<1	ug/L	1	EPA 8260B	8/1/2007 5:12:00 PM	IMcMullen
Trichloroethene	<1	ug/L	1	EPA 8260B	8/1/2007 5:12:00 PM	IMcMullen

Approved: *Walter Van Arsdale*
Quality Assurance Manager

Reported: 8/17/2007 7:01:17 AM

RDL = Reporting Detection Limit N/A = Not Applicable
Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A07080436
Project Name: Black & Decker WWTP
Receive Date: 8/8/2007
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A07080436-01

Sample Date: 8/8/2007 10:55

Site: Black & Decker 001
Client Sample ID:
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
BOD-5	6	mg/L	2	SM 5210 B	8/9/2007 11:00:00 AM	SKent
Total Suspended Solids	16	mg/L	8	SM 2540D	8/9/2007 12:15:00 PM	MTinnerello

Sample # A07080436-01A

Sample Date: 8/8/2007 10:55

Site: Black & Decker 001
Client Sample ID: A
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	<5.1	mg/L	5.1	EPA 1664	8/14/2007 10:00:00 AM	WVanArsdall

Sample # A07080436-01B

Sample Date: 8/8/2007 10:55

Site: Black & Decker 001
Client Sample ID: B
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	8/10/2007 6:52:00 PM	IMcMullen
Tetrachloroethene	<1	ug/L	1	EPA 8260B	8/10/2007 6:52:00 PM	IMcMullen
Trichloroethene	<1	ug/L	1	EPA 8260B	8/10/2007 6:52:00 PM	IMcMullen

Approved:



Laboratory Operations Manager

Reported:

8/29/2007 12:06:35 PM

RDL = Reporting Detection Limit N/A = Not Applicable
Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A07091004
Project Name: Black & Decker WWTP
Receive Date: 9/20/2007
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A07091004-01 **Sample Date: 9/19/2007 11:25**

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	9/26/2007 11:47:00 PM	IMcMullen
Tetrachloroethene	<1	ug/L	1	EPA 8260B	9/26/2007 11:47:00 PM	IMcMullen
Trichlorofluoromethane	<1	ug/L	1	EPA 8260B	9/26/2007 11:47:00 PM	IMcMullen

Approved:

Warren Van Arsdale
Quality Assurance Manager

Reported:

10/1/2007 7:04:05 AM

RDL = Reporting Detection Limit N/A = Not Applicable

Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A07090959
Project Name: Black & Decker WWTP
Receive Date: 9/19/2007
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A07090959-01

Sample Date: 9/19/2007 11:25

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
BOD-5	4	mg/L	2	SM 5210 B	9/20/2007 11:00:00 AM	SKent
Total Suspended Solids	10	mg/L	4	SM 2540D	9/24/2007 3:15:00 PM	JMcGuire

Sample # A07090959-01A

Sample Date: 9/19/2007 11:25

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID: A

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	8.4	mg/L	5.2	EPA 1664	9/30/2007 4:30:00 PM	SHess

Approved:

Walter Van Antwerp
Quality Assurance Manager

Reported:

10/9/2007 7:12:12 AM

RDL = Reporting Detection Limit

N/A = Not Applicable

Laboratory Certification Numbers:

Delaware - DE00011

Maryland - #138

Pennsylvania - 68-335

New Jersey - DE568

APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(AUGUST 2007)

ANALYTICAL REPORT

Job Number: 500-5884-1

Job Description: Black and Decker

For:


Weston Solutions, Inc.

1400 Weston Way

PO BOX 2653

West Chester, PA 19380

Attention: Mr. Tom Cornuet



Richard C Wright
Project Manager II
rwright@stl-inc.com
08/23/2007

These test results meet all the requirements of NELAC for accredited parameters.

The Lab Certification ID# is 100201.

All questions regarding this test report should be directed to the TestAmerica Project Manager whose signature appears on this report. All pages of this report are integral parts of the analytical data. Therefore, this report should be

TestAmerica Laboratories, Inc.

TestAmerica Chicago 2417 Bond Street, University Park, IL 60466

Tel (708) 534-5200 Fax (708) 534-5211 www.testamericainc.com



Job Narrative
500-J5884-1

Comments

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

GC/MS VOA

The following sample was diluted due to the abundance of target analytes: 18.
Elevated reporting limits (RLs) are provided.

No other analytical or quality issues were noted.

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-5884-3 Trichloroethene	RFW-2A	1.0	1.0	ug/L	8260B
500-5884-5 cis-1,2-Dichloroethene Tetrachloroethene	RFW-3B	5.4 1.9	1.0 1.0	ug/L ug/L	8260B 8260B
500-5884-6 cis-1,2-Dichloroethene Chloroform Trichloroethene Tetrachloroethene	RFW-4A	1.0 1.1 41 38	1.0 1.0 1.0 1.0	ug/L ug/L ug/L ug/L	8260B 8260B 8260B 8260B
500-5884-7 cis-1,2-Dichloroethene Chloroform Trichloroethene Tetrachloroethene	RFW-4B	4.0 1.8 55 120	1.0 1.0 1.0 10	ug/L ug/L ug/L ug/L	8260B 8260B 8260B 8260B
500-5884-8 cis-1,2-Dichloroethene Chloroform Trichloroethene Tetrachloroethene	RFW-4B-DUP	3.6 1.7 54 96	1.0 1.0 1.0 1.0	ug/L ug/L ug/L ug/L	8260B 8260B 8260B 8260B
500-5884-9 Trichloroethene Tetrachloroethene	RFW-6	2.0 2.6	1.0 1.0	ug/L ug/L	8260B 8260B
500-5884-10 Trichloroethene	RFW-7	5.2	1.0	ug/L	8260B

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-5884-11	RFW-9				
1,1-Dichloroethene		1.0	1.0	ug/L	8260B
1,1-Dichloroethane		1.3	1.0	ug/L	8260B
cis-1,2-Dichloroethene		14	1.0	ug/L	8260B
1,1,1-Trichloroethane		1.5	1.0	ug/L	8260B
Trichloroethene		18	1.0	ug/L	8260B
Tetrachloroethene		6.4	1.0	ug/L	8260B
500-5884-12	RFW-11B				
Trichloroethene		16	1.0	ug/L	8260B
500-5884-13	RFW-12B				
cis-1,2-Dichloroethene		5.5	1.0	ug/L	8260B
Trichloroethene		370	10	ug/L	8260B
Tetrachloroethene		34	1.0	ug/L	8260B
500-5884-14	RFW-13				
Trichloroethene		3.9	1.0	ug/L	8260B
Tetrachloroethene		19	1.0	ug/L	8260B
500-5884-15	RFW-17				
Methylene Chloride		1.5	1.0	ug/L	8260B
500-5884-16	EW-2				
cis-1,2-Dichloroethene		2.3	1.0	ug/L	8260B
Trichloroethene		480	10	ug/L	8260B
Tetrachloroethene		68	1.0	ug/L	8260B
500-5884-17	EW-3				
cis-1,2-Dichloroethene		2.4	1.0	ug/L	8260B
Trichloroethene		220	10	ug/L	8260B
Tetrachloroethene		5.3	1.0	ug/L	8260B
500-5884-18	EW-4				
Trichloroethene		1600	50	ug/L	8260B
Tetrachloroethene		31	5.0	ug/L	8260B

TestAmerica Chicago

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-5884-19	EW-5				
1,1,1-Trichloroethane		1.4	1.0	ug/L	8260B
Trichloroethene		210	10	ug/L	8260B
Tetrachloroethene		13	1.0	ug/L	8260B
500-5884-20	EW-6				
Trichloroethene		9.2	1.0	ug/L	8260B
Tetrachloroethene		21	1.0	ug/L	8260B
500-5884-21	EW-7				
cis-1,2-Dichloroethene		5.8	1.0	ug/L	8260B
Trichloroethene		5.5	1.0	ug/L	8260B
Tetrachloroethene		12	1.0	ug/L	8260B
500-5884-22	EW-8				
cis-1,2-Dichloroethene		19	1.0	ug/L	8260B
Trichloroethene		11	1.0	ug/L	8260B
Tetrachloroethene		82	1.0	ug/L	8260B
500-5884-23	EW-9				
Trichloroethene		1.7	1.0	ug/L	8260B
Tetrachloroethene		190	10	ug/L	8260B
500-5884-24	EW-9 DUP				
Trichloroethene		1.8	1.0	ug/L	8260B
Tetrachloroethene		220	10	ug/L	8260B
500-5884-25	EW-10				
Tetrachloroethene		4.6	1.0	ug/L	8260B

METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Description	Lab Location	Method	Preparation Method
Matrix: Water			
VOC	TAL CHI	SW846 8260B	
Purge-and-Trap	TAL CHI		SW846 5030B

Lab References:

TAL CHI = TestAmerica Chicago

Method References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
500-5884-1	RFW-1A	Water	08/06/2007 0810	08/09/2007 0950
500-5884-2	RFW-1B	Water	08/06/2007 1725	08/09/2007 0950
500-5884-3	RFW-2A	Water	08/06/2007 0900	08/09/2007 0950
500-5884-4	RFW-2B	Water	08/06/2007 0920	08/09/2007 0950
500-5884-5	RFW-3B	Water	08/06/2007 1815	08/09/2007 0950
500-5884-6	RFW-4A	Water	08/07/2007 0845	08/09/2007 0950
500-5884-7	RFW-4B	Water	08/07/2007 0950	08/09/2007 0950
500-5884-8	RFW-4B-DUP	Water	08/07/2007 0950	08/09/2007 0950
500-5884-9	RFW-6	Water	08/07/2007 0700	08/09/2007 0950
500-5884-10	RFW-7	Water	08/07/2007 0955	08/09/2007 0950
500-5884-11	RFW-9	Water	08/07/2007 1725	08/09/2007 0950
500-5884-12	RFW-11B	Water	08/07/2007 0715	08/09/2007 0950
500-5884-13	RFW-12B	Water	08/07/2007 0935	08/09/2007 0950
500-5884-14	RFW-13	Water	08/06/2007 1435	08/09/2007 0950
500-5884-15	RFW-17	Water	08/06/2007 1030	08/09/2007 0950
500-5884-16	EW-2	Water	08/07/2007 0940	08/09/2007 0950
500-5884-17	EW-3	Water	08/07/2007 0950	08/09/2007 0950
500-5884-18	EW-4	Water	08/07/2007 1000	08/09/2007 0950
500-5884-19	EW-5	Water	08/07/2007 1010	08/09/2007 0950
500-5884-20	EW-6	Water	08/07/2007 1139	08/09/2007 0950
500-5884-21	EW-7	Water	08/07/2007 1215	08/09/2007 0950
500-5884-22	EW-8	Water	08/07/2007 1320	08/09/2007 0950
500-5884-23	EW-9	Water	08/07/2007 1240	08/09/2007 0950
500-5884-24	EW-9 DUP	Water	08/07/2007 1240	08/09/2007 0950
500-5884-25	EW-10	Water	08/07/2007 1225	08/09/2007 0950
500-5884-26	LEISTER-1	Water	08/06/2007 1315	08/09/2007 0950
500-5884-27	LEISTER-DAIRY	Water	08/06/2007 1320	08/09/2007 0950
500-5884-28	TRIP BLANK	Water	08/06/2007 1200	08/09/2007 0950

SAMPLE RESULTS

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-1A
 Lab Sample ID: 500-5884-1

Date Sampled: 08/06/2007 0810
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/15/2007 1137			
Prep Method: 5030B		Date Prepared: 08/15/2007 1137			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-1A
 Lab Sample ID: 500-5884-1

Date Sampled: 08/06/2007 0810
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	103	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	98	%		75 - 120	
Dibromofluoromethane	100	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-1B
 Lab Sample ID: 500-5884-2

Date Sampled: 08/06/2007 1725
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/15/2007 1200			
Prep Method: 5030B		Date Prepared: 08/15/2007 1200			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-1B
 Lab Sample ID: 500-5884-2

Date Sampled: 08/06/2007 1725
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	111	%		70 - 125	
Toluene-d8 (Surr)	105	%		75 - 120	
4-Bromofluorobenzene (Surr)	102	%		75 - 120	
Dibromofluoromethane	106	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-2A
 Lab Sample ID: 500-5884-3

Date Sampled: 08/06/2007 0900
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/15/2007 1223			
Prep Method: 5030B		Date Prepared: 08/15/2007 1223			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-2A
 Lab Sample ID: 500-5884-3

Date Sampled: 08/06/2007 0900
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	111	%		70 - 125	
Toluene-d8 (Surr)	104	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	106	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-2B
 Lab Sample ID: 500-5884-4

Date Sampled: 08/06/2007 0920
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	08/15/2007 1246		
Prep Method: 5030B		Date Prepared:	08/15/2007 1246		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-2B
 Lab Sample ID: 500-5884-4

Date Sampled: 08/06/2007 0920
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	113	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	102	%		75 - 120	
Dibromofluoromethane	108	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-3B
 Lab Sample ID: 500-5884-5

Date Sampled: 08/06/2007 1815
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/15/2007 1308			
Prep Method: 5030B		Date Prepared: 08/15/2007 1308			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	5.4	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	1.9	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-3B
 Lab Sample ID: 500-5884-5

Date Sampled: 08/06/2007 1815
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	113	%		70 - 125	
Toluene-d8 (Surr)	102	%		75 - 120	
4-Bromofluorobenzene (Surr)	101	%		75 - 120	
Dibromofluoromethane	109	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-4A
 Lab Sample ID: 500-5884-6

Date Sampled: 08/07/2007 0845
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/15/2007 1415			
Prep Method: 5030B		Date Prepared: 08/15/2007 1415			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	1.1	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	41	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	38	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-4A
 Lab Sample ID: 500-5884-6

Date Sampled: 08/07/2007 0845
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	115	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	112	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-4B
 Lab Sample ID: 500-5884-7

Date Sampled: 08/07/2007 0950
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/15/2007 1438			
Prep Method: 5030B		Date Prepared: 08/15/2007 1438			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	4.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	1.8	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	55	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-4B
 Lab Sample ID: 500-5884-7

Date Sampled: 08/07/2007 0950
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	104	%		75 - 120	
4-Bromofluorobenzene (Surr)	103	%		75 - 120	
Dibromofluoromethane	113	%		75 - 120	
Method: 8260B Run Type: DL				Date Analyzed: 08/15/2007 1509	
Prep Method: 5030B				Date Prepared: 08/15/2007 1509	
Tetrachloroethene	120	ug/L	1.8	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	105	%		75 - 120	
4-Bromofluorobenzene (Surr)	101	%		75 - 120	
Dibromofluoromethane	112	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-4B-DUP
 Lab Sample ID: 500-5884-8

Date Sampled: 08/07/2007 0950
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/15/2007 1533			
Prep Method: 5030B		Date Prepared: 08/15/2007 1533			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	3.6	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	1.7	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	54	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	96	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-4B-DUP
 Lab Sample ID: 500-5884-8

Date Sampled: 08/07/2007 0950
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	116	%		70 - 125	
Toluene-d8 (Surr)	105	%		75 - 120	
4-Bromofluorobenzene (Surr)	99	%		75 - 120	
Dibromofluoromethane	111	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-6
 Lab Sample ID: 500-5884-9

Date Sampled: 08/07/2007 0700
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/15/2007 1619			
Prep Method: 5030B		Date Prepared: 08/15/2007 1619			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	2.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	2.6	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-6
 Lab Sample ID: 500-5884-9

Date Sampled: 08/07/2007 0700
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate					
1,2-Dichloroethane-d4 (Surr)	116	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	111	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-7
 Lab Sample ID: 500-5884-10

Date Sampled: 08/07/2007 0955
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	08/15/2007 1642		
Prep Method: 5030B		Date Prepared:	08/15/2007 1642		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	5.2	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-7
 Lab Sample ID: 500-5884-10

Date Sampled: 08/07/2007 0955
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	116	%		70 - 125	
Toluene-d8 (Surr)	104	%		75 - 120	
4-Bromofluorobenzene (Surr)	103	%		75 - 120	
Dibromofluoromethane	117	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-9
 Lab Sample ID: 500-5884-11

Date Sampled: 08/07/2007 1725
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/15/2007 1705			
Prep Method: 5030B		Date Prepared: 08/15/2007 1705			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	1.3	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	14	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	1.5	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	18	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	6.4	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-9
 Lab Sample ID: 500-5884-11

Date Sampled: 08/07/2007 1725
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	116	%		70 - 125	
Toluene-d8 (Surr)	104	%		75 - 120	
4-Bromofluorobenzene (Surr)	99	%		75 - 120	
Dibromofluoromethane	115	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-11B
 Lab Sample ID: 500-5884-12

Date Sampled: 08/07/2007 0715
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/16/2007 1052			
Prep Method: 5030B		Date Prepared: 08/16/2007 1052			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	16	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-11B
 Lab Sample ID: 500-5884-12

Date Sampled: 08/07/2007 0715
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	104	%		75 - 120	
4-Bromofluorobenzene (Surr)	97	%		75 - 120	
Dibromofluoromethane	116	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-12B
 Lab Sample ID: 500-5884-13

Date Sampled: 08/07/2007 0935
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/16/2007 1138			
Prep Method: 5030B		Date Prepared: 08/16/2007 1138			
Trichloroethene	370	ug/L	1.3	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	117	%		70 - 125	
Toluene-d8 (Surr)	105	%		75 - 120	
4-Bromofluorobenzene (Surr)	96	%		75 - 120	
Dibromofluoromethane	120	%		75 - 120	
Method: 8260B Run Type: DL		Date Analyzed: 08/16/2007 1115			
Prep Method: 5030B		Date Prepared: 08/16/2007 1115			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	5.5	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-12B
 Lab Sample ID: 500-5884-13

Date Sampled: 08/07/2007 0935
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Tetrachloroethene	34	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	115	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	101	%		75 - 120	
Dibromofluoromethane	119	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-13
 Lab Sample ID: 500-5884-14

Date Sampled: 08/06/2007 1435
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/16/2007 1201			
Prep Method: 5030B		Date Prepared: 08/16/2007 1201			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	3.9	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	19	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-13
 Lab Sample ID: 500-5884-14

Date Sampled: 08/06/2007 1435
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	115	%		70 - 125	
Toluene-d8 (Surr)	104	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	119	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-17
 Lab Sample ID: 500-5884-15

Date Sampled: 08/06/2007 1030
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/17/2007 1305			
Prep Method: 5030B		Date Prepared: 08/17/2007 1305			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	1.5	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-17
 Lab Sample ID: 500-5884-15

Date Sampled: 08/06/2007 1030
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0 *	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0 *	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0 *	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0 *	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	106	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-2
 Lab Sample ID: 500-5884-16

Date Sampled: 08/07/2007 0940
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/16/2007 1247			
Prep Method: 5030B		Date Prepared: 08/16/2007 1247			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	2.3	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	68	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-2
 Lab Sample ID: 500-5884-16

Date Sampled: 08/07/2007 0940
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	116	%		70 - 125	
Toluene-d8 (Surr)	104	%		75 - 120	
4-Bromofluorobenzene (Surr)	96	%		75 - 120	
Dibromofluoromethane	115	%		75 - 120	
Method: 8260B Run Type: DL			Date Analyzed: 08/20/2007 1125		
Prep Method: 5030B			Date Prepared: 08/20/2007 1125		
Trichloroethene	480	ug/L	1.3	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	99	%		75 - 120	
Dibromofluoromethane	105	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-3
 Lab Sample ID: 500-5884-17

Date Sampled: 08/07/2007 0950
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/20/2007 1148			
Prep Method: 5030B		Date Prepared: 08/20/2007 1148			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	2.4	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	5.3	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-3
 Lab Sample ID: 500-5884-17

Date Sampled: 08/07/2007 0950
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	110	%		70 - 125	
Toluene-d8 (Surr)	102	%		75 - 120	
4-Bromofluorobenzene (Surr)	101	%		75 - 120	
Dibromofluoromethane	106	%		75 - 120	
Method: 8260B Run Type: DL			Date Analyzed: 08/20/2007 1212		
Prep Method: 5030B			Date Prepared: 08/20/2007 1212		
Trichloroethene	220	ug/L	1.3	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	108	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-4
 Lab Sample ID: 500-5884-18

Date Sampled: 08/07/2007 1000
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/20/2007 1235			
Prep Method: 5030B		Date Prepared: 08/20/2007 1235			
Benzene	<5.0	ug/L	1.2	5.0	5.0
Dichlorodifluoromethane	<5.0	ug/L	0.60	5.0	5.0
Chloromethane	<5.0	ug/L	1.0	5.0	5.0
Vinyl chloride	<5.0	ug/L	0.80	5.0	5.0
Bromomethane	<5.0	ug/L	3.0	5.0	5.0
Chloroethane	<5.0	ug/L	1.6	5.0	5.0
Trichlorofluoromethane	<5.0	ug/L	0.70	5.0	5.0
1,1-Dichloroethene	<5.0	ug/L	1.3	5.0	5.0
Carbon disulfide	<25	ug/L	0.75	25	5.0
Acetone	<25	ug/L	7.0	25	5.0
Methylene Chloride	<5.0	ug/L	1.2	5.0	5.0
trans-1,2-Dichloroethene	<5.0	ug/L	1.5	5.0	5.0
1,1-Dichloroethane	<5.0	ug/L	0.75	5.0	5.0
2,2-Dichloropropane	<5.0	ug/L	0.85	5.0	5.0
cis-1,2-Dichloroethene	<5.0	ug/L	1.0	5.0	5.0
2-Butanone (MEK)	<25	ug/L	5.0	25	5.0
Bromochloromethane	<5.0	ug/L	1.4	5.0	5.0
Chloroform	<5.0	ug/L	0.70	5.0	5.0
1,1,1-Trichloroethane	<5.0	ug/L	0.85	5.0	5.0
1,1-Dichloropropene	<5.0	ug/L	1.9	5.0	5.0
Carbon tetrachloride	<5.0	ug/L	1.7	5.0	5.0
1,2-Dichloroethane	<5.0	ug/L	1.3	5.0	5.0
1,2-Dichloropropane	<5.0	ug/L	0.95	5.0	5.0
Dibromomethane	<5.0	ug/L	1.1	5.0	5.0
Bromodichloromethane	<5.0	ug/L	1.1	5.0	5.0
cis-1,3-Dichloropropene	<5.0	ug/L	0.75	5.0	5.0
4-Methyl-2-pentanone (MIBK)	<25	ug/L	4.6	25	5.0
Toluene	<5.0	ug/L	0.90	5.0	5.0
trans-1,3-Dichloropropene	<5.0	ug/L	0.80	5.0	5.0
1,1,2-Trichloroethane	<5.0	ug/L	1.2	5.0	5.0
Tetrachloroethene	31	ug/L	0.90	5.0	5.0
1,3-Dichloropropane	<5.0	ug/L	1.1	5.0	5.0
2-Hexanone	<25	ug/L	5.0	25	5.0
Dibromochloromethane	<5.0	ug/L	1.1	5.0	5.0
1,2-Dibromoethane	<5.0	ug/L	1.7	5.0	5.0
Chlorobenzene	<5.0	ug/L	0.75	5.0	5.0
1,1,1,2-Tetrachloroethane	<5.0	ug/L	1.7	5.0	5.0
Ethylbenzene	<5.0	ug/L	1.1	5.0	5.0
m&p-Xylene	<10	ug/L	1.8	10	5.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-4
 Lab Sample ID: 500-5884-18

Date Sampled: 08/07/2007 1000
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<5.0	ug/L	0.95	5.0	5.0
Styrene	<5.0	ug/L	0.90	5.0	5.0
Bromoform	<5.0	ug/L	1.6	5.0	5.0
Isopropylbenzene	<5.0	ug/L	1.0	5.0	5.0
Bromobenzene	<5.0	ug/L	1.1	5.0	5.0
1,1,2,2-Tetrachloroethane	<5.0	ug/L	1.7	5.0	5.0
1,2,3-Trichloropropane	<5.0	ug/L	1.8	5.0	5.0
N-Propylbenzene	<5.0	ug/L	0.80	5.0	5.0
2-Chlorotoluene	<5.0	ug/L	0.80	5.0	5.0
1,3,5-Trimethylbenzene	<5.0	ug/L	0.90	5.0	5.0
4-Chlorotoluene	<5.0	ug/L	0.90	5.0	5.0
tert-Butylbenzene	<5.0	ug/L	0.80	5.0	5.0
1,2,4-Trimethylbenzene	<5.0	ug/L	1.3	5.0	5.0
sec-Butylbenzene	<5.0	ug/L	0.95	5.0	5.0
1,3-Dichlorobenzene	<5.0	ug/L	1.1	5.0	5.0
p-Isopropyltoluene	<5.0	ug/L	1.5	5.0	5.0
1,4-Dichlorobenzene	<5.0	ug/L	1.3	5.0	5.0
n-Butylbenzene	<5.0	ug/L	1.8	5.0	5.0
1,2-Dichlorobenzene	<5.0	ug/L	1.5	5.0	5.0
1,2-Dibromo-3-Chloropropane	<5.0	ug/L	2.1	5.0	5.0
1,2,4-Trichlorobenzene	<5.0	ug/L	1.8	5.0	5.0
Hexachlorobutadiene	<5.0	ug/L	1.8	5.0	5.0
Naphthalene	<5.0	ug/L	1.9	5.0	5.0
1,2,3-Trichlorobenzene	<5.0	ug/L	2.2	5.0	5.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	112	%	70 - 125
Toluene-d8 (Surr)	103	%	75 - 120
4-Bromofluorobenzene (Surr)	103	%	75 - 120
Dibromofluoromethane	109	%	75 - 120

Method: 8260B Run Type: DL

Date Analyzed: 08/20/2007 1258

Prep Method: 5030B

Date Prepared: 08/20/2007 1258

Trichloroethene	1600	ug/L	6.5	50	50
-----------------	------	------	-----	----	----

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	116	%	70 - 125
Toluene-d8 (Surr)	103	%	75 - 120
4-Bromofluorobenzene (Surr)	102	%	75 - 120
Dibromofluoromethane	109	%	75 - 120

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-5
 Lab Sample ID: 500-5884-19

Date Sampled: 08/07/2007 1010
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/20/2007 1322			
Prep Method: 5030B		Date Prepared: 08/20/2007 1322			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	1.4	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	13	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-5
 Lab Sample ID: 500-5884-19

Date Sampled: 08/07/2007 1010
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	112	%		70 - 125	
Toluene-d8 (Surr)	102	%		75 - 120	
4-Bromofluorobenzene (Surr)	101	%		75 - 120	
Dibromofluoromethane	111	%		75 - 120	
Method: 8260B Run Type: DL			Date Analyzed: 08/20/2007 1345		
Prep Method: 5030B			Date Prepared: 08/20/2007 1345		
Trichloroethene	210	ug/L	1.3	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	113	%		70 - 125	
Toluene-d8 (Surr)	101	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	112	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-6
 Lab Sample ID: 500-5884-20

Date Sampled: 08/07/2007 1139
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/20/2007 1408			
Prep Method: 5030B		Date Prepared: 08/20/2007 1408			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	9.2	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	21	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-6
 Lab Sample ID: 500-5884-20

Date Sampled: 08/07/2007 1139
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	115	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	102	%		75 - 120	
Dibromofluoromethane	111	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-7
 Lab Sample ID: 500-5884-21

Date Sampled: 08/07/2007 1215
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/20/2007 1431			
Prep Method: 5030B		Date Prepared: 08/20/2007 1431			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	5.8	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	5.5	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	12	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-7
 Lab Sample ID: 500-5884-21

Date Sampled: 08/07/2007 1215
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	113	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	99	%		75 - 120	
Dibromofluoromethane	111	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-8
 Lab Sample ID: 500-5884-22

Date Sampled: 08/07/2007 1320
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/20/2007 1455			
Prep Method: 5030B		Date Prepared: 08/20/2007 1455			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	19	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	11	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	82	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-8
 Lab Sample ID: 500-5884-22

Date Sampled: 08/07/2007 1320
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	113	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	96	%		75 - 120	
Dibromofluoromethane	108	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-9
 Lab Sample ID: 500-5884-23

Date Sampled: 08/07/2007 1240
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/20/2007 1541			
Prep Method: 5030B		Date Prepared: 08/20/2007 1541			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	1.7	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-9
 Lab Sample ID: 500-5884-23

Date Sampled: 08/07/2007 1240
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	116	%		70 - 125	
Toluene-d8 (Surr)	102	%		75 - 120	
4-Bromofluorobenzene (Surr)	99	%		75 - 120	
Dibromofluoromethane	113	%		75 - 120	
Method: 8260B Run Type: DL			Date Analyzed: 08/20/2007 1604		
Prep Method: 5030B			Date Prepared: 08/20/2007 1604		
Tetrachloroethene	190	ug/L	1.8	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		70 - 125	
Toluene-d8 (Surr)	101	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	115	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-9 DUP
 Lab Sample ID: 500-5884-24

Date Sampled: 08/07/2007 1240
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/20/2007 1628			
Prep Method: 5030B		Date Prepared: 08/20/2007 1628			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	1.8	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-9 DUP
 Lab Sample ID: 500-5884-24

Date Sampled: 08/07/2007 1240
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	115	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	101	%		75 - 120	
Dibromofluoromethane	114	%		75 - 120	
Method: 8260B Run Type: DL				Date Analyzed: 08/20/2007 1651	
Prep Method: 5030B				Date Prepared: 08/20/2007 1651	
Tetrachloroethene	220	ug/L	1.8	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	102	%		75 - 120	
4-Bromofluorobenzene (Surr)	97	%		75 - 120	
Dibromofluoromethane	114	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-10
 Lab Sample ID: 500-5884-25

Date Sampled: 08/07/2007 1225
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/20/2007 1714			
Prep Method: 5030B		Date Prepared: 08/20/2007 1714			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	4.6	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-10
 Lab Sample ID: 500-5884-25

Date Sampled: 08/07/2007 1225
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	112	%		70 - 125	
Toluene-d8 (Surr)	104	%		75 - 120	
4-Bromofluorobenzene (Surr)	94	%		75 - 120	
Dibromofluoromethane	115	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: LEISTER-1
 Lab Sample ID: 500-5884-26

Date Sampled: 08/06/2007 1315
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/20/2007 1737			
Prep Method: 5030B		Date Prepared: 08/20/2007 1737			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: LEISTER-1
 Lab Sample ID: 500-5884-26

Date Sampled: 08/06/2007 1315
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	115	%		70 - 125	
Toluene-d8 (Surr)	102	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	116	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: LEISTER-DAIRY
 Lab Sample ID: 500-5884-27

Date Sampled: 08/06/2007 1320
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	08/20/2007	1801	
Prep Method: 5030B		Date Prepared:	08/20/2007	1801	
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: LEISTER-DAIRY
 Lab Sample ID: 500-5884-27

Date Sampled: 08/06/2007 1320
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	115	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: TRIP BLANK
 Lab Sample ID: 500-5884-28

Date Sampled: 08/06/2007 1200
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 08/20/2007 1824			
Prep Method: 5030B		Date Prepared: 08/20/2007 1824			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: TRIP BLANK
 Lab Sample ID: 500-5884-28

Date Sampled: 08/06/2007 1200
 Date Received: 08/09/2007 0950
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	105	%		75 - 120	
4-Bromofluorobenzene (Surr)	99	%		75 - 120	
Dibromofluoromethane	114	%		75 - 120	

DATA REPORTING QUALIFIERS

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

<u>Lab Section</u>	<u>Qualifier</u>	<u>Description</u>
GC/MS VOA	*	LCS or LCSD exceeds the control limits

QUALITY CONTROL RESULTS

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

QC Association Summary

Lab Sample ID	Client Sample ID	Report Basis	Client Matrix	Method	Prep Batch
GC/MS VOA					
Analysis Batch:500-20672					
LCS 500-20672/4	Lab Control Spike	T	Water	8260B	
MB 500-20672/3	Method Blank	T	Water	8260B	
500-5884-1	RFW-1A	T	Water	8260B	
500-5884-2	RFW-1B	T	Water	8260B	
500-5884-3	RFW-2A	T	Water	8260B	
500-5884-4	RFW-2B	T	Water	8260B	
500-5884-5	RFW-3B	T	Water	8260B	
500-5884-6	RFW-4A	T	Water	8260B	
500-5884-7	RFW-4B	T	Water	8260B	
500-5884-7DL	RFW-4B	T	Water	8260B	
500-5884-8	RFW-4B-DUP	T	Water	8260B	
500-5884-9	RFW-6	T	Water	8260B	
500-5884-10	RFW-7	T	Water	8260B	
500-5884-11	RFW-9	T	Water	8260B	
Analysis Batch:500-20756					
LCS 500-20756/4	Lab Control Spike	T	Water	8260B	
MB 500-20756/3	Method Blank	T	Water	8260B	
500-5884-12	RFW-11B	T	Water	8260B	
500-5884-13	RFW-12B	T	Water	8260B	
500-5884-13DL	RFW-12B	T	Water	8260B	
500-5884-14	RFW-13	T	Water	8260B	
500-5884-16	EW-2	T	Water	8260B	
Analysis Batch:500-20851					
LCS 500-20851/4	Lab Control Spike	T	Water	8260B	
MB 500-20851/3	Method Blank	T	Water	8260B	
500-5884-15	RFW-17	T	Water	8260B	

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

QC Association Summary

Lab Sample ID	Client Sample ID	Report Basis	Client Matrix	Method	Prep Batch
GC/MS VOA					
Analysis Batch:500-20970					
LCS 500-20970/4	Lab Control Spike	T	Water	8260B	
MB 500-20970/3	Method Blank	T	Water	8260B	
500-5884-16DL	EW-2	T	Water	8260B	
500-5884-17	EW-3	T	Water	8260B	
500-5884-17DL	EW-3	T	Water	8260B	
500-5884-18	EW-4	T	Water	8260B	
500-5884-18DL	EW-4	T	Water	8260B	
500-5884-19	EW-5	T	Water	8260B	
500-5884-19DL	EW-5	T	Water	8260B	
500-5884-20	EW-6	T	Water	8260B	
500-5884-21	EW-7	T	Water	8260B	
500-5884-22	EW-8	T	Water	8260B	
500-5884-23	EW-9	T	Water	8260B	
500-5884-23DL	EW-9	T	Water	8260B	
500-5884-24	EW-9 DUP	T	Water	8260B	
500-5884-24DL	EW-9 DUP	T	Water	8260B	
500-5884-25	EW-10	T	Water	8260B	
500-5884-26	LEISTER-1	T	Water	8260B	
500-5884-27	LEISTER-DAIRY	T	Water	8260B	
500-5884-28	TRIP BLANK	T	Water	8260B	

Report Basis

T = Total

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Surrogate Recovery Report

8260B VOC

Client Matrix: Water

<u>Lab Sample ID</u>	<u>Client Sample ID</u>	<u>12DCE %Rec</u>	<u>BFB %Rec</u>	<u>DBFM %Rec</u>	<u>TOL %Rec</u>
500-5884-1	RFW-1A	103	98	100	103
500-5884-2	RFW-1B	111	102	106	105
500-5884-3	RFW-2A	111	100	106	104
500-5884-4	RFW-2B	113	102	108	103
500-5884-5	RFW-3B	113	101	109	102
500-5884-6	RFW-4A	115	100	112	103
500-5884-7	RFW-4B	114	103	113	104
500-5884-7 DL	RFW-4B	114	101	112	105
500-5884-8	RFW-4B-DUP	116	99	111	105
500-5884-9	RFW-6	116	100	111	103
500-5884-10	RFW-7	116	103	117	104
500-5884-11	RFW-9	116	99	115	104
500-5884-12	RFW-11B	114	97	116	104
500-5884-13	RFW-12B	117	96	120	105
500-5884-13 DL	RFW-12B	115	101	119	103
500-5884-14	RFW-13	115	100	119	104
500-5884-15	RFW-17	114	100	106	103
500-5884-16	EW-2	116	96	115	104

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Surrogate Recovery Report

8260B VOC

Client Matrix: Water

		12DCE %Rec	BFB %Rec	DBFM %Rec	TOL %Rec
500-5884-16 DL	EW-2	109	99	105	103
500-5884-17	EW-3	110	101	106	102
500-5884-17 DL	EW-3	114	100	108	103
500-5884-18	EW-4	112	103	109	103
500-5884-18 DL	EW-4	116	102	109	103
500-5884-19	EW-5	112	101	111	102
500-5884-19 DL	EW-5	113	100	112	101
500-5884-20	EW-6	115	102	111	103
500-5884-21	EW-7	113	99	111	103
500-5884-22	EW-8	113	96	108	103
500-5884-23	EW-9	116	99	113	102
500-5884-23 DL	EW-9	109	100	115	101
500-5884-24	EW-9 DUP	115	101	114	103
500-5884-24 DL	EW-9 DUP	114	97	114	102
500-5884-25	EW-10	112	94	115	104
500-5884-26	LEISTER-1	115	100	116	102
500-5884-27	LEISTER-DAIRY	114	100	115	103
500-5884-28	TRIP BLANK	114	99	114	105

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Surrogate Recovery Report

8260B VOC

Client Matrix: Water

	12DCE %Rec	BFB %Rec	DBFM %Rec	TOL %Rec
LCS 500-20672/4	108	104	105	105
LCS 500-20756/4	107	103	108	103
LCS 500-20851/4	108	106	103	104
LCS 500-20970/4	108	104	105	103
MB 500-20672/3	108	99	106	101
MB 500-20756/3	110	101	112	102
MB 500-20851/3	107	101	108	102
MB 500-20970/3	107	99	108	102

Surrogate		Acceptance Limits
12DCE	1,2-Dichloroethane-d4 (Surr)	70 - 125
BFB	4-Bromofluorobenzene (Surr)	75 - 120
DBFM	Dibromofluoromethane	75 - 120
TOL	Toluene-d8 (Surr)	75 - 120

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Method Blank - Batch: 500-20672

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-20672/3
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/15/2007 1022
Date Prepared: 08/15/2007 1022

Analysis Batch: 500-20672
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2M0815.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.23	1.0
Dichlorodifluoromethane	<1.0		0.12	1.0
Chloromethane	<1.0		0.20	1.0
Vinyl chloride	<1.0		0.16	1.0
Bromomethane	<1.0		0.59	1.0
Chloroethane	<1.0		0.32	1.0
Trichlorofluoromethane	<1.0		0.14	1.0
1,1-Dichloroethene	<1.0		0.25	1.0
Carbon disulfide	<5.0		0.15	5.0
Acetone	<5.0		1.4	5.0
Methylene Chloride	<1.0		0.24	1.0
trans-1,2-Dichloroethene	<1.0		0.29	1.0
1,1-Dichloroethane	<1.0		0.15	1.0
2,2-Dichloropropane	<1.0		0.17	1.0
cis-1,2-Dichloroethene	<1.0		0.20	1.0
2-Butanone (MEK)	<5.0		1.0	5.0
Bromochloromethane	<1.0		0.27	1.0
Chloroform	<1.0		0.14	1.0
1,1,1-Trichloroethane	<1.0		0.17	1.0
1,1-Dichloropropene	<1.0		0.38	1.0
Carbon tetrachloride	<1.0		0.34	1.0
1,2-Dichloroethane	<1.0		0.25	1.0
Trichloroethene	<1.0		0.13	1.0
1,2-Dichloropropane	<1.0		0.19	1.0
Dibromomethane	<1.0		0.21	1.0
Bromodichloromethane	<1.0		0.22	1.0
cis-1,3-Dichloropropene	<1.0		0.15	1.0
4-Methyl-2-pentanone (MIBK)	<5.0		0.92	5.0
Toluene	<1.0		0.18	1.0
trans-1,3-Dichloropropene	<1.0		0.16	1.0
1,1,2-Trichloroethane	<1.0		0.24	1.0
Tetrachloroethene	<1.0		0.18	1.0
1,3-Dichloropropane	<1.0		0.22	1.0
2-Hexanone	<5.0		0.99	5.0
Dibromochloromethane	<1.0		0.22	1.0
1,2-Dibromoethane	<1.0		0.33	1.0
Chlorobenzene	<1.0		0.15	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.33	1.0
Ethylbenzene	<1.0		0.21	1.0
m&p-Xylene	<2.0		0.36	2.0
o-Xylene	<1.0		0.19	1.0

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Method Blank - Batch: 500-20672

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-20672/3
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/15/2007 1022
Date Prepared: 08/15/2007 1022

Analysis Batch: 500-20672
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2M0815.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Styrene	<1.0		0.18	1.0
Bromoform	<1.0		0.32	1.0
Isopropylbenzene	<1.0		0.20	1.0
Bromobenzene	<1.0		0.22	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.34	1.0
1,2,3-Trichloropropane	<1.0		0.35	1.0
N-Propylbenzene	<1.0		0.16	1.0
2-Chlorotoluene	<1.0		0.16	1.0
1,3,5-Trimethylbenzene	<1.0		0.18	1.0
4-Chlorotoluene	<1.0		0.18	1.0
tert-Butylbenzene	<1.0		0.16	1.0
1,2,4-Trimethylbenzene	<1.0		0.26	1.0
sec-Butylbenzene	<1.0		0.19	1.0
1,3-Dichlorobenzene	<1.0		0.21	1.0
p-Isopropyltoluene	<1.0		0.29	1.0
1,4-Dichlorobenzene	<1.0		0.25	1.0
n-Butylbenzene	<1.0		0.35	1.0
1,2-Dichlorobenzene	<1.0		0.29	1.0
1,2-Dibromo-3-Chloropropane	<1.0		0.41	1.0
1,2,4-Trichlorobenzene	<1.0		0.36	1.0
Hexachlorobutadiene	<1.0		0.36	1.0
Naphthalene	<1.0		0.37	1.0
1,2,3-Trichlorobenzene	<1.0		0.43	1.0
Surrogate	% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	108		70 - 125	
Toluene-d8 (Surr)	101		75 - 120	
4-Bromofluorobenzene (Surr)	99		75 - 120	
Dibromofluoromethane	106		75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Control Spike - Batch: 500-20672

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-20672/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/15/2007 1045
Date Prepared: 08/15/2007 1045

Analysis Batch: 500-20672
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2S0815.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	25.0	24.2	97	68 - 120	
Dichlorodifluoromethane	25.0	16.1	64	21 - 178	
Chloromethane	25.0	20.3	81	50 - 140	
Vinyl chloride	25.0	18.9	76	57 - 135	
Bromomethane	25.0	21.7	87	61 - 172	
Chloroethane	25.0	20.2	81	56 - 152	
Trichlorofluoromethane	25.0	21.9	87	58 - 147	
1,1-Dichloroethene	25.0	19.9	79	50 - 121	
Carbon disulfide	25.0	20.4	82	33 - 120	
Acetone	25.0	29.8	119	22 - 175	
Methylene Chloride	25.0	23.5	94	52 - 126	
trans-1,2-Dichloroethene	25.0	22.6	90	57 - 122	
1,1-Dichloroethane	25.0	22.3	89	63 - 121	
2,2-Dichloropropane	25.0	19.0	76	56 - 134	
cis-1,2-Dichloroethene	25.0	24.5	98	62 - 127	
2-Butanone (MEK)	25.0	29.8	119	36 - 157	
Bromochloromethane	25.0	20.5	82	61 - 125	
Chloroform	25.0	23.8	95	65 - 127	
1,1,1-Trichloroethane	25.0	22.0	88	65 - 129	
1,1-Dichloropropene	25.0	21.0	84	62 - 122	
Carbon tetrachloride	25.0	24.3	97	67 - 121	
1,2-Dichloroethane	25.0	25.9	104	68 - 120	
Trichloroethene	25.0	26.3	105	73 - 120	
1,2-Dichloropropane	25.0	26.2	105	72 - 120	
Dibromomethane	25.0	27.0	108	71 - 120	
Bromodichloromethane	25.0	28.3	113	71 - 131	
cis-1,3-Dichloropropene	26.9	25.0	93	60 - 120	
4-Methyl-2-pentanone (MIBK)	25.0	30.7	123	65 - 128	
Toluene	25.0	24.6	98	75 - 120	
trans-1,3-Dichloropropene	24.3	23.4	96	61 - 120	
1,1,2-Trichloroethane	25.0	26.7	107	59 - 135	
Tetrachloroethene	25.0	26.6	106	65 - 120	
1,3-Dichloropropane	25.0	26.1	104	73 - 120	
2-Hexanone	25.0	29.4	117	54 - 139	
Dibromochloromethane	25.0	29.2	117	57 - 132	
1,2-Dibromoethane	25.0	27.1	109	68 - 125	
Chlorobenzene	25.0	25.4	102	75 - 120	
1,1,1,2-Tetrachloroethane	25.0	27.1	108	72 - 120	
Ethylbenzene	25.0	25.1	100	75 - 120	
m&p-Xylene	50.0	47.9	96	75 - 120	
o-Xylene	25.0	24.6	99	75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Control Spike - Batch: 500-20672

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-20672/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/15/2007 1045
Date Prepared: 08/15/2007 1045

Analysis Batch: 500-20672
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2S0815.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Styrene	25.0	26.1	105	77 - 120	
Bromoform	25.0	28.6	115	55 - 120	
Isopropylbenzene	25.0	20.5	82	68 - 120	
Bromobenzene	25.0	25.6	103	76 - 120	
1,1,2,2-Tetrachloroethane	25.0	23.8	95	68 - 120	
1,2,3-Trichloropropane	25.0	24.2	97	70 - 120	
N-Propylbenzene	25.0	22.0	88	74 - 120	
2-Chlorotoluene	25.0	21.9	88	74 - 120	
1,3,5-Trimethylbenzene	25.0	23.5	94	76 - 120	
4-Chlorotoluene	25.0	21.7	87	75 - 120	
tert-Butylbenzene	25.0	22.9	92	75 - 120	
1,2,4-Trimethylbenzene	25.0	23.3	93	76 - 120	
sec-Butylbenzene	25.0	22.8	91	73 - 120	
1,3-Dichlorobenzene	25.0	24.6	98	76 - 120	
p-Isopropyltoluene	25.0	23.9	96	71 - 120	
1,4-Dichlorobenzene	25.0	24.4	97	74 - 120	
n-Butylbenzene	25.0	23.6	95	68 - 120	
1,2-Dichlorobenzene	25.0	25.7	103	74 - 120	
1,2-Dibromo-3-Chloropropane	25.0	22.7	91	60 - 120	
1,2,4-Trichlorobenzene	25.0	30.2	121	63 - 120	
Hexachlorobutadiene	25.0	30.0	120	54 - 131	
Naphthalene	25.0	24.8	99	50 - 120	
1,2,3-Trichlorobenzene	25.0	28.9	115	62 - 120	
Surrogate		% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)		108		70 - 125	
Toluene-d8 (Surr)		105		75 - 120	
4-Bromofluorobenzene (Surr)		104		75 - 120	
Dibromofluoromethane		105		75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Method Blank - Batch: 500-20756

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-20756/3
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/16/2007 1006
Date Prepared: 08/16/2007 1006

Analysis Batch: 500-20756
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2M0815.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.23	1.0
Dichlorodifluoromethane	<1.0		0.12	1.0
Chloromethane	<1.0		0.20	1.0
Vinyl chloride	<1.0		0.16	1.0
Bromomethane	<1.0		0.59	1.0
Chloroethane	<1.0		0.32	1.0
Trichlorofluoromethane	<1.0		0.14	1.0
1,1-Dichloroethene	<1.0		0.25	1.0
Carbon disulfide	<5.0		0.15	5.0
Acetone	<5.0		1.4	5.0
Methylene Chloride	<1.0		0.24	1.0
trans-1,2-Dichloroethene	<1.0		0.29	1.0
1,1-Dichloroethane	<1.0		0.15	1.0
2,2-Dichloropropane	<1.0		0.17	1.0
cis-1,2-Dichloroethene	<1.0		0.20	1.0
2-Butanone (MEK)	<5.0		1.0	5.0
Bromochloromethane	<1.0		0.27	1.0
Chloroform	<1.0		0.14	1.0
1,1,1-Trichloroethane	<1.0		0.17	1.0
1,1-Dichloropropene	<1.0		0.38	1.0
Carbon tetrachloride	<1.0		0.34	1.0
1,2-Dichloroethane	<1.0		0.25	1.0
Trichloroethene	<1.0		0.13	1.0
1,2-Dichloropropane	<1.0		0.19	1.0
Dibromomethane	<1.0		0.21	1.0
Bromodichloromethane	<1.0		0.22	1.0
cis-1,3-Dichloropropene	<1.0		0.15	1.0
4-Methyl-2-pentanone (MIBK)	<5.0		0.92	5.0
Toluene	<1.0		0.18	1.0
trans-1,3-Dichloropropene	<1.0		0.16	1.0
1,1,2-Trichloroethane	<1.0		0.24	1.0
Tetrachloroethene	<1.0		0.18	1.0
1,3-Dichloropropane	<1.0		0.22	1.0
2-Hexanone	<5.0		0.99	5.0
Dibromochloromethane	<1.0		0.22	1.0
1,2-Dibromoethane	<1.0		0.33	1.0
Chlorobenzene	<1.0		0.15	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.33	1.0
Ethylbenzene	<1.0		0.21	1.0
m&p-Xylene	<2.0		0.36	2.0
o-Xylene	<1.0		0.19	1.0

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Method Blank - Batch: 500-20756

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-20756/3
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/16/2007 1006
Date Prepared: 08/16/2007 1006

Analysis Batch: 500-20756
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2M0815.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Styrene	<1.0		0.18	1.0
Bromoform	<1.0		0.32	1.0
Isopropylbenzene	<1.0		0.20	1.0
Bromobenzene	<1.0		0.22	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.34	1.0
1,2,3-Trichloropropane	<1.0		0.35	1.0
N-Propylbenzene	<1.0		0.16	1.0
2-Chlorotoluene	<1.0		0.16	1.0
1,3,5-Trimethylbenzene	<1.0		0.18	1.0
4-Chlorotoluene	<1.0		0.18	1.0
tert-Butylbenzene	<1.0		0.16	1.0
1,2,4-Trimethylbenzene	<1.0		0.26	1.0
sec-Butylbenzene	<1.0		0.19	1.0
1,3-Dichlorobenzene	<1.0		0.21	1.0
p-Isopropyltoluene	<1.0		0.29	1.0
1,4-Dichlorobenzene	<1.0		0.25	1.0
n-Butylbenzene	<1.0		0.35	1.0
1,2-Dichlorobenzene	<1.0		0.29	1.0
1,2-Dibromo-3-Chloropropane	<1.0		0.41	1.0
1,2,4-Trichlorobenzene	<1.0		0.36	1.0
Hexachlorobutadiene	<1.0		0.36	1.0
Naphthalene	<1.0		0.37	1.0
1,2,3-Trichlorobenzene	<1.0		0.43	1.0
Surrogate	% Rec	Acceptance Limits		
1,2-Dichloroethane-d4 (Surr)	110	70 - 125		
Toluene-d8 (Surr)	102	75 - 120		
4-Bromofluorobenzene (Surr)	101	75 - 120		
Dibromofluoromethane	112	75 - 120		

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Control Spike - Batch: 500-20756

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-20756/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/16/2007 1029
Date Prepared: 08/16/2007 1029

Analysis Batch: 500-20756
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2S0815.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10. mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	25.0	22	86	68 - 120	
Dichlorodifluoromethane	25.0	17	69	21 - 178	
Chloromethane	25.0	22	89	50 - 140	
Vinyl chloride	25.0	21	84	57 - 135	
Bromomethane	25.0	23	94	61 - 172	
Chloroethane	25.0	22	88	56 - 152	
Trichlorofluoromethane	25.0	24	97	58 - 147	
1,1-Dichloroethene	25.0	18	73	50 - 121	
Carbon disulfide	25.0	18	72	33 - 120	
Acetone	25.0	28	113	22 - 175	
Methylene Chloride	25.0	23	91	52 - 126	
trans-1,2-Dichloroethene	25.0	21	83	57 - 122	
1,1-Dichloroethane	25.0	21	83	63 - 121	
2,2-Dichloropropane	25.0	18	73	56 - 134	
cis-1,2-Dichloroethene	25.0	22	90	62 - 127	
2-Butanone (MEK)	25.0	29	117	36 - 157	
Bromochloromethane	25.0	22	88	61 - 125	
Chloroform	25.0	22	88	65 - 127	
1,1,1-Trichloroethane	25.0	21	82	65 - 129	
1,1-Dichloropropene	25.0	20	81	62 - 122	
Carbon tetrachloride	25.0	22	88	67 - 121	
1,2-Dichloroethane	25.0	23	91	68 - 120	
Trichloroethene	25.0	23	93	73 - 120	
1,2-Dichloropropane	25.0	23	92	72 - 120	
Dibromomethane	25.0	24	97	71 - 120	
Bromodichloromethane	25.0	25	101	71 - 131	
cis-1,3-Dichloropropene	26.9	22	80	60 - 120	
4-Methyl-2-pentanone (MIBK)	25.0	27	109	65 - 128	
Toluene	25.0	22	88	75 - 120	
trans-1,3-Dichloropropene	24.3	20	84	61 - 120	
1,1,2-Trichloroethane	25.0	24	96	59 - 135	
Tetrachloroethene	25.0	24	98	65 - 120	
1,3-Dichloropropane	25.0	23	92	73 - 120	
2-Hexanone	25.0	27	109	54 - 139	
Dibromochloromethane	25.0	26	104	57 - 132	
1,2-Dibromoethane	25.0	24	97	68 - 125	
Chlorobenzene	25.0	24	95	75 - 120	
1,1,1,2-Tetrachloroethane	25.0	25	100	72 - 120	
Ethylbenzene	25.0	23	91	75 - 120	
m&p-Xylene	50.0	44	88	75 - 120	
o-Xylene	25.0	22	90	75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Control Spike - Batch: 500-20756

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-20756/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/16/2007 1029
Date Prepared: 08/16/2007 1029

Analysis Batch: 500-20756
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2S0815.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Styrene	25.0	24	96	77 - 120	
Bromoform	25.0	26	102	55 - 120	
Isopropylbenzene	25.0	19	77	68 - 120	
Bromobenzene	25.0	24	95	76 - 120	
1,1,2,2-Tetrachloroethane	25.0	22	89	68 - 120	
1,2,3-Trichloropropane	25.0	23	93	70 - 120	
N-Propylbenzene	25.0	21	83	74 - 120	
2-Chlorotoluene	25.0	21	83	74 - 120	
1,3,5-Trimethylbenzene	25.0	22	89	76 - 120	
4-Chlorotoluene	25.0	21	83	75 - 120	
tert-Butylbenzene	25.0	22	87	75 - 120	
1,2,4-Trimethylbenzene	25.0	22	90	76 - 120	
sec-Butylbenzene	25.0	22	88	73 - 120	
1,3-Dichlorobenzene	25.0	24	96	76 - 120	
p-Isopropyltoluene	25.0	23	90	71 - 120	
1,4-Dichlorobenzene	25.0	23	92	74 - 120	
n-Butylbenzene	25.0	23	90	68 - 120	
1,2-Dichlorobenzene	25.0	24	96	74 - 120	
1,2-Dibromo-3-Chloropropane	25.0	22	87	60 - 120	
1,2,4-Trichlorobenzene	25.0	29	117	63 - 120	
Hexachlorobutadiene	25.0	29	114	54 - 131	
Naphthalene	25.0	24	95	50 - 120	
1,2,3-Trichlorobenzene	25.0	28	112	62 - 120	
Surrogate		% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)		107		70 - 125	
Toluene-d8 (Surr)		103		75 - 120	
4-Bromofluorobenzene (Surr)		103		75 - 120	
Dibromofluoromethane		108		75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Method Blank - Batch: 500-20851

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-20851/3
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/17/2007 1045
Date Prepared: 08/17/2007 1045

Analysis Batch: 500-20851
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2M0817.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.23	1.0
Dichlorodifluoromethane	<1.0		0.12	1.0
Chloromethane	<1.0		0.20	1.0
Vinyl chloride	<1.0		0.16	1.0
Bromomethane	<1.0		0.59	1.0
Chloroethane	<1.0		0.32	1.0
Trichlorofluoromethane	<1.0		0.14	1.0
1,1-Dichloroethene	<1.0		0.25	1.0
Carbon disulfide	<5.0		0.15	5.0
Acetone	<5.0		1.4	5.0
Methylene Chloride	<1.0		0.24	1.0
trans-1,2-Dichloroethene	<1.0		0.29	1.0
1,1-Dichloroethane	<1.0		0.15	1.0
2,2-Dichloropropane	<1.0		0.17	1.0
cis-1,2-Dichloroethene	<1.0		0.20	1.0
2-Butanone (MEK)	<5.0		1.0	5.0
Bromochloromethane	<1.0		0.27	1.0
Chloroform	<1.0		0.14	1.0
1,1,1-Trichloroethane	<1.0		0.17	1.0
1,1-Dichloropropene	<1.0		0.38	1.0
Carbon tetrachloride	<1.0		0.34	1.0
1,2-Dichloroethane	<1.0		0.25	1.0
Trichloroethene	<1.0		0.13	1.0
1,2-Dichloropropane	<1.0		0.19	1.0
Dibromomethane	<1.0		0.21	1.0
Bromodichloromethane	<1.0		0.22	1.0
cis-1,3-Dichloropropene	<1.0		0.15	1.0
4-Methyl-2-pentanone (MIBK)	<5.0		0.92	5.0
Toluene	<1.0		0.18	1.0
trans-1,3-Dichloropropene	<1.0		0.16	1.0
1,1,2-Trichloroethane	<1.0		0.24	1.0
Tetrachloroethene	<1.0		0.18	1.0
1,3-Dichloropropane	<1.0		0.22	1.0
2-Hexanone	<5.0		0.99	5.0
Dibromochloromethane	<1.0		0.22	1.0
1,2-Dibromoethane	<1.0		0.33	1.0
Chlorobenzene	<1.0		0.15	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.33	1.0
Ethylbenzene	<1.0		0.21	1.0
m&p-Xylene	<2.0		0.36	2.0
o-Xylene	<1.0		0.19	1.0

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Method Blank - Batch: 500-20851

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-20851/3
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/17/2007 1045
Date Prepared: 08/17/2007 1045

Analysis Batch: 500-20851
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2M0817.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Styrene	<1.0		0.18	1.0
Bromoform	<1.0		0.32	1.0
Isopropylbenzene	<1.0		0.20	1.0
Bromobenzene	<1.0		0.22	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.34	1.0
1,2,3-Trichloropropane	<1.0		0.35	1.0
N-Propylbenzene	<1.0		0.16	1.0
2-Chlorotoluene	<1.0		0.16	1.0
1,3,5-Trimethylbenzene	<1.0		0.18	1.0
4-Chlorotoluene	<1.0		0.18	1.0
tert-Butylbenzene	<1.0		0.16	1.0
1,2,4-Trimethylbenzene	<1.0		0.26	1.0
sec-Butylbenzene	<1.0		0.19	1.0
1,3-Dichlorobenzene	<1.0		0.21	1.0
p-Isopropyltoluene	<1.0		0.29	1.0
1,4-Dichlorobenzene	<1.0		0.25	1.0
n-Butylbenzene	<1.0		0.35	1.0
1,2-Dichlorobenzene	<1.0		0.29	1.0
1,2-Dibromo-3-Chloropropane	<1.0		0.41	1.0
1,2,4-Trichlorobenzene	<1.0		0.36	1.0
Hexachlorobutadiene	<1.0		0.36	1.0
Naphthalene	<1.0		0.37	1.0
1,2,3-Trichlorobenzene	<1.0		0.43	1.0

Surrogate	% Rec	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	107	70 - 125
Toluene-d8 (Surr)	102	75 - 120
4-Bromofluorobenzene (Surr)	101	75 - 120
Dibromofluoromethane	108	75 - 120

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Control Spike - Batch: 500-20851

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-20851/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/17/2007 1132
Date Prepared: 08/17/2007 1132

Analysis Batch: 500-20851
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2S0817.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	25.0	20.3	81	68 - 120	
Dichlorodifluoromethane	25.0	18.4	74	21 - 178	
Chloromethane	25.0	21.8	87	50 - 140	
Vinyl chloride	25.0	21.4	86	57 - 135	
Bromomethane	25.0	23.8	95	61 - 172	
Chloroethane	25.0	21.6	86	56 - 152	
Trichlorofluoromethane	25.0	24.3	97	58 - 147	
1,1-Dichloroethene	25.0	19.0	76	50 - 121	
Carbon disulfide	25.0	21.3	85	33 - 120	
Acetone	25.0	23.6	95	22 - 175	
Methylene Chloride	25.0	22.6	90	52 - 126	
trans-1,2-Dichloroethene	25.0	20.3	81	57 - 122	
1,1-Dichloroethane	25.0	19.2	77	63 - 121	
2,2-Dichloropropane	25.0	16.5	66	56 - 134	
cis-1,2-Dichloroethene	25.0	20.4	82	62 - 127	
2-Butanone (MEK)	25.0	23.2	93	36 - 157	
Bromochloromethane	25.0	22.7	91	61 - 125	
Chloroform	25.0	19.5	78	65 - 127	
1,1,1-Trichloroethane	25.0	18.8	75	65 - 129	
1,1-Dichloropropene	25.0	17.9	72	62 - 122	
Carbon tetrachloride	25.0	20.4	82	67 - 121	
1,2-Dichloroethane	25.0	21.1	85	68 - 120	
Trichloroethene	25.0	21.7	87	73 - 120	
1,2-Dichloropropane	25.0	21.0	84	72 - 120	
Dibromomethane	25.0	21.1	84	71 - 120	
Bromodichloromethane	25.0	22.8	91	71 - 131	
cis-1,3-Dichloropropene	26.9	20.0	75	60 - 120	
4-Methyl-2-pentanone (MIBK)	25.0	23.9	96	65 - 128	
Toluene	25.0	19.9	79	75 - 120	
trans-1,3-Dichloropropene	24.3	18.4	76	61 - 120	
1,1,2-Trichloroethane	25.0	20.8	83	59 - 135	
Tetrachloroethene	25.0	22.0	88	65 - 120	
1,3-Dichloropropane	25.0	21.6	86	73 - 120	
2-Hexanone	25.0	23.3	93	54 - 139	
Dibromochloromethane	25.0	23.4	93	57 - 132	
1,2-Dibromoethane	25.0	21.7	87	68 - 125	
Chlorobenzene	25.0	21.6	87	75 - 120	
1,1,1,2-Tetrachloroethane	25.0	22.8	91	72 - 120	
Ethylbenzene	25.0	20.5	82	75 - 120	
m&p-Xylene	50.0	39.4	79	75 - 120	
o-Xylene	25.0	20.3	81	75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Control Spike - Batch: 500-20851

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-20851/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/17/2007 1132
Date Prepared: 08/17/2007 1132

Analysis Batch: 500-20851
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2S0817.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Styrene	25.0	21.5	86	77 - 120	
Bromoform	25.0	23.3	93	55 - 120	
Isopropylbenzene	25.0	16.6	67	68 - 120	*
Bromobenzene	25.0	20.8	83	76 - 120	
1,1,2,2-Tetrachloroethane	25.0	19.4	78	68 - 120	
1,2,3-Trichloropropane	25.0	20.4	82	70 - 120	
N-Propylbenzene	25.0	17.8	71	74 - 120	*
2-Chlorotoluene	25.0	18.0	72	74 - 120	*
1,3,5-Trimethylbenzene	25.0	19.3	77	76 - 120	
4-Chlorotoluene	25.0	18.1	72	75 - 120	*
tert-Butylbenzene	25.0	18.9	76	75 - 120	
1,2,4-Trimethylbenzene	25.0	19.3	77	76 - 120	
sec-Butylbenzene	25.0	18.9	76	73 - 120	
1,3-Dichlorobenzene	25.0	20.3	81	76 - 120	
p-Isopropyltoluene	25.0	19.7	79	71 - 120	
1,4-Dichlorobenzene	25.0	19.7	79	74 - 120	
n-Butylbenzene	25.0	19.7	79	68 - 120	
1,2-Dichlorobenzene	25.0	21.3	85	74 - 120	
1,2-Dibromo-3-Chloropropane	25.0	18.4	73	60 - 120	
1,2,4-Trichlorobenzene	25.0	26.3	105	63 - 120	
Hexachlorobutadiene	25.0	25.0	100	54 - 131	
Naphthalene	25.0	21.1	85	50 - 120	
1,2,3-Trichlorobenzene	25.0	24.8	99	62 - 120	
Surrogate		% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)		108		70 - 125	
Toluene-d8 (Surr)		104		75 - 120	
4-Bromofluorobenzene (Surr)		106		75 - 120	
Dibromofluoromethane		103		75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Method Blank - Batch: 500-20970

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-20970/3
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/20/2007 1039
Date Prepared: 08/20/2007 1039

Analysis Batch: 500-20970
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2M0820.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.23	1.0
Dichlorodifluoromethane	<1.0		0.12	1.0
Chloromethane	<1.0		0.20	1.0
Vinyl chloride	<1.0		0.16	1.0
Bromomethane	<1.0		0.59	1.0
Chloroethane	<1.0		0.32	1.0
Trichlorofluoromethane	<1.0		0.14	1.0
1,1-Dichloroethene	<1.0		0.25	1.0
Carbon disulfide	<5.0		0.15	5.0
Acetone	<5.0		1.4	5.0
Methylene Chloride	<1.0		0.24	1.0
trans-1,2-Dichloroethene	<1.0		0.29	1.0
1,1-Dichloroethane	<1.0		0.15	1.0
2,2-Dichloropropane	<1.0		0.17	1.0
cis-1,2-Dichloroethene	<1.0		0.20	1.0
2-Butanone (MEK)	<5.0		1.0	5.0
Bromochloromethane	<1.0		0.27	1.0
Chloroform	<1.0		0.14	1.0
1,1,1-Trichloroethane	<1.0		0.17	1.0
1,1-Dichloropropene	<1.0		0.38	1.0
Carbon tetrachloride	<1.0		0.34	1.0
1,2-Dichloroethane	<1.0		0.25	1.0
Trichloroethene	<1.0		0.13	1.0
1,2-Dichloropropane	<1.0		0.19	1.0
Dibromomethane	<1.0		0.21	1.0
Bromodichloromethane	<1.0		0.22	1.0
cis-1,3-Dichloropropene	<1.0		0.15	1.0
4-Methyl-2-pentanone (MIBK)	<5.0		0.92	5.0
Toluene	<1.0		0.18	1.0
trans-1,3-Dichloropropene	<1.0		0.16	1.0
1,1,2-Trichloroethane	<1.0		0.24	1.0
Tetrachloroethene	<1.0		0.18	1.0
1,3-Dichloropropane	<1.0		0.22	1.0
2-Hexanone	<5.0		0.99	5.0
Dibromochloromethane	<1.0		0.22	1.0
1,2-Dibromoethane	<1.0		0.33	1.0
Chlorobenzene	<1.0		0.15	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.33	1.0
Ethylbenzene	<1.0		0.21	1.0
m&p-Xylene	<2.0		0.36	2.0
o-Xylene	<1.0		0.19	1.0

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Method Blank - Batch: 500-20970

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-20970/3
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/20/2007 1039
Date Prepared: 08/20/2007 1039

Analysis Batch: 500-20970
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2M0820.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Styrene	<1.0		0.18	1.0
Bromoform	<1.0		0.32	1.0
Isopropylbenzene	<1.0		0.20	1.0
Bromobenzene	<1.0		0.22	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.34	1.0
1,2,3-Trichloropropane	<1.0		0.35	1.0
N-Propylbenzene	<1.0		0.16	1.0
2-Chlorotoluene	<1.0		0.16	1.0
1,3,5-Trimethylbenzene	<1.0		0.18	1.0
4-Chlorotoluene	<1.0		0.18	1.0
tert-Butylbenzene	<1.0		0.16	1.0
1,2,4-Trimethylbenzene	<1.0		0.26	1.0
sec-Butylbenzene	<1.0		0.19	1.0
1,3-Dichlorobenzene	<1.0		0.21	1.0
p-Isopropyltoluene	<1.0		0.29	1.0
1,4-Dichlorobenzene	<1.0		0.25	1.0
n-Butylbenzene	<1.0		0.35	1.0
1,2-Dichlorobenzene	<1.0		0.29	1.0
1,2-Dibromo-3-Chloropropane	<1.0		0.41	1.0
1,2,4-Trichlorobenzene	<1.0		0.36	1.0
Hexachlorobutadiene	<1.0		0.36	1.0
Naphthalene	<1.0		0.37	1.0
1,2,3-Trichlorobenzene	<1.0		0.43	1.0

Surrogate	% Rec	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	107	70 - 125
Toluene-d8 (Surr)	102	75 - 120
4-Bromofluorobenzene (Surr)	99	75 - 120
Dibromofluoromethane	108	75 - 120

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Control Spike - Batch: 500-20970

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-20970/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/20/2007 1102
Date Prepared: 08/20/2007 1102

Analysis Batch: 500-20970
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2S0820.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	25.0	25.3	101	68 - 120	
Dichlorodifluoromethane	25.0	9.46	38	21 - 178	
Chloromethane	25.0	17.2	69	50 - 140	
Vinyl chloride	25.0	17.2	69	57 - 135	
Bromomethane	25.0	19.8	79	61 - 172	
Chloroethane	25.0	18.6	74	56 - 152	
Trichlorofluoromethane	25.0	21.9	88	58 - 147	
1,1-Dichloroethene	25.0	22.8	91	50 - 121	
Carbon disulfide	25.0	25.7	103	33 - 120	
Acetone	25.0	24.1	96	22 - 175	
Methylene Chloride	25.0	26.1	104	52 - 126	
trans-1,2-Dichloroethene	25.0	25.0	100	57 - 122	
1,1-Dichloroethane	25.0	24.1	96	63 - 121	
2,2-Dichloropropane	25.0	20.2	81	56 - 134	
cis-1,2-Dichloroethene	25.0	26.2	105	62 - 127	
2-Butanone (MEK)	25.0	35.7	143	36 - 157	
Bromochloromethane	25.0	20.4	81	61 - 125	
Chloroform	25.0	24.9	100	65 - 127	
1,1,1-Trichloroethane	25.0	23.4	94	65 - 129	
1,1-Dichloropropene	25.0	22.0	88	62 - 122	
Carbon tetrachloride	25.0	25.2	101	67 - 121	
1,2-Dichloroethane	25.0	26.1	105	68 - 120	
Trichloroethene	25.0	26.7	107	73 - 120	
1,2-Dichloropropane	25.0	27.1	108	72 - 120	
Dibromomethane	25.0	27.3	109	71 - 120	
Bromodichloromethane	25.0	29.0	116	71 - 131	
cis-1,3-Dichloropropene	26.9	25.4	95	60 - 120	
4-Methyl-2-pentanone (MIBK)	25.0	31.5	126	65 - 128	
Toluene	25.0	24.9	100	75 - 120	
trans-1,3-Dichloropropene	24.3	23.6	97	61 - 120	
1,1,2-Trichloroethane	25.0	26.7	107	59 - 135	
Tetrachloroethene	25.0	26.6	106	65 - 120	
1,3-Dichloropropane	25.0	26.8	107	73 - 120	
2-Hexanone	25.0	30.5	122	54 - 139	
Dibromochloromethane	25.0	30.1	120	57 - 132	
1,2-Dibromoethane	25.0	27.9	112	68 - 125	
Chlorobenzene	25.0	26.6	106	75 - 120	
1,1,1,2-Tetrachloroethane	25.0	27.7	111	72 - 120	
Ethylbenzene	25.0	25.1	100	75 - 120	
m&p-Xylene	50.0	47.7	95	75 - 120	
o-Xylene	25.0	24.7	99	75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Control Spike - Batch: 500-20970

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-20970/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/20/2007 1102
Date Prepared: 08/20/2007 1102

Analysis Batch: 500-20970
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2S0820.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Styrene	25.0	26.8	107	77 - 120	
Bromoform	25.0	29.3	117	55 - 120	
Isopropylbenzene	25.0	19.8	79	68 - 120	
Bromobenzene	25.0	26.7	107	76 - 120	
1,1,2,2-Tetrachloroethane	25.0	24.4	98	68 - 120	
1,2,3-Trichloropropane	25.0	26.0	104	70 - 120	
N-Propylbenzene	25.0	20.4	81	74 - 120	
2-Chlorotoluene	25.0	21.8	87	74 - 120	
1,3,5-Trimethylbenzene	25.0	21.9	88	76 - 120	
4-Chlorotoluene	25.0	21.4	85	75 - 120	
tert-Butylbenzene	25.0	20.8	83	75 - 120	
1,2,4-Trimethylbenzene	25.0	22.4	89	76 - 120	
sec-Butylbenzene	25.0	20.1	80	73 - 120	
1,3-Dichlorobenzene	25.0	24.4	98	76 - 120	
p-Isopropyltoluene	25.0	20.8	83	71 - 120	
1,4-Dichlorobenzene	25.0	23.8	95	74 - 120	
n-Butylbenzene	25.0	19.6	78	68 - 120	
1,2-Dichlorobenzene	25.0	25.5	102	74 - 120	
1,2-Dibromo-3-Chloropropane	25.0	24.5	98	60 - 120	
1,2,4-Trichlorobenzene	25.0	27.2	109	63 - 120	
Hexachlorobutadiene	25.0	24.9	100	54 - 131	
Naphthalene	25.0	24.7	99	50 - 120	
1,2,3-Trichlorobenzene	25.0	26.4	106	62 - 120	
Surrogate		% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)		108		70 - 125	
Toluene-d8 (Surr)		103		75 - 120	
4-Bromofluorobenzene (Surr)		104		75 - 120	
Dibromofluoromethane		105		75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

**SEVERN
TRENT
STL**

STL Chicago
2417 Bond Street
University Park, IL 60466
Phone: 708-534-5200
Fax: 708-534-5211

Report To:

Contact: Greg Flisinski
Company: Weston
Address: 1400 King St.
W Chester PA
Phone: 610-701-7293
Fax: _____
E-Mail: _____

Bill To:

Contact: _____
Company: _____
Address: _____
Phone: _____
Fax: _____
PO#: _____ Quota: _____

Shaded Areas For Internal Use Only

Lab Lot# 500-5884

Package Sealed <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Samples Sealed <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Received on Ice <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Samples Intact <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Temperature °C of Cooler <u>3.0</u>	
Within Hold Time <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Preserv. Indicated <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
pH Check OK <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	Res Cl ₂ Check OK <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Sample Labels and COC Agree <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> COC not present	

08/23/2007

Sampler Name: Greg Flisinski Signature: _____
Project Name: Black + Decker Project Number: 62501.004.004.0700
Project Location: Thurpstead Md Date Required: _____
Lab PM: _____ Hard Copy: _____ Fax: _____

Laboratory ID	MS-RSD	Client Sample ID	Sampling		Matrix	Comp/Grab	Retrg #	N / Cont.	Volume	Preserv
			Date	Time						
1		RFW-1A	8/6/07	810	W					
2		RFW-1B		1725						
3		RFW-2A		900						
4		RFW-2B		920						
5		RFW-3B		1815						
6		RFW-4A	8/7/07	845						
7		RFW-4B		950						
8		RFW-4B Dup		950						
9		RFW-6	8/8/07	700						
10		RFW-7	8/8/07	955						
11		RFW-9		1725						
12		RFW-11B	8/7/07	0715						

Additional Analyses / Remarks

Page 8B of 91

RELINQUISHED BY: <u>[Signature]</u>	COMPANY: _____	DATE: _____	TIME: _____	RECEIVED BY: <u>[Signature]</u>	COMPANY: <u>TAL</u>	DATE: <u>8/9/07</u>	TIME: <u>0950</u>
RELINQUISHED BY: _____	COMPANY: _____	DATE: _____	TIME: _____	RECEIVED BY: _____	COMPANY: _____	DATE: _____	TIME: _____

- Matrix Key**
- WW = Wastewater
 - W = Water
 - S = Sol
 - SL = Sludge
 - MS = Miscellaneous
 - OL = Oil
 - A = Air
 - SE = Sediment
 - SO = Sodic
 - DS = Drurr Solid
 - DL = Drurr Liquid
 - L = Leachate
 - WI = Wipe
 - O = _____

- Container Key**
1. Plastic
 2. VOA Vial
 3. Sterile Plastic
 4. Amber Glass
 5. Wadsworth Glass
 6. Other

- Preservative Key**
1. HCl, Cool to 4°
 2. H2SO4, Cool to 4°
 3. HNO3, Cool to 4°
 4. NaOH, Cool to 4°
 5. NaOH/Zn, Cool to 4°
 6. Cool to 4°
 7. None

COMMENTS

Date Received 8/9/07
Courier: Ex Hand Delivered
Bill of Lading see attached

**SEVERN
TRENT** **STL**

STL Chicago
2417 Bond Street
University Park, IL 60466
Phone: 708-534-5200
Fax: 708-534-5211

Contact: _____
Company: _____
Address: _____
Phone: _____
Fax: _____
E-Mail: _____

*Save as
Page 1*

Contact: _____
Company: _____
Address: _____
Phone: _____
Fax: _____
PO#: _____ Quote: _____

Lab Lot# **500-5884**

Package Sealed Yes No	Samples Sealed Yes No
Received on Ice Yes No	Samples Intact Yes No

Temperature °C of Cooler

Within Hold Time Yes No	Preserv. Indicated Yes No NA
pH Check OK Yes No NA	Res Cl ₂ Check OK Yes No NA

Sample Labels and COC Agree
Yes No COC not present

Additional Analyses / Remarks

Sampler Name:		Signature:		Refr #											Within Hold Time		Preserv. Indicated			
Project Name:		Project Number:		# / Cont.											Yes No		Yes No NA			
Project Location:		Date Required		Volume											pH Check OK		Res Cl ₂ Check OK			
Lab PM:		Hard Copy:		Preserv											Yes No NA		Yes No NA			
Laboratory ID	MS-MSD	Client Sample ID	Sampling		Matrix	Comp/Grab											Sample Labels and COC Agree		COC not present	
			Date	Time													Yes No		COC not present	
13		RFW-12B	8/2/07	935	W															
14		RFW-13	8/6/07	1435																
15		RFW-17		1030																
16		EW-2	8/2/07	940																
17		EW-3		950																
18		EW-4		1000																
19		EW-5		1010																
20		EW-6		1139																
21		EW-7		1215																
22		EW-8		1320																
23		EW-9		1240																
24		EW-9		1240																

RELINQUISHED BY: <i>[Signature]</i>	COMPANY: <i>[Signature]</i>	DATE: <i>8/8/07</i>	TIME:	RECEIVED BY: <i>[Signature]</i>	COMPANY: <i>[Signature]</i>	DATE: <i>8/9/07</i>	TIME: <i>0950</i>
RELINQUISHED BY:	COMPANY:	DATE:	TIME:	RECEIVED BY:	COMPANY:	DATE:	TIME:

- | | | | |
|--|---|---|---|
| <p>Matrix Key</p> <p>WW = Wastewater
W = Water
S = Soil
SL = Sludge
MS = Miscellaneous
CL = Oil
A = Air</p> | <p>SE = Sediment
SO = Solid
DS = Drum Solid
DL = Drum Liquid
L = Leachate
W = Wipe
O =</p> | <p>Container Key</p> <p>1. Plastic
2. VOA Vial
3. Sterile Plastic
4. Amber Glass
5. Widemouth Glass
6. Other</p> | <p>Preservative Key</p> <p>1. HC, Cool to 4°
2. H2SO4, Cool to 4°
3. HNO3, Cool to 4°
4. NaOH, Cool to 4°
5. NaOH/Zn, Cool to 4°
6. Cool to 4°
7. None</p> |
|--|---|---|---|

COMMENTS

Date Received *8/9/07*

Courier: *FX* Hand Delivered

Bill of Lading

SEVERN TREN **STL**

STL Chicago
 2417 Banc Street
 University Park, IL 60466
 Phone: 708-534-5200
 Fax: 708-534-5211

Contact: See Page 1
 Company: _____
 Address: _____
 Phone: _____
 Fax: _____
 E-Mail: _____

Contact: _____
 Company: _____
 Address: _____
 Phone: _____
 Fax: _____
 PO#: _____ Quote: _____

Lab Lot# **500-5884**

Package Sealed Yes No	Samples Sealed Yes No
Received on Ice Yes No	Samples Intact Yes No
Temperature °C of Cooler	

08/23/07

Sampler Name: Greg Flasinski		Signature: _____		Reg #	
Project Name: Black & Decker		Project Number:		# / Cont.	2
Project Location: Hampstead, Md		Data Required Hard Copy: _____ Fax: _____		Values	Yacht
Lab PM:				Preserv	HCl

Within Hold Time Yes No	Preserv. Indicated Yes No NA
pH Check OK Yes No NA	Res Cl ₂ Check OK Yes No NA
Sample Labels and COC Agree Yes No COC not present	

Laboratory ID	MS-MSD	Client Sample ID	Sampling		Matrix	Comp/Grab	VOA											Additional Analyses / Remarks
			Date	Time														
25		EW-10	8/7/07	1225	W													
26		Leister-1	8/6/07	1315														
27		Leister-Dummy	8/6/07	1320														
28		TRIP Blank																added by TAL

Page 90 of 91

RELINQUISHED BY: <u>[Signature]</u>	COMPANY	DATE: 8/8/07	TIME	RECEIVED BY: <u>[Signature]</u>	COMPANY: TAL	DATE: 8/9/07	TIME: 0950
RELINQUISHED BY: _____	COMPANY	DATE: _____	TIME	RECEIVED BY: _____	COMPANY	DATE	TIME

- | | | |
|---|--|--|
| <p>Matrix Key</p> <ul style="list-style-type: none"> WW - Wastewater W - Water S - Soil SL - S Ldge MS - Miscellaneous OL - Oil A - Air | <p>Container Key</p> <ul style="list-style-type: none"> 1. Plastic 2. VOA Vial 3. Sterile Plastic 4. Amber Glass 5. Wide-mouth Glass 6. Other | <p>Preservative Key</p> <ul style="list-style-type: none"> 1. HCl, Cool to 4° 2. H₂SO₄, Cool to 4° 3. HNO₃, Cool to 4° 4. NaOH, Cool to 4° 5. NaOH/Zn, Cool to 4° 6. Cool to 4° 7. None |
| <ul style="list-style-type: none"> SE = Sediment SD = Solid DS = Drum Solid DL = Drum Liquid L = Leachate WI = Wipe O = | | |

COMMENTS _____

Date Received **8/9/07**

Courier: **FX** Hand Delivered

Bill of Lading _____

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Login Number: 5884

Question	T/F/NA	Comment
Radioactivity either was not measured or, if measured, is at or below background	True	
The cooler's custody seal, if present, is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	3.0
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	True	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	

ANALYTICAL REPORT


Job Number: 680-29067-1

Job Description: Black & Decker

For:

Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Attention: Greg Flasiński



Designee for

Abbie Page

Project Manager I

abbie.page@testamericainc.com

08/21/2007

The test results in this report meet all NELAP requirements for parameters for which accreditation is required or available. Any exceptions to NELAP requirements are noted in this report. Pursuant to NELAP, this report may not be reproduced, except in full, without the written approval of the laboratory. All questions regarding this report should be directed to the TestAmerica Project Manager who signed this report.

TestAmerica Laboratories, Inc.

TestAmerica Savannah 5102 LaRoche Avenue, Savannah, GA 31404
Tel (912) 354-7858 Fax (912) 352-0165 www.testamericainc.com

METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Description	Lab Location	Method	Preparation Method
Matrix Water			
Purgeable Organic Compounds in Water by GC/MS	TAL SAV	EPA-DW 524.2	

Lab References:

TAL SAV = TestAmerica Savannah

Method References:

EPA-DW = "Methods For The Determination Of Organic Compounds In Drinking Water", EPA/600/4-88/039, December 1988 And Its Supplements.

SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

<u>Lab Sample ID</u>	<u>Client Sample ID</u>	<u>Client Matrix</u>	<u>Date/Time Sampled</u>	<u>Date/Time Received</u>
680-29067-1	RFW-20	Drinking Water	08/06/2007 1735	08/09/2007 0940
680-29067-2	RFW-21	Drinking Water	08/06/2007 1310	08/09/2007 0940
680-29067-3	Hamp-22	Drinking Water	08/07/2007 1040	08/09/2007 0940
680-29067-4	Hamp-23	Drinking Water	08/07/2007 1045	08/09/2007 0940
680-29067-5TB	Trip Blank	Drinking Water	08/06/2007 0900	08/09/2007 0940

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Client Sample ID: RFW-20

Lab Sample ID: 680-29067-1

Date Sampled: 08/06/2007 1735

Client Matrix: Drinking Water

Date Received: 08/09/2007 0940

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-83051

Instrument ID: GC/MS Volatiles - U

Preparation: N/A

Lab File ID: u6066.d

Dilution: 1.0

Initial Weight/Volume: 5 mL

Date Analyzed: 08/16/2007 0939

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0		0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
Methyl Ethyl Ketone	<10		5.0	10
methyl isobutyl ketone	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.13	1.0

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Client Sample ID: RFW-20

Lab Sample ID: 680-29067-1
Client Matrix: Drinking Water

Date Sampled: 08/06/2007 1735
Date Received: 08/09/2007 0940

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch: 680-83051	Instrument ID:	GC/MS Volatiles - U
Preparation:	N/A		Lab File ID:	u6066.d
Dilution:	1.0		Initial Weight/Volume:	5 mL
Date Analyzed:	08/16/2007 0939		Final Weight/Volume:	5 mL
Date Prepared:	N/A			

Analyte	Result (ug/L)	Qualifier	MDL	RL
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0		1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,4-Trichlorobenzene	<0.50		0.10	0.50
1,2,3-Trichlorobenzene	<0.50		0.12	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
Trichloroethene	1.0		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50

Surrogate	%Rec	Acceptance Limits
4-Bromofluorobenzene	92	70 - 130
1,2-Dichlorobenzene-d4	88	70 - 130

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Client Sample ID: RFW-21

Lab Sample ID: 680-29067-2
Client Matrix: Drinking WaterDate Sampled: 08/06/2007 1310
Date Received: 08/09/2007 0940

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2 Analysis Batch: 680-83051 Instrument ID: GC/MS Volatiles - U
 Preparation: N/A Lab File ID: u6067.d
 Dilution: 1.0 Initial Weight/Volume: 5 mL
 Date Analyzed: 08/16/2007 0959 Final Weight/Volume: 5 mL
 Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0		0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
Methyl Ethyl Ketone	<10		5.0	10
methyl isobutyl ketone	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.13	1.0

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Client Sample ID: RFW-21

Lab Sample ID: 680-29067-2
 Client Matrix: Drinking Water

Date Sampled: 08/06/2007 1310
 Date Received: 08/09/2007 0940

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch: 680-83051	Instrument ID: GC/MS Volatiles - U
Preparation:	N/A		Lab File ID: u6067.d
Dilution:	1.0		Initial Weight/Volume: 5 mL
Date Analyzed:	08/16/2007 0959		Final Weight/Volume: 5 mL
Date Prepared:	N/A		

Analyte	Result (ug/L)	Qualifier	MDL	RL
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0		1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,4-Trichlorobenzene	<0.50		0.10	0.50
1,2,3-Trichlorobenzene	<0.50		0.12	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
Trichloroethene	<0.50		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50

Surrogate	%Rec	Acceptance Limits
4-Bromofluorobenzene	92	70 - 130
1,2-Dichlorobenzene-d4	86	70 - 130

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Client Sample ID: Hamp-22

Lab Sample ID: 680-29067-3

Date Sampled: 08/07/2007 1040

Client Matrix: Drinking Water

Date Received: 08/09/2007 0940

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-83051

Instrument ID: GC/MS Volatiles - U

Preparation: N/A

Lab File ID: u6068.d

Dilution: 1.0

Initial Weight/Volume: 5 mL

Date Analyzed: 08/16/2007 1019

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0		0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
Methyl Ethyl Ketone	<10		5.0	10
methyl isobutyl ketone	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.13	1.0

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Client Sample ID: Hamp-22

Lab Sample ID: 680-29067-3

Date Sampled: 08/07/2007 1040

Client Matrix: Drinking Water

Date Received: 08/09/2007 0940

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-83051

Instrument ID: GC/MS Volatiles - U

Preparation: N/A

Lab File ID: u6068.d

Dilution: 1.0

Initial Weight/Volume: 5 mL

Date Analyzed: 08/16/2007 1019

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	MDL	RL
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0		1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,4-Trichlorobenzene	<0.50		0.10	0.50
1,2,3-Trichlorobenzene	<0.50		0.12	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
Trichloroethene	<0.50		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50

Surrogate	%Rec	Acceptance Limits
4-Bromofluorobenzene	93	70 - 130
1,2-Dichlorobenzene-d4	89	70 - 130

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Client Sample ID: Hamp-23

Lab Sample ID: 680-29067-4
 Client Matrix: Drinking Water

Date Sampled: 08/07/2007 1045
 Date Received: 08/09/2007 0940

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2
 Preparation: N/A
 Dilution: 1.0
 Date Analyzed: 08/16/2007 1104
 Date Prepared: N/A

Analysis Batch: 680-83051

Instrument ID: GC/MS Volatiles - U
 Lab File ID: u6069.d
 Initial Weight/Volume: 5 mL
 Final Weight/Volume: .5 mL

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0		0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
Methyl Ethyl Ketone	<10		5.0	10
methyl isobutyl ketone	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.13	1.0

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Client Sample ID: Hamp-23

Lab Sample ID: 680-29067-4

Date Sampled: 08/07/2007 1045

Client Matrix: Drinking Water

Date Received: 08/09/2007 0940

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch: 680-83051	Instrument ID:	GC/MS Volatiles - U
Preparation:	N/A		Lab File ID:	u6069.d
Dilution:	1.0		Initial Weight/Volume:	5 mL
Date Analyzed:	08/16/2007 1104		Final Weight/Volume:	5 mL
Date Prepared:	N/A			

Analyte	Result (ug/L)	Qualifier	MDL	RL
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0		1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,4-Trichlorobenzene	<0.50		0.10	0.50
1,2,3-Trichlorobenzene	<0.50		0.12	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
Trichloroethene	<0.50		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50

Surrogate	%Rec	Acceptance Limits
4-Bromofluorobenzene	96	70 - 130
1,2-Dichlorobenzene-d4	92	70 - 130

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-29067-5TB

Date Sampled: 08/06/2007 0900

Client Matrix: Drinking Water

Date Received: 08/09/2007 0940

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-83051

Instrument ID: GC/MS Volatiles - U

Preparation: N/A

Lab File ID: u6065.d

Dilution: 1.0

Initial Weight/Volume: 5 mL

Date Analyzed: 08/16/2007 0920

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0		0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
Methyl Ethyl Ketone	<10		5.0	10
methyl isobutyl ketone	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.13	1.0

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-29067-5TB

Date Sampled: 08/06/2007 0900

Client Matrix: Drinking Water

Date Received: 08/09/2007 0940

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch: 680-83051	Instrument ID:	GC/MS Volatiles - U
Preparation:	N/A		Lab File ID:	u6065.d
Dilution:	1.0		Initial Weight/Volume:	5 mL
Date Analyzed:	08/16/2007 0920		Final Weight/Volume:	5 mL
Date Prepared:	N/A			

Analyte	Result (ug/L)	Qualifier	MDL	RL
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0		1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,4-Trichlorobenzene	<0.50		0.10	0.50
1,2,3-Trichlorobenzene	<0.50		0.12	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
Trichloroethene	<0.50		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50

Surrogate	%Rec	Acceptance Limits
4-Bromofluorobenzene	92	70 - 130
1,2-Dichlorobenzene-d4	88	70 - 130

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Surrogate Recovery Report

524.2 Purgeable Organic Compounds in Water by GC/MS

Client Matrix: Water

<u>Lab Sample ID</u>	<u>Client Sample ID</u>	<u>12DCB %Rec</u>	<u>BFB %Rec</u>
LCS 680-83051/7		98	99
MB 680-83051/8		89	93
680-29067-1	RFW-20	88	92
680-29067-2	RFW-21	86	92
680-29067-3	Hamp-22	89	93
680-29067-4	Hamp-23	92	96
680-29067-5	Trip Blank	88	92

<u>Surrogate</u>		<u>Acceptance Limits</u>
12DCB	1,2-Dichlorobenzene-d4	70 - 130
BFB	4-Bromofluorobenzene	70 - 130

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Method Blank - Batch: 680-83051

Method: 524.2

Preparation: N/A

Lab Sample ID: MB 680-83051/8

Analysis Batch: 680-83051

Instrument ID: GC/MS Volatiles - U

Client Matrix: Water

Prep Batch: N/A

Lab File ID: uq2091.d

Dilution: 1.0

Units: ug/L

Initial Weight/Volume: 5 mL

Date Analyzed: 08/16/2007 0602

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result	Qual	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0		0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
Methyl Ethyl Ketone	<10		5.0	10

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Method Blank - Batch: 680-83051

Method: 524.2
Preparation: N/A

Lab Sample ID: MB 680-83051/8
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 08/16/2007 0602
Date Prepared: N/A

Analysis Batch: 680-83051
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - U
Lab File ID: uq2091.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	Result	Qual	MDL	RL
methyl isobutyl ketone	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.13	1.0
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0		1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,3-Trichlorobenzene	<0.50		0.12	0.50
1,2,4-Trichlorobenzene	<0.50		0.10	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
Trichloroethene	<0.50		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50

Surrogate	% Rec	Acceptance Limits
4-Bromofluorobenzene	93	70 - 130
1,2-Dichlorobenzene-d4	89	70 - 130

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Lab Control Spike - Batch: 680-83051

Method: 524.2

Preparation: N/A

Lab Sample ID: LCS 680-83051/7
 Client Matrix: Water
 Dilution: 1.0
 Date Analyzed: 08/16/2007 0522
 Date Prepared: N/A

Analysis Batch: 680-83051
 Prep Batch: N/A
 Units: ug/L

Instrument ID: GC/MS Volatiles - U
 Lab File ID: uq2090.d
 Initial Weight/Volume: 5 mL
 Final Weight/Volume: 5 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Acetone	40.0	38.9	97	70 - 130	
Benzene	20.0	18.4	92	70 - 130	
Bromobenzene	20.0	18.8	94	70 - 130	
Bromoform	20.0	17.4	87	70 - 130	
Bromomethane	20.0	17.7	89	70 - 130	
Carbon tetrachloride	20.0	20.1	101	70 - 130	
Chlorobenzene	20.0	18.7	94	70 - 130	
Chlorobromomethane	20.0	19.1	95	70 - 130	
Chlorodibromomethane	20.0	18.3	91	70 - 130	
Chloroethane	20.0	22.1	111	70 - 130	
Chloroform	20.0	18.6	93	70 - 130	
Chloromethane	20.0	17.9	90	70 - 130	
2-Chlorotoluene	20.0	18.8	94	70 - 130	
4-Chlorotoluene	20.0	19.1	96	70 - 130	
cis-1,2-Dichloroethene	20.0	17.5	87	70 - 130	
cis-1,3-Dichloropropene	20.0	19.3	97	70 - 130	
1,2-Dibromo-3-Chloropropane	20.0	18.1	90	70 - 130	
Dibromomethane	20.0	19.2	96	70 - 130	
1,2-Dichlorobenzene	20.0	18.9	95	70 - 130	
1,3-Dichlorobenzene	20.0	18.8	94	70 - 130	
1,4-Dichlorobenzene	20.0	18.9	95	70 - 130	
Dichlorobromomethane	20.0	19.0	95	70 - 130	
Dichlorodifluoromethane	20.0	17.9	90	70 - 130	
1,1-Dichloroethane	20.0	18.8	94	70 - 130	
1,2-Dichloroethane	20.0	20.3	101	70 - 130	
1,1-Dichloroethene	20.0	19.0	95	70 - 130	
1,2-Dichloropropane	20.0	18.7	94	70 - 130	
1,3-Dichloropropane	20.0	19.1	95	70 - 130	
2,2-Dichloropropane	20.0	19.2	96	70 - 130	
1,1-Dichloropropene	20.0	19.4	97	70 - 130	
1,3-Dichloropropene, Total	40.0	39.4	99	70 - 130	
Diisopropyl ether	16.0	15.4	96	70 - 130	
Ethylbenzene	20.0	19.0	95	70 - 130	
Ethylene Dibromide	20.0	18.7	94	70 - 130	
Freon 113	16.0	19.0	119	70 - 130	
Hexachlorobutadiene	20.0	18.7	94	70 - 130	
2-Hexanone	40.0	33.7	84	70 - 130	
Isopropylbenzene	20.0	19.2	96	70 - 130	
4-Isopropyltoluene	20.0	19.9	100	70 - 130	
Methylene Chloride	20.0	18.5	92	70 - 130	
Methyl Ethyl Ketone	40.0	34.1	85	70 - 130	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-29067-1

Lab Control Spike - Batch: 680-83051

Method: 524.2

Preparation: N/A

Lab Sample ID: LCS 680-83051/7
 Client Matrix: Water
 Dilution: 1.0
 Date Analyzed: 08/16/2007 0522
 Date Prepared: N/A

Analysis Batch: 680-83051
 Prep Batch: N/A
 Units: ug/L

Instrument ID: GC/MS Volatiles - U
 Lab File ID: uq2090.d
 Initial Weight/Volume: 5 mL
 Final Weight/Volume: 5 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
methyl isobutyl ketone	40.0	35.3	88	70 - 130	
m-Xylene & p-Xylene	40.0	37.8	94	70 - 130	
Naphthalene	20.0	18.0	90	70 - 130	
n-Butylbenzene	20.0	19.3	97	70 - 130	
N-Propylbenzene	20.0	19.4	97	70 - 130	
o-Xylene	20.0	19.0	95	70 - 130	
sec-Butylbenzene	20.0	19.5	97	70 - 130	
Styrene	20.0	19.5	97	70 - 130	
Tert-amyl methyl ether	16.0	15.3	95	70 - 130	
tert-Butyl alcohol	80.0	65.0	81	70 - 130	
tert-Butylbenzene	20.0	19.3	96	70 - 130	
Tert-butyl ethyl ether	16.0	15.3	95	70 - 130	
1,1,1,2-Tetrachloroethane	20.0	19.8	99	70 - 130	
1,1,2,2-Tetrachloroethane	20.0	18.5	93	70 - 130	
Tetrachloroethene	20.0	18.8	94	70 - 130	
Toluene	20.0	18.2	91	70 - 130	
trans-1,2-Dichloroethene	20.0	18.9	94	70 - 130	
trans-1,3-Dichloropropene	20.0	20.1	101	70 - 130	
1,2,3-Trichlorobenzene	20.0	18.8	94	70 - 130	
1,2,4-Trichlorobenzene	20.0	18.8	94	70 - 130	
1,1,1-Trichloroethane	20.0	19.2	96	70 - 130	
1,1,2-Trichloroethane	20.0	18.8	94	70 - 130	
Trichloroethene	20.0	18.2	91	70 - 130	
Trichlorofluoromethane	20.0	21.0	105	70 - 130	
1,2,3-Trichloropropane	20.0	18.3	91	70 - 130	
Trihalomethanes, Total	80.0	73.0	91	70 - 130	
1,2,4-Trimethylbenzene	20.0	19.5	98	70 - 130	
1,3,5-Trimethylbenzene	20.0	19.7	98	70 - 130	
Vinyl chloride	20.0	18.4	92	70 - 130	
Xylenes, Total	60.0	56.8	95	70 - 130	

Surrogate	% Rec	Acceptance Limits
4-Bromofluorobenzene	99	70 - 130
1,2-Dichlorobenzene-d4	98	70 - 130

Calculations are performed before rounding to avoid round-off errors in calculated results.

SEVERN
TRENT

STL

STL Chicago
2417 Bond Street
University Park, IL 60466
Phone: 708-534-5200
Fax: 708-534-5211

Report To: Greg Flasiński

Bill To:

Shaded Areas For Internal Use Only ____ of ____

Contact: Tom Cornuet
Company: Weston
Address: 1400 Weston Way
W Chester PA 19380
Phone: 610-701-7293
Fax:
E-Mail:

Contact:
Company:
Address:
Phone:
Fax:
PO#: Quote:

Lab Lot#	
Package Sealed Yes No	Samples Sealed Yes No
Received on Ice Yes No	Samples Intact Yes No
Temperature °C of Cooler	
Within Hold Time Yes No	Preserv. Indicated Yes No NA
pH Check OK Yes No NA	Res Cl ₂ Check OK Yes No NA
Sample Labels and COC Agree Yes No COC not present	
Additional Analyses / Remarks	

Laboratory ID	MS-MSD	Client Sample ID	Sampling		Matrix	Comp/Grab	Retrg #	#/Cont.	Volume	Preserv	Date	Time
			Date	Time								
		REW-20	8/6/07	1735	W	X		2	40ml	HCl		
		REW-21		1310		X						
		Hamp-22	8/7/07	1040		X						
		Hamp-23	8/7/07	1045		X						
		Trip Blank	8/6/07	900		X						

TEMP.: 5.3

680-29067

Page 19 of 19

RELINQUISHED BY: [Signature] COMPANY: Weston DATE: 8/7/07 TIME: 1600

RECEIVED BY: [Signature] COMPANY: _____ DATE: 8-9-07 TIME: 0940

- Matrix Key**
 WW = Wastewater SE = Sediment
 W = Water SO = Solid
 S = Soil DS = Drum Solid
 SL = Sludge DL = Drum Liquid
 MS = Miscellaneous L = Leachate
 OL = Oil WI = Wipe
 A = Air O = _____
- Container Key**
 1. Plastic
 2. VOA Vial
 3. Sterile Plastic
 4. Amber Glass
 5. Widemouth Glass
 6. Other
- Preservative Key**
 1. HCl, Cool to 4°
 2. H2SO4, Cool to 4°
 3. HNO3, Cool to 4°
 4. NaOH, Cool to 4°
 5. NaOH/Zn, Cool to 4°
 6. Cool to 4°
 7. None

COMMENTS

Date Received / /
 Courier: Hand Delivered
 Bill of Lading