

Quarterly Groundwater Monitoring Report

Prepared for
Black & Decker (U.S.) Inc.

Hampstead, Maryland

October 2011

Prepared by

WESTON SOLUTIONS, INC.
West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 3rd Quarter 2011	2-2
Table 2-2 Groundwater Elevation Data – 3rd Quarter 2011	2-3
Table 2-3 Effluent Characteristics Summary – 3rd Quarter 2011	2-4
Table 2-4 Summary of Groundwater Analytical Results - August 2011	2-5
Table 3-1 Treatment System Maintenance Activities – 3rd Quarter 2011	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of July through September 2011.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of July through September 2011, the extraction wells were pumping at an average combined rate of approximately 158 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of July through September 2011 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of July through September 2011, approximately 11.64 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (83 %) and tetrachloroethene (PCE) (17 %). Analytical results of the groundwater collected from the air stripper for the period of July through September 2011 are included in Appendix C.

A summary of the analytical results from the third quarter (August 2011) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 3rd Quarter 2011
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
July 2011	6,548,083
August 2011	6,654,014
September 2011	5,361,690

Table 2-2
Groundwater Elevation Data - 3rd Quarter 2011
Black & Decker
Hampstead, Maryland

WELL NO	TOC ELEV	TOTAL DEPTH	7/16/2011		8/24/2011		9/27/2011	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NC	DRY	NC	DRY	NC
EW-2	849.21	110	91.43	757.78	91.86	757.35	91.23	757.98
EW-3	846.64	118	88.43	758.21	88.82	757.82	88.76	757.88
EW-4	858.01	97.5	PC	NC	PC	NC	PC	NC
EW-5	864.17	98	90.50	773.67	89.87	774.30	90.43	773.74
EW-6	831.98	115	103.00	728.98	100.33	731.65	103.21	728.77
EW-7	818.38	78	71.60	746.78	71.34	747.04	70.77	747.61
EW-8	811.13	98	91.50	719.63	93.00	718.13	30.66*	811.13
EW-9	811.35	141	102.50	708.85	102.62	708.73	103.00	708.35
EW-10	807.74	INA	46.22	761.52	52.26	755.48	47.48	760.26
RFW-1A	864.37	78	51.15	813.22	52.81	811.56	52.68	811.69
RFW-1B	864.23	200	51.18	813.05	52.86	811.37	52.73	811.50
RFW-2A	857.41	35	13.10	844.31	17.32	840.09	16.94	840.47
RFW-2B	857.73	75	13.65	844.08	17.98	839.75	17.28	840.45
RFW-3B	839.21	153	37.41	801.80	37.26	801.95	34.32	804.89
RFW-4A	830.37	62	36.12	794.25	38.57	791.80	36.92	793.45
RFW-4B	830.37	120	36.05	794.32	38.52	791.85	36.85	793.52
RFW-5A	817.50	30	DRY	NC	DRY	NC	DRY	NC
RFW-6	785.04	120	4.10	780.94	4.89	780.15	3.90	781.14
RFW-7	805.14	29	7.94	797.20	7.10	798.04	6.98	798.16
RFW-8	860.07	56	DRY	NC	DRY	NC	DRY	NC
RFW-9	862.02	49	25.47	836.55	27.97	834.05	25.26	836.76
RFW-10	852.06	58	DRY	NC	DRY	NC	DRY	NC
RFW-11A	849.32	72	Damaged	NC	Damaged	NC	Damaged	NC
RFW-11B	849.62	116	64.23	785.39	64.58	785.04	64.08	785.54
RFW-12B	844.87	264	51.87	793.00	51.11	793.76	51.34	793.53
RFW-13	849.11	150	65.43	783.68	65.78	783.33	65.70	783.41
RFW-14B	812.39	281	58.47	753.92	49.77	762.62	52.63	759.76
RFW-16	856.14	41	DRY	NC	DRY	NC	DRY	NC
RFW-17	834.66	60.5	26.41	808.25	27.43	807.23	27.58	807.08
RFW-20	842.49	142	33.13	809.36	35.03	807.46	36.71	805.78
RFW-21	832.65	102	20.68	811.97	22.22	810.43	22.63	810.02
PH-7	805.94	89	33.30	772.64	34.26	771.68	24.22	781.72
PH-9	814.94	98	51.02	763.92	54.71	760.23	51.30	763.64
PH-11	820.68	78	49.62	771.06	47.60	773.08	43.22	777.46
PH-12	828.35	87	49.83	778.52	53.63	774.72	51.51	776.84
B-3	803.02	83	10.40	792.62	10.60	792.42	10.38	792.64
Amoco	842.29	INA	NA	NC	NA	NC	NA	NC
Hamp. Town #22	804.96	INA	0.96	804.00	2.34	802.62	3.31	801.65
Pembroke #1	INA	INA	11.36	NC	10.96	NC	10.87	NC
Pembroke #2	INA	INA	Damaged	NC	Damaged	NC	Damaged	NC
N. Houcks. Rd.	INA	INA	11.43	NC	10.88	NC	10.98	NC
E. Century St.	INA	INA	19.24	NC	19.24	NC	19.21	NC
Lwr. Beckleys. Rd.	INA	INA	55.67	NC	56.13	NC	55.48	NC

* - Pump not running at time of water level due to damage from a downed tree.

NA - Not Available/Not Accessible

NC - Not Calculable

INA - Information not available

PC - Pump Cycles

**Table 2-3
Effluent Characteristics Summary - 3rd Quarter 2011
Black & Decker
Hampstead, Maryland**

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				July 2011	August 2011	September 2011	
001	FLOW	average	MGD	NA	0.111	0.166	0.288
		maximum	MGD	NA	0.133	0.410	1.470
	1,1,1-Trichloroethane		ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene		ug/l	5	< 1	< 1	< 1
	Trichloroethylene		ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		monthly average	mg/l	10	< 5	< 5	< 5
	pH	minimum	STD	6.0	6.6	6.3	6.1
		maximum	STD	8.5	7.0	8.5	7.3
BOD		mg/l	15	4.0	5.0	0.0	
TSS	maximum	mg/l	30	9.0	20.0	5.0	
	monthly average	mg/l	20	9.0	20.0	5.0	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.178	0.208	0.208
		maximum	MGD	NA	0.223	0.325	0.255
	Fecal Coliform		MPN/100ml	200	2.0	1.0	5.0
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.202
		maximum	MGD	NA	NR	NR	0.268
	1,1,1-Trichloroethane		ug/l	NA	NR	NR	< 1
	Tetrachloroethylene		ug/l	NA	NR	NR	< 1
	Trichloroethylene		ug/l	NA	NR	NR	< 1

DMR - Discharge Monitoring Report
 NA - Not Applicable
 NR - Not Reported

Table 2-4

Summary of Groundwater Analytical Results - August 2011
 Black & Decker
 Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	0.9 J	0.9 J	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	4.5	1 U	1 U	1 U	1 U	9	25	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	280	73	770	120	6.7	6.6	9.1	0.8	0.8	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	55	2.3	13	3.4	13	14	62	100	110	1 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

NS = Not Sampled

Table 2-4
 Summary of Groundwater Analytical Results - August 2011
 Black & Decker
 Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1.1	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	NS	2 U	2 U	NS	2 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	2.5	0.7 J	1 U	3.4	NS	1 U	1 U	NS	11	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	0.8 J	1 U	1.7	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	0.9	1	1 U	28	27	50	NS	3	3.7	NS	12	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	0.8 J	21	20	78	NS	2.9	1 U	NS	4.7	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicate sample
 NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
 J = Indicates an estimated value.

Table 2-4

Summary of Groundwater Analytical Results - August 2011

Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	RFW-20	RFW-21	Town #22	Town #23	Trip Blank
		USEPA drinking water method 524.2														
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	NS	2 U	ABD	ABD	ABD	2 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	NA	NA	NA	NA	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	2.7	0.9 J	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.32 J	0.3 J	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trichloroethene	ug/L	NS	1 U	120	3.2	NS	1 U	ABD	ABD	ABD	1 U	0.5	0.5 U	0.5 U	0.5 U	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	1.5	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	1 U	8.9	18	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division. Samples from all of the other wells are analyzed with USEPA Method 8260.

NS = Not sampled

U = Compound was analyzed but not detected.

ABD = Well has been abandoned

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from well EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (July through September 2011) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 3rd Quarter 2011
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Jul-11	Alarm at the air stripper due to a loss of the air compressors to the pumping valve. The system is back online.
Jul-11	Alarm at the air stripper due to a high column blower failure, reset the system is back online.
Jul-11	Alarm at the air stripper due to a bad Moore controller, the controller was repaired and the system is back online.
Jul-11	Alarm at the air stripper due to a series of power outages caused by severe weather.
Aug-11	Alarm at the air stripper, due to a high wet well. Reset the system, the stripper is back online.
Aug-11	Alarm at the air stripper, high column and blower failure. Reset the system, the stripper is back online.
Aug-11	Alarm at the air stripper due to a power outage caused by Hurricane Irene. A temporary electrical feed was run from old well house #2. The system is up and running wells EW-8 and EW-10 are still down. EW-8 was damaged by a downed tree, a new well house and replacement parts were ordered. EW-10 is still down so we don't trip the temporary breaker.
Sep-11	The temporary electric feed is moved to a larger breaker at the boiler room. Well EW-10 is back online after it was down for 2 weeks.
Sep-11	Alarm at the air stripper, EW-3 is down due to a bad control relay. The control relay is replaced the well is back online.

4. RECOMMENDATIONS

For the reporting period of July through September 2011, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(JULY – SEPTEMBER 2011)

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 626 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrance Jones 0763, Gary Dickerson 0782, Anthony Phillips 3001, Francis Schmidt 2757, David Smith 9153, Brian Musselman 2775

Permit Number: 02-DP-0022
Superintendent: Earle Villarreal

Certification # 1017

Month: July
Year: 2011

Final Effluent: outfall:001											Outfall:101					Outfall:201			Operator		
Date	Appearance	Discharge MGD	pH	Cl2 mg/l	Trichloroethylene ug/l	1,1,1-Trichloroethylene ug/l	Trichloroethylene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal: mpn	Basin: Inches	Alum: Gpd	Hypochlorite: Gpd	Post Cl2 mg/l	Trichloroethylene ug/l	1,1,1-Trichloroethylene ug/l		Trichloroethylene ug/l	Discharge mgd
1	Clear	0.12200									0.175000		0.0	1.0	1.0	5.0				0.236424	Djones
2	Clear	0.09100									0.163000		0.0	1.0	1.0	5.0				0.170884	APhillips
3	Clear	0.10700									0.163000		0.0	1.0	1.0	5.0				0.242028	APhillips
4	Clear	0.09600									0.169000		0.0	1.0	1.0	5.0				0.201690	Fschmidt
5	Clear	0.11400	6.87	0.00							0.177000		0.0	1.0	1.0	5.0				0.227725	Djones
6	Clear	0.11700									0.163000	2.0	0.0	1.0	1.0	5.0				0.256823	Djones
7	Clear	0.10900	6.65	0.00							0.183000		0.0	1.0	1.0	5.0				0.085417	Djones
8	Clear	0.12000									0.155000		0.0	1.0	1.0	5.0				0.249383	Djones
9	Clear	0.10300									0.167000		0.0	1.0	1.0	5.0				0.200451	Djones
10	Clear	0.11600									0.181000		0.0	1.0	1.0	5.0				0.199197	Djones
11	Clear	0.10900									0.181000		0.0	1.0	1.0	5.0				0.245163	Bmusselman
12	Clear	0.10500	6.64	0.00							0.186000	< 1.8	0.0	1.0	1.0	5.0				0.214168	Gdickerson
13	Clear	0.11100									0.178000		0.0	1.0	1.0	5.0				0.234864	Djones
14	Clear	0.11100	6.75	0.00							0.188000		0.0	1.0	1.0	5.0				0.222817	Djones
15	Clear	0.11200									0.220000		0.0	1.0	1.0	5.0				0.224561	Djones
16	Clear	0.09700									0.117000		0.0	1.0	1.0	5.0				0.170868	Dsmith
17	Clear	0.11200									0.200000		0.0	1.0	1.0	5.0				0.225118	Dsmith
18	Clear	0.13200									0.188000		0.0	1.0	1.0	5.0				0.267848	Djones
19	Clear	0.11700	6.73	0.00	< 1.00	< 1.00	< 1.00	4.0	9.0		0.164000	< 1.8	0.0	1.0	1.0	5.0	< 1.0	< 1.0	< 1.0	0.140160	Djones
20	Clear	0.10100									0.183000		0.0	1.0	1.0	5.0				0.088587	Djones
21	Clear	0.11600	6.70	0.00							0.178000		0.0	1.0	1.0	5.0				0.259058	Gdickerson
22	Clear	0.11200									0.198000		0.0	1.0	1.0	5.0				0.230580	Gdickerson
23	Clear	0.11300									0.175000		0.0	1.0	1.0	5.0				0.189602	APhillips
24	Clear	0.11100									0.174000		0.0	1.0	1.0	5.0				0.220351	APhillips
25	Clear	0.10900									0.171000		0.0	1.0	1.0	5.0				0.227284	Gdickerson
26	Clear	0.10700	6.96	0.00							0.202000	< 1.8	0.0	1.0	1.0	5.0				0.204766	Gdickerson
27	Clear	0.12900									0.180000		0.0	1.0	1.0	5.0				0.254597	Djones
28	Clear	0.09700	6.68	0.00					< 5.5		0.192000		0.0	1.0	1.0	5.0				0.207609	Djones
29	Clear	0.12300									0.173000		0.0	1.0	1.0	5.0				0.222919	Djones
30	Clear	0.09400									0.223000		0.0	1.0	1.0	5.0				0.172116	Djones
31	Clear	0.13300									0.164000		0.0	1.0	1.0	5.0				0.255025	Djones
Total		3.44600									5.531000									6.548083	
Average		0.11116	6.73	<0.10	0	0	0	4	9	0	0.178419	1	0.0	1.0	1.0	5.0	0	0	0	0.211228	
Minimum		0.09100	6.6	0.00	0	0	0	4	9	0	0.117000	1	0.0	1.0	1.0	5.0	0	0	0	0.085417	
Maximum		0.13300	7.0	<0.10	0	0	0	4	9	0	0.223000	2	0.0	1.0	1.0	5.0	0	0	0	0.267848	MOR 5-11-09

COMMENTS:

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 626 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrance Jones 0763, Gary Dickerson 0782, David Smith 9153, Jamaal Downs 2755, Anthony Phillips 3001

Permit Number: 02-DP-0022
Superintendent: Earle Villarreal
Certification # 1017

Month: August
Year: 2011

Final Effluent outfall 001											Outfall 101					Outfall 201			Operator		
Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethane ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l		Trichloroethane ug/l	Discharge mgd
1	Clear	0.09700									0.189000		0.0	1.0	1.0	5.0				0.206326	Gdickerson
2	Clear	0.10800	8.49	0.00							0.197000	< 1.8	0.0	1.0	1.0	5.0				0.221248	Gdickerson
3	Clear	0.10700									0.181000		0.0	1.0	1.0	5.0				0.228370	Djones
4	Clear	0.10600	8.18	0.00							0.203000		0.0	1.0	1.0	5.0				0.219572	Djones
5	Clear	0.10800									0.203000		0.0	1.0	1.0	5.0				0.209913	Djones
6	Clear	0.11200									0.156000		0.0	1.0	1.0	5.0				0.214885	Dsmith
7	Clear	0.09000									0.217000		0.0	1.0	1.0	5.0				0.263622	Dsmith
8	Clear	0.12800									0.190000		0.0	1.0	1.0	5.0				0.262839	Djones
9	Clear	0.10800	6.25	0.00							0.222000	< 1.8	0.0	1.0	1.0	5.0				0.196909	Djones
10	Clear	0.10800									0.195000		0.0	1.0	1.0	5.0				0.216238	Djones
11	Clear	0.10000	8.23	0.00							0.196000		0.0	1.0	1.0	5.0				0.214671	Djones
12	Clear	0.10000									0.223000		0.0	1.0	1.0	5.0				0.203782	Gdickerson
13	Clear	0.11500									0.215000		0.0	1.0	1.0	5.0				0.220347	Gdickerson
14	Clear	0.10700									0.200000		0.0	1.0	1.0	5.0				0.203100	Gdickerson
15	Clear	0.10400	6.55	0.00							0.210000		0.0	1.0	1.0	5.0				0.232508	Djones
16	Clear	0.09400			< 1.00	< 1.00	< 1.00	5.0	20.0	< 5.5	0.208000	< 1.8	0.0	1.0	1.0	5.0				0.216670	Djones
17	Clear	0.12600									0.185000		0.0	1.0	1.0	5.0				0.225060	Djones
18	Clear	0.09500	6.43	0.00							0.253000		0.0	1.0	1.0	5.0				0.207578	Djones
19	Clear	0.10700									0.188000		0.0	1.0	1.0	5.0				0.216361	Djones
20	Clear	0.21600									0.219000		0.0	1.0	1.0	5.0				0.176643	Djones
21	Clear	0.25300									0.230000		0.0	1.0	1.0	5.0				0.222697	Djones
22	Clear	0.26500									0.150000		0.0	1.0	1.0	5.0				0.246777	Gdickerson
23	Clear	0.24600	7.60	0.00							0.155000	< 1.8	0.0	1.0	1.0	5.0				0.209144	Gdickerson
24	Clear	0.26800									0.215000		0.0	1.0	1.0	5.0				0.230688	Djones
25	Clear	0.22600	7.52	0.00							0.234000		0.0	1.0	1.0	5.0				0.215146	Djones
26	Clear	0.27200									0.144000		0.0	1.0	1.0	5.0				0.216610	Djones
27	Clear	0.18800									0.325000		0.0	1.0	1.0	5.0				0.165770	Dsmith
28	Clear	0.35300									0.235000		0.0	1.0	1.0	5.0				0.219673	AP/JD
29	Clear	0.41000									0.235000		0.0	1.0	1.0	5.0				0.219673	Djones
30	Clear	0.21500									0.231000	< 1.8	0.0	1.0	1.0	5.0				0.191507	Djones
31	Clear	0.20000	8.25	0.00							0.255000		0.0	1.0	1.0	5.0				0.159687	Djones
Total		5.13200									6.459000									6.654014	
Average		0.16555	7.5	<0.10	0.00	0.00	0.00	5	20	0.0	0.208355	1.0	0.0	1.0	1.0	5.0	#DIV/0!	#DIV/0!	#####	0.214646	
Minimum		0.09000	6.3	0.00	0.00	0.00	0.00	5	20	0.0	0.144000	1.0	0.0	1.0	1.0	5.0	0	0	0	0.159687	
Maximum		0.41000	8.5	<0.10	0.00	0.00	0.00	5	20	0.0	0.325000	1.0	0.0	1.0	1.0	5.0	0	0	0	0.263622	MOR 5-11-09

COMMENTS:

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Neojokes Road, Millersville MD

Facility: BTR Capital Group
Address: 626 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrancc Jones 0763, Gary Dickerson 0782, Phillips Pitts 2999, David Smith 9153, Brian Musselman 2775, Jamaal Downs 2755

Permit Number: 02-DP-0022
Superintendent: Earle Villarreal

Certification # 1017

Month: September
Year: 2011

Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Final Effluent outfall 001					Outfall 101					Outfall 201				Operator			
					Tetrachloroethylene ug/l	1,2,3-Trichlorobenzene ug/l	Trichlorobenzene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,2,3-Trichlorobenzene ug/l		Trichlorobenzene ug/l	Discharge mgd	
1	Clear	0.24400	7.27	0.00							0.239000		0.0	1.0	0.5	5.0				0.178458	Djones	
2	Clear	0.22100									0.202000		0.0	1.0	0.5	5.0				0.166333	Djones	
3	Clear	0.19200									0.222000		0.0	1.0	0.5	5.0				0.129450	Djones	
4	Clear	0.20900									0.236000		0.0	1.0	0.5	5.0				0.155745	Djones	
5	Clear	0.23100									0.193000		0.0	1.0	0.5	5.0				0.171020	Gdickerson	
6	Clear	0.20500	6.61	0.00							0.232000		0.0	1.0	0.5	5.0				0.163521	Gdickerson	
7	Clear	0.47300									0.198000	< 1.8	0.0	1.0	0.5	5.0				0.169244	Djones	
8	Clear	1.47000	6.33	0.00							0.226000		0.0	1.0	0.5	5.0				0.151177	Djones	
9	Clear	1.07600									0.194000		0.0	1.0	0.5	5.0				0.177414	Ppitts	
10	Clear	0.32400									0.219000		0.0	1.0	0.5	5.0				0.162620	Ppitts	
11	Clear	0.16900									0.217000		0.0	1.0	0.5	5.0				0.158565	Ppitts	
12	Clear	0.20700									0.237000		0.0	1.0	0.5	5.0				0.173103	Bmusselman	
13	Clear	0.20500	6.12	0.00	< 1.00	< 1.00	< 1.00	< 2.0	5.0	< 5.5	0.215000	< 1.8	0.0	1.0	0.5	5.0				0.108876	Djones	
14	Clear	0.20800									0.211000		0.0	1.0	0.5	5.0				0.163921	Djones	
15	Clear	0.19200	6.20	0.00							0.220000		0.0	1.0	0.5	5.0				0.133229	Djones	
16	Clear	0.21600									0.130000		0.0	1.0	0.5	5.0				0.139542	Djones	
17	Clear	0.16700									0.152000		0.0	1.0	0.5	5.0				0.162154	Dsmith	
18	Clear	0.20900									0.185000		0.0	1.0	0.5	5.0				0.206739	Dsmith	
19	Clear	0.23400									0.171000		0.0	1.0	0.5	5.0				0.246223	Djones	
20	Clear	0.20300	6.35	0.00							0.200000		0.0	1.0	0.5	5.0				0.204750	Djones	
21	Clear	0.21800									0.202000	< 2.0	0.0	1.0	0.5	5.0				0.208670	Djones	
22	Clear	0.20900	6.23	0.00							0.227000		0.0	1.0	0.5	5.0				0.203381	Djones	
23	Clear	0.21100									0.185000		0.0	1.0	0.5	5.0				0.205740	Djones	
24	Clear	0.16900									0.255000		0.0	1.0	0.5	5.0				0.158692	Jdowns	
25	Clear	0.23100									0.236000		0.0	1.0	0.5	5.0				0.233970	Jdowns	
26	Clear	0.19800									0.222000		0.0	1.0	0.5	5.0				0.214740	Djones	
27	Clear	0.21000	6.27	0.00						< 5.0	0.204000	4.5	0.0	1.0	0.5	5.0				0.205959	Djones	
28	Clear	0.21600									0.202000		0.0	1.0	0.5	5.0				0.200740	Djones	
29	Clear	0.21400	6.25	0.00							0.216000		0.0	1.0	0.5	5.0				0.202083	Djones	
30	Clear	0.11800									0.189000		0.0	1.0	0.5	5.0				0.200631	Djones	
31																						
Total		8.64900									6.237000										5.361690	
Average		0.28830	6.4	<0.10	0	0	0	2	5	0	0.207900	2	0.0	1.0	0.5	5.0	#DIV/0!	#DIV/0!	#####	0.178723		
Minimum		0.11800	6.1	0.00	0	0	0	2	5	0	0.130000	1	0.0	1.0	0.5	5.0	0	0	0	0.108876		
Maximum		1.47000	7.3	<0.10	0	0	0	0	5	0	0.255000	5	0.0	1.0	0.5	5.0	0	0	0	0.246223	MOR.S-11-09	

COMMENTS:

**APPENDIX B
DISCHARGE MONITORING REPORTS
(JULY - SEPTEMBER 2011)**

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

State Discharge Permit

02-DP-0022

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	11	07	01		11	07	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	4	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY-MX	MG/L		ONCE/ MONTH	GRAB
pH 00400 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	6.6	*****	7.0	(12)	0	TWICE/ WEEK	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY-MN	*****	8.5 DAILY-MX	SU		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	9	9	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA-AVG	30 DAILY-MX	MG/L		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	111,161	133,000	(07)	*****	*****	*****	****	0	Measured	RECORD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	0.01 30DA-AVG	0.019 DAILY-MX	MG/L		ONCE/ MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY-MX	UG/L		ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY-MX	UG/L		ONCE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
James M. Harkins MES Director TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	410	729-8350	11	08
		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name AG/GFI Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address 626 Hanover Pike

MD0001881

001

Approval expires

Hampstead, MD 21074

PERMIT NUMBER

DISCHARGE NUMBER

Facility Black and Decker WWTP

MONITORING PERIOD

*** NO DISCHARGE ***
NOTE: Read instructions before completing this form

Location 626 Hanover Pike

YEAR	MO	DAY	YEAR	MO	DAY
11	07	01	11	07	31

State Discharge Permit

Attn:

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	(46-53)	(54-61)			
TRICHLOROETHENE 79141 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	(28)	0	0	0	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	UG/L	5	DAILY-MX	0	ONCE/ MONTH	GRAB	
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	0	(19)	0	0	0	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	10 30DA-AVG	MG/L	15 DAILY-MX	0	0	ONCE/ MONTH	GRAB	
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER James M. Harkins MES Director	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 133 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410	729-8350	11	08	22
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
FROM 11	07	01	TO 11	07	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	REPORT	178,419	223,000	(07) GPD	*****	*****	*****	****	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0	REPORT	*****	*****	****	*****	*****	2	(30)	0	ONCE/ WEEK	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX	MPN		ONCE/ WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)				SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT			TELEPHONE		DATE	
James M. Harkins MES Director					410	729-8350	11	08	22		
TYPED OR PRINTED	AREA CODE	NUMBER	YEAR	MONTH	DAY						

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc
Address 626 Hanover Pike
Hampstead, MD 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)

MD0001881
PERMIT NUMBER

001
DISCHARGE NUMBER


Form Approved.
OMB No.
Approval expires

Facility Black and Decker WWTP
Location 626 Hanover Pike
Attn.

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 11	08	01	TO 11	08	31
(20-21)		(22-23)		(24-25)	
(26-27)		(28-29)		(30-31)	

*** NO DISCHARGE ***
NOTE: Read instructions before completing this form

State Discharge Permit
02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)		
		(46-53) AVERAGE		(54-61) MAXIMUM	(38-45) MINIMUM		(46-53) AVERAGE				(54-61) MAXIMUM	
		UNITS	UNITS	UNITS	UNITS	UNITS						
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	5	(19)	0	ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB	
pH 00400 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	6.3	*****	8.5	(12)	0	TWICE/ WEEK	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY MN	*****	8.5 DAILY MX	SU		TWICE/ WEEK	GRAB	
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	20	(19)	0	ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	20 30DA AVG	MG/L		ONCE/ MONTH	GRAB	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	165,548	410,000	(07)	*****	*****	*****	****	0	Measured	RECORD	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	RECORD	
CHLORINE, TOTAL RESIDUAL 50060 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	<0.1	(19)	0	ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	0.011 30DA AVG	MG/L		ONCE/ MONTH	GRAB	
TETRACHLOROETHYLENE 34475 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB	
1,1,1-TRICHLOROETHANE 34506 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)						TELEPHONE		DATE			
James M. Harkins MES Director							410	729-8350	11	09	23	
TYPED OR PRINTED							AREA CODE	NUMBER	YEAR	MONTH	DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMIT NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name AG/GFI Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address 626 Hanover Pike

MD0001881

001

Approval expires

Hampstead, MD 21074

PERMIT NUMBER

DISCHARGE NUMBER

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
11	08	01	TO	11	08	31
(20-21)		(22-23)	(24-25)	(26-27)		(28-29) (30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53)			QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB					
79141 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L	ONCE/MONTH	GRAB						
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(19)	0	ONCE/MONTH	GRAB					
OIL AND GREASE TOTAL RECOVERABLE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	10	MG/L	ONCE/MONTH	GRAB						
70030 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	30DA AVG	DAILY MX	ONCE/MONTH	GRAB						
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****										
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER James M. Harkins MES Director TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 851001 AND 33 U.S.C. 851319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
		410	729-8350	11	09	27
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.
 Address 626 Hanover Pike
Hampstead, MD 21074

Facility Black and Decker WWTP
 Location 626 Hanover Pike
 Attn _____

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)
 MD0001881 101
 PERMIT NUMBER DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 11	08	01	TO 11	08	31
(20-21)		(22-23)	(24-25)	(26-27)	
		(28-29)	(30-31)		

State Discharge Permit
 02-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		(3 Card Only) (46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(4 Card Only) (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM				UNITS
FLOW, IN CONDUIT OR THRU TREATMENT PLANT. 50050 1 0 0	SAMPLE MEASUREMENT	208,355	325,000	(07)	*****	*****	*****	0	ONCE/MONTH	GRAB	
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	0	ONCE/MONTH	GRAB	
COLIFORM, FECAL GENERAL. 74055 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	ONCE/WEEK	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX	MPN	ONCE/WEEK	GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)						TFL PHONE		DATE		
James M. Harkins MES Director TYPED OR PRINTED							410 729-8350		11	09	23
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						AREA CODE	NUMBER	YFAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name AG/GFI Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address 626 Hanover Pike

MD0001881

001

Approval expires

Hampstead, MD 21074

PERMIT NUMBER

DISCHARGE NUMBER

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 11	09	01	TO 11	09	30
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

State Discharge Permit
02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(19)	0	ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15	MG/L		ONCE/ MONTH	GRAB	
pH	SAMPLE MEASUREMENT	*****	*****	****	6.1	*****	7.3	(12)	0	TWICE/ WEEK	GRAB	
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	8.5	SU		TWICE/ WEEK	GRAB	
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	5	*****	5	(19)	0	ONCE/ MONTH	GRAB	
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	20	30DA AVG		ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	288,300	1,470,000	(07)	*****	*****	*****	*****	0	Measured	RECORD	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	*****		Measured	RECORD	
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	<0.1	(19)	0	ONCE/ MONTH	GRAB	
CHLORINE, TOTAL RESIDUAL 50060 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	0.011	MG/L		ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0.019	MG/L		ONCE/ MONTH	GRAB	
TETRACHLOROETHYLENE 34475 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30DA AVG	DAILY MX		ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	*****	0	(28)	ONCE/ MONTH	GRAB	
1,1,1-TRICHLOROETHANE 34506 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	*****	5	UG/L	ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	*****	0	(28)	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	*****	5	UG/L	ONCE/ MONTH	GRAB	
		*****	*****	****	*****	*****	*****	5	UG/L	ONCE/ MONTH	GRAB	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER James M. Harkins MES Director TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §§1001 AND 33 U.S.C. §§ 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410	729-8350	11	10	17
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.
 Address 626 Hanover Pike
Hampstead, MD 21074

Facility Black and Decker WWTP
 Location 626 Hanover Pike
 Attn: _____

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)

MD0001881 101
 PERMIT NUMBER DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD

FROM 11 09 01 TO 11 09 30
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

State Discharge Permit
 02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53) QUANTITY OR LOADING			(4 Card Only) (38-45) QUANTITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	207,900	255,000	(07)	*****	*****	*****	0	ONCE/MONTH	GRAB	
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****		ONCE/MONTH	GRAB	
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	*****	5	0	ONCE/WEEK	GRAB	
	PERMIT REQUIREMENT	*****	*****	***	*****	*****	200 DAILY MX		ONCE/WEEK	GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1091 AND 23 U.S.C. SS 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS)				SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TFI PHONE NUMBER		DATE		
James M. Harkins MES Director TYPED OR PRINTED							410	729-8350	11	10	17
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)							AREA CODE	NUMBER	YEAR	MONTH	DAY

PERMIT NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.
 Address 626 Hanover Pike
Hampstead, MD 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

201

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP
 Location 626 Hanover Pike
 Attn: _____

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
11	07	01	11	09	30
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

State Discharge Permit
 02-DP-0022

PARAMETER (32-37)		(3 Card Only) (45-53)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	AVERAGE	MAXIMUM			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	201,780	267,848	(07)	*****	*****	*****	*****	*****	*****	0	Measured	Record
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	*****	*****	*****		Measured	Record
	TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	*****	0	0	(28)	0	One/ Quarter
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	*****	0	0	(28)	0	One/ Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	*****	0	0	(28)	0	One/ Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER James M. Harkins MES Director TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 551001 AND 33 U.S.C. 551319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	410	729-8350	11	10
COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)		AREA CODE	NUMBER	YEAR	MONTH	DAY

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(JULY - SEPTEMBER 2011)



ATLANTIC COAST Laboratories

A Division of QC Laboratories

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

Maryland Environmental Services (A)

Order Number: A11070975

Sample # A11070975-01

Sample Date: 7/19/2011 9:35

Site: Black & Decker 001
Client Sample ID:
Sample Comments: None

Matrix: Waste Water

Test	Result	Qualifier	RL	Units	Method	Analysis Date	Analyst
BOD-5	4	B	2	mg/L	SM 5210 B	7/20/2011 7:20:00 AM	Skent
Total Suspended Solids	9		4	mg/L	SM 2540D	7/20/2011 8:35:00 AM	Jantiago

Sample # A11070975-02

Sample Date: 7/19/2011 9:42

Site: Black & Decker 001
Client Sample ID:
Sample Comments: None

Matrix: Waste Water

Test	Result	Qualifier	RL	Units	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1		1	ug/L	EPA 624	7/23/2011 3:45:00 AM	JKozlowski
Tetrachloroethene	< 1		1	ug/L	EPA 624	7/23/2011 3:45:00 AM	JKozlowski
Trichloroethene	< 1		1	ug/L	EPA 624	7/23/2011 3:45:00 AM	JKozlowski

Approved:

Keith A. Handreckit

General Manager/Technical Director

Reported:

7/28/2011 12:31:13 PM



ATLANTIC COAST Laboratories
A Division of QC Laboratories

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

Maryland Environmental Services (A)

Order Number: A11071607

Sample # A11071607-01

Sample Date: 7/28/2011 11:20

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Qualifier</u>	<u>RL</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	< 5.5		5.5	mg/L	EPA 1664	8/1/2011 1:55:00 PM	JMcGuire

Approved:

Keith R. Hausknecht

General Manager/Technical Director

Reported:

8/8/2011 9:29:33 AM

Page 2 of 3



ATLANTIC COAST Laboratories

A Division of QC Laboratories

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

Maryland Environmental Services (A)

Order Number: A11080448

Sample # A11080448-01

Sample Date: 7/19/2011 9:25

Site: Black & Decker 101

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Qualifier</u>	<u>RL</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Fecal Coliform, MPN	<1.8		N/A	MPN/100 mL	SM 9221 E	7/19/2011 1:45:00 PM	ChesapeakeEnvironmental

Approved:

Keith A. Handwerker

General Manager/Technical Director

Reported:

8/8/2011 2:39:20 PM



Maryland Environmental Services (A)

Order Number: A11081050

Sample # A11081050-01 **Sample Date: 8/16/2011 9:08**

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Qualifier</u>	<u>RL</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
BOD-5	5	B YL	2	mg/L	SM 5210 B	8/17/2011 7:00:00 AM	Ythomas
Total Suspended Solids	20		7	mg/L	SM 2540D	8/19/2011 11:12:00 AM	Jsantiago

Sample # A11081050-02 **Sample Date: 8/16/2011 9:11**

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Qualifier</u>	<u>RL</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	< 1		1	ug/L	EPA 624	8/18/2011 12:43:00 AM	JKozlowski
Tetrachloroethene	< 1		1	ug/L	EPA 624	8/18/2011 12:43:00 AM	JKozlowski
Trichloroethene	< 1		1	ug/L	EPA 624	8/18/2011 12:43:00 AM	JKozlowski

Sample # A11081050-03 **Sample Date: 8/16/2011 9:09**

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Qualifier</u>	<u>RL</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	< 5.5		5.5	mg/L	EPA 1664	8/18/2011 4:40:00 PM	JMcGuire

Approved:

Keith A. Hausknecht

General Manager/Technical Director

Reported:

8/25/2011 9:23:50 AM



ATLANTIC COAST Laboratories
A Division of QC Laboratories

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

Maryland Environmental Services (A)

Order Number: A11080717

Sample # A11080717-01

Sample Date: 8/2/2011 9:00

Site: Black & Decker 101

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Qualifier</u>	<u>RL</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Fecal Coliform, MPN	<1.8		N/A	MPN/100 mL	SM 9221 E	8/2/2011 2:42:00 PM	ChesapeakeEnvironmental

Approved:

Keith A. Handkecht

General Manager/Technical Director

Reported:

8/11/2011 9:11:51 AM

Page 2 of 3



Maryland Environmental Services (A)

Order Number: A11090613

Sample # A11090613-01

Sample Date: 9/13/2011 9:08

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

Test	Result	Qualifier	RL	Units	Method	Analysis Date	Analyst
BOD-5	< 2	YL	2	mg/L	SM 5210 B	9/14/2011 7:30:00 AM	Ythomas
Total Suspended Solids	5		4	mg/L	SM 2540D	9/15/2011 10:06:00 AM	Jsantiago

Sample # A11090613-02

Sample Date: 9/13/2011 9:09

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

Test	Result	Qualifier	RL	Units	Method	Analysis Date	Analyst
Oil and Grease (HEM)	< 5.5		5.5	mg/L	EPA 1664	9/16/2011 12:10:00 PM	JMcGuire

Sample # A11090613-03

Sample Date: 9/13/2011 9:11

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

Test	Result	Qualifier	RL	Units	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1		1	ug/L	EPA 624	9/16/2011 5:53:00 AM	JKozlowski
Tetrachloroethene	< 1		1	ug/L	EPA 624	9/16/2011 5:53:00 AM	JKozlowski
Trichloroethene	< 1		1	ug/L	EPA 624	9/16/2011 5:53:00 AM	JKozlowski

Approved:

Keith A. Hausknecht

General Manager/Technical Director

Reported:

9/21/2011 2:50:51 PM



ATLANTIC COAST Laboratories
A Division of QC Laboratories

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

Maryland Environmental Services (A)

Order Number: A11091452

Sample # A11091452-01

Sample Date: 9/27/2011 9:15

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Qualifier</u>	<u>RL</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	<5		5	mg/L	EPA 1664	10/4/2011 2:25:00 PM	JMcGuire

Approved:

Keith A. Handwerker

General Manager/Technical Director

Reported:

10/11/2011 7:22:24 AM



Maryland Environmental Services (A)

Order Number: A11091092

Sample # A11091092-01

Sample Date: 9/13/2011 9:25

Site: Black & Decker 101

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Qualifier</u>	<u>RL</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Fecal Coliform, MPN	<1.8		N/A	MPN/100 mL	SM 9221 E	9/13/2011 3:13:00 PM	ChesapeakeEnvironmentalL

Approved:

Keith A. Hansbrecht

General Manager/Technical Director

Reported:

9/22/2011 9:57:55 AM

**APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(AUGUST 2011)**

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.
TestAmerica Chicago
2417 Bond Street
University Park, IL 60484
Tel: (708)534-5200

TestAmerica Job ID: 500-38462-1
Client Project/Site: Black and Decker

For:
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, Pennsylvania 19380

Attn: Mr. Tom Cornuet



Authorized for release by:
08/31/2011 08:39:40 AM

Richard Wright
Project Manager II
richard.wright@testamericainc.com

LINKS

Review your project
results through
Total Access

Have a Question?

? Ask
The
Expert

Visit us at:
www.testamericainc.com

Results relate only to the items tested and the sample(s) as received by the laboratory. The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Table of Contents

Cover Page	1
Table of Contents	2
Case Narrative	3
Detection Summary	4
Method Summary	7
Sample Summary	8
Client Sample Results	9
Definitions	61
QC Association	62
Surrogate Summary	63
QC Sample Results	64
Certification Summary	70
Chain of Custody	71
Receipt Checklists	74

Case Narrative

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Job ID: 500-38462-1

Laboratory: TestAmerica Chicago

Narrative

Job Narrative
500-38462-1

Comments

No additional comments.

Receipt

Samples EW-5 and EW-9 the vials have large bubbles. Some of the other vials have tiny bubbles, but are acceptable.

All other samples were received in good condition within temperature requirements.

GC/MS VOA

No analytical or quality issues were noted.

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-38462-1

No Detections

Client Sample ID: RFW-1B

Lab Sample ID: 500-38462-2

No Detections

Client Sample ID: RFW-2A

Lab Sample ID: 500-38462-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloromethane	1.1		1.0	0.24	ug/L	1		8260B	Total/NA
Trichloroethene	0.94		0.50	0.18	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-2B

Lab Sample ID: 500-38462-4

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.95		0.50	0.18	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-3B

Lab Sample ID: 500-38462-5

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	2.5		1.0	0.22	ug/L	1		8260B	Total/NA
Tetrachloroethene	0.82	J	1.0	0.22	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-6

Lab Sample ID: 500-38462-6

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	3.0		0.50	0.18	ug/L	1		8260B	Total/NA
Tetrachloroethene	2.9		1.0	0.22	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-7

Lab Sample ID: 500-38462-7

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	3.7		0.50	0.18	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-13

Lab Sample ID: 500-38462-8

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.92	J	1.0	0.22	ug/L	1		8260B	Total/NA
Trichloroethene	3.2		0.50	0.18	ug/L	1		8260B	Total/NA
Tetrachloroethene	18		1.0	0.22	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-17

Lab Sample ID: 500-38462-9

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Benzene	1.5		0.50	0.12	ug/L	1		8260B	Total/NA

Client Sample ID: EW-5

Lab Sample ID: 500-38462-10

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	120		0.50	0.18	ug/L	1		8260B	Total/NA
Tetrachloroethene	3.4		1.0	0.22	ug/L	1		8260B	Total/NA

Client Sample ID: EW-6

Lab Sample ID: 500-38462-11

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-6 (Continued)

Lab Sample ID: 500-38462-11

Analyte	Result	Qualifier	RL	MDL	Unit	DII Fac	D	Method	Prep Type
Trichloroethene	6.7		0.50	0.18	ug/L	1		8260B	Total/NA
Tetrachloroethene	13		1.0	0.22	ug/L	1		8260B	Total/NA

Client Sample ID: EW-7

Lab Sample ID: 500-38462-12

Analyte	Result	Qualifier	RL	MDL	Unit	DII Fac	D	Method	Prep Type
1,1-Dichloroethane	0.87	J	1.0	0.24	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	9.0		1.0	0.22	ug/L	1		8260B	Total/NA
Trichloroethene	6.6		0.50	0.18	ug/L	1		8260B	Total/NA
Tetrachloroethene	14		1.0	0.22	ug/L	1		8260B	Total/NA

Client Sample ID: EW-8

Lab Sample ID: 500-38462-13

Analyte	Result	Qualifier	RL	MDL	Unit	DII Fac	D	Method	Prep Type
1,1-Dichloroethane	0.86	J	1.0	0.24	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	25		1.0	0.22	ug/L	1		8260B	Total/NA
Trichloroethene	9.1		0.50	0.18	ug/L	1		8260B	Total/NA
Tetrachloroethene	62		1.0	0.22	ug/L	1		8260B	Total/NA

Client Sample ID: EW-9

Lab Sample ID: 500-38462-14

Analyte	Result	Qualifier	RL	MDL	Unit	DII Fac	D	Method	Prep Type
Trichloroethene	0.75		0.50	0.18	ug/L	1		8260B	Total/NA
Tetrachloroethene	100		1.0	0.22	ug/L	1		8260B	Total/NA

Client Sample ID: EW-9 DUP

Lab Sample ID: 500-38462-15

Analyte	Result	Qualifier	RL	MDL	Unit	DII Fac	D	Method	Prep Type
Trichloroethene	0.79		0.50	0.18	ug/L	1		8260B	Total/NA
Tetrachloroethene	110		1.0	0.22	ug/L	1		8260B	Total/NA

Client Sample ID: EW-10

Lab Sample ID: 500-38462-16

No Detections

Client Sample ID: TRIP BLANK

Lab Sample ID: 500-38462-17

No Detections

Client Sample ID: EW-2

Lab Sample ID: 500-38462-18

Analyte	Result	Qualifier	RL	MDL	Unit	DII Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	4.5		1.0	0.22	ug/L	1		8260B	Total/NA
Tetrachloroethene	55		1.0	0.22	ug/L	1		8260B	Total/NA
Trichloroethene - DL	280		2.5	0.90	ug/L	5		8260B	Total/NA

Client Sample ID: EW-3

Lab Sample ID: 500-38462-19

Analyte	Result	Qualifier	RL	MDL	Unit	DII Fac	D	Method	Prep Type
Trichloroethene	73		0.50	0.18	ug/L	1		8260B	Total/NA
Tetrachloroethene	2.3		1.0	0.22	ug/L	1		8260B	Total/NA

Client Sample ID: EW-4

Lab Sample ID: 500-38462-20

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-4 (Continued)

Lab Sample ID: 500-38462-20

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Tetrachloroethene	13		1.0	0.22	ug/L	1		8260B	Total/NA
Trichloroethene - DL	770		5.0	1.8	ug/L	10		8260B	Total/NA

Client Sample ID: RFW-11B

Lab Sample ID: 500-38462-21

No Detections

Client Sample ID: RFW-9

Lab Sample ID: 500-38462-22

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethene	1.0		1.0	0.29	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	11		1.0	0.22	ug/L	1		8260B	Total/NA
Trichloroethene	12		0.50	0.18	ug/L	1		8260B	Total/NA
Tetrachloroethene	4.7		1.0	0.22	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-4A

Lab Sample ID: 500-38462-23

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.73	J	1.0	0.22	ug/L	1		8260B	Total/NA
Chloroform	0.84	J	1.0	0.25	ug/L	1		8260B	Total/NA
Trichloroethene	28		0.50	0.18	ug/L	1		8260B	Total/NA
Tetrachloroethene	21		1.0	0.22	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-4A DUP

Lab Sample ID: 500-38462-24

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	27		0.50	0.18	ug/L	1		8260B	Total/NA
Tetrachloroethene	20		1.0	0.22	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-4B

Lab Sample ID: 500-38462-25

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	3.4		1.0	0.22	ug/L	1		8260B	Total/NA
Chloroform	1.7		1.0	0.25	ug/L	1		8260B	Total/NA
Trichloroethene	50		0.50	0.18	ug/L	1		8260B	Total/NA
Tetrachloroethene	78		1.0	0.22	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-12B

Lab Sample ID: 500-38462-26

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	2.7		1.0	0.22	ug/L	1		8260B	Total/NA
Trichloroethene	120		0.50	0.18	ug/L	1		8260B	Total/NA
Tetrachloroethene	8.9		1.0	0.22	ug/L	1		8260B	Total/NA

Method Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Method	Method Description	Protocol	Laboratory
8260B	VOC	SW846	TAL CHI

Protocol References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200

Sample Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
500-38462-1	RFW-1A	Water	08/24/11 09:10	08/27/11 09:50
500-38462-2	RFW-1B	Water	08/24/11 16:30	08/27/11 09:50
500-38462-3	RFW-2A	Water	08/24/11 07:50	08/27/11 09:50
500-38462-4	RFW-2B	Water	08/24/11 08:15	08/27/11 09:50
500-38462-5	RFW-3B	Water	08/24/11 15:20	08/27/11 09:50
500-38462-6	RFW-6	Water	08/24/11 16:45	08/27/11 09:50
500-38462-7	RFW-7	Water	08/24/11 13:05	08/27/11 09:50
500-38462-8	RFW-13	Water	08/24/11 16:35	08/27/11 09:50
500-38462-9	RFW-17	Water	08/24/11 10:10	08/27/11 09:50
500-38462-10	EW-5	Water	08/24/11 09:00	08/27/11 09:50
500-38462-11	EW-6	Water	08/24/11 14:15	08/27/11 09:50
500-38462-12	EW-7	Water	08/24/11 14:00	08/27/11 09:50
500-38462-13	EW-8	Water	08/24/11 13:55	08/27/11 09:50
500-38462-14	EW-9	Water	08/24/11 13:50	08/27/11 09:50
500-38462-15	EW-9 DUP	Water	08/24/11 13:50	08/27/11 09:50
500-38462-16	EW-10	Water	08/24/11 13:40	08/27/11 09:50
500-38462-17	TRIP BLANK	Water	08/24/11 07:00	08/27/11 09:50
500-38462-18	EW-2	Water	08/26/11 11:00	08/27/11 09:50
500-38462-19	EW-3	Water	08/26/11 08:15	08/27/11 09:50
500-38462-20	EW-4	Water	08/26/11 08:00	08/27/11 09:50
500-38462-21	RFW-11B	Water	08/26/11 08:20	08/27/11 09:50
500-38462-22	RFW-9	Water	08/26/11 09:10	08/27/11 09:50
500-38462-23	RFW-4A	Water	08/26/11 10:05	08/27/11 09:50
500-38462-24	RFW-4A DUP	Water	08/26/11 10:05	08/27/11 09:50
500-38462-25	RFW-4B	Water	08/26/11 10:30	08/27/11 09:50
500-38462-26	RFW-12B	Water	08/26/11 12:00	08/27/11 09:50

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-38462-1

Date Collected: 08/24/11 09:10

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 12:55	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 12:55	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 12:55	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 12:55	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 12:55	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 12:55	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 12:55	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 12:55	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 12:55	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 12:55	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 12:55	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 12:55	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 12:55	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 12:55	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/29/11 12:55	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 12:55	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 12:55	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 12:55	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 12:55	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 12:55	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 12:55	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 12:55	1
Trichloroethene	<0.50		0.50	0.18	ug/L			08/29/11 12:55	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 12:55	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 12:55	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 12:55	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 12:55	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 12:55	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 12:55	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 12:55	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 12:55	1
Tetrachloroethene	<1.0		1.0	0.22	ug/L			08/29/11 12:55	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 12:55	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 12:55	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 12:55	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 12:55	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 12:55	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 12:55	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 12:55	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 12:55	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 12:55	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 12:55	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 12:55	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 12:55	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 12:55	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 12:55	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 12:55	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 12:55	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 12:55	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 12:55	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-38462-1

Date Collected: 08/24/11 09:10

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 12:55	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 12:55	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 12:55	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 12:55	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 12:55	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 12:55	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 12:55	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 12:55	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 12:55	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 12:55	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 12:55	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 12:55	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 12:55	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 12:55	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	101		77 - 124					08/29/11 12:55	1
Toluene-d8 (Surr)	100		80 - 121					08/29/11 12:55	1
4-Bromofluorobenzene (Surr)	96		77 - 112					08/29/11 12:55	1
Dibromofluoromethane	100		78 - 119					08/29/11 12:55	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-38462-2

Date Collected: 08/24/11 16:30

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 13:21	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 13:21	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 13:21	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 13:21	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 13:21	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 13:21	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 13:21	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 13:21	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 13:21	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 13:21	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 13:21	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 13:21	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 13:21	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 13:21	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/29/11 13:21	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 13:21	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 13:21	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 13:21	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 13:21	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 13:21	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 13:21	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 13:21	1
Trichloroethene	<0.50		0.50	0.18	ug/L			08/29/11 13:21	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 13:21	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 13:21	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 13:21	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 13:21	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 13:21	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 13:21	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 13:21	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 13:21	1
Tetrachloroethene	<1.0		1.0	0.22	ug/L			08/29/11 13:21	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 13:21	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 13:21	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 13:21	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 13:21	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 13:21	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 13:21	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 13:21	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 13:21	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 13:21	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 13:21	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 13:21	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 13:21	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 13:21	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 13:21	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 13:21	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 13:21	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 13:21	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 13:21	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-38462-2

Date Collected: 08/24/11 16:30

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 13:21	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 13:21	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 13:21	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 13:21	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 13:21	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 13:21	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 13:21	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 13:21	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 13:21	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 13:21	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 13:21	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 13:21	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 13:21	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 13:21	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		77 - 124					08/29/11 13:21	1
Toluene-d8 (Surr)	101		80 - 121					08/29/11 13:21	1
4-Bromofluorobenzene (Surr)	95		77 - 112					08/29/11 13:21	1
Dibromofluoromethane	103		78 - 119					08/29/11 13:21	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-38462-3

Date Collected: 08/24/11 07:50

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 13:47	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 13:47	1
Chloromethane	1.1		1.0	0.24	ug/L			08/29/11 13:47	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 13:47	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 13:47	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 13:47	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 13:47	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 13:47	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 13:47	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 13:47	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 13:47	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 13:47	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 13:47	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 13:47	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/29/11 13:47	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 13:47	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 13:47	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 13:47	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 13:47	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 13:47	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 13:47	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 13:47	1
Trichloroethene	0.94		0.50	0.18	ug/L			08/29/11 13:47	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 13:47	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 13:47	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 13:47	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 13:47	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 13:47	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 13:47	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 13:47	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 13:47	1
Tetrachloroethene	<1.0		1.0	0.22	ug/L			08/29/11 13:47	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 13:47	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 13:47	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 13:47	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 13:47	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 13:47	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 13:47	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 13:47	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 13:47	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 13:47	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 13:47	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 13:47	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 13:47	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 13:47	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 13:47	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 13:47	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 13:47	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 13:47	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 13:47	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-38462-3

Date Collected: 08/24/11 07:50

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 13:47	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 13:47	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 13:47	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 13:47	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 13:47	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 13:47	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 13:47	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 13:47	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 13:47	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 13:47	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 13:47	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 13:47	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 13:47	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 13:47	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	DII Fac
1,2-Dichloroethane-d4 (Surr)	106		77 - 124					08/29/11 13:47	1
Toluene-d8 (Surr)	102		80 - 121					08/29/11 13:47	1
4-Bromofluorobenzene (Surr)	99		77 - 112					08/29/11 13:47	1
Dibromofluoromethane	103		78 - 119					08/29/11 13:47	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-38462-4

Date Collected: 08/24/11 08:15

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 14:13	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 14:13	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 14:13	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 14:13	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 14:13	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 14:13	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 14:13	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 14:13	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 14:13	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 14:13	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 14:13	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 14:13	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 14:13	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 14:13	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/29/11 14:13	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 14:13	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 14:13	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 14:13	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 14:13	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 14:13	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 14:13	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 14:13	1
Trichloroethene	0.95		0.50	0.18	ug/L			08/29/11 14:13	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 14:13	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 14:13	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 14:13	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 14:13	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 14:13	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 14:13	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 14:13	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 14:13	1
Tetrachloroethene	<1.0		1.0	0.22	ug/L			08/29/11 14:13	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 14:13	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 14:13	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 14:13	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 14:13	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 14:13	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 14:13	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 14:13	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 14:13	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 14:13	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 14:13	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 14:13	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 14:13	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 14:13	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 14:13	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 14:13	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 14:13	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 14:13	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 14:13	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-38462-4

Date Collected: 08/24/11 08:15

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 14:13	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 14:13	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 14:13	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 14:13	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 14:13	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 14:13	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 14:13	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 14:13	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 14:13	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 14:13	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 14:13	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 14:13	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 14:13	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 14:13	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	DII Fac
1,2-Dichloroethane-d4 (Surr)	89		77 - 124					08/29/11 14:13	1
Toluene-d8 (Surr)	85		80 - 121					08/29/11 14:13	1
4-Bromofluorobenzene (Surr)	80		77 - 112					08/29/11 14:13	1
Dibromofluoromethane	86		78 - 119					08/29/11 14:13	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-38462-5

Date Collected: 08/24/11 15:20

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 14:38	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 14:38	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 14:38	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 14:38	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 14:38	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 14:38	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 14:38	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 14:38	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 14:38	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 14:38	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 14:38	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 14:38	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 14:38	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 14:38	1
cis-1,2-Dichloroethene	2.5		1.0	0.22	ug/L			08/29/11 14:38	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 14:38	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 14:38	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 14:38	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 14:38	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 14:38	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 14:38	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 14:38	1
Trichloroethene	<0.50		0.50	0.18	ug/L			08/29/11 14:38	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 14:38	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 14:38	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 14:38	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 14:38	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 14:38	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 14:38	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 14:38	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 14:38	1
Tetrachloroethene	0.82	J	1.0	0.22	ug/L			08/29/11 14:38	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 14:38	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 14:38	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 14:38	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 14:38	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 14:38	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 14:38	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 14:38	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 14:38	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 14:38	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 14:38	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 14:38	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 14:38	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 14:38	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 14:38	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 14:38	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 14:38	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 14:38	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 14:38	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-38462-5

Date Collected: 08/24/11 15:20

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 14:38	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 14:38	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 14:38	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 14:38	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 14:38	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 14:38	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 14:38	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 14:38	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 14:38	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 14:38	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 14:38	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 14:38	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 14:38	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 14:38	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	DII Fac
1,2-Dichloroethane-d4 (Surr)	109		77 - 124					08/29/11 14:38	1
Toluene-d8 (Surr)	103		80 - 121					08/29/11 14:38	1
4-Bromofluorobenzene (Surr)	99		77 - 112					08/29/11 14:38	1
Dibromofluoromethane	108		78 - 119					08/29/11 14:38	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-6

Lab Sample ID: 500-38462-6

Date Collected: 08/24/11 16:45

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 15:04	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 15:04	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 15:04	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 15:04	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 15:04	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 15:04	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 15:04	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 15:04	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 15:04	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 15:04	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 15:04	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 15:04	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 15:04	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 15:04	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/29/11 15:04	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 15:04	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 15:04	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 15:04	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 15:04	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 15:04	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 15:04	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 15:04	1
Trichloroethene	3.0		0.50	0.18	ug/L			08/29/11 15:04	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 15:04	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 15:04	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 15:04	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 15:04	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 15:04	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 15:04	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 15:04	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 15:04	1
Tetrachloroethene	2.9		1.0	0.22	ug/L			08/29/11 15:04	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 15:04	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 15:04	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 15:04	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 15:04	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 15:04	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 15:04	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 15:04	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 15:04	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 15:04	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 15:04	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 15:04	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 15:04	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 15:04	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 15:04	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 15:04	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 15:04	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 15:04	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 15:04	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-6

Lab Sample ID: 500-38462-6

Date Collected: 08/24/11 16:45

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 15:04	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 15:04	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 15:04	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 15:04	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 15:04	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 15:04	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 15:04	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 15:04	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 15:04	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 15:04	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 15:04	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 15:04	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 15:04	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 15:04	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	DII Fac
1,2-Dichloroethane-d4 (Surr)	104		77 - 124					08/29/11 15:04	1
Toluene-d8 (Surr)	99		80 - 121					08/29/11 15:04	1
4-Bromofluorobenzene (Surr)	91		77 - 112					08/29/11 15:04	1
Dibromofluoromethane	99		78 - 119					08/29/11 15:04	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-7

Lab Sample ID: 500-38462-7

Date Collected: 08/24/11 13:05

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 15:30	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 15:30	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 15:30	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 15:30	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 15:30	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 15:30	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 15:30	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 15:30	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 15:30	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 15:30	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 15:30	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 15:30	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 15:30	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 15:30	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/29/11 15:30	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 15:30	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 15:30	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 15:30	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 15:30	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 15:30	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 15:30	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 15:30	1
Trichloroethene	3.7		0.50	0.18	ug/L			08/29/11 15:30	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 15:30	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 15:30	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 15:30	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 15:30	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 15:30	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 15:30	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 15:30	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 15:30	1
Tetrachloroethene	<1.0		1.0	0.22	ug/L			08/29/11 15:30	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 15:30	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 15:30	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 15:30	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 15:30	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 15:30	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 15:30	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 15:30	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 15:30	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 15:30	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 15:30	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 15:30	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 15:30	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 15:30	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 15:30	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 15:30	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 15:30	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 15:30	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 15:30	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-7

Lab Sample ID: 500-38462-7

Date Collected: 08/24/11 13:05

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 15:30	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 15:30	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 15:30	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 15:30	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 15:30	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 15:30	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 15:30	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 15:30	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 15:30	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 15:30	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 15:30	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 15:30	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 15:30	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 15:30	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		77 - 124					08/29/11 15:30	1
Toluene-d8 (Surr)	100		80 - 121					08/29/11 15:30	1
4-Bromofluorobenzene (Surr)	96		77 - 112					08/29/11 15:30	1
Dibromofluoromethane	104		78 - 119					08/29/11 15:30	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-13

Lab Sample ID: 500-38462-8

Date Collected: 08/24/11 16:35

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 15:56	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 15:56	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 15:56	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 15:56	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 15:56	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 15:56	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 15:56	1
1,1-Dichloroethane	<1.0		1.0	0.29	ug/L			08/29/11 15:56	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 15:56	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 15:56	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 15:56	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 15:56	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 15:56	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 15:56	1
cis-1,2-Dichloroethene	0.92	J	1.0	0.22	ug/L			08/29/11 15:56	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 15:56	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 15:56	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 15:56	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 15:56	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 15:56	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 15:56	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 15:56	1
Trichloroethene	3.2		0.50	0.18	ug/L			08/29/11 15:56	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 15:56	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 15:56	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 15:56	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 15:56	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 15:56	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 15:56	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 15:56	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 15:56	1
Tetrachloroethene	18		1.0	0.22	ug/L			08/29/11 15:56	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 15:56	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 15:56	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 15:56	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 15:56	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 15:56	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 15:56	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 15:56	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 15:56	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 15:56	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 15:56	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 15:56	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 15:56	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 15:56	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 15:56	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 15:56	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 15:56	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 15:56	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 15:56	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-13

Lab Sample ID: 500-38462-8

Date Collected: 08/24/11 16:35

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 15:56	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 15:56	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 15:56	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 15:56	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 15:56	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 15:56	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 15:56	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 15:56	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 15:56	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 15:56	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 15:56	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 15:56	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 15:56	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 15:56	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	DII Fac
1,2-Dichloroethane-d4 (Surr)	102		77 - 124					08/29/11 15:56	1
Toluene-d8 (Surr)	97		80 - 121					08/29/11 15:56	1
4-Bromofluorobenzene (Surr)	89		77 - 112					08/29/11 15:56	1
Dibromofluoromethane	103		78 - 119					08/29/11 15:56	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-17

Lab Sample ID: 500-38462-9

Date Collected: 08/24/11 10:10

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	1.5		0.50	0.12	ug/L			08/29/11 16:21	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 16:21	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 16:21	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 16:21	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 16:21	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 16:21	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 16:21	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 16:21	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 16:21	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 16:21	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 16:21	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 16:21	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 16:21	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 16:21	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/29/11 16:21	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 16:21	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 16:21	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 16:21	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 16:21	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 16:21	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 16:21	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 16:21	1
Trichloroethene	<0.50		0.50	0.18	ug/L			08/29/11 16:21	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 16:21	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 16:21	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 16:21	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 16:21	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 16:21	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 16:21	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 16:21	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 16:21	1
Tetrachloroethene	<1.0		1.0	0.22	ug/L			08/29/11 16:21	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 16:21	1
2-Hexanone	<5.0		5.0	0.58	ug/L			08/29/11 16:21	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 16:21	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 16:21	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 16:21	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 16:21	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 16:21	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 16:21	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 16:21	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 16:21	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 16:21	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 16:21	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 16:21	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 16:21	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 16:21	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 16:21	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 16:21	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 16:21	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-17

Lab Sample ID: 500-38462-9

Date Collected: 08/24/11 10:10

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 16:21	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 16:21	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 16:21	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 16:21	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 16:21	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 16:21	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 16:21	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 16:21	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 16:21	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 16:21	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 16:21	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 16:21	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 16:21	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 16:21	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	DII Fac
1,2-Dichloroethane-d4 (Surr)	106		77 - 124					08/29/11 16:21	1
Toluene-d8 (Surr)	103		80 - 121					08/29/11 16:21	1
4-Bromofluorobenzene (Surr)	94		77 - 112					08/29/11 16:21	1
Dibromofluoromethane	107		78 - 119					08/29/11 16:21	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-5

Lab Sample ID: 500-38462-10

Date Collected: 08/24/11 09:00

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 16:47	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 16:47	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 16:47	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 16:47	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 16:47	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 16:47	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 16:47	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 16:47	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 16:47	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 16:47	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 16:47	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 16:47	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 16:47	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 16:47	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/29/11 16:47	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 16:47	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 16:47	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 16:47	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 16:47	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 16:47	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 16:47	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 16:47	1
Trichloroethene	120		0.50	0.18	ug/L			08/29/11 16:47	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 16:47	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 16:47	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 16:47	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 16:47	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 16:47	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 16:47	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 16:47	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 16:47	1
Tetrachloroethene	3.4		1.0	0.22	ug/L			08/29/11 16:47	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 16:47	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 16:47	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 16:47	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 16:47	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 16:47	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 16:47	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 16:47	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 16:47	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 16:47	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 16:47	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 16:47	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 16:47	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 16:47	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 16:47	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 16:47	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 16:47	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 16:47	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 16:47	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-5

Lab Sample ID: 500-38462-10

Date Collected: 08/24/11 09:00

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 16:47	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 16:47	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 16:47	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 16:47	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 16:47	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 16:47	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 16:47	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 16:47	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 16:47	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 16:47	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 16:47	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 16:47	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 16:47	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 16:47	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	101		77 - 124					08/29/11 16:47	1
Toluene-d8 (Surr)	95		80 - 121					08/29/11 16:47	1
4-Bromofluorobenzene (Surr)	88		77 - 112					08/29/11 16:47	1
Dibromofluoromethane	100		78 - 119					08/29/11 16:47	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-6

Lab Sample ID: 500-38462-11

Date Collected: 08/24/11 14:15

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 17:13	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 17:13	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 17:13	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 17:13	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 17:13	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 17:13	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 17:13	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 17:13	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 17:13	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 17:13	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 17:13	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 17:13	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 17:13	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 17:13	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/29/11 17:13	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 17:13	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 17:13	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 17:13	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 17:13	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 17:13	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 17:13	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 17:13	1
Trichloroethene	6.7		0.50	0.18	ug/L			08/29/11 17:13	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 17:13	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 17:13	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 17:13	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 17:13	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 17:13	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 17:13	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 17:13	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 17:13	1
Tetrachloroethene	13		1.0	0.22	ug/L			08/29/11 17:13	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 17:13	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 17:13	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 17:13	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 17:13	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 17:13	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 17:13	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 17:13	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 17:13	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 17:13	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 17:13	1
Bromofom	<1.0		1.0	0.45	ug/L			08/29/11 17:13	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 17:13	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 17:13	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 17:13	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 17:13	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 17:13	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 17:13	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 17:13	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-6

Lab Sample ID: 500-38462-11

Date Collected: 08/24/11 14:15

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 17:13	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 17:13	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 17:13	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 17:13	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 17:13	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 17:13	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 17:13	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 17:13	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 17:13	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 17:13	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 17:13	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 17:13	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 17:13	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 17:13	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	DII Fac
1,2-Dichloroethane-d4 (Surr)	109		77 - 124					08/29/11 17:13	1
Toluene-d8 (Surr)	102		80 - 121					08/29/11 17:13	1
4-Bromofluorobenzene (Surr)	95		77 - 112					08/29/11 17:13	1
Dibromofluoromethane	109		78 - 119					08/29/11 17:13	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-7

Lab Sample ID: 500-38462-12

Date Collected: 08/24/11 14:00

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 17:39	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 17:39	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 17:39	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 17:39	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 17:39	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 17:39	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 17:39	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 17:39	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 17:39	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 17:39	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 17:39	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 17:39	1
1,1-Dichloroethane	0.87	J	1.0	0.24	ug/L			08/29/11 17:39	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 17:39	1
cis-1,2-Dichloroethene	9.0		1.0	0.22	ug/L			08/29/11 17:39	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 17:39	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 17:39	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 17:39	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 17:39	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 17:39	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 17:39	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 17:39	1
Trichloroethene	6.6		0.50	0.18	ug/L			08/29/11 17:39	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 17:39	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 17:39	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 17:39	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 17:39	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 17:39	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 17:39	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 17:39	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 17:39	1
Tetrachloroethene	14		1.0	0.22	ug/L			08/29/11 17:39	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 17:39	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 17:39	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 17:39	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 17:39	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 17:39	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 17:39	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 17:39	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 17:39	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 17:39	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 17:39	1
Bromofom	<1.0		1.0	0.45	ug/L			08/29/11 17:39	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 17:39	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 17:39	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 17:39	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 17:39	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 17:39	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 17:39	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 17:39	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-7

Lab Sample ID: 500-38462-12

Date Collected: 08/24/11 14:00

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 17:39	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 17:39	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 17:39	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 17:39	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 17:39	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 17:39	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 17:39	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 17:39	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 17:39	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 17:39	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 17:39	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 17:39	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 17:39	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 17:39	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	DII Fac
1,2-Dichloroethane-d4 (Surr)	110		77 - 124					08/29/11 17:39	1
Toluene-d8 (Surr)	105		80 - 121					08/29/11 17:39	1
4-Bromofluorobenzene (Surr)	97		77 - 112					08/29/11 17:39	1
Dibromofluoromethane	114		78 - 119					08/29/11 17:39	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-8

Lab Sample ID: 500-38462-13

Date Collected: 08/24/11 13:55

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC										
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil	Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 18:05		1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 18:05		1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 18:05		1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 18:05		1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 18:05		1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 18:05		1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 18:05		1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 18:05		1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 18:05		1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 18:05		1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 18:05		1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 18:05		1
1,1-Dichloroethane	0.86	J	1.0	0.24	ug/L			08/29/11 18:05		1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 18:05		1
cis-1,2-Dichloroethene	25		1.0	0.22	ug/L			08/29/11 18:05		1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 18:05		1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 18:05		1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 18:05		1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 18:05		1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 18:05		1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 18:05		1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 18:05		1
Trichloroethene	9.1		0.50	0.18	ug/L			08/29/11 18:05		1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 18:05		1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 18:05		1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 18:05		1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 18:05		1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 18:05		1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 18:05		1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 18:05		1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 18:05		1
Tetrachloroethene	62		1.0	0.22	ug/L			08/29/11 18:05		1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 18:05		1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 18:05		1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 18:05		1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 18:05		1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 18:05		1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 18:05		1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 18:05		1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 18:05		1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 18:05		1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 18:05		1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 18:05		1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 18:05		1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 18:05		1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 18:05		1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 18:05		1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 18:05		1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 18:05		1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 18:05		1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-8

Lab Sample ID: 500-38462-13

Date Collected: 08/24/11 13:55

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 18:05	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 18:05	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 18:05	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 18:05	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 18:05	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 18:05	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 18:05	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 18:05	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 18:05	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 18:05	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 18:05	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 18:05	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 18:05	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 18:05	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	DII Fac
1,2-Dichloroethane-d4 (Surr)	104		77 - 124					08/29/11 18:05	1
Toluene-d8 (Surr)	100		80 - 121					08/29/11 18:05	1
4-Bromofluorobenzene (Surr)	93		77 - 112					08/29/11 18:05	1
Dibromofluoromethane	107		78 - 119					08/29/11 18:05	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-9

Lab Sample ID: 500-38462-14

Date Collected: 08/24/11 13:50

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 18:31	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 18:31	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 18:31	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 18:31	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 18:31	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 18:31	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 18:31	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 18:31	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 18:31	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 18:31	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 18:31	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 18:31	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 18:31	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 18:31	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/29/11 18:31	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 18:31	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 18:31	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 18:31	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 18:31	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 18:31	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 18:31	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 18:31	1
Trichloroethene	0.75		0.50	0.18	ug/L			08/29/11 18:31	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 18:31	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 18:31	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 18:31	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 18:31	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 18:31	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 18:31	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 18:31	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 18:31	1
Tetrachloroethene	100		1.0	0.22	ug/L			08/29/11 18:31	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 18:31	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 18:31	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 18:31	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 18:31	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 18:31	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 18:31	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 18:31	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 18:31	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 18:31	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 18:31	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 18:31	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 18:31	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 18:31	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 18:31	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 18:31	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 18:31	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 18:31	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 18:31	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-9

Lab Sample ID: 500-38462-14

Date Collected: 08/24/11 13:50

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 18:31	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 18:31	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 18:31	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 18:31	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 18:31	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 18:31	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 18:31	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 18:31	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 18:31	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 18:31	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 18:31	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 18:31	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 18:31	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 18:31	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		77 - 124					08/29/11 18:31	1
Toluene-d8 (Surr)	99		80 - 121					08/29/11 18:31	1
4-Bromofluorobenzene (Surr)	90		77 - 112					08/29/11 18:31	1
Dibromofluoromethane	108		78 - 119					08/29/11 18:31	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-9 DUP

Lab Sample ID: 500-38462-15

Date Collected: 08/24/11 13:50

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 18:56	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 18:56	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 18:56	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 18:56	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 18:56	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 18:56	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 18:56	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 18:56	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 18:56	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 18:56	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 18:56	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 18:56	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 18:56	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 18:56	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/29/11 18:56	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 18:56	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 18:56	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 18:56	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 18:56	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 18:56	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 18:56	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 18:56	1
Trichloroethene	0.79		0.50	0.18	ug/L			08/29/11 18:56	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 18:56	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 18:56	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 18:56	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 18:56	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 18:56	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 18:56	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 18:56	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 18:56	1
Tetrachloroethene	110		1.0	0.22	ug/L			08/29/11 18:56	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 18:56	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 18:56	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 18:56	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 18:56	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 18:56	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 18:56	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 18:56	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 18:56	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 18:56	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 18:56	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 18:56	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 18:56	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 18:56	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 18:56	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 18:56	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 18:56	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 18:56	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 18:56	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-9 DUP

Lab Sample ID: 500-38462-15

Date Collected: 08/24/11 13:50

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 18:56	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 18:56	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 18:56	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 18:56	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 18:56	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 18:56	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 18:56	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 18:56	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 18:56	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 18:56	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 18:56	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 18:56	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 18:56	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 18:56	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	108		77 - 124					08/29/11 18:56	1
Toluene-d8 (Surr)	100		80 - 121					08/29/11 18:56	1
4-Bromofluorobenzene (Surr)	92		77 - 112					08/29/11 18:56	1
Dibromofluoromethane	106		78 - 119					08/29/11 18:56	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-10

Lab Sample ID: 500-38462-16

Date Collected: 08/24/11 13:40

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 19:22	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 19:22	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 19:22	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 19:22	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 19:22	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 19:22	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 19:22	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 19:22	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 19:22	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 19:22	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 19:22	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 19:22	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 19:22	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 19:22	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/29/11 19:22	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 19:22	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 19:22	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 19:22	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 19:22	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 19:22	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 19:22	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 19:22	1
Trichloroethene	<0.50		0.50	0.18	ug/L			08/29/11 19:22	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 19:22	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 19:22	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 19:22	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 19:22	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 19:22	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 19:22	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 19:22	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 19:22	1
Tetrachloroethene	<1.0		1.0	0.22	ug/L			08/29/11 19:22	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 19:22	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 19:22	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 19:22	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 19:22	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 19:22	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 19:22	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 19:22	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 19:22	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 19:22	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 19:22	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 19:22	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 19:22	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 19:22	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 19:22	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 19:22	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 19:22	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 19:22	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 19:22	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-10
Date Collected: 08/24/11 13:40
Date Received: 08/27/11 09:50

Lab Sample ID: 500-38462-16
Matrix: Water

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 19:22	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 19:22	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 19:22	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 19:22	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 19:22	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 19:22	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 19:22	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 19:22	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 19:22	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 19:22	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 19:22	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 19:22	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 19:22	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 19:22	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	DII Fac
1,2-Dichloroethane-d4 (Surr)	111		77 - 124					08/29/11 19:22	1
Toluene-d8 (Surr)	102		80 - 121					08/29/11 19:22	1
4-Bromofluorobenzene (Surr)	95		77 - 112					08/29/11 19:22	1
Dibromofluoromethane	109		78 - 119					08/29/11 19:22	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: TRIP BLANK

Lab Sample ID: 500-38462-17

Date Collected: 08/24/11 07:00

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 19:48	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 19:48	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 19:48	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 19:48	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 19:48	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 19:48	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 19:48	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 19:48	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 19:48	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 19:48	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 19:48	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 19:48	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 19:48	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 19:48	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/29/11 19:48	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 19:48	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 19:48	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 19:48	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 19:48	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 19:48	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 19:48	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 19:48	1
Trichloroethene	<0.50		0.50	0.18	ug/L			08/29/11 19:48	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 19:48	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 19:48	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 19:48	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 19:48	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 19:48	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 19:48	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 19:48	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 19:48	1
Tetrachloroethene	<1.0		1.0	0.22	ug/L			08/29/11 19:48	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 19:48	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 19:48	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 19:48	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 19:48	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 19:48	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 19:48	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 19:48	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 19:48	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 19:48	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 19:48	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 19:48	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 19:48	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 19:48	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 19:48	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 19:48	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 19:48	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 19:48	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 19:48	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: TRIP BLANK

Lab Sample ID: 500-38462-17

Date Collected: 08/24/11 07:00

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 19:48	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 19:48	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 19:48	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 19:48	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 19:48	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 19:48	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 19:48	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 19:48	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 19:48	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 19:48	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 19:48	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 19:48	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 19:48	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 19:48	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	110		77 - 124					08/29/11 19:48	1
Toluene-d8 (Surr)	101		80 - 121					08/29/11 19:48	1
4-Bromofluorobenzene (Surr)	96		77 - 112					08/29/11 19:48	1
Dibromofluoromethane	113		78 - 119					08/29/11 19:48	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-2

Lab Sample ID: 500-38462-18

Date Collected: 08/26/11 11:00

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 20:13	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 20:13	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 20:13	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 20:13	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 20:13	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 20:13	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 20:13	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 20:13	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 20:13	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 20:13	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 20:13	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 20:13	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 20:13	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 20:13	1
cis-1,2-Dichloroethene	4.5		1.0	0.22	ug/L			08/29/11 20:13	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 20:13	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 20:13	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 20:13	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 20:13	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 20:13	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 20:13	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 20:13	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 20:13	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 20:13	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 20:13	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 20:13	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 20:13	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 20:13	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 20:13	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 20:13	1
Tetrachloroethene	55		1.0	0.22	ug/L			08/29/11 20:13	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 20:13	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 20:13	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 20:13	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 20:13	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 20:13	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 20:13	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 20:13	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 20:13	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 20:13	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 20:13	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 20:13	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 20:13	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 20:13	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 20:13	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 20:13	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 20:13	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 20:13	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 20:13	1
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 20:13	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-2

Lab Sample ID: 500-38462-18

Date Collected: 08/26/11 11:00

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 20:13	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 20:13	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 20:13	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 20:13	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 20:13	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 20:13	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 20:13	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 20:13	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 20:13	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 20:13	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 20:13	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 20:13	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 20:13	1

Surrogate	% Recovery	Qualifier	Limits	Prepared	Analyzed	DII Fac
1,2-Dichloroethane-d4 (Surr)	107		77 - 124		08/29/11 20:13	1
Toluene-d8 (Surr)	98		80 - 121		08/29/11 20:13	1
4-Bromofluorobenzene (Surr)	90		77 - 112		08/29/11 20:13	1
Dibromofluoromethane	105		78 - 119		08/29/11 20:13	1

Method: 8260B - VOC - DL

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Trichloroethene	280		2.5	0.90	ug/L			08/29/11 20:39	5

Surrogate	% Recovery	Qualifier	Limits	Prepared	Analyzed	DII Fac
1,2-Dichloroethane-d4 (Surr)	102		77 - 124		08/29/11 20:39	5
Toluene-d8 (Surr)	97		80 - 121		08/29/11 20:39	5
4-Bromofluorobenzene (Surr)	89		77 - 112		08/29/11 20:39	5
Dibromofluoromethane	106		78 - 119		08/29/11 20:39	5

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-3
Date Collected: 08/26/11 08:15
Date Received: 08/27/11 09:50

Lab Sample ID: 500-38462-19
Matrix: Water

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 21:05	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 21:05	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 21:05	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 21:05	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 21:05	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 21:05	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 21:05	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 21:05	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 21:05	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 21:05	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 21:05	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 21:05	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 21:05	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 21:05	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/29/11 21:05	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 21:05	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 21:05	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 21:05	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 21:05	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 21:05	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 21:05	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 21:05	1
Trichloroethene	73		0.50	0.18	ug/L			08/29/11 21:05	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 21:05	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 21:05	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 21:05	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 21:05	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 21:05	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 21:05	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 21:05	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 21:05	1
Tetrachloroethene	2.3		1.0	0.22	ug/L			08/29/11 21:05	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 21:05	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 21:05	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 21:05	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 21:05	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 21:05	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 21:05	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 21:05	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 21:05	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 21:05	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 21:05	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 21:05	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 21:05	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 21:05	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 21:05	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 21:05	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 21:05	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 21:05	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 21:05	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-3

Lab Sample ID: 500-38462-19

Date Collected: 08/26/11 08:15

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 21:05	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 21:05	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 21:05	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 21:05	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 21:05	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 21:05	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 21:05	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 21:05	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 21:05	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 21:05	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 21:05	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 21:05	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 21:05	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 21:05	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	115		77 - 124					08/29/11 21:05	1
Toluene-d8 (Surr)	106		80 - 121					08/29/11 21:05	1
4-Bromofluorobenzene (Surr)	99		77 - 112					08/29/11 21:05	1
Dibromofluoromethane	116		78 - 119					08/29/11 21:05	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-4

Lab Sample ID: 500-38462-20

Date Collected: 08/26/11 08:00

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.12	ug/L			08/30/11 10:35	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/30/11 10:35	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/30/11 10:35	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/30/11 10:35	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/30/11 10:35	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/30/11 10:35	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/30/11 10:35	1
1,1-Dichloroethane	<1.0		1.0	0.29	ug/L			08/30/11 10:35	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/30/11 10:35	1
Acetone	<5.0		5.0	1.9	ug/L			08/30/11 10:35	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/30/11 10:35	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/30/11 10:35	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/30/11 10:35	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/30/11 10:35	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/30/11 10:35	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/30/11 10:35	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/30/11 10:35	1
Chloroform	<1.0		1.0	0.25	ug/L			08/30/11 10:35	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/30/11 10:35	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/30/11 10:35	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/30/11 10:35	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/30/11 10:35	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/30/11 10:35	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/30/11 10:35	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/30/11 10:35	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/30/11 10:35	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/30/11 10:35	1
Toluene	<0.50		0.50	0.15	ug/L			08/30/11 10:35	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/30/11 10:35	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/30/11 10:35	1
Tetrachloroethene	13		1.0	0.22	ug/L			08/30/11 10:35	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/30/11 10:35	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/30/11 10:35	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/30/11 10:35	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/30/11 10:35	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 10:35	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/30/11 10:35	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/30/11 10:35	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/30/11 10:35	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/30/11 10:35	1
Styrene	<1.0		1.0	0.26	ug/L			08/30/11 10:35	1
Bromoform	<1.0		1.0	0.45	ug/L			08/30/11 10:35	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 10:35	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/30/11 10:35	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/30/11 10:35	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/30/11 10:35	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 10:35	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 10:35	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/30/11 10:35	1
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 10:35	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: EW-4

Lab Sample ID: 500-38462-20

Date Collected: 08/26/11 08:00

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/30/11 10:35	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/30/11 10:35	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 10:35	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/30/11 10:35	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/30/11 10:35	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 10:35	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 10:35	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/30/11 10:35	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/30/11 10:35	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/30/11 10:35	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/30/11 10:35	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/30/11 10:35	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/30/11 10:35	1

Surrogate	% Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	90		77 - 124		08/30/11 10:35	1
Toluene-d8 (Surr)	86		80 - 121		08/30/11 10:35	1
4-Bromofluorobenzene (Surr)	81		77 - 112		08/30/11 10:35	1
Dibromofluoromethane	89		78 - 119		08/30/11 10:35	1

Method: 8260B - VOC - DL

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Trichloroethene	770		5.0	1.8	ug/L			08/30/11 11:01	10

Surrogate	% Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	108		77 - 124		08/30/11 11:01	10
Toluene-d8 (Surr)	104		80 - 121		08/30/11 11:01	10
4-Bromofluorobenzene (Surr)	97		77 - 112		08/30/11 11:01	10
Dibromofluoromethane	104		78 - 119		08/30/11 11:01	10

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-11B

Lab Sample ID: 500-38462-21

Date Collected: 08/26/11 08:20

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.12	ug/L			08/30/11 11:27	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/30/11 11:27	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/30/11 11:27	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/30/11 11:27	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/30/11 11:27	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/30/11 11:27	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/30/11 11:27	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/30/11 11:27	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/30/11 11:27	1
Acetone	<5.0		5.0	1.9	ug/L			08/30/11 11:27	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/30/11 11:27	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/30/11 11:27	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/30/11 11:27	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/30/11 11:27	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/30/11 11:27	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/30/11 11:27	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/30/11 11:27	1
Chloroform	<1.0		1.0	0.25	ug/L			08/30/11 11:27	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/30/11 11:27	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/30/11 11:27	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/30/11 11:27	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/30/11 11:27	1
Trichloroethene	<0.50		0.50	0.18	ug/L			08/30/11 11:27	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/30/11 11:27	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/30/11 11:27	1
Dibromodichloromethane	<1.0		1.0	0.23	ug/L			08/30/11 11:27	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/30/11 11:27	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/30/11 11:27	1
Toluene	<0.50		0.50	0.15	ug/L			08/30/11 11:27	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/30/11 11:27	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/30/11 11:27	1
Tetrachloroethene	<1.0		1.0	0.22	ug/L			08/30/11 11:27	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/30/11 11:27	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/30/11 11:27	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/30/11 11:27	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/30/11 11:27	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 11:27	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/30/11 11:27	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/30/11 11:27	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/30/11 11:27	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/30/11 11:27	1
Styrene	<1.0		1.0	0.26	ug/L			08/30/11 11:27	1
Bromoform	<1.0		1.0	0.45	ug/L			08/30/11 11:27	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 11:27	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/30/11 11:27	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/30/11 11:27	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/30/11 11:27	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 11:27	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 11:27	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/30/11 11:27	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-11B

Lab Sample ID: 500-38462-21

Date Collected: 08/26/11 08:20

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 11:27	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/30/11 11:27	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/30/11 11:27	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 11:27	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/30/11 11:27	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/30/11 11:27	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 11:27	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 11:27	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/30/11 11:27	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/30/11 11:27	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/30/11 11:27	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/30/11 11:27	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/30/11 11:27	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/30/11 11:27	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	97		77 - 124					08/30/11 11:27	1
Toluene-d8 (Surr)	93		80 - 121					08/30/11 11:27	1
4-Bromofluorobenzene (Surr)	87		77 - 112					08/30/11 11:27	1
Dibromofluoromethane	95		78 - 119					08/30/11 11:27	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-9

Lab Sample ID: 500-38462-22

Date Collected: 08/26/11 09:10

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.12	ug/L			08/30/11 11:52	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/30/11 11:52	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/30/11 11:52	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/30/11 11:52	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/30/11 11:52	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/30/11 11:52	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/30/11 11:52	1
1,1-Dichloroethene	1.0		1.0	0.29	ug/L			08/30/11 11:52	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/30/11 11:52	1
Acetone	<5.0		5.0	1.9	ug/L			08/30/11 11:52	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/30/11 11:52	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/30/11 11:52	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/30/11 11:52	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/30/11 11:52	1
cis-1,2-Dichloroethene	11		1.0	0.22	ug/L			08/30/11 11:52	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/30/11 11:52	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/30/11 11:52	1
Chloroform	<1.0		1.0	0.25	ug/L			08/30/11 11:52	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/30/11 11:52	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/30/11 11:52	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/30/11 11:52	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/30/11 11:52	1
Trichloroethene	12		0.50	0.18	ug/L			08/30/11 11:52	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/30/11 11:52	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/30/11 11:52	1
Bromochloromethane	<1.0		1.0	0.23	ug/L			08/30/11 11:52	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/30/11 11:52	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/30/11 11:52	1
Toluene	<0.50		0.50	0.15	ug/L			08/30/11 11:52	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/30/11 11:52	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/30/11 11:52	1
Tetrachloroethene	4.7		1.0	0.22	ug/L			08/30/11 11:52	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/30/11 11:52	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/30/11 11:52	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/30/11 11:52	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/30/11 11:52	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 11:52	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/30/11 11:52	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/30/11 11:52	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/30/11 11:52	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/30/11 11:52	1
Styrene	<1.0		1.0	0.26	ug/L			08/30/11 11:52	1
Bromoform	<1.0		1.0	0.45	ug/L			08/30/11 11:52	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 11:52	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/30/11 11:52	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/30/11 11:52	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/30/11 11:52	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 11:52	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 11:52	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/30/11 11:52	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-9

Lab Sample ID: 500-38462-22

Date Collected: 08/26/11 09:10

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 11:52	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/30/11 11:52	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/30/11 11:52	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 11:52	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/30/11 11:52	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/30/11 11:52	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 11:52	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 11:52	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/30/11 11:52	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/30/11 11:52	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/30/11 11:52	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/30/11 11:52	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/30/11 11:52	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/30/11 11:52	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	103		77 - 124					08/30/11 11:52	1
Toluene-d8 (Surr)	98		80 - 121					08/30/11 11:52	1
4-Bromofluorobenzene (Surr)	92		77 - 112					08/30/11 11:52	1
Dibromofluoromethane	99		78 - 119					08/30/11 11:52	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-4A

Lab Sample ID: 500-38462-23

Date Collected: 08/26/11 10:05

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Benzene	<0.50		0.50	0.12	ug/L			08/30/11 12:18	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/30/11 12:18	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/30/11 12:18	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/30/11 12:18	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/30/11 12:18	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/30/11 12:18	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/30/11 12:18	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/30/11 12:18	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/30/11 12:18	1
Acetone	<5.0		5.0	1.9	ug/L			08/30/11 12:18	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/30/11 12:18	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/30/11 12:18	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/30/11 12:18	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/30/11 12:18	1
cis-1,2-Dichloroethene	0.73	J	1.0	0.22	ug/L			08/30/11 12:18	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/30/11 12:18	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/30/11 12:18	1
Chloroform	0.84	J	1.0	0.25	ug/L			08/30/11 12:18	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/30/11 12:18	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/30/11 12:18	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/30/11 12:18	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/30/11 12:18	1
Trichloroethene	28		0.50	0.18	ug/L			08/30/11 12:18	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/30/11 12:18	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/30/11 12:18	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/30/11 12:18	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/30/11 12:18	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/30/11 12:18	1
Toluene	<0.50		0.50	0.15	ug/L			08/30/11 12:18	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/30/11 12:18	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/30/11 12:18	1
Tetrachloroethene	21		1.0	0.22	ug/L			08/30/11 12:18	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/30/11 12:18	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/30/11 12:18	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/30/11 12:18	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/30/11 12:18	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 12:18	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/30/11 12:18	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/30/11 12:18	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/30/11 12:18	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/30/11 12:18	1
Styrene	<1.0		1.0	0.26	ug/L			08/30/11 12:18	1
Bromofom	<1.0		1.0	0.45	ug/L			08/30/11 12:18	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 12:18	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/30/11 12:18	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/30/11 12:18	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/30/11 12:18	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 12:18	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 12:18	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/30/11 12:18	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-4A

Lab Sample ID: 500-38462-23

Date Collected: 08/26/11 10:05

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 12:18	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/30/11 12:18	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/30/11 12:18	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 12:18	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/30/11 12:18	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/30/11 12:18	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 12:18	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 12:18	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/30/11 12:18	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/30/11 12:18	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/30/11 12:18	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/30/11 12:18	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/30/11 12:18	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/30/11 12:18	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	DII Fac
1,2-Dichloroethane-d4 (Surr)	109		77 - 124					08/30/11 12:18	1
Toluene-d8 (Surr)	101		80 - 121					08/30/11 12:18	1
4-Bromofluorobenzene (Surr)	94		77 - 112					08/30/11 12:18	1
Dibromofluoromethane	108		78 - 119					08/30/11 12:18	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-4A DUP

Lab Sample ID: 500-38462-24

Date Collected: 08/26/11 10:05

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.12	ug/L			08/30/11 12:43	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/30/11 12:43	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/30/11 12:43	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/30/11 12:43	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/30/11 12:43	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/30/11 12:43	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/30/11 12:43	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/30/11 12:43	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/30/11 12:43	1
Acetone	<5.0		5.0	1.9	ug/L			08/30/11 12:43	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/30/11 12:43	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/30/11 12:43	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/30/11 12:43	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/30/11 12:43	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/30/11 12:43	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/30/11 12:43	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/30/11 12:43	1
Chloroform	<1.0		1.0	0.25	ug/L			08/30/11 12:43	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/30/11 12:43	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/30/11 12:43	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/30/11 12:43	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/30/11 12:43	1
Trichloroethene	27		0.50	0.18	ug/L			08/30/11 12:43	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/30/11 12:43	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/30/11 12:43	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/30/11 12:43	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/30/11 12:43	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/30/11 12:43	1
Toluene	<0.50		0.50	0.15	ug/L			08/30/11 12:43	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/30/11 12:43	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/30/11 12:43	1
Tetrachloroethene	20		1.0	0.22	ug/L			08/30/11 12:43	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/30/11 12:43	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/30/11 12:43	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/30/11 12:43	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/30/11 12:43	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 12:43	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/30/11 12:43	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/30/11 12:43	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/30/11 12:43	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/30/11 12:43	1
Styrene	<1.0		1.0	0.26	ug/L			08/30/11 12:43	1
Bromoform	<1.0		1.0	0.45	ug/L			08/30/11 12:43	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 12:43	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/30/11 12:43	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/30/11 12:43	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/30/11 12:43	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 12:43	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 12:43	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/30/11 12:43	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-4A DUP

Lab Sample ID: 500-38462-24

Date Collected: 08/26/11 10:05

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 12:43	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/30/11 12:43	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/30/11 12:43	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 12:43	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/30/11 12:43	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/30/11 12:43	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 12:43	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 12:43	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/30/11 12:43	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/30/11 12:43	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/30/11 12:43	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/30/11 12:43	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/30/11 12:43	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/30/11 12:43	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	105		77 - 124					08/30/11 12:43	1
Toluene-d8 (Surr)	97		80 - 121					08/30/11 12:43	1
4-Bromofluorobenzene (Surr)	93		77 - 112					08/30/11 12:43	1
Dibromofluoromethane	101		78 - 119					08/30/11 12:43	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-4B

Lab Sample ID: 500-38462-25

Date Collected: 08/26/11 10:30

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.12	ug/L			08/30/11 13:09	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/30/11 13:09	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/30/11 13:09	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/30/11 13:09	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/30/11 13:09	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/30/11 13:09	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/30/11 13:09	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/30/11 13:09	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/30/11 13:09	1
Acetone	<5.0		5.0	1.9	ug/L			08/30/11 13:09	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/30/11 13:09	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/30/11 13:09	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/30/11 13:09	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/30/11 13:09	1
cis-1,2-Dichloroethene	3.4		1.0	0.22	ug/L			08/30/11 13:09	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/30/11 13:09	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/30/11 13:09	1
Chloroform	1.7		1.0	0.25	ug/L			08/30/11 13:09	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/30/11 13:09	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/30/11 13:09	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/30/11 13:09	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/30/11 13:09	1
Trichloroethene	50		0.50	0.18	ug/L			08/30/11 13:09	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/30/11 13:09	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/30/11 13:09	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/30/11 13:09	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/30/11 13:09	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/30/11 13:09	1
Toluene	<0.50		0.50	0.15	ug/L			08/30/11 13:09	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/30/11 13:09	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/30/11 13:09	1
Tetrachloroethene	78		1.0	0.22	ug/L			08/30/11 13:09	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/30/11 13:09	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/30/11 13:09	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/30/11 13:09	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/30/11 13:09	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 13:09	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/30/11 13:09	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/30/11 13:09	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/30/11 13:09	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/30/11 13:09	1
Styrene	<1.0		1.0	0.26	ug/L			08/30/11 13:09	1
Bromoform	<1.0		1.0	0.45	ug/L			08/30/11 13:09	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 13:09	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/30/11 13:09	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/30/11 13:09	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/30/11 13:09	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 13:09	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 13:09	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/30/11 13:09	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-4B

Lab Sample ID: 500-38462-25

Date Collected: 08/26/11 10:30

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 13:09	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/30/11 13:09	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/30/11 13:09	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 13:09	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/30/11 13:09	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/30/11 13:09	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 13:09	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 13:09	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/30/11 13:09	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/30/11 13:09	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/30/11 13:09	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/30/11 13:09	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/30/11 13:09	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/30/11 13:09	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	109		77 - 124					08/30/11 13:09	1
Toluene-d8 (Surr)	102		80 - 121					08/30/11 13:09	1
4-Bromofluorobenzene (Surr)	95		77 - 112					08/30/11 13:09	1
Dibromofluoromethane	109		78 - 119					08/30/11 13:09	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-12B

Lab Sample ID: 500-38462-26

Date Collected: 08/26/11 12:00

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Benzene	<0.50		0.50	0.12	ug/L			08/30/11 13:35	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/30/11 13:35	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/30/11 13:35	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/30/11 13:35	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/30/11 13:35	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/30/11 13:35	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/30/11 13:35	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/30/11 13:35	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/30/11 13:35	1
Acetone	<5.0		5.0	1.9	ug/L			08/30/11 13:35	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/30/11 13:35	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/30/11 13:35	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/30/11 13:35	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/30/11 13:35	1
cis-1,2-Dichloroethene	2.7		1.0	0.22	ug/L			08/30/11 13:35	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/30/11 13:35	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/30/11 13:35	1
Chloroform	<1.0		1.0	0.25	ug/L			08/30/11 13:35	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/30/11 13:35	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/30/11 13:35	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/30/11 13:35	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/30/11 13:35	1
Trichloroethene	120		0.50	0.18	ug/L			08/30/11 13:35	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/30/11 13:35	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/30/11 13:35	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/30/11 13:35	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/30/11 13:35	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/30/11 13:35	1
Toluene	<0.50		0.50	0.15	ug/L			08/30/11 13:35	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/30/11 13:35	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/30/11 13:35	1
Tetrachloroethene	8.9		1.0	0.22	ug/L			08/30/11 13:35	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/30/11 13:35	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/30/11 13:35	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/30/11 13:35	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/30/11 13:35	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 13:35	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/30/11 13:35	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/30/11 13:35	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/30/11 13:35	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/30/11 13:35	1
Styrene	<1.0		1.0	0.26	ug/L			08/30/11 13:35	1
Bromoform	<1.0		1.0	0.45	ug/L			08/30/11 13:35	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 13:35	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/30/11 13:35	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/30/11 13:35	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/30/11 13:35	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 13:35	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 13:35	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/30/11 13:35	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Client Sample ID: RFW-12B

Lab Sample ID: 500-38462-26

Date Collected: 08/26/11 12:00

Matrix: Water

Date Received: 08/27/11 09:50

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 13:35	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/30/11 13:35	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/30/11 13:35	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 13:35	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/30/11 13:35	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/30/11 13:35	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 13:35	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 13:35	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/30/11 13:35	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/30/11 13:35	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/30/11 13:35	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/30/11 13:35	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/30/11 13:35	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/30/11 13:35	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	109		77 - 124					08/30/11 13:35	1
Toluene-d8 (Surr)	103		80 - 121					08/30/11 13:35	1
4-Bromofluorobenzene (Surr)	95		77 - 112					08/30/11 13:35	1
Dibromofluoromethane	113		78 - 119					08/30/11 13:35	1

Definitions/Glossary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Qualifiers

GC/MS VOA

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☆	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
DL, RA, RE, IN	Indicates a Dilution, Reanalysis, Re-extraction, or additional Initial metals/anion analysis of the sample
EDL	Estimated Detection Limit (Dioxin)
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
ND	Not detected at the reporting limit (or method detection limit if shown)
PQL	Practical Quantitation Limit
RL	Reporting Limit
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

QC Association Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

GC/MS VOA

Analysis Batch: 123933

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-38462-1	RFW-1A	Total/NA	Water	8260B	
500-38462-2	RFW-1B	Total/NA	Water	8260B	
500-38462-3	RFW-2A	Total/NA	Water	8260B	
500-38462-4	RFW-2B	Total/NA	Water	8260B	
500-38462-5	RFW-3B	Total/NA	Water	8260B	
500-38462-6	RFW-6	Total/NA	Water	8260B	
500-38462-7	RFW-7	Total/NA	Water	8260B	
500-38462-8	RFW-13	Total/NA	Water	8260B	
500-38462-9	RFW-17	Total/NA	Water	8260B	
500-38462-10	EW-5	Total/NA	Water	8260B	
500-38462-11	EW-6	Total/NA	Water	8260B	
500-38462-12	EW-7	Total/NA	Water	8260B	
500-38462-13	EW-8	Total/NA	Water	8260B	
500-38462-14	EW-9	Total/NA	Water	8260B	
500-38462-15	EW-9 DUP	Total/NA	Water	8260B	
500-38462-16	EW-10	Total/NA	Water	8260B	
500-38462-17	TRIP BLANK	Total/NA	Water	8260B	
500-38462-18	EW-2	Total/NA	Water	8260B	
500-38462-18 - DL	EW-2	Total/NA	Water	8260B	
500-38462-19	EW-3	Total/NA	Water	8260B	
LCS 500-123933/5	Lab Control Sample	Total/NA	Water	8260B	
MB 500-123933/4	Method Blank	Total/NA	Water	8260B	

Analysis Batch: 123958

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-38462-20	EW-4	Total/NA	Water	8260B	
500-38462-20 - DL	EW-4	Total/NA	Water	8260B	
500-38462-21	RFW-11B	Total/NA	Water	8260B	
500-38462-22	RFW-9	Total/NA	Water	8260B	
500-38462-23	RFW-4A	Total/NA	Water	8260B	
500-38462-24	RFW-4A DUP	Total/NA	Water	8260B	
500-38462-25	RFW-4B	Total/NA	Water	8260B	
500-38462-26	RFW-12B	Total/NA	Water	8260B	
LCS 500-123958/5	Lab Control Sample	Total/NA	Water	8260B	
MB 500-123958/4	Method Blank	Total/NA	Water	8260B	

Surrogate Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Method: 8260B - VOC

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		12DCE (77-124)	TOL (80-121)	BFB (77-112)	DBFM (78-119)
500-38462-1	RFW-1A	101	100	96	100
500-38462-2	RFW-1B	104	101	95	103
500-38462-3	RFW-2A	106	102	99	103
500-38462-4	RFW-2B	89	85	80	86
500-38462-5	RFW-3B	109	103	99	108
500-38462-6	RFW-6	104	99	91	99
500-38462-7	RFW-7	102	100	96	104
500-38462-8	RFW-13	102	97	89	103
500-38462-9	RFW-17	106	103	94	107
500-38462-10	EW-5	101	95	88	100
500-38462-11	EW-6	109	102	95	109
500-38462-12	EW-7	110	105	97	114
500-38462-13	EW-8	104	100	93	107
500-38462-14	EW-9	102	99	90	108
500-38462-15	EW-9 DUP	108	100	92	106
500-38462-16	EW-10	111	102	95	109
500-38462-17	TRIP BLANK	110	101	96	113
500-38462-18	EW-2	107	98	90	105
500-38462-18 - DL	EW-2	102	97	89	106
500-38462-19	EW-3	115	106	99	116
500-38462-20	EW-4	90	86	81	89
500-38462-20 - DL	EW-4	108	104	97	104
500-38462-21	RFW-11B	97	93	87	95
500-38462-22	RFW-9	103	98	92	99
500-38462-23	RFW-4A	109	101	94	108
500-38462-24	RFW-4A DUP	105	97	93	101
500-38462-25	RFW-4B	109	102	95	109
500-38462-26	RFW-12B	109	103	95	113
LCS 500-123933/5	Lab Control Sample	101	100	95	99
LCS 500-123958/5	Lab Control Sample	99	99	96	99
MB 500-123933/4	Method Blank	105	102	96	106
MB 500-123958/4	Method Blank	99	97	91	98

Surrogate Legend

12DCE = 1,2-Dichloroethane-d4 (Surr)
 TOL = Toluene-d8 (Surr)
 BFB = 4-Bromofluorobenzene (Surr)
 DBFM = Dibromofluoromethane

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Method: 8260B - VOC

Lab Sample ID: MB 500-123933/4

Matrix: Water

Analysis Batch: 123933

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Benzene	<0.50		0.50	0.12	ug/L			08/29/11 11:12	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/29/11 11:12	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/29/11 11:12	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/29/11 11:12	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/29/11 11:12	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/29/11 11:12	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/29/11 11:12	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/29/11 11:12	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/29/11 11:12	1
Acetone	<5.0		5.0	1.9	ug/L			08/29/11 11:12	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/29/11 11:12	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/29/11 11:12	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/29/11 11:12	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/29/11 11:12	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/29/11 11:12	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/29/11 11:12	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/29/11 11:12	1
Chloroform	<1.0		1.0	0.25	ug/L			08/29/11 11:12	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/29/11 11:12	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/29/11 11:12	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/29/11 11:12	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/29/11 11:12	1
Trichloroethene	<0.50		0.50	0.18	ug/L			08/29/11 11:12	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/29/11 11:12	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/29/11 11:12	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/29/11 11:12	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/29/11 11:12	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/29/11 11:12	1
Toluene	<0.50		0.50	0.15	ug/L			08/29/11 11:12	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/29/11 11:12	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/29/11 11:12	1
Tetrachloroethene	<1.0		1.0	0.22	ug/L			08/29/11 11:12	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/29/11 11:12	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/29/11 11:12	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/29/11 11:12	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/29/11 11:12	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 11:12	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/29/11 11:12	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/29/11 11:12	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/29/11 11:12	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/29/11 11:12	1
Styrene	<1.0		1.0	0.26	ug/L			08/29/11 11:12	1
Bromoform	<1.0		1.0	0.45	ug/L			08/29/11 11:12	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 11:12	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/29/11 11:12	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/29/11 11:12	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/29/11 11:12	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 11:12	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 11:12	1

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Method: 8260B - VOC (Continued)

Lab Sample ID: MB 500-123933/4
Matrix: Water
Analysis Batch: 123933

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/29/11 11:12	1
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/29/11 11:12	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/29/11 11:12	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/29/11 11:12	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/29/11 11:12	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/29/11 11:12	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/29/11 11:12	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/29/11 11:12	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/29/11 11:12	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/29/11 11:12	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/29/11 11:12	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/29/11 11:12	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/29/11 11:12	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/29/11 11:12	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/29/11 11:12	1

Surrogate	MB MB		Limits	Prepared	Analyzed	Dil Fac
	% Recovery	Qualifier				
1,2-Dichloroethane-d4 (Surr)	105		77 - 124		08/29/11 11:12	1
Toluene-d8 (Surr)	102		80 - 121		08/29/11 11:12	1
4-Bromofluorobenzene (Surr)	96		77 - 112		08/29/11 11:12	1
0-Bromofluoromethane	106		78 - 119		08/29/11 11:12	1

Lab Sample ID: LCS 500-123933/5
Matrix: Water
Analysis Batch: 123933

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS LCS		Unit	D	% Rec	% Rec. Limits
		Result	Qualifier				
Benzene	50.0	46.9		ug/L		94	74 - 113
Dichlorodifluoromethane	50.0	42.0		ug/L		84	39 - 139
Chloromethane	50.0	46.5		ug/L		93	36 - 148
Vinyl chloride	50.0	52.0		ug/L		104	47 - 138
Bromomethane	50.0	52.7		ug/L		105	46 - 155
Chloroethane	50.0	56.5		ug/L		113	54 - 149
Trichlorofluoromethane	50.0	51.7		ug/L		103	60 - 141
1,1-Dichloroethene	50.0	42.4		ug/L		85	60 - 126
Carbon disulfide	50.0	36.8		ug/L		74	36 - 110
Acetone	50.0	54.5		ug/L		109	43 - 153
Methylene Chloride	50.0	44.3		ug/L		89	65 - 125
trans-1,2-Dichloroethene	50.0	46.8		ug/L		94	67 - 120
1,1-Dichloroethane	50.0	45.3		ug/L		91	64 - 117
2,2-Dichloropropane	50.0	45.9		ug/L		92	50 - 127
cis-1,2-Dichloroethene	50.0	46.9		ug/L		94	66 - 111
Methyl Ethyl Ketone	50.0	49.0		ug/L		98	42 - 152
Bromochloromethane	50.0	46.4		ug/L		93	69 - 116
Chloroform	50.0	47.2		ug/L		94	71 - 116
1,1,1-Trichloroethane	50.0	47.3		ug/L		95	66 - 128
1,1-Dichloropropene	50.0	44.7		ug/L		89	71 - 112
Carbon tetrachloride	50.0	47.3		ug/L		95	58 - 132
1,2-Dichloroethane	50.0	47.2		ug/L		94	69 - 115

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-123933/5

Matrix: Water

Analysis Batch: 123933

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS		Unit	D	% Rec	% Rec. Limits
		Result	Qualifier				
Trichloroethene	50.0	46.9		ug/L		94	75 - 116
1,2-Dichloropropane	50.0	49.3		ug/L		99	68 - 123
Dibromomethane	50.0	46.5		ug/L		93	73 - 115
Bromodichloromethane	50.0	47.7		ug/L		95	73 - 120
cis-1,3-Dichloropropene	53.8	49.4		ug/L		92	65 - 114
methyl isobutyl ketone	50.0	46.3		ug/L		93	56 - 138
Toluene	50.0	47.5		ug/L		95	76 - 121
trans-1,3-Dichloropropene	48.6	45.0		ug/L		93	60 - 119
1,1,2-Trichloroethane	50.0	49.6		ug/L		99	62 - 137
Tetrachloroethene	50.0	47.7		ug/L		95	76 - 114
1,3-Dichloropropane	50.0	48.9		ug/L		98	71 - 119
2-Hexanone	50.0	49.6		ug/L		99	55 - 138
Dibromochloromethane	50.0	49.8		ug/L		100	73 - 118
1,2-Dibromoethane	50.0	47.0		ug/L		94	71 - 125
Chlorobenzene	50.0	46.9		ug/L		94	81 - 111
1,1,1,2-Tetrachloroethane	50.0	49.1		ug/L		98	73 - 122
Ethylbenzene	50.0	46.9		ug/L		94	79 - 114
m&p-Xylene	100	93.7		ug/L		94	77 - 117
o-Xylene	50.0	46.6		ug/L		93	74 - 117
Styrene	50.0	47.7		ug/L		95	76 - 118
Bromofom	50.0	48.8		ug/L		98	64 - 126
Isopropylbenzene	50.0	43.0		ug/L		88	65 - 110
Bromobenzene	50.0	48.1		ug/L		96	80 - 117
1,1,2,2-Tetrachloroethane	50.0	50.7		ug/L		101	66 - 121
1,2,3-Trichloropropane	50.0	49.2		ug/L		98	68 - 124
N-Propylbenzene	50.0	47.2		ug/L		94	76 - 116
2-Chlorotoluene	50.0	48.3		ug/L		97	77 - 117
1,3,5-Trimethylbenzene	50.0	50.2		ug/L		100	77 - 117
4-Chlorotoluene	50.0	46.4		ug/L		93	75 - 114
tert-Butylbenzene	50.0	48.9		ug/L		98	75 - 117
1,2,4-Trimethylbenzene	50.0	48.4		ug/L		97	76 - 117
sec-Butylbenzene	50.0	48.1		ug/L		96	76 - 116
1,3-Dichlorobenzene	50.0	45.8		ug/L		92	79 - 110
p-Isopropyltoluene	50.0	45.6		ug/L		91	72 - 114
1,4-Dichlorobenzene	50.0	44.6		ug/L		89	79 - 109
n-Butylbenzene	50.0	47.3		ug/L		95	72 - 120
1,2-Dichlorobenzene	50.0	46.2		ug/L		92	80 - 110
1,2-Dibromo-3-Chloropropane	50.0	47.2		ug/L		94	54 - 119
1,2,4-Trichlorobenzene	50.0	41.6		ug/L		83	63 - 115
Hexachlorobutadiene	50.0	46.1		ug/L		92	62 - 124
Naphthalene	50.0	44.1		ug/L		88	62 - 122
1,2,3-Trichlorobenzene	50.0	42.6		ug/L		85	66 - 119

Surrogate	LCS		Limits
	% Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	101		77 - 124
Toluene-d8 (Surr)	100		80 - 121
4-Bromofluorobenzene (Surr)	95		77 - 112
Dibromofluoromethane	99		78 - 119

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Method: 8260B - VOC (Continued)

Lab Sample ID: MB 500-123958/4
Matrix: Water
Analysis Batch: 123958

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
	Result	Qualifier							
Benzene	<0.50		0.50	0.12	ug/L			08/30/11 09:06	1
Dichlorodifluoromethane	<1.0		1.0	0.26	ug/L			08/30/11 09:06	1
Chloromethane	<1.0		1.0	0.24	ug/L			08/30/11 09:06	1
Vinyl chloride	<0.50		0.50	0.13	ug/L			08/30/11 09:06	1
Bromomethane	<1.0		1.0	0.49	ug/L			08/30/11 09:06	1
Chloroethane	<1.0		1.0	0.33	ug/L			08/30/11 09:06	1
Trichlorofluoromethane	<1.0		1.0	0.22	ug/L			08/30/11 09:06	1
1,1-Dichloroethene	<1.0		1.0	0.29	ug/L			08/30/11 09:06	1
Carbon disulfide	<5.0		5.0	0.44	ug/L			08/30/11 09:06	1
Acetone	<5.0		5.0	1.9	ug/L			08/30/11 09:06	1
Methylene Chloride	<5.0		5.0	0.63	ug/L			08/30/11 09:06	1
trans-1,2-Dichloroethene	<1.0		1.0	0.27	ug/L			08/30/11 09:06	1
1,1-Dichloroethane	<1.0		1.0	0.24	ug/L			08/30/11 09:06	1
2,2-Dichloropropane	<1.0		1.0	0.31	ug/L			08/30/11 09:06	1
cis-1,2-Dichloroethene	<1.0		1.0	0.22	ug/L			08/30/11 09:06	1
Methyl Ethyl Ketone	<5.0		5.0	1.0	ug/L			08/30/11 09:06	1
Bromochloromethane	<1.0		1.0	0.50	ug/L			08/30/11 09:06	1
Chloroform	<1.0		1.0	0.25	ug/L			08/30/11 09:06	1
1,1,1-Trichloroethane	<1.0		1.0	0.26	ug/L			08/30/11 09:06	1
1,1-Dichloropropene	<1.0		1.0	0.25	ug/L			08/30/11 09:06	1
Carbon tetrachloride	<1.0		1.0	0.28	ug/L			08/30/11 09:06	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/30/11 09:06	1
Trichloroethene	<0.50		0.50	0.18	ug/L			08/30/11 09:06	1
1,2-Dichloropropane	<1.0		1.0	0.36	ug/L			08/30/11 09:06	1
Dibromomethane	<1.0		1.0	0.39	ug/L			08/30/11 09:06	1
Bromodichloromethane	<1.0		1.0	0.23	ug/L			08/30/11 09:06	1
cis-1,3-Dichloropropene	<1.0		1.0	0.28	ug/L			08/30/11 09:06	1
methyl isobutyl ketone	<5.0		5.0	0.79	ug/L			08/30/11 09:06	1
Toluene	<0.50		0.50	0.15	ug/L			08/30/11 09:06	1
trans-1,3-Dichloropropene	<1.0		1.0	0.35	ug/L			08/30/11 09:06	1
1,1,2-Trichloroethane	<1.0		1.0	0.30	ug/L			08/30/11 09:06	1
Tetrachloroethene	<1.0		1.0	0.22	ug/L			08/30/11 09:06	1
1,3-Dichloropropane	<1.0		1.0	0.27	ug/L			08/30/11 09:06	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/30/11 09:06	1
Dibromochloromethane	<1.0		1.0	0.25	ug/L			08/30/11 09:06	1
1,2-Dibromoethane	<1.0		1.0	0.45	ug/L			08/30/11 09:06	1
Chlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 09:06	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.31	ug/L			08/30/11 09:06	1
Ethylbenzene	<0.50		0.50	0.14	ug/L			08/30/11 09:06	1
m&p-Xylene	<1.0		1.0	0.30	ug/L			08/30/11 09:06	1
o-Xylene	<0.50		0.50	0.13	ug/L			08/30/11 09:06	1
Styrene	<1.0		1.0	0.26	ug/L			08/30/11 09:06	1
Bromoform	<1.0		1.0	0.45	ug/L			08/30/11 09:06	1
Isopropylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 09:06	1
Bromobenzene	<1.0		1.0	0.31	ug/L			08/30/11 09:06	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.35	ug/L			08/30/11 09:06	1
1,2,3-Trichloropropane	<1.0		1.0	0.60	ug/L			08/30/11 09:06	1
N-Propylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 09:06	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 09:06	1

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Method: 8260B - VOC (Continued)

Lab Sample ID: MB 500-123958/4

Matrix: Water

Analysis Batch: 123958

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
1,3,5-Trimethylbenzene	<1.0		1.0	0.23	ug/L			08/30/11 09:06	1
4-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/30/11 09:06	1
tert-Butylbenzene	<1.0		1.0	0.24	ug/L			08/30/11 09:06	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.22	ug/L			08/30/11 09:06	1
sec-Butylbenzene	<1.0		1.0	0.19	ug/L			08/30/11 09:06	1
1,3-Dichlorobenzene	<1.0		1.0	0.26	ug/L			08/30/11 09:06	1
p-Isopropyltoluene	<1.0		1.0	0.24	ug/L			08/30/11 09:06	1
1,4-Dichlorobenzene	<1.0		1.0	0.24	ug/L			08/30/11 09:06	1
n-Butylbenzene	<1.0		1.0	0.21	ug/L			08/30/11 09:06	1
1,2-Dichlorobenzene	<1.0		1.0	0.21	ug/L			08/30/11 09:06	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	1.2	ug/L			08/30/11 09:06	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.22	ug/L			08/30/11 09:06	1
Hexachlorobutadiene	<1.0		1.0	0.45	ug/L			08/30/11 09:06	1
Naphthalene	<1.0		1.0	0.24	ug/L			08/30/11 09:06	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.36	ug/L			08/30/11 09:06	1

Surrogate	MB MB		Limits	Prepared	Analyzed	Dil Fac
	% Recovery	Qualifier				
1,2-Dichloroethane-d4 (Surr)	99		77 - 124		08/30/11 09:06	1
Toluene-d8 (Surr)	97		80 - 121		08/30/11 09:06	1
4-Bromofluorobenzene (Surr)	91		77 - 112		08/30/11 09:06	1
Dibromofluoromethane	98		78 - 119		08/30/11 09:06	1

Lab Sample ID: LCS 500-123958/5

Matrix: Water

Analysis Batch: 123958

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS LCS		Unit	D	% Rec	% Rec. Limits
		Result	Qualifier				
Benzene	50.0	50.4		ug/L		101	74 - 113
Dichlorodifluoromethane	50.0	37.9		ug/L		76	39 - 139
Chloromethane	50.0	41.8		ug/L		84	36 - 148
Vinyl chloride	50.0	46.8		ug/L		94	47 - 138
Bromomethane	50.0	46.8		ug/L		94	46 - 155
Chloroethane	50.0	49.0		ug/L		98	54 - 149
Trichlorofluoromethane	50.0	45.7		ug/L		91	60 - 141
1,1-Dichloroethene	50.0	48.2		ug/L		96	60 - 126
Carbon disulfide	50.0	45.9		ug/L		92	36 - 110
Acetone	50.0	71.5		ug/L		143	43 - 153
Methylene Chloride	50.0	46.9		ug/L		94	65 - 125
trans-1,2-Dichloroethene	50.0	50.9		ug/L		102	67 - 120
1,1-Dichloroethane	50.0	48.7		ug/L		97	64 - 117
2,2-Dichloropropane	50.0	49.1		ug/L		98	50 - 127
cis-1,2-Dichloroethene	50.0	49.8		ug/L		100	66 - 111
Methyl Ethyl Ketone	50.0	54.2		ug/L		108	42 - 152
Bromochloromethane	50.0	47.2		ug/L		94	69 - 116
Chloroform	50.0	49.7		ug/L		99	71 - 116
1,1,1-Trichloroethane	50.0	52.0		ug/L		104	66 - 128
1,1-Dichloropropene	50.0	48.3		ug/L		97	71 - 112
Carbon tetrachloride	50.0	52.1		ug/L		104	58 - 132
1,2-Dichloroethane	50.0	50.0		ug/L		100	69 - 115

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-123958/5
Matrix: Water
Analysis Batch: 123958

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike	LCS	LCS	Unit	D	% Rec	% Rec.
	Added	Result	Qualifier				
Trichloroethene	50.0	49.7		ug/L		99	75 - 116
1,2-Dichloropropane	50.0	51.0		ug/L		102	68 - 123
Dibromomethane	50.0	49.0		ug/L		98	73 - 115
Bromodichloromethane	50.0	50.4		ug/L		101	73 - 120
cis-1,3-Dichloropropene	53.8	51.8		ug/L		96	65 - 114
methyl isobutyl ketone	50.0	48.2		ug/L		96	56 - 138
Toluene	50.0	50.0		ug/L		100	76 - 121
trans-1,3-Dichloropropene	48.6	46.7		ug/L		96	60 - 119
1,1,2-Trichloroethane	50.0	52.1		ug/L		104	62 - 137
Tetrachloroethene	50.0	50.4		ug/L		101	76 - 114
1,3-Dichloropropane	50.0	50.7		ug/L		101	71 - 119
2-Hexanone	50.0	57.3		ug/L		115	55 - 138
Dibromochloromethane	50.0	52.7		ug/L		105	73 - 118
1,2-Dibromoethane	50.0	49.6		ug/L		99	71 - 125
Chlorobenzene	50.0	49.5		ug/L		99	81 - 111
1,1,1,2-Tetrachloroethane	50.0	51.8		ug/L		104	73 - 122
Ethylbenzene	50.0	49.8		ug/L		100	79 - 114
m&p-Xylene	100	98.9		ug/L		99	77 - 117
o-Xylene	50.0	49.4		ug/L		99	74 - 117
Styrene	50.0	50.2		ug/L		100	76 - 118
Bromoform	50.0	52.0		ug/L		104	64 - 126
Isopropylbenzene	50.0	44.9		ug/L		90	65 - 110
Bromobenzene	50.0	49.8		ug/L		100	80 - 117
1,1,2,2-Tetrachloroethane	50.0	52.0		ug/L		104	66 - 121
1,2,3-Trichloropropane	50.0	52.9		ug/L		106	68 - 124
N-Propylbenzene	50.0	49.5		ug/L		99	76 - 116
2-Chlorotoluene	50.0	50.6		ug/L		101	77 - 117
1,3,5-Trimethylbenzene	50.0	53.0		ug/L		106	77 - 117
4-Chlorotoluene	50.0	48.2		ug/L		96	75 - 114
tert-Butylbenzene	50.0	51.6		ug/L		103	75 - 117
1,2,4-Trimethylbenzene	50.0	51.0		ug/L		102	76 - 117
sec-Butylbenzene	50.0	50.5		ug/L		101	76 - 116
1,3-Dichlorobenzene	50.0	47.6		ug/L		95	79 - 110
p-Isopropyltoluene	50.0	48.1		ug/L		96	72 - 114
1,4-Dichlorobenzene	50.0	46.6		ug/L		93	79 - 109
n-Butylbenzene	50.0	49.8		ug/L		100	72 - 120
1,2-Dichlorobenzene	50.0	48.3		ug/L		97	80 - 110
1,2-Dibromo-3-Chloropropane	50.0	48.6		ug/L		97	54 - 119
1,2,4-Trichlorobenzene	50.0	45.0		ug/L		90	63 - 115
Hexachlorobutadiene	50.0	49.7		ug/L		99	62 - 124
Naphthalene	50.0	47.1		ug/L		94	62 - 122
1,2,3-Trichlorobenzene	50.0	46.0		ug/L		92	66 - 119

Surrogate	LCS LCS		Limits
	% Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	99		77 - 124
Toluene-d8 (Surr)	99		80 - 121
4-Bromofluorobenzene (Surr)	96		77 - 112
Dibromofluoromethane	99		78 - 119

Certification Summary

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-38462-1

Laboratory	Authority	Program	EPA Region	Certification ID
TestAmerica Chicago	ACCLASS	DoD ELAP		ADE-1429
TestAmerica Chicago	ACCLASS	ISO/IEC 17025		AT-1428
TestAmerica Chicago	Alabama	State Program	4	40461
TestAmerica Chicago	California	NELAC	9	01132CA
TestAmerica Chicago	Florida	NELAC	4	E871072
TestAmerica Chicago	Georgia	Georgia EPD	4	N/A
TestAmerica Chicago	Georgia	State Program	4	939
TestAmerica Chicago	Hawaii	State Program	9	N/A
TestAmerica Chicago	Illinois	NELAC	5	100201
TestAmerica Chicago	Indiana	State Program	5	C-IL-02
TestAmerica Chicago	Iowa	State Program	7	82
TestAmerica Chicago	Kansas	NELAC	7	E-10161
TestAmerica Chicago	Kentucky	Kentucky UST	4	66
TestAmerica Chicago	Kentucky	State Program	4	90023
TestAmerica Chicago	Louisiana	NELAC	6	30720
TestAmerica Chicago	Massachusetts	State Program	1	M-IL035
TestAmerica Chicago	Mississippi	State Program	4	N/A
TestAmerica Chicago	North Carolina	North Carolina DENR	4	291
TestAmerica Chicago	Oklahoma	State Program	6	8908
TestAmerica Chicago	South Carolina	State Program	4	77001
TestAmerica Chicago	Texas	NELAC	6	T104704252-09-TX
TestAmerica Chicago	USDA	USDA		P330-09-00027
TestAmerica Chicago	Virginia	NELAC Secondary AB	3	460142
TestAmerica Chicago	Wisconsin	State Program	5	999580010
TestAmerica Chicago	Wyoming	State Program	8	8TMS-Q

Accreditation may not be offered or required for all methods and analytes reported in this package. Please contact your project manager for the laboratory's current list of certified methods and analytes.

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

2417 Bond Street, University Park, IL 60484
Phone: 708.534.5200 Fax: 708.534.5211

Report To _____ (optional)
Contact: _____
Company: _____
Address: _____
Address: _____
Phone: _____
Fax: _____
E-Mail: _____

Bill To _____ (optional)
Contact: _____
Company: _____
Address: _____
Address: _____
Phone: _____
Fax: _____
POW/Reference: _____

Chain of Custody Record

Lab Job #: 500-30462
Chain of Custody Number: _____
Page 2 of 3
Temperature °C of Cooler: _____

Client		Client Project #		Preservatives		Parameter		Matrix		Preservatives Key 1. HCL, Cool to 4° 2. H2SO4, Cool to 4° 3. HNO3, Cool to 4° 4. NaOH, Cool to 4° 5. NaOH/Zn, Cool to 4° 6. NaHSO4 7. Cool to 4° 8. None 9. Other
Project Name		Lab Project #		Sampling		# of Containers		Comments		
Project Location/State		Sampler		Date	Time	Mark				
Lab ID	MS/MSD	Sample ID								
Western Solution				HCL						
Block + Decker										
Hagerstown, MD		Lab PM: Dick Dr. JW								
Greg Flakuski										
		RFW-21	GDF	8/24/11	110	2	1	✓		
10		EW-5						✓		
11		EW-6			145			✓		
12		EW-7			1400			✓		
13		EW-8			1355			✓		
14		EW-9			1350			✓		
15		EW-9 Dup			1350			✓		
16		EW-10			1340			✓		
17		Trip Blank		8/24/11	700			✓		

Turnaround Time Required (Business Days): 1 Day 3 Days 5 Days 7 Days 10 Days 15 Days Other
Requested Due Date: _____

Sample Disposal: Return to Client Disposal by Lab Archive for _____ Months (A fee may be assessed if samples are retained longer than 1 month)

Relinquished By: <u>[Signature]</u>	Company: <u>Western</u>	Date: <u>8/26/11</u>	Time: <u>1600</u>	Received By: <u>[Signature]</u>	Company: <u>TP</u>	Date: <u>8/27/11</u>	Time: <u>0950</u>	Lab Courier: _____
Relinquished By: _____	Company: _____	Date: _____	Time: _____	Received By: _____	Company: _____	Date: _____	Time: _____	Shipped: <u>FX</u>
Relinquished By: _____	Company: _____	Date: _____	Time: _____	Received By: _____	Company: _____	Date: _____	Time: _____	Hand Delivered: _____

- Matrix Key:
- WW - Wastewater
 - W - Water
 - S - Soil
 - SL - Sludge
 - MS - Miscellaneous
 - OL - Oil
 - A - Air
 - SE - Sediment
 - SO - Soil
 - L - Leachate
 - WI - Wipe
 - DW - Drinking Water
 - O - Other

Client Comments: _____

Lab Comments: _____

1
2
3
4
5
6
7
8
9
10
11
12
13
14

Login Sample Receipt Checklist

Client: Weston Solutions, Inc.

Job Number: 500-38462-1

Login Number: 38462

List Source: TestAmerica Chicago

List Number: 1

Creator: Lunt, Jeff T

Question	Answer	Comment
Radioactivity either was not measured or, if measured, is at or below background	True	
The cooler's custody seal, if present, is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	2.7
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	False	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	True	

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.
TestAmerica Savannah
5102 LaRoche Avenue
Savannah, GA 31404
Tel: (912)354-7858

TestAmerica Job ID: 680-71880-1
Client Project/Site: Black & Decker

For:
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, Pennsylvania 19380

Attn: Mr. Tom Cornuet



Authorized for release by:
09/08/2011 08:58:48 AM

Abbie Yant
Project Manager I
abbie.yant@testamericainc.com

LINKS

Review your project
results through

Total Access

Have a Question?

Ask
The
Expert

Visit us at:

www.testamericainc.com

Results relate only to the items tested and the sample(s) as received by the laboratory. The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Table of Contents

Cover Page	1
Table of Contents	2
Case Narrative	3
Sample Summary	4
Method Summary	5
Definitions	6
Client Sample Results	7
Surrogate Summary	16
QC Sample Results	17
Chronicle	22
Chain of Custody	23
Certification Summary	24



Case Narrative

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Job ID: 680-71880-1

Laboratory: TestAmerica Savannah

Narrative

Job Narrative
680-71880-1

Comments

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

GC/MS VOA

Method(s) 524.2: The method blank for batch 214034 contained 1,2,3-Trichlorobenzene above the method detection limit. This target analyte concentration was less than the reporting limit (RL); therefore, re-extraction and/or re-analysis of samples was not performed.

No other analytical or quality issues were noted.

Sample Summary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
680-71880-1	HAMP22	Drinking Water	08/26/11 10:10	08/30/11 09:25
680-71880-2	HAMP23	Drinking Water	08/26/11 10:15	08/30/11 09:25
680-71880-3	RFW-20	Drinking Water	08/24/11 16:45	08/30/11 09:25
680-71880-4	RFW-21	Drinking Water	08/24/11 11:10	08/30/11 09:25
680-71880-5	Trip Blank	Drinking Water	08/24/11 09:00	08/30/11 09:25

Method Summary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Method	Method Description	Protocol	Laboratory
524.2	Volatile Organic Compounds (GC/MS)	EPA-DW	TAL SAV

Protocol References:

EPA-DW = "Methods For The Determination Of Organic Compounds In Drinking Water", EPA/600/4-88/039, December 1988 And Its Supplements.

Laboratory References:

TAL SAV = TestAmerica Savannah, 5102 LaRoche Avenue, Savannah, GA 31404, TEL (912)354-7858

Definitions/Glossary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Qualifiers

GC/MS VOA

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☆	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
DL, RA, RE, IN	Indicates a Dilution, Reanalysis, Re-extraction, or additional Initial metals/anion analysis of the sample
EDL	Estimated Detection Limit (Dioxin)
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
ND	Not detected at the reporting limit (or method detection limit if shown)
PQL	Practical Quantitation Limit
RL	Reporting Limit
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Client Sample ID: HAMP22

Lab Sample ID: 680-71880-1

Date Collected: 08/26/11 10:10

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Acetone	<10		10	5.0	ug/L			09/07/11 04:32	1
Benzene	<0.50		0.50	0.18	ug/L			09/07/11 04:32	1
Bromobenzene	<0.50		0.50	0.42	ug/L			09/07/11 04:32	1
Bromoform	<0.50		0.50	0.39	ug/L			09/07/11 04:32	1
Bromomethane	<1.0		1.0	0.45	ug/L			09/07/11 04:32	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			09/07/11 04:32	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			09/07/11 04:32	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/07/11 04:32	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			09/07/11 04:32	1
Chloroethane	<1.0		1.0	0.33	ug/L			09/07/11 04:32	1
Chloroform	0.32	J	0.50	0.29	ug/L			09/07/11 04:32	1
Chloromethane	<0.50		0.50	0.32	ug/L			09/07/11 04:32	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			09/07/11 04:32	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			09/07/11 04:32	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			09/07/11 04:32	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			09/07/11 04:32	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/07/11 04:32	1
Dibromomethane	<0.50		0.50	0.38	ug/L			09/07/11 04:32	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			09/07/11 04:32	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			09/07/11 04:32	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			09/07/11 04:32	1
Dichlorobromomethane	<1.0		1.0	0.54	ug/L			09/07/11 04:32	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/07/11 04:32	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			09/07/11 04:32	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			09/07/11 04:32	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			09/07/11 04:32	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			09/07/11 04:32	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			09/07/11 04:32	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			09/07/11 04:32	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			09/07/11 04:32	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			09/07/11 04:32	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/07/11 04:32	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			09/07/11 04:32	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/07/11 04:32	1
Freon 113	<0.50		0.50	0.15	ug/L			09/07/11 04:32	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/07/11 04:32	1
2-Hexanone	<10		10	5.0	ug/L			09/07/11 04:32	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/07/11 04:32	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/07/11 04:32	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			09/07/11 04:32	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/07/11 04:32	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/07/11 04:32	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			09/07/11 04:32	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/07/11 04:32	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/07/11 04:32	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/07/11 04:32	1
o-Xylene	<0.50		0.50	0.27	ug/L			09/07/11 04:32	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/07/11 04:32	1
Styrene	<0.50		0.50	0.28	ug/L			09/07/11 04:32	1
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/07/11 04:32	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Client Sample ID: HAMP22

Lab Sample ID: 680-71880-1

Date Collected: 08/26/11 10:10

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
tert-Butyl alcohol	<2.0		2.0	1.6	ug/L			09/07/11 04:32	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/07/11 04:32	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/07/11 04:32	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			09/07/11 04:32	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			09/07/11 04:32	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			09/07/11 04:32	1
Toluene	<0.50		0.50	0.23	ug/L			09/07/11 04:32	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			09/07/11 04:32	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			09/07/11 04:32	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/07/11 04:32	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			09/07/11 04:32	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			09/07/11 04:32	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			09/07/11 04:32	1
Trichloroethene	<0.50		0.50	0.37	ug/L			09/07/11 04:32	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/07/11 04:32	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			09/07/11 04:32	1
Trihalomethanes, Total	0.32	J	0.50	0.29	ug/L			09/07/11 04:32	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/07/11 04:32	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/07/11 04:32	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			09/07/11 04:32	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			09/07/11 04:32	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	102		70 - 130					09/07/11 04:32	1
1,2-Dichlorobenzene-d4	94		70 - 130					09/07/11 04:32	1

Client Sample ID: HAMP23

Lab Sample ID: 680-71880-2

Date Collected: 08/26/11 10:15

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			09/07/11 04:55	1
Benzene	<0.50		0.50	0.18	ug/L			09/07/11 04:55	1
Bromobenzene	<0.50		0.50	0.42	ug/L			09/07/11 04:55	1
Bromoform	<0.50		0.50	0.39	ug/L			09/07/11 04:55	1
Bromomethane	<1.0		1.0	0.45	ug/L			09/07/11 04:55	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			09/07/11 04:55	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			09/07/11 04:55	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/07/11 04:55	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			09/07/11 04:55	1
Chloroethane	<1.0		1.0	0.33	ug/L			09/07/11 04:55	1
Chloroform	0.30	J	0.50	0.29	ug/L			09/07/11 04:55	1
Chloromethane	<0.50		0.50	0.32	ug/L			09/07/11 04:55	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			09/07/11 04:55	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			09/07/11 04:55	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			09/07/11 04:55	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			09/07/11 04:55	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/07/11 04:55	1
Dibromomethane	<0.50		0.50	0.38	ug/L			09/07/11 04:55	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Client Sample ID: HAMP23

Lab Sample ID: 680-71880-2

Date Collected: 08/26/11 10:15

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			09/07/11 04:55	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			09/07/11 04:55	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			09/07/11 04:55	1
Dichlorobromomethane	<1.0		1.0	0.54	ug/L			09/07/11 04:55	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/07/11 04:55	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			09/07/11 04:55	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			09/07/11 04:55	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			09/07/11 04:55	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			09/07/11 04:55	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			09/07/11 04:55	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			09/07/11 04:55	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			09/07/11 04:55	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			09/07/11 04:55	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/07/11 04:55	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			09/07/11 04:55	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/07/11 04:55	1
Freon 113	<0.50		0.50	0.15	ug/L			09/07/11 04:55	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/07/11 04:55	1
2-Hexanone	<10		10	5.0	ug/L			09/07/11 04:55	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/07/11 04:55	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/07/11 04:55	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			09/07/11 04:55	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/07/11 04:55	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/07/11 04:55	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			09/07/11 04:55	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/07/11 04:55	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/07/11 04:55	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/07/11 04:55	1
o-Xylene	<0.50		0.50	0.27	ug/L			09/07/11 04:55	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/07/11 04:55	1
Styrene	<0.50		0.50	0.28	ug/L			09/07/11 04:55	1
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/07/11 04:55	1
tert-Butyl alcohol	<2.0		2.0	1.6	ug/L			09/07/11 04:55	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/07/11 04:55	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/07/11 04:55	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			09/07/11 04:55	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			09/07/11 04:55	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			09/07/11 04:55	1
Toluene	<0.50		0.50	0.23	ug/L			09/07/11 04:55	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			09/07/11 04:55	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			09/07/11 04:55	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/07/11 04:55	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			09/07/11 04:55	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			09/07/11 04:55	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			09/07/11 04:55	1
Trichloroethene	<0.50		0.50	0.37	ug/L			09/07/11 04:55	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/07/11 04:55	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			09/07/11 04:55	1
Trihalomethanes, Total	0.30	J	0.50	0.29	ug/L			09/07/11 04:55	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/07/11 04:55	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Client Sample ID: HAMP23

Lab Sample ID: 680-71880-2

Date Collected: 08/26/11 10:15

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/07/11 04:55	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			09/07/11 04:55	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			09/07/11 04:55	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	DII Fac
4-Bromofluorobenzene	101		70 - 130					09/07/11 04:55	1
1,2-Dichlorobenzene-d4	94		70 - 130					09/07/11 04:55	1

Client Sample ID: RFW-20

Lab Sample ID: 680-71880-3

Date Collected: 08/24/11 16:45

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Acetone	<10		10	5.0	ug/L			09/07/11 05:17	1
Benzene	<0.50		0.50	0.18	ug/L			09/07/11 05:17	1
Bromobenzene	<0.50		0.50	0.42	ug/L			09/07/11 05:17	1
Bromoform	<0.50		0.50	0.39	ug/L			09/07/11 05:17	1
Bromomethane	<1.0		1.0	0.45	ug/L			09/07/11 05:17	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			09/07/11 05:17	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			09/07/11 05:17	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/07/11 05:17	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			09/07/11 05:17	1
Chloroethane	<1.0		1.0	0.33	ug/L			09/07/11 05:17	1
Chloroform	<0.50		0.50	0.29	ug/L			09/07/11 05:17	1
Chloromethane	<0.50		0.50	0.32	ug/L			09/07/11 05:17	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			09/07/11 05:17	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			09/07/11 05:17	1
cis-1,2-Dichloroethane	<0.50		0.50	0.37	ug/L			09/07/11 05:17	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			09/07/11 05:17	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/07/11 05:17	1
Dibromomethane	<0.50		0.50	0.38	ug/L			09/07/11 05:17	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			09/07/11 05:17	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			09/07/11 05:17	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			09/07/11 05:17	1
Dichlorobromomethane	<1.0		1.0	0.54	ug/L			09/07/11 05:17	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/07/11 05:17	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			09/07/11 05:17	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			09/07/11 05:17	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			09/07/11 05:17	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			09/07/11 05:17	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			09/07/11 05:17	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			09/07/11 05:17	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			09/07/11 05:17	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			09/07/11 05:17	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/07/11 05:17	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			09/07/11 05:17	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/07/11 05:17	1
Freon 113	<0.50		0.50	0.15	ug/L			09/07/11 05:17	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/07/11 05:17	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Client Sample ID: RFW-20

Lab Sample ID: 680-71880-3

Date Collected: 08/24/11 16:45

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
2-Hexanone	<10		10	5.0	ug/L			09/07/11 05:17	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/07/11 05:17	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/07/11 05:17	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			09/07/11 05:17	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/07/11 05:17	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/07/11 05:17	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			09/07/11 05:17	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/07/11 05:17	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/07/11 05:17	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/07/11 05:17	1
o-Xylene	<0.50		0.50	0.27	ug/L			09/07/11 05:17	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/07/11 05:17	1
Styrene	<0.50		0.50	0.28	ug/L			09/07/11 05:17	1
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/07/11 05:17	1
tert-Butyl alcohol	<2.0		2.0	1.6	ug/L			09/07/11 05:17	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/07/11 05:17	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/07/11 05:17	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			09/07/11 05:17	1
1,1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			09/07/11 05:17	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			09/07/11 05:17	1
Toluene	<0.50		0.50	0.23	ug/L			09/07/11 05:17	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			09/07/11 05:17	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			09/07/11 05:17	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/07/11 05:17	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			09/07/11 05:17	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			09/07/11 05:17	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			09/07/11 05:17	1
Trichloroethene	0.53		0.50	0.37	ug/L			09/07/11 05:17	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/07/11 05:17	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			09/07/11 05:17	1
Trihalomethanes, Total	<0.50		0.50	0.29	ug/L			09/07/11 05:17	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/07/11 05:17	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/07/11 05:17	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			09/07/11 05:17	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			09/07/11 05:17	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	103		70 - 130					09/07/11 05:17	1
1,2-Dichlorobenzene-d4	99		70 - 130					09/07/11 05:17	1

Client Sample ID: RFW-21

Lab Sample ID: 680-71880-4

Date Collected: 08/24/11 11:10

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			09/07/11 05:40	1
Benzene	<0.50		0.50	0.18	ug/L			09/07/11 05:40	1
Bromobenzene	<0.50		0.50	0.42	ug/L			09/07/11 05:40	1
Bromoform	<0.50		0.50	0.39	ug/L			09/07/11 05:40	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Client Sample ID: RFW-21

Lab Sample ID: 680-71880-4

Date Collected: 08/24/11 11:10

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Bromomethane	<1.0		1.0	0.45	ug/L			09/07/11 05:40	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			09/07/11 05:40	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			09/07/11 05:40	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/07/11 05:40	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			09/07/11 05:40	1
Chloroethane	<1.0		1.0	0.33	ug/L			09/07/11 05:40	1
Chloroform	<0.50		0.50	0.29	ug/L			09/07/11 05:40	1
Chloromethane	<0.50		0.50	0.32	ug/L			09/07/11 05:40	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			09/07/11 05:40	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			09/07/11 05:40	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			09/07/11 05:40	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			09/07/11 05:40	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/07/11 05:40	1
Dibromomethane	<0.50		0.50	0.38	ug/L			09/07/11 05:40	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			09/07/11 05:40	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			09/07/11 05:40	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			09/07/11 05:40	1
Dichlorobromomethane	<1.0		1.0	0.54	ug/L			09/07/11 05:40	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/07/11 05:40	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			09/07/11 05:40	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			09/07/11 05:40	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			09/07/11 05:40	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			09/07/11 05:40	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			09/07/11 05:40	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			09/07/11 05:40	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			09/07/11 05:40	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			09/07/11 05:40	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/07/11 05:40	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			09/07/11 05:40	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/07/11 05:40	1
Freon 113	<0.50		0.50	0.15	ug/L			09/07/11 05:40	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/07/11 05:40	1
2-Hexanone	<10		10	5.0	ug/L			09/07/11 05:40	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/07/11 05:40	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/07/11 05:40	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			09/07/11 05:40	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/07/11 05:40	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/07/11 05:40	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			09/07/11 05:40	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/07/11 05:40	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/07/11 05:40	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/07/11 05:40	1
o-Xylene	<0.50		0.50	0.27	ug/L			09/07/11 05:40	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/07/11 05:40	1
Styrene	<0.50		0.50	0.28	ug/L			09/07/11 05:40	1
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/07/11 05:40	1
tert-Butyl alcohol	<2.0		2.0	1.6	ug/L			09/07/11 05:40	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/07/11 05:40	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/07/11 05:40	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			09/07/11 05:40	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Client Sample ID: RFW-21

Lab Sample ID: 680-71880-4

Date Collected: 08/24/11 11:10

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			09/07/11 05:40	1
Tetrachloroethane	<0.50		0.50	0.30	ug/L			09/07/11 05:40	1
Toluene	<0.50		0.50	0.23	ug/L			09/07/11 05:40	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			09/07/11 05:40	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			09/07/11 05:40	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/07/11 05:40	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			09/07/11 05:40	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			09/07/11 05:40	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			09/07/11 05:40	1
Trichloroethene	<0.50		0.50	0.37	ug/L			09/07/11 05:40	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/07/11 05:40	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			09/07/11 05:40	1
Trihalomethanes, Total	<0.50		0.50	0.29	ug/L			09/07/11 05:40	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/07/11 05:40	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/07/11 05:40	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			09/07/11 05:40	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			09/07/11 05:40	1
Surrogate	% Recovery	Qualifier	Limits				Prepared	Analyzed	DII Fac
4-Bromofluorobenzene	101		70 - 130					09/07/11 05:40	1
1,2-Dichlorobenzene-d4	96		70 - 130					09/07/11 05:40	1

Client Sample ID: Trip Blank

Lab Sample ID: 680-71880-5

Date Collected: 08/24/11 09:00

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Acetone	<10		10	5.0	ug/L			09/07/11 06:02	1
Benzene	<0.50		0.50	0.18	ug/L			09/07/11 06:02	1
Bromobenzene	<0.50		0.50	0.42	ug/L			09/07/11 06:02	1
Bromofom	<0.50		0.50	0.39	ug/L			09/07/11 06:02	1
Bromomethane	<1.0		1.0	0.45	ug/L			09/07/11 06:02	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			09/07/11 06:02	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			09/07/11 06:02	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/07/11 06:02	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			09/07/11 06:02	1
Chloroethane	<1.0		1.0	0.33	ug/L			09/07/11 06:02	1
Chloroform	<0.50		0.50	0.29	ug/L			09/07/11 06:02	1
Chloromethane	<0.50		0.50	0.32	ug/L			09/07/11 06:02	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			09/07/11 06:02	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			09/07/11 06:02	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			09/07/11 06:02	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			09/07/11 06:02	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/07/11 06:02	1
Dibromomethane	<0.50		0.50	0.38	ug/L			09/07/11 06:02	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			09/07/11 06:02	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			09/07/11 06:02	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			09/07/11 06:02	1
Dichlorobromomethane	<1.0		1.0	0.54	ug/L			09/07/11 06:02	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-71880-5

Date Collected: 08/24/11 09:00

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/07/11 06:02	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			09/07/11 06:02	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			09/07/11 06:02	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			09/07/11 06:02	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			09/07/11 06:02	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			09/07/11 06:02	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			09/07/11 06:02	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			09/07/11 06:02	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			09/07/11 06:02	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/07/11 06:02	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			09/07/11 06:02	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/07/11 06:02	1
Freon 113	<0.50		0.50	0.15	ug/L			09/07/11 06:02	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/07/11 06:02	1
2-Hexanone	<10		10	5.0	ug/L			09/07/11 06:02	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/07/11 06:02	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/07/11 06:02	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			09/07/11 06:02	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/07/11 06:02	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/07/11 06:02	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			09/07/11 06:02	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/07/11 06:02	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/07/11 06:02	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/07/11 06:02	1
o-Xylene	<0.50		0.50	0.27	ug/L			09/07/11 06:02	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/07/11 06:02	1
Styrene	<0.50		0.50	0.28	ug/L			09/07/11 06:02	1
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/07/11 06:02	1
tert-Butyl alcohol	<2.0		2.0	1.6	ug/L			09/07/11 06:02	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/07/11 06:02	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/07/11 06:02	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			09/07/11 06:02	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			09/07/11 06:02	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			09/07/11 06:02	1
Toluene	<0.50		0.50	0.23	ug/L			09/07/11 06:02	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			09/07/11 06:02	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			09/07/11 06:02	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/07/11 06:02	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			09/07/11 06:02	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			09/07/11 06:02	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			09/07/11 06:02	1
Trichloroethene	<0.50		0.50	0.37	ug/L			09/07/11 06:02	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/07/11 06:02	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			09/07/11 06:02	1
Trihalomethanes, Total	<0.50		0.50	0.29	ug/L			09/07/11 06:02	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/07/11 06:02	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/07/11 06:02	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			09/07/11 06:02	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			09/07/11 06:02	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-71880-5

Date Collected: 08/24/11 09:00

Matrix: Drinking Water

Date Received: 08/30/11 09:25

<u>Surrogate</u>	<u>% Recovery</u>	<u>Qualifier</u>	<u>Limits</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Dil Fac</u>
4-Bromofluorobenzene	102		70 - 130		09/07/11 06:02	1
1,2-Dichlorobenzene-d4	98		70 - 130		09/07/11 06:02	1

Surrogate Summary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)	
		BFB (70-130)	12DCB (70-130)
680-71880-1	HAMP22	102	94
680-71880-2	HAMP23	101	94
680-71880-3	RFW-20	103	99
680-71880-4	RFW-21	101	96
680-71880-5	Trip Blank	102	98

Surrogate Legend
BFB = 4-Bromofluorobenzene
12DCB = 1,2-Dichlorobenzene-d4

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)	
		BFB (70-130)	12DCB (70-130)
LCS 680-214034/23	Lab Control Sample	107	107
LCSD 680-214034/24	Lab Control Sample Dup	110	102
MB 680-214034/26	Method Blank	102	101

Surrogate Legend
BFB = 4-Bromofluorobenzene
12DCB = 1,2-Dichlorobenzene-d4

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Lab Sample ID: MB 680-214034/26
Matrix: Water
Analysis Batch: 214034

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
	Result	Qualifier							
Acetone	<10		10	5.0	ug/L			09/06/11 22:33	1
Benzene	<0.50		0.50	0.18	ug/L			09/06/11 22:33	1
Bromobenzene	<0.50		0.50	0.42	ug/L			09/06/11 22:33	1
Bromoform	<0.50		0.50	0.39	ug/L			09/06/11 22:33	1
Bromomethane	<1.0		1.0	0.45	ug/L			09/06/11 22:33	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			09/06/11 22:33	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			09/06/11 22:33	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/06/11 22:33	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			09/06/11 22:33	1
Chloroethane	<1.0		1.0	0.33	ug/L			09/06/11 22:33	1
Chloroform	<0.50		0.50	0.29	ug/L			09/06/11 22:33	1
Chloromethane	<0.50		0.50	0.32	ug/L			09/06/11 22:33	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			09/06/11 22:33	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			09/06/11 22:33	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			09/06/11 22:33	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			09/06/11 22:33	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/06/11 22:33	1
Dibromomethane	<0.50		0.50	0.38	ug/L			09/06/11 22:33	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			09/06/11 22:33	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			09/06/11 22:33	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			09/06/11 22:33	1
Dichlorobromomethane	<1.0		1.0	0.54	ug/L			09/06/11 22:33	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/06/11 22:33	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			09/06/11 22:33	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			09/06/11 22:33	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			09/06/11 22:33	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			09/06/11 22:33	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			09/06/11 22:33	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			09/06/11 22:33	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			09/06/11 22:33	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			09/06/11 22:33	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/06/11 22:33	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			09/06/11 22:33	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/06/11 22:33	1
Freon 113	<0.50		0.50	0.15	ug/L			09/06/11 22:33	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/06/11 22:33	1
2-Hexanone	<10		10	5.0	ug/L			09/06/11 22:33	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/06/11 22:33	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/06/11 22:33	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			09/06/11 22:33	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/06/11 22:33	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/06/11 22:33	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			09/06/11 22:33	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/06/11 22:33	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/06/11 22:33	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/06/11 22:33	1
o-Xylene	<0.50		0.50	0.27	ug/L			09/06/11 22:33	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/06/11 22:33	1
Styrene	<0.50		0.50	0.28	ug/L			09/06/11 22:33	1

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 680-214034/26

Matrix: Water

Analysis Batch: 214034

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/06/11 22:33	1
tert-Butyl alcohol	<2.0		2.0	1.6	ug/L			09/06/11 22:33	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/06/11 22:33	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/06/11 22:33	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			09/06/11 22:33	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			09/06/11 22:33	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			09/06/11 22:33	1
Toluene	<0.50		0.50	0.23	ug/L			09/06/11 22:33	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			09/06/11 22:33	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			09/06/11 22:33	1
1,2,3-Trichlorobenzene	0.225	J	0.50	0.14	ug/L			09/06/11 22:33	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			09/06/11 22:33	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			09/06/11 22:33	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			09/06/11 22:33	1
Trichloroethene	<0.50		0.50	0.37	ug/L			09/06/11 22:33	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/06/11 22:33	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			09/06/11 22:33	1
Trihalomethanes, Total	<0.50		0.50	0.29	ug/L			09/06/11 22:33	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/06/11 22:33	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/06/11 22:33	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			09/06/11 22:33	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			09/06/11 22:33	1

Surrogate	MB MB		Limits	Prepared	Analyzed	Dil Fac
	% Recovery	Qualifier				
4-Bromofluorobenzene	102		70 - 130		09/06/11 22:33	1
1,2-Dichlorobenzene-d4	101		70 - 130		09/06/11 22:33	1

Lab Sample ID: LCS 680-214034/23

Matrix: Water

Analysis Batch: 214034

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	% Rec	% Rec Limits
Acetone	40.0	40.7		ug/L		102	70 - 130
Benzene	20.0	20.7		ug/L		103	70 - 130
Bromobenzene	20.0	20.5		ug/L		103	70 - 130
Bromoform	20.0	21.9		ug/L		109	70 - 130
Bromomethane	20.0	17.5		ug/L		87	70 - 130
Carbon tetrachloride	20.0	21.4		ug/L		107	70 - 130
Chlorobenzene	20.0	20.3		ug/L		101	70 - 130
Chlorobromomethane	20.0	21.5		ug/L		108	70 - 130
Chlorodibromomethane	20.0	21.6		ug/L		108	70 - 130
Chloroethane	20.0	18.3		ug/L		92	70 - 130
Chloroform	20.0	20.0		ug/L		100	70 - 130
Chloromethane	20.0	18.4		ug/L		92	70 - 130
2-Chlorotoluene	20.0	20.6		ug/L		103	70 - 130
4-Chlorotoluene	20.0	20.8		ug/L		104	70 - 130
cis-1,2-Dichloroethene	20.0	19.7		ug/L		99	70 - 130
cis-1,3-Dichloropropene	20.0	21.4		ug/L		107	70 - 130
1,2-Dibromo-3-Chloropropane	20.0	19.7		ug/L		99	70 - 130

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 680-214034/23

Matrix: Water

Analysis Batch: 214034

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS		Unit	D	% Rec	% Rec. Limits
		Result	Qualifier				
Dibromomethane	20.0	20.8		ug/L		104	70 - 130
1,2-Dichlorobenzene	20.0	20.0		ug/L		100	70 - 130
1,3-Dichlorobenzene	20.0	20.6		ug/L		103	70 - 130
1,4-Dichlorobenzene	20.0	20.7		ug/L		103	70 - 130
Dichlorobromomethane	20.0	20.6		ug/L		103	70 - 130
Dichlorodifluoromethane	20.0	19.3		ug/L		97	70 - 130
1,1-Dichloroethane	20.0	20.1		ug/L		100	70 - 130
1,2-Dichloroethane	20.0	20.9		ug/L		105	70 - 130
1,1-Dichloroethene	20.0	20.3		ug/L		101	70 - 130
1,2-Dichloropropane	20.0	20.6		ug/L		103	70 - 130
1,3-Dichloropropane	20.0	20.1		ug/L		101	70 - 130
2,2-Dichloropropane	20.0	21.4		ug/L		107	70 - 130
1,1-Dichloropropene	20.0	20.7		ug/L		103	70 - 130
1,3-Dichloropropene, Total	40.0	43.3		ug/L		108	70 - 130
Diisopropyl ether	16.0	16.5		ug/L		103	70 - 130
Ethylbenzene	20.0	20.6		ug/L		103	70 - 130
Ethylene Dibromide	20.0	21.1		ug/L		105	70 - 130
Freon 113	16.0	18.1		ug/L		113	70 - 130
Hexachlorobutadiene	20.0	21.1		ug/L		106	70 - 130
2-Hexanone	40.0	40.7		ug/L		102	70 - 130
Isopropylbenzene	20.0	20.8		ug/L		104	70 - 130
4-Isopropyltoluene	20.0	21.1		ug/L		106	70 - 130
Methylene Chloride	20.0	20.2		ug/L		101	70 - 130
2-Butanone (MEK)	40.0	40.7		ug/L		102	70 - 130
4-Methyl-2-pentanone (MIBK)	40.0	40.1		ug/L		100	70 - 130
m-Xylene & p-Xylene	40.0	41.7		ug/L		104	70 - 130
Naphthalene	20.0	21.2		ug/L		106	70 - 130
n-Butylbenzene	20.0	21.1		ug/L		106	70 - 130
N-Propylbenzene	20.0	21.1		ug/L		106	70 - 130
o-Xylene	20.0	19.5		ug/L		98	70 - 130
sec-Butylbenzene	20.0	20.8		ug/L		104	70 - 130
Styrene	20.0	21.4		ug/L		107	70 - 130
Tert-amyl methyl ether	16.0	16.7		ug/L		105	70 - 130
tert-Butyl alcohol	80.0	80.0		ug/L		100	70 - 130
tert-Butylbenzene	20.0	20.5		ug/L		102	70 - 130
Tert-butyl ethyl ether	16.0	17.3		ug/L		108	70 - 130
1,1,1,2-Tetrachloroethane	20.0	21.5		ug/L		108	70 - 130
1,1,2,2-Tetrachloroethane	20.0	20.8		ug/L		104	70 - 130
Tetrachloroethene	20.0	19.7		ug/L		99	70 - 130
Toluene	20.0	20.0		ug/L		100	70 - 130
trans-1,2-Dichloroethene	20.0	20.0		ug/L		100	70 - 130
trans-1,3-Dichloropropene	20.0	21.9		ug/L		110	70 - 130
1,2,3-Trichlorobenzene	20.0	20.2		ug/L		101	70 - 130
1,2,4-Trichlorobenzene	20.0	20.3		ug/L		101	70 - 130
1,1,1-Trichloroethane	20.0	21.1		ug/L		106	70 - 130
1,1,2-Trichloroethane	20.0	21.1		ug/L		106	70 - 130
Trichloroethene	20.0	19.9		ug/L		100	70 - 130
Trichlorofluoromethane	20.0	20.4		ug/L		102	70 - 130
1,2,3-Trichloropropane	20.0	20.1		ug/L		101	70 - 130
1,2,4-Trimethylbenzene	20.0	20.7		ug/L		103	70 - 130

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 680-214034/23				Client Sample ID: Lab Control Sample			
Matrix: Water				Prep Type: Total/NA			
Analysis Batch: 214034							
Analyte	Spike Added	LCS	LCS	Unit	D	% Rec	% Rec. Limits
		Result	Qualifier				
1,3,5-Trimethylbenzene	20.0	20.7		ug/L		103	70 - 130
Vinyl chloride	20.0	19.2		ug/L		96	70 - 130
Xylenes, Total	60.0	61.3		ug/L		102	70 - 130
		LCS	LCS				
Surrogate	% Recovery	Qualifier	Limits				
4-Bromofluorobenzene	107		70 - 130				
1,2-Dichlorobenzene-d4	107		70 - 130				

Lab Sample ID: LCSD 680-214034/24				Client Sample ID: Lab Control Sample Dup					
Matrix: Water				Prep Type: Total/NA					
Analysis Batch: 214034									
Analyte	Spike Added	LCSD	LCSD	Unit	D	% Rec	% Rec. Limits	RPD	
		Result	Qualifier					RPD	Limit
Acetone	40.0	39.5		ug/L		99	70 - 130	3	30
Benzene	20.0	20.2		ug/L		101	70 - 130	2	30
Bromobenzene	20.0	19.6		ug/L		98	70 - 130	5	30
Bromoform	20.0	21.0		ug/L		105	70 - 130	4	30
Bromomethane	20.0	16.8		ug/L		84	70 - 130	4	30
Carbon tetrachloride	20.0	21.8		ug/L		109	70 - 130	2	30
Chlorobenzene	20.0	20.1		ug/L		101	70 - 130	1	30
Chlorobromomethane	20.0	21.5		ug/L		108	70 - 130	0	30
Chlorodibromomethane	20.0	20.6		ug/L		103	70 - 130	5	30
Chloroethane	20.0	18.7		ug/L		94	70 - 130	2	30
Chloroform	20.0	20.0		ug/L		100	70 - 130	0	30
Chloromethane	20.0	18.9		ug/L		94	70 - 130	3	30
2-Chlorotoluene	20.0	20.6		ug/L		103	70 - 130	0	30
4-Chlorotoluene	20.0	20.3		ug/L		102	70 - 130	2	30
cis-1,2-Dichloroethane	20.0	19.4		ug/L		97	70 - 130	2	30
cis-1,3-Dichloropropene	20.0	21.2		ug/L		106	70 - 130	1	30
1,2-Dibromo-3-Chloropropane	20.0	18.9		ug/L		95	70 - 130	4	30
Dibromomethane	20.0	20.3		ug/L		101	70 - 130	3	30
1,2-Dichlorobenzene	20.0	20.0		ug/L		100	70 - 130	0	30
1,3-Dichlorobenzene	20.0	20.6		ug/L		103	70 - 130	0	30
1,4-Dichlorobenzene	20.0	20.5		ug/L		102	70 - 130	1	30
Dichlorobromomethane	20.0	20.1		ug/L		101	70 - 130	2	30
Dichlorodifluoromethane	20.0	19.6		ug/L		98	70 - 130	1	30
1,1-Dichloroethane	20.0	19.8		ug/L		99	70 - 130	1	30
1,2-Dichloroethane	20.0	19.8		ug/L		99	70 - 130	6	30
1,1-Dichloroethene	20.0	20.7		ug/L		103	70 - 130	2	30
1,2-Dichloropropane	20.0	20.4		ug/L		102	70 - 130	1	30
1,3-Dichloropropane	20.0	19.3		ug/L		96	70 - 130	5	30
2,2-Dichloropropane	20.0	22.0		ug/L		110	70 - 130	3	30
1,1-Dichloropropene	20.0	20.6		ug/L		103	70 - 130	0	30
1,3-Dichloropropene, Total	40.0	42.7		ug/L		107	70 - 130	1	30
Diisopropyl ether	16.0	16.0		ug/L		100	70 - 130	3	30
Ethylbenzene	20.0	20.4		ug/L		102	70 - 130	1	30
Ethylene Dibromide	20.0	20.0		ug/L		100	70 - 130	5	30
Freon 113	16.0	18.7		ug/L		117	70 - 130	3	30
Hexachlorobutadiene	20.0	21.3		ug/L		107	70 - 130	1	30

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 680-214034/24
Matrix: Water
Analysis Batch: 214034

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike	LCSD		Unit	D	% Rec	% Rec.		RPD	Limit
	Added	Result	Qualifier				Limits	RPD		
2-Hexanone	40.0	37.7		ug/L		94	70 - 130	8	30	
Isopropylbenzene	20.0	21.1		ug/L		105	70 - 130	1	30	
4-Isopropyltoluene	20.0	21.3		ug/L		107	70 - 130	1	30	
Methylene Chloride	20.0	19.6		ug/L		98	70 - 130	3	30	
2-Butanone (MEK)	40.0	38.2		ug/L		96	70 - 130	6	30	
4-Methyl-2-pentanone (MIBK)	40.0	38.6		ug/L		96	70 - 130	4	30	
m-Xylene & p-Xylene	40.0	40.7		ug/L		102	70 - 130	2	30	
Naphthalene	20.0	20.5		ug/L		102	70 - 130	4	30	
n-Butylbenzene	20.0	21.5		ug/L		108	70 - 130	2	30	
N-Propylbenzene	20.0	21.2		ug/L		106	70 - 130	0	30	
o-Xylene	20.0	20.1		ug/L		101	70 - 130	3	30	
sec-Butylbenzene	20.0	21.3		ug/L		106	70 - 130	2	30	
Styrene	20.0	21.0		ug/L		105	70 - 130	2	30	
Tert-amyl methyl ether	16.0	16.1		ug/L		101	70 - 130	4	30	
tert-Butyl alcohol	80.0	78.7		ug/L		98	70 - 130	2	30	
tert-Butylbenzene	20.0	20.7		ug/L		103	70 - 130	1	30	
Tert-butyl ethyl ether	16.0	16.8		ug/L		105	70 - 130	3	30	
1,1,1,2-Tetrachloroethane	20.0	21.8		ug/L		109	70 - 130	1	30	
1,1,2,2-Tetrachloroethane	20.0	19.8		ug/L		99	70 - 130	5	30	
Tetrachloroethene	20.0	19.0		ug/L		95	70 - 130	4	30	
Toluene	20.0	19.6		ug/L		98	70 - 130	2	30	
trans-1,2-Dichloroethene	20.0	20.1		ug/L		100	70 - 130	0	30	
trans-1,3-Dichloropropene	20.0	21.5		ug/L		107	70 - 130	2	30	
1,2,3-Trichlorobenzene	20.0	18.9		ug/L		95	70 - 130	7	30	
1,2,4-Trichlorobenzene	20.0	20.1		ug/L		100	70 - 130	1	30	
1,1,1-Trichloroethane	20.0	21.5		ug/L		108	70 - 130	2	30	
1,1,2-Trichloroethane	20.0	20.0		ug/L		100	70 - 130	5	30	
Trichloroethene	20.0	20.1		ug/L		100	70 - 130	1	30	
Trichlorofluoromethane	20.0	20.5		ug/L		102	70 - 130	1	30	
1,2,3-Trichloropropane	20.0	19.8		ug/L		99	70 - 130	2	30	
1,2,4-Trimethylbenzene	20.0	20.9		ug/L		104	70 - 130	1	30	
1,3,5-Trimethylbenzene	20.0	20.5		ug/L		102	70 - 130	1	30	
Vinyl chloride	20.0	19.3		ug/L		96	70 - 130	0	30	
Xylenes, Total	60.0	60.9		ug/L		101	70 - 130	1	30	

Surrogate	LCSD		Limits
	% Recovery	Qualifier	
4-Bromofluorobenzene	110		70 - 130
1,2-Dichlorobenzene-d4	102		70 - 130

Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-71880-1

Client Sample ID: HAMP22

Lab Sample ID: 680-71880-1

Date Collected: 08/26/11 10:10

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared Or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	214034	09/07/11 04:32	SMC	TAL SAV

Client Sample ID: HAMP23

Lab Sample ID: 680-71880-2

Date Collected: 08/26/11 10:15

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared Or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	214034	09/07/11 04:55	SMC	TAL SAV

Client Sample ID: RFW-20

Lab Sample ID: 680-71880-3

Date Collected: 08/24/11 16:45

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared Or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	214034	09/07/11 05:17	SMC	TAL SAV

Client Sample ID: RFW-21

Lab Sample ID: 680-71880-4

Date Collected: 08/24/11 11:10

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared Or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	214034	09/07/11 05:40	SMC	TAL SAV

Client Sample ID: Trip Blank

Lab Sample ID: 680-71880-5

Date Collected: 08/24/11 09:00

Matrix: Drinking Water

Date Received: 08/30/11 09:25

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared Or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	214034	09/07/11 06:02	SMC	TAL SAV

Laboratory References:

TAL SAV = TestAmerica Savannah, 5102 LaRoche Avenue, Savannah, GA 31404, TEL (912)354-7858

Chain of Custody Record

Temperature on Receipt _____
 Drinking Water? Yes No

TestAmerica
 THE LEADER IN ENVIRONMENTAL TESTING

TAL-4124 (1007)

Client: Black + Decker / Weston Project Manager: _____ Date: _____ Chain of Custody Number: 145710
 Address: _____ Telephone Number (Area Code)/Fax Number: _____ Lab Number: _____
 City: W. Chester State: PA Zip Code: _____ Site Contact: _____ Lab Contact: _____ Page _____ of _____

Project Name and Location (State): Black + Decker / Hampstead, PA Carrier/Waybill Number: _____
 Contract/Purchase Order/Quote No.: _____

Sample I.D. No. and Description (Containers for each sample may be combined on one line)	Date	Time	Matrix				Containers & Preservatives						Analysis (Attach list if more space is needed)	Special Instructions/ Conditions of Receipt	
			Air	Aqueous	Soil	Soil	Unpres.	H2SO4	HNO3	HCl	NaOH	ZnAc			NaOH
HAMP22	8/26/11	1010		✓								3	✓	524.2	
HAMP23	8/26/11	1015		✓								3	✓		
RFW-20	8/24/11	1645		✓								3	✓		
RFW-21	↓	1110		✓								3	✓		
Top Blank	↓	900		✓								3	✓		

Page 23 of 24

Possible Hazard Identification: Non-Hazard Flammable Skin Irritant Poison B Unknown Return To Client Disposal By Lab Archive For _____ Months (A fee may be assessed if samples are retained longer than 1 month)

Turn Around Time Required: 24 Hours 48 Hours 7 Days 14 Days 21 Days Other _____ QC Requirements (Specify): _____

1. Relinquished By: <u>[Signature]</u>	Date: <u>8/29/11</u>	Time: <u>1600</u>	1. Received By: <u>Beth A. Daugherty</u>	Date: <u>08/31/11</u>	Time: <u>0935</u>
2. Relinquished By: _____	Date: _____	Time: _____	2. Received By: _____	Date: _____	Time: _____
3. Relinquished By: _____	Date: _____	Time: _____	3. Received By: _____	Date: _____	Time: _____

Comments: _____ Temp 1.4°C 680 71880

09/08/2011