

Quarterly Groundwater Monitoring Report

Prepared for

Black & Decker (U.S.) Inc.

Hampstead, Maryland

October 2014

Prepared by

WESTON SOLUTIONS, INC.

West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 3rd Quarter 2014	2-2
Table 2-2 Groundwater Elevation Data – 3rd Quarter 2014.....	2-3
Table 2-3 Effluent Characteristics Summary – 3rd Quarter 2014.....	2-4
Table 2-4 Summary of Groundwater Analytical Results - August 2014.....	2-5
Table 3-1 Treatment System Maintenance Activities – 3rd Quarter 2014.....	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of July through September 2014.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of July through September 2014, the extraction wells were pumping at an average combined rate of approximately 185 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of July through September 2014 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of July through September 2014, approximately 12.26 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (76.2 %) and tetrachloroethene (PCE) (23.8 %). Analytical results of the groundwater collected from the air stripper for the period of July through September 2014 are included in Appendix C.

A summary of the analytical results from the third quarter (August 2014) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 3rd Quarter 2014
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
July 2014	8,365,626
August 2014	7,970,793
September 2014	7,680,935

Table 2-2
Groundwater Elevation Data - 3rd Quarter 2014
Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV.	TOTAL DEPTH	7/15/2014		8/27/2014		9/25/2014	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NC	DRY	NC	DRY	NC
EW-2	849.21	110	72.74	776.47	78.84	770.37	78.10	771.11
EW-3	846.64	118	89.19	757.45	86.49	760.15	85.94	760.70
EW-4	858.01	97.5	PC	NC	PC	NC	PC	NC
EW-5	864.17	98	89.75	774.42	89.91	774.26	89.74	774.43
EW-6	831.98	115	74.30	757.68	77.91	754.07	78.11	753.87
EW-7	818.38	78	59.44	758.94	55.36	763.02	57.23	761.15
EW-8	811.13	98	93.00	718.13	91.43	719.70	91.30	719.83
EW-9	811.35	141	96.30	715.05	95.87	715.48	95.81	715.54
EW-10	807.74	INA	53.22	754.52	48.97	758.77	49.73	758.01
RFW-1A	864.37	78	48.02	816.35	47.92	816.45	48.11	816.26
RFW-1B	864.23	200	48.05	816.18	47.99	816.24	48.18	816.05
RFW-2A	857.41	35	11.31	846.10	14.51	842.90	14.53	842.88
RFW-2B	857.73	75	11.82	845.91	15.16	842.57	15.21	842.52
RFW-3B	839.21	153	27.01	812.20	30.33	808.88	30.30	808.91
RFW-4A	830.37	62	32.91	797.46	35.78	794.59	35.84	794.53
RFW-4B	830.37	120	32.63	797.74	35.69	794.68	35.77	794.60
RFW-5A	817.50	30	DRY	NC	DRY	NC	DRY	NC
RFW-6	785.04	120	4.02	781.02	2.95	782.09	4.10	780.94
RFW-7	805.14	29	7.65	797.49	5.81	799.33	7.03	798.11
RFW-8	860.07	56	DRY	NC	DRY	NC	DRY	NC
RFW-9	862.02	49	23.83	838.19	25.55	836.47	26.03	835.99
RFW-10	852.06	58	DRY	NC	DRY	NC	DRY	NC
RFW-11A	849.32	72	Damaged	NC	Damaged	NC	Damaged	NC
RFW-11B	849.62	116	58.13	791.49	59.44	790.18	58.73	790.89
RFW-12B	844.87	264	49.28	795.59	48.23	796.64	48.94	795.93
RFW-13	849.11	150	60.51	788.60	57.29	791.82	59.04	790.07
RFW-14B	812.39	281	53.47	758.92	53.79	758.60	54.80	757.59
RFW-16	856.14	41	DRY	NC	DRY	NC	DRY	NC
RFW-17	834.66	60.5	23.52	811.14	24.36	810.30	34.41	800.25
RFW-20	842.49	142	30.31	812.18	32.16	810.33	32.21	810.28
RFW-21	832.65	102	19.29	813.36	20.18	812.47	20.19	812.46
PH-7	805.94	89	26.04	779.90	27.43	778.51	27.81	778.13
PH-9	814.94	98	50.39	764.55	43.28	771.66	44.24	770.70
PH-11	820.68	78	47.17	773.51	48.11	772.57	48.23	772.45
PH-12	828.35	87	48.13	780.22	49.06	779.29	49.01	779.34
B-3	803.02	83	10.84	792.18	9.88	793.14	10.37	792.65
Amoco	842.29	INA	NA	NC	NA	NC	NA	NC
Hamp. Town #22	804.96	INA	1.29	803.67	1.03	803.93	1.43	803.53
Pembroke #1	INA	INA	10.45	NC	10.58	NC	10.73	NC
Pembroke #2	INA	INA	Damaged	NC	Damaged	NC	Damaged	NC
N. Houcks. Rd.	INA	INA	9.96	NC	10.39	NC	10.51	NC
E. Century St.	INA	INA	19.29	NC	19.21	NC	19.27	NC
Lwr. Beckleys. Rd.	INA	INA	53.56	NC	54.55	NC	54.21	NC

NA - Not Available/Not Accessible
NC - Not Calculable
INA - Information not available
PC - Pump Cycles

**Table 2-3
Effluent Characteristics Summary - 3rd Quarter 2014
Black & Decker
Hampstead, Maryland**

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				July 2014	August 2014	September 2014	
001	FLOW	average	MGD	NA	0.311	0.231	0.155
		maximum	MGD	NA	0.777	0.819	0.419
	1,1,1-Trichloroethane		ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene		ug/l	5	< 1	< 1	< 1
	Trichloroethylene		ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		monthly average	mg/l	10	< 5	< 5	< 5
	pH	minimum	STD	6.0	7.2	7.1	7.4
		maximum	STD	8.5	8.4	8.2	8.3
BOD		mg/l	15	5.0	7.0	5.0	
TSS	maximum	mg/l	30	0	0	0	
	monthly average	mg/l	20	0	0	0	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.180	0.149	0.145
		maximum	MGD	NA	0.210	0.190	0.163
	Fecal Coliform		MPN/100ml	200	10.0	1.0	1.0
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.261
		maximum	MGD	NA	NR	NR	0.314
	1,1,1-Trichloroethane		ug/l	NA	NR	NR	< 1
	Tetrachloroethylene		ug/l	NA	NR	NR	< 1
	Trichloroethylene		ug/l	NA	NR	NR	< 1

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

Table 2-4

Summary of Groundwater Analytical Results - August 2014
Black & Decker
Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	0.8 J	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3	1.8	1 U	1 U	1 U	2.9	23	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	130	34	540	100	4.6	2	6.8	0.4 J	0.5 J	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	51	1.4	11	3.6	10	5.1	73	98	99	2
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

NS = Not Sampled

Table 2-4
Summary of Groundwater Analytical Results - August 2014
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1.6	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	2 U	2 U	2 U	2 U	2 U	1 U	1 U	1 U	NS	1 U	7	NS	1 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	0.6 J	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	0.7 J	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	1.2	0.9 J	0.9 J	3	NS	1 U	1 U	NS	15	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	0.6 J	0.5 J	1.2	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	0.6 J	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	0.3 J	0.3 J	1 U	34	33	48	NS	0.5 J	2.1	NS	7.5	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	0.2 J	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	0.7 J	28	28	84	NS	0.7 J	1 U	NS	4.2	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicate sample
NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
J = Indicates an estimated value.

Table 2-4

Summary of Groundwater Analytical Results - August 2014
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	USEPA drinking water method 524.2				
												RFW-20	RFW-21	Town #22	Town #23	Trip Blank
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	1 U	2 U	2 U	NS	2 U	ABD	ABD	ABD	2 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	NA	NA	NA	NA	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	1.6	0.7 J	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.4 J	0.5 U	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trichloroethene	ug/L	NS	1.8	60	2.5	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	0.6	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	1 U	4.5	15	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division.

Samples from all of the other wells are analyzed with USEPA Method 8260.

NS = Not sampled

U = Compound was analyzed but not detected.

ABD = Well has been abandoned

RFW -20 was not sampled because it was damaged. The well is now repaired and will be sampled during the 4th quarter.

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells EW-2 and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from wells RFW-4B & EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (July through September 2014) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 3rd Quarter 2014
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Aug-14	EW -10 is off due to bad underground control wires. EW-10 was repaired and back in service.
Aug-14	Scheduled power outage for work in the yard substation. Power was off for 9:30 hours. Everything restarted and running.

4. RECOMMENDATIONS

For the reporting period of July through September 2014, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(JULY – SEPTEMBER 2014)

ENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By: **Facility: BTR Capital Group**
 Maryland Environmental Service **Address: 627 Hanover Pike, Hampstead Maryland**
 259 Najoles Road, Millersville MD **Additional Op's & cert # - Dorrance Jones 0763, James Elliott 3738, Anthony Phillips 3001**

Permit Number: 07-DP-0022
Superintendent: Earle Villarreal Certification # 1017

Month: July
Year: 2014

Date	Appearance	Final Effluent outfall 001														Outfall 101					Outfall 201			Operator		
		Discharge MGD	pH su	Cl2 mg/l	Turbidity ug/l	TSS mg/l	BOD ₅ mg/l	TSS mg/l	TKN mg/l	N+N mg/l	TP mg/l	TN mg/l	O&G mg/l	eColi mpn	Flow MGD	eColi mpn	Basin inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Turbidity ug/l	TSS mg/l	Discharge mgd			
1	Clear	0.17300											<1	0.163000	<1	1.0	1.0	1.0	5.0				0.278164	APhillips		
2	Clear	0.21000	7.45	0.00										0.173000		3.0	1.0	1.0	5.0				0.270754	Djones		
3	Clear	0.19300	8.16	0.00										0.181000		3.0	1.0	1.0	5.0				0.286041	Djones		
4	Clear	0.65600												0.202000		0.0	1.0	1.0	5.0				0.186051	Djones		
5	Clear	0.28200												0.177000		0.0	1.0	1.0	5.0				0.290171	APhillips		
6	Clear	0.24800												0.175000		0.0	1.0	1.0	5.0				0.265684	APhillips		
7	Clear	0.27300	7.47	0.00										0.165000		3.0	1.0	1.0	5.0				0.283729	Djones		
8	Clear	0.27400			<1	<1	<1	5.00	15.80	0.99	0.90	0.09	1.9	<5	30.6	0.186000	9.90	3.0	1.0	1.0	5.0		0.273107	Djones		
9	Clear	0.36800	7.19	0.00										0.196000		1.0	1.0	1.0	5.0				0.283062	Djones		
10	Clear	0.44400												0.183000		1.0	1.0	1.0	5.0				0.261373	Djones		
11	Clear	0.62600												0.198000		0.0	1.0	1.0	5.0				0.274277	Djones		
12	Clear	0.23600												0.184000		0.0	1.0	1.0	5.0				0.263635	APhillips		
13	Clear	0.24400												0.180000		0.0	1.0	1.0	5.0				0.271356	APhillips		
14	Clear	0.77700												0.185000		0.0	1.0	1.0	5.0				0.281417	Djones		
15	Clear	0.77100	8.38	0.00										0.185000	<1	0.0	1.0	1.0	5.0				0.270180	Djones		
16	Clear	0.35200												0.186000		0.0	1.0	1.0	5.0				0.271524	Djones		
17	Clear	0.28000	7.26	0.00										0.197000		1.0	1.0	1.0	5.0				0.265816	Djones		
18	Clear	0.27800												0.190000		1.0	1.0	1.0	5.0				0.277019	Djones		
19	Clear	0.28000												0.171000		1.0	1.0	1.0	5.0				0.273880	Djones		
20	Clear	0.26000												0.192000		1.0	1.0	1.0	5.0				0.257874	Djones		
21	Clear	0.27500	8.32	0.00										0.178000		1.0	1.0	1.0	5.0				0.285224	APhillips		
22	Clear	0.27000	8.17	0.00										0.175000	<1	1.0	1.0	1.0	5.0				0.270208	APhillips		
23	Clear	0.21300												0.146000		1.0	1.0	1.0	5.0				0.270000	APhillips		
24	Clear	0.30100												0.196000		1.0	1.0	1.0	5.0				0.224602	APhillips		
25	Clear	0.24700												0.187000		1.0	1.0	1.0	5.0				0.303062	Jelliott		
26	Clear	0.15000												0.166000		1.0	1.0	1.0	5.0				0.249405	Jelliott		
27	Clear	0.17400												0.150000		1.0	1.0	1.0	5.0				0.266828	Jelliott		
28	Clear	0.37800	8.34	0.00										0.210000		1.0	1.0	1.0	5.0				0.264684	Jelliott		
29	Clear	0.16900	7.29	0.00										0.175000	<1	1.0	1.0	1.0	5.0				0.284753	A.phillips		
30	Clear	0.11800												0.176000		2.0	1.0	1.0	5.0				0.284042	Djones		
31	Clear	0.12300												0.165000		2.0	1.0	1.0	5.0				0.277704	Djones		
Total		9.64300												5.593000									8.365626			
Average		0.31106	7.8	<0.10	0.000	0.000	0.000	5	16	1	1	0	2	0	6	0.180419	1.6	1.0	1.0	1.0	5.0	#DIV/0!	#DIV/0!	#DIV/0!	0.269859	
Minimum		0.11800	7.2	0.00	0.000	0.000	0.000	5	16	1	1	0	2	0	0	0.146000	0.0	0.0	1.0	1.0	5.0	0.0	0.0	0.0	0.186051	
Maximum		0.77700	8.4	<0.10	0.000	0.000	0.000	5	16	1	1	0	2	0	31	0.210000	10	3.0	1.0	1.0	5.0	0.0	0.0	0.0	0.303062	MOR 01-3-14

COMMENTS:

Created By:
Maryland Environmental Service
9 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 627 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrance Jones 0763, Keith White 4609, Chris Dallas 6202, Anthony Phillips 3001

Permit Number: 07-DP-0022
Superintendent: Earle Villarreal

Certification # 1017

Month: August
Year: 2014

Date	Appearance	Discharge MGD	pH	Cl2 mg/l	Final Effluent outfall 001										Outfall 101					Outfall 201			Operator				
					Trichloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	TKN mg/l	N+N mg/l	TP mg/l	TN mg/l	O&G mg/l	eColi mpn	Flow MGD	eColi mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Trichloroethylene ug/l		1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	Discharge mgd	
1	Clear	0.10800														0.188000		2.0	1.0	1.0	5.0				0.270051	Djones	
2	Clear	0.12500														0.163000		2.0	1.0	1.0	5.0				0.255688	APhillips	
3	Clear	0.58200														0.173000		0.0	1.0	1.0	5.0				0.247096	APhillips	
4	Clear	0.27000														0.140000		0.0	1.0	1.0	5.0				0.297789	Djones	
5	Clear	0.14100				<1	<1	<1	7.00	9.60	0.999	0.85	<0.05	1.9	<5	9.9	0.160000	<1	0.0	1.0	1.0	5.0				0.227908	Djones
6	Clear	0.16700	7.14	0.00												0.163000		0.0	1.0	1.0	5.0				0.245214	Kwhite	
7	Clear	0.12700														0.133000		0.0	1.0	1.0	5.0				0.232003	Kwhite	
8	Clear	0.10000	7.55	0.00												0.149000		0.0	1.0	1.0	5.0				0.239082	Kwhite	
9	Clear	0.12000														0.138000		0.0	2.0	1.0	5.0				0.252032	Djones	
10	Clear	0.12300														0.155000		0.0	5.0	1.0	5.0				0.254093	Djones	
11	Clear	0.40000														0.130000		0.0	5.0	1.0	5.0				0.297872	Kwhite	
12	Clear	0.41400														0.144000	<1	0.0	5.0	1.0	5.0				0.265889	Kwhite	
13	Clear	0.81900	7.65	0.00												0.148000		0.0	5.0	1.0	5.0				0.249227	Kwhite	
14	Clear	0.19400	8.02	0.00												0.156000		0.0	5.0	1.0	5.0				0.215517	Kwhite	
15	Clear	0.13300														0.162000		0.0	5.0	1.0	5.0				0.259543	Kwhite	
16	Clear	0.13100														0.115000		0.0	5.0	1.0	5.0				0.281408	Kwhite	
17	Clear	0.12500														0.190000		0.0	5.0	1.0	5.0				0.253190	Kwhite	
18	Clear	0.12700														0.003500	<1	0.0	5.0	1.0	5.0				0.251014	Cdallas	
19	Clear	0.12200														0.147000		0.0	5.0	1.0	5.0				0.233688	Cdallas	
20	Clear	0.17300	7.18	0.00												0.154000		0.0	5.0	1.0	5.0				0.307327	Cdallas	
21	Clear	0.14000	8.16	0.00												0.143000		0.0	5.0	1.0	5.0				0.239568	Djones	
22	Clear	0.13400														0.151000		0.0	5.0	1.0	5.0				0.256905	Djones	
23	Clear	0.14500														0.144000		0.0	5.0	1.0	5.0				0.260362	APhillips	
24	Clear	0.49300														0.168000		0.0	5.0	1.0	5.0				0.250706	APhillips	
25	Clear	0.28400	7.43	0.00												0.167000		0.0	5.0	1.0	5.0				0.309336	Djones	
26	Clear	0.44100														0.160000	<1	0.0	5.0	1.0	5.0	<1	<1	<1	0.261267	Djones	
27	Clear	0.28100														0.149000		0.0	5.0	1.0	5.0				0.259180	Kwhite	
28	Clear	0.33700	7.81	0.00												0.168000		1.0	5.0	1.0	5.0				0.267688	Kwhite	
29	Clear	0.12900														0.131000		1.0	5.0	1.0	5.0				0.257533	Kwhite	
30	Clear	0.07400														0.157000		1.0	5.0	1.0	5.0				0.206407	Djones	
31	Clear	0.18800														0.159000		1.0	5.0	1.0	5.0				0.266210	Djones	
Total		7.14700														4.608500										7.970793	
Average		0.23055	7.6	<0.10	0.000	0.000	0.000	7.0	9.6	1.0	0.9	0.0	1.9	0.0	9.9	0.148661	1.0	0.3	3.9	1.0	5.0	0.0	0.0	0.0	0.257122		
Minimum		0.07400	7.1	0.00	0.000	0.000	0.000	7.0	9.6	1.0	0.9	0.0	1.9	0.0	9.9	0.003500	0.0	0.0	1.0	1.0	5.0	0.0	0.0	0.0	0.206407		
Maximum		0.81900	8.2	<0.10	0.000	0.000	0.000	7.0	9.6	1.0	0.9	0.0	1.9	0.0	9.9	0.190000	0.0	2.0	5.0	1.0	5.0	0.0	0.0	0.0	0.309336	MOR 01-3-14	

COMMENTS:

ENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 627 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrance Jones 0763, James Elliott 3738, Anthony Phillips 3001, Keith White 4609, Ryan Thomas 0781

Permit Number: 07-DP-0022
Superintendent: Earle Villarreal Certification # 1017

Month: September
Year: 2014

Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Final Effluent outfall 001										Outfall 101					Outfall 201			Operator						
					Turbidity ug/l	1,1,1-Trichloroethane ug/l	Toxics ug/l	BOD ₅ mg/l	TSS mg/l	TKN mg/l	N+N mg/l	TP mg/l	TN mg/l	O&G mg/l	eColi mpn	Flow MGD	eColi mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Turbidity ug/l		1,1,1-Trichloroethane ug/l	Toxics ug/l	Discharge mgd			
1	Clear	0.11000																0.157000		1.0	5.0	1.0	5.0					0.155349	APhillips
2	Clear	0.14900	8.03	0.00														0.148000		1.0	5.0	1.0	5.0					0.266203	APhillips
3	Clear	0.18900			<1	<1	<1	5.00	4.80	<0.2	10.20	<0.05	10.2	<5.0			0.158000	<1	1.0	5.0	1.0	5.0					0.265283	APhillips	
4	Clear	0.15300	7.52	0.00													0.139000		3.0	5.0	1.0	5.0					0.313562	Kwhite	
5	Clear	0.15400															0.137000		3.0	5.0	1.0	5.0					0.246148	Djones	
6	Clear	0.24100															0.142000		3.0	5.0	1.0	5.0					0.258635	Jelliott	
7	Clear	0.17100															0.143000		3.0	5.0	1.0	5.0					0.212615	Jelliott	
8	Clear	0.16300	8.03	0.00													0.163000		4.0	5.0	1.0	5.0					0.280140	Djones	
9	Clear	0.16400															0.140000	<1	4.0	5.0	1.0	5.0					0.262659	Djones	
10	Clear	0.12700	7.81	0.00													0.139000		5.0	5.0	1.0	5.0					0.260544	Djones	
11	Clear	0.10500															0.145000		5.0	5.0	1.0	5.0					0.241583	Djones	
12	Clear	0.12700															0.155000		6.0	5.0	1.0	5.0					0.281308	Djones	
13	Clear	0.11400															0.147000		6.0	5.0	1.0	5.0					0.251917	APhillips	
14	Clear	0.11200															0.148000		6.0	5.0	1.0	5.0					0.247922	APhillips	
15	Clear	0.11300	8.32	0.00													0.145000		6.0	5.0	1.0	5.0					0.275320	Djones	
16	Clear	0.11600															0.131000	<1	6.0	5.0	1.0	5.0					0.263449	Djones	
17	Clear	0.09900															0.143000		6.0	5.0	1.0	5.0					0.233644	Djones	
18	Clear	0.11400	7.87	0.00													0.151000		6.0	5.0	1.0	5.0					0.293304	Djones	
19	Clear	0.18300															0.155000		6.0	5.0	1.0	5.0					0.243354	Djones	
20	Clear	0.10100															0.128000		6.0	5.0	1.0	5.0					0.260188	Djones	
21	Clear	0.09100															0.138000		6.0	5.0	1.0	5.0					0.250180	Djones	
22	Clear	0.17500															0.151000		6.0	5.0	1.0	5.0					0.277903	Kwhite	
23	Clear	0.11000	7.57	0.00													0.158000	1.00	6.0	5.0	1.0	5.0					0.244783	Kwhite	
24	Clear	0.11400															0.135000		6.0	5.0	1.0	5.0					0.262788	Kwhite	
25	Clear	0.41900	7.58	0.00													0.153000		5.0	5.0	1.0	5.0					0.227985	Kwhite	
26	Clear	0.38500													5.2		0.134000		5.0	5.0	1.0	5.0					0.285616	Kwhite	
27	Clear	0.11900															0.147000		5.0	5.0	1.0	5.0					0.235148	Kwhite	
28	Clear	0.15300															0.134000		5.0	5.0	1.0	5.0					0.268768	Kwhite	
29	Clear	0.12800	7.36	0.00													0.141000		5.0	5.0	1.0	5.0					0.254968	Rthomas	
30	Clear	0.14800	8.21	0.00													0.143000	<1	5.0	5.0	1.0	5.0					0.259669	Rthomas	
31																													
Total		4.64700															4.348000											7.680935	
Average		0.15490	7.8	<0.10	0	0	0	5.0	5	0.0	10.2	0	10	0	5	0.144933	1.0	4.7	5.0	1.0	5.0	#DIV/0!	#DIV/0!	#DIV/0!		0.256031			
Minimum		0.09100	7.4	0.00	0	0	0	5.0	5	0.0	10.2	0	10	0	5	0.128000	0.0	1.0	5.0	1.0	5.0	0.0	0.0	0.0		0.155349			
Maximum		0.41900	8.3	<0.10	0	0	0	5.0	5	0.0	10.2	0	10	0	5	0.163000	1.0	6.0	5.0	1.0	5.0	0.0	0.0	0.0		0.313562	MOR 01-3-14		

COMMENTS:

**APPENDIX B
DISCHARGE MONITORING REPORTS
(JULY - SEPTEMBER 2014)**

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name **BTR Hampstead, Inc**
 Address **c/o BTR Captial Group Management**
222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) **MD0001881** (17-19) **001**
PERMIT NUMBER **DISCHARGE NUMBER**

Form Approved.
 OMB No.
 Approval expires

Facility **Groundwater Remediation and WWTP**
 Location **626 Hanover Pike**
 Attn:

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form

State Discharge Permit
 07-DP-0022

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
14	07	01	TO	14	07	31
(20-21)		(22-23) (24-25)		(26-27)		(28-29) (30-31)

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	5	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
pH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	7.2	*****	8.4	(12)	0	TWICE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	DAILY MN	*****	8.5 DAILY MX	SU		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	36	Lbs/day	*****	16	16	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	1,271	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
SOLIDS, TOTAL SUSPENDED 00530 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	2,917	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0 EFFLUENT GROSS VALUE	MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	10 30DA AVG	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
NITROGEN, TOTAL (AS N) 00600 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	4	Lbs/day	*****	2	2	(19)	0	ONCE/ MONTH	COMP -8
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	Req. Mon. DAILY MX	MG/L		ONCE/ MONTH	COMP -8
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUES IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)				TELEPHONE		DATE				
Nicole Finneyrock Property Manager					410	729-8350	14	08	21		
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				AREA CODE	NUMBER	YEAR	MONTH	DAY		

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments he

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name BTR Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address c/o BTR Captial Group Management

MD0001881

001

Approval expires

222 Courthouse Ct., Suite 300, Towson MD 21204

PERMIT NUMBER

DISCHARGE NUMBER

Facility Groundwater Remediation and WWTP

MONITORING PERIOD

*** NO DISCHARGE ***
NOTE: Read instructions before completing this form

Location 626 Hanover Pike

Attn:

FROM 14 07 01 TO 14 07 31
(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

State Discharge Permit
07-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
NITROGEN, TOTAL (AS N) 00600 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	152	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
NITROGEN, TOTAL (AS N) 00600 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	1,524	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/day	*****	0	0	(19)	0	ONCE/ MONTH	COMP -8
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	DAILY MX	MG/L		ONCE/ MONTH	COMP -8
PHOSPHOROUS, TOTAL (AS P) 00665 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	7	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	26	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
TETRACHLOROETHYLE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Nicole Finneyrock Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410	729-8350	14	08	21
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)
 Name **BTR Hampstead, Inc**
 Address **c/o BTR Capital Group Management**
222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) **MD0001881** (17-19) **001**
PERMIT NUMBER **DISCHARGE NUMBER**

Form Approved.
 OMB No.
 Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility **Groundwater Remediation and WWTP**
 Location **626 Hanover Pike**
 Attn:


MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
14	07	01	14	07	31
FROM				TO	
(20-21)		(22-23) (24-25)		(26-27) (28-29) (30-31)	

State Discharge Permit
 07-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0.3111	0.7770	(03)	*****	*****	*****	0	ONCE/ MONTH	Measured
	PERMIT REQUIREMENT	REPORT	REPORT	MGD	*****	*****	*****			
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX			
E. COLI, MPN 51040 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	6	*****	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	Req. Mon. GEO MEAN	*****			
TRICHLOROETHENE 78391 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TI
Nicole Finneyfrock
Property Manager
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 8 MONTHS AND 5 YEARS.)


 SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE
 410 | 729-8350
 AREA CODE | NUMBER

DATE
 14 | 08 | 21
 YEAR | MONTH | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name **BTR Hampstead, Inc**
 Address **c/o BTR Captial Group Management**
222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) **MD0001881** (17-19) **101**
PERMIT NUMBER **DISCHARGE NUMBER**

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility **Groundwater Remediation and WWTP**

Location **626 Hanover Pike**


Attn:

State Discharge Permit

07-DP-0022

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
14	07	01	14	07	31
FROM		TO			
(20-21)		(22-23)		(24-25)	
		(26-27)		(28-29)	
				(30-31)	

PARAMETER (32-37)		(3 Card Only) (46-53) QUANTITY OR LOADING			(4 Card Only) (38-45) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (54-51)	MAXIMUM (54-51)	UNITS	MINIMUM (54-51)	AVERAGE (54-51)	MAXIMUM (54-51)	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	180,419	210,000	(07)	*****	*****	*****	****	0	ONCE/ WEEK	Measured/ Recorded
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	Measured/ Recorded
E.COLI, MPN 51040 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	10	(30)	0	ONCE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	126 DAILY MX	MPN		ONCE/ WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Nicole Finneyfrock Property Manager	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
		TYPED OR PRINTED		410	729-8350	14
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YFAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

ERMITTEE NAME/ADDRESS (Include facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.
OMB No.
Approval expires

ame BTR Hampstead, Inc
ddress c/o BTR Capital Group Management
222 Courthouse Ct., Suite 300, Towson MD 21204

(2-16)	(17-19)
MD0001881	001
PERMIT NUMBER	DISCHARGE NUMBER

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

ility Groundwater Remediation and WWTP
ocation 626 Hanover Pike
ttn:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 14	08	01	TO 14	08	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

State Discharge Permit
07-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(3 Card Only) (46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(4 Card Only) (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
30D, 5-DAY (20 DEG. C)	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	7	(19)	0	ONCE/ MONTH	GRAB
00310 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	7.1	*****	8.2	(12)	0	TWICE/ WEEK	GRAB
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	****	DAILY MN	*****	8.5 DAILY MX	SU		TWICE/ WEEK	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	11	Lbs/day	*****	10	10	(19)	0	ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	PREMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/ MONTH	GRAB
00530 1 0 0	SAMPLE MEASUREMENT	*****	572	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
00530 1 1 0	SAMPLE MEASUREMENT	*****	3,489	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/ MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE	PERMIT REQUIREMENT	*****	*****	****	*****	10 30DA AVG	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
70030 1 0 0	SAMPLE MEASUREMENT	*****	2	Lbs/day	*****	2	2	(19)	0	ONCE/ MONTH	COMP -8
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	Req. Mon. DAILY MX	MG/L		ONCE/ MONTH	COMP -8
NITROGEN, TOTAL (AS N)	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	*****	****		ONCE/ MONTH	COMP -8
00600 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	*****	****		ONCE/ MONTH	COMP -8
EFFLUENT GROSS VALUE											

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Nicole Finneyfrock Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
		410	729-8350	14	09	22
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments he

ERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name BTR Hampstead, Inc
 Address c/o BTR Capital Group Management
 222 Courthouse Ct., Suite 300, Towson MD 21204

(2-16)	(17-19)
MD0001881	001
PERMIT NUMBER	DISCHARGE NUMBER

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attention:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
14	08	01	14	08	31
FROM (20-21) (22-23) (24-25)			TO (26-27) (28-29) (30-31)		

State Discharge Permit

07-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING (3 Card Only) (46-53)			QUALITY OR CONCENTRATION (4 Card Only) (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (54-51)	MAXIMUM	UNITS	MINIMUM (54-51)	AVERAGE	MAXIMUM			
NITROGEN, TOTAL (AS N) 00600 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	110	Lbs/mo	*****	*****	*****	0	ONCE/MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****		ONCE/MONTH	Calculated
NITROGEN, TOTAL (AS N) 00600 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	1,635	Lbs/yr	*****	*****	*****	0	ONCE/MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****		ONCE/MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/day	*****	0	0	(19)	ONCE/MONTH	COMP -8
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	DAILY MX		ONCE/MONTH	COMP -8
PHOSPHOROUS, TOTAL (AS P) 00665 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/mo	*****	*****	*****	0	ONCE/MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****		ONCE/MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	26	Lbs/yr	*****	*****	*****	0	ONCE/MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****		ONCE/MONTH	Calculated
TETRACHLOROETHYLE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX		ONCE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX		ONCE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Nicole Finneyrock Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410	729-8350	14	09	22
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

ERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

name BTR Hampstead, Inc
 address c/o BTR Captial Group Management
222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881
PERMIT NUMBER

001
DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Groundwater Remediation and WWTP
 Location 626 Hanover Pike
 City/State


MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
14	08	01		14	08	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit
 07-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM			
		UNITS								
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.2305	0.8190	(03)	*****	*****	*****	0	ONCE/ MONTH	Measured
30050 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	MGD	*****	*****	*****		ONCE/ MONTH	Measured
EFFLUENT GROSS VALUE CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0 ONCE/ MONTH	GRAB
50060 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L	ONCE/ MONTH	GRAB
E.COLI, MPN	SAMPLE MEASUREMENT	*****	*****	****	*****	10	*****	(30)	0 ONCE/ MONTH	GRAB
51040 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	Req. Mon. GEO MEAN	*****	MPN	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0 ONCE/ MONTH	GRAB
78391 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TI
 Nicole Finneyfrock
 Property Manager
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)


 SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OF AUTHORIZED AGENT

TELEPHONE
 410 729-8350
 AREA CODE NUMBER

DATE
 14 09 22
 YEAR MONTH DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 Name BTR Hampstead, Inc
 Address c/o BTR Captial Group Management
 222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDE)

DISCHARGE MONITORING REPORT (DMR)

(2-16)	(17-19)
MD0001881	101
PERMIT NUMBER	DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires

Facility Groundwater Remediation and WWTP
 Location 626 Hanover Pike
 Attn:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
14	08	01	14	08	31
FROM (20-21) (22-23) (24-25)			TO (28-27) (28-29) (30-31)		

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form

State Discharge Permit
 07-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	148,661	190,000	(07)	*****	*****	*****	****	0	ONCE/WEEK	Measured/Recorded
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/MONTH	Measured/Recorded
E.COLI, MPN 51040 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	126 DAILY MX	MPN		ONCE/WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Nicole Finneyfrack Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
		410	729-8350	14	09	22
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name **BTR Hampstead, Inc**

Address **c/o BTR Capital Group Management**

222 Courthouse Ct., Suite 300, Towson MD 21204

Facility **Groundwater Remediation and WWTP**

Location **626 Hanover Pike**

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO-DISCHARGE ***

NOTE: Read instructions before completing this form

State Discharge Permit

07-DP-0022

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 14	09	01	TO 14	09	30
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	5	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
pH 00400 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	7.4	*****	8.3	(12)	0	TWICE/ WEEK	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	DAILY MN	*****	8.5 DAILY MX	SU		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 C	SAMPLE MEASUREMENT	*****	8	Lbs/day	*****	*****	5	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	*****	20 30DA AVG	MG/L		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 1 C	SAMPLE MEASUREMENT	*****	186	Lbs/mo	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	*****		ONCE/ MONTH	Calculated
SOLIDS, TOTAL SUSPENDED 00530 1 2 C	SAMPLE MEASUREMENT	*****	3,675	Lbs/yr	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	*****		ONCE/ MONTH	Calculated
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	10 30DA AVG	MG/L		ONCE/ MONTH	GRAB
NITROGEN, TOTAL (AS N) 00600 1 0 0	SAMPLE MEASUREMENT	*****	16	Lbs/day	*****	*****	10	(19)	0	ONCE/ MONTH	COMP -8
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	*****	Req. Mon. 30DA AVG	MG/L		ONCE/ MONTH	COMP -8
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §§1001 AND 33 U.S.C. §§ 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)				TFI PHONE		DATE			
Nicole Finneyfrock Property Manager TYPED OR PRINTED						410	729-8350	14	10	20	
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				AREA CODE	NUMBER	YEAR	MONTH	DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDE)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name BTR Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address c/o BTR Capital Group Management

MD0001881

001

Approval expires

222 Courthouse Ct., Suite 300, Towson MD 21204

PERMIT NUMBER

DISCHARGE NUMBER

*** NO DISCHARGE ***

Facility Groundwater Remediation and WWTP

MONITORING PERIOD

NOTE: Read instructions before completing this form

Location 626 Hanover Pike

YEAR	MO	DAY	YEAR	MO	DAY
14	09	01	14	09	30
FROM (20-21) (22-23) (24-25)			TO (26-27) (28-29) (30-31)		

State Discharge Permit

07-DP-0022

Attn:

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (45-53) (54-61)			(4 Card Only) QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
NITROGEN, TOTAL (AS N) 00600 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	395	Lbs/mo	*****	*****	*****	****	0	ONCE/MONTH	Calculated	
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/MONTH	Calculated	
NITROGEN, TOTAL (AS N) 00600 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	2,030	Lbs/yr	*****	*****	*****	****	0	ONCE/MONTH	Calculated	
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/MONTH	Calculated	
PHOSPHOROUS, TOTAL (AS P) 00665 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/day	*****	0	0	(19)	0	ONCE/MONTH	COMP -8	
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	DAILY MX	MG/L		ONCE/MONTH	COMP -8	
PHOSPHOROUS, TOTAL (AS P) 00665 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/mo	*****	*****	*****	****	0	ONCE/MONTH	Calculated	
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/MONTH	Calculated	
PHOSPHOROUS, TOTAL (AS P) 00665 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	26	Lbs/yr	*****	*****	*****	****	0	ONCE/MONTH	Calculated	
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/MONTH	Calculated	
TETRACHLOROETHYLE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	5	UG/L		ONCE/MONTH	GRAB
									DAILY MX			
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	5	UG/L		ONCE/MONTH	GRAB
									DAILY MX			

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 651001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN

TFI PHONE		DATE		
410	729-8350	14	10	20
AREA CODE	NUMBER	YFAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name BTR Hampstead, Inc

Address c/o BTR Captial Group Management

222 Courthouse Ct., Suite 300, Towson MD 21204

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attn: _____

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

State Discharge Permit
07-DP-0022

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
FROM 14	09	01		14	09	30
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE SUREMENT	0.1549	0.4190	(03)	*****	*****	*****	****	0	ONCE/ MONTH	Measured
	PERMIT REQUIREMENT	REPORT	REPORT	MGD	*****	*****	*****	****		ONCE/ MONTH	Measured
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L		ONCE/ MONTH	GRAB
CHLORINE, TOTAL RESIDUAL 50060 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	5	*****	(30)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	Req. Mon. GEO MEAN	*****	MPN		ONCE/ MONTH	GRAB
E. COLI, MPN 51040 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB
TRICHLOROETHENE 78391 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	*****				
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	*****				
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TI Nicole Finneyrock Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410	729-8350	14	10	20
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN	AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name BTR Hampstead, Inc

Address c/o BTR Capital Group Management

222 Courthouse Ct., Suite 300, Towson MD 21204

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDE)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	14	09	01		14	09	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

07-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(3 Card Only) (46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(4 Card Only) (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	144,933	163,000	(07)	*****	*****	*****	****	0	ONCE/ WEEK	Measured/ Recorded
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	Measured/ Recorded
E. COLI, MPN 51040 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	126 DAILY MX	MPN		ONCE/ WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Nicole Finneyrock Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 881001 AND 33 U.S.C. 88 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI FPHONE		DATE		
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN	410 AREA CODE	729-8350 NUMBER	14 YEAR	10 MONTH

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name BTR Hampstead, Inc

Address c/o BTR Captial Group Management

222 Courthouse Ct., Suite 300, Towson MD 21204

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDE)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

201

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
FROM 14	07	01		14	09	30
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

07-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		(48-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM				UNITS
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	261,058	313,562	(07)	*****	*****	*****	****	0	Measured	Record
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	Record
Total Volatile Organics (VOC) 51415 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	100	UG/L		One/ Quarter	Grab
TRICHLOROETHENE 78391 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Nicole Finneyfrock Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410 AREA CODE	729-8350 NUMBER	14 YEAR	10 MONTH	20 DAY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(JULY - SEPTEMBER 2014)

QC Laboratories

Analytical Report

Printed 07/16/14 19:36 DE36

CHERYL GRIFFIN
MARYLAND ENVIRONMENTAL SERVICE A
259 NAJOLLES ROAD
RE: BLACK & DECKER WWTP
MILLERSVILLE, MD 21108

Order Number: L5113810
Project Name: BLACK & DECKER WWTP
Receive Date: 07-08-2014
Client Code: MES_A
Project Location: BLACK & DECKER WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No: Inv. No: MES_AL0341
PWSID No:

Sample ID L5113810-1 Sample Description BTR 001 GRAB
Received Date/Time/Temp 07/08/14 04:30pm 2.5 C Iced (Y/N): Y
Satellite Received Temp 4.0 C Iced (Y/N): Y

Samp. Date/Time/Temp 07/08/14 09:30am NA C
Sampled by Customer

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
GENERAL CHEMISTRY							
Hexane Ext. Material-HEM (oil+grease)	ND	5.00	mg/l	1664B HEM	1		07/11/14 12:20PM AGM
Total Suspended Solids (Delaware)	15.8	4.00	mg/l	SM 2540D	1		07/09/14 12:31PM MS3
Biochemical Oxygen Demand, 5 Day (DE)	5.00	2.00	mg/l	SM 5210B	1.5		07/09/14 08:35AM SKJ
GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES							
1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		07/10/14 04:15PM JAD
Tetrachloroethene	ND	1.00	ug/l	EPA 624	1		07/10/14 04:15PM JAD
Trichloroethene	ND	1.00	ug/l	EPA 624	1		07/10/14 04:15PM JAD

Sample ID L5113810-2 Sample Description BTR 001 COMP
Received Date/Time/Temp 07/08/14 04:30pm 4.0 C Iced (Y/N): Y
Satellite Received Temp 4.0 C Iced (Y/N): Y

Samp. Date/Time/Temp 07/08/14 09:32am NA C
Sampled by Customer

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

PIN: 17237

Serial Number: 3826372

QC Laboratories

Analytical Report

Printed 07/16/14 11:49 DE36

CHERYL GRIFFIN
MARYLAND ENVIRONMENTAL SERVICE A
259 NAJOLES ROAD
RE: BLACK & DECKER WWTP
MILLERSVILLE, MD 21108

Order Number: L5157134
Project Name: BLACK & DECKER WWTP
Receive Date: 07-15-2014
Client Code: MES_A
Project Location: BLACK & DECKER WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No: Inv. No: MES_AL0341
PWSID No:

Sample ID Sample Description Samp. Date/Time/Temp Sampled by
L5157134-1 BLACK & DECKER 101 07/08/14 09:45am NA C Customer
Received Date/Time 07/15/14 09:00am

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY							
E. Coli, MPN Cel(Delaware)	9.9		MPN/100ml	SM 9221F			07/08/14 02:38PM SUB

Sample Comments:

L5157134-1 :
E. coli was analyzed by Chesapeake Environmental Lab, Inc in Stevensville, MD.



PIN: 17237

Serial Number: 3821787

QC Laboratories

Analytical Report

Printed 08/18/14 15:25 DE36

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE A
 259 NAJOLES ROAD
 RE: BLACK & DECKER WWTP
 MILLERSVILLE, MD 21108

Order Number: L5159511
 Project Name: BLACK & DECKER WWTP
 Receive Date: 08-05-2014
 Client Code: MES_A
 Project Location: BLACK & DECKER WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
 Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID Sample Description Samp. Date/Time/Temp Sampled by
 L5159511-1 BTR 001 GRAB 08/05/14 09:15am NA C Customer
 Received Date/Time/Temp 08/05/14 04:30pm 2.4 C Iced (Y/N): Y

Satellite Received Temp 4.1 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

GENERAL CHEMISTRY

Hexane Ext. Material-HEM (oil+grease)	ND	5.00	mg/l	1664B HEM	1		08/07/14 06:35PM AGM
Total Suspended Solids (Delaware)	9.60	4.00	mg/l	SM 2540D	1		08/06/14 12:55PM MS3
Biochemical Oxygen Demand, 5 Day (DE)	7.00	2.00	mg/l	SM 5210B	1.5		08/06/14 10:25AM SKJ

GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES

1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		08/07/14 09:31PM JAD
Tetrachloroethene	ND	1.00	ug/l	EPA 624	1		08/07/14 09:31PM JAD
Trichloroethene	ND	1.00	ug/l	EPA 624	1		08/07/14 09:31PM JAD

Sample ID Sample Description Samp. Date/Time/Temp Sampled by
 L5159511-2 BTR 001 COMP 08/05/14 09:15am NA C Customer
 Received Date/Time/Temp 08/05/14 04:30pm 2.4 C Iced (Y/N): Y

Satellite Received Temp 4.1 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

PIN: 17237

Serial Number: 3949465

QC Laboratories

Analytical Report

Printed 08/05/14 10:42 DE36

CHERYL GRIFFIN
MARYLAND ENVIRONMENTAL SERVICE A
259 NAJILES ROAD
RE: BLACK & DECKER WWTP
MILLERSVILLE, MD 21108

Order Number: L5193315
Project Name: BLACK & DECKER WWTP
Receive Date: 08-04-2014
Client Code: MES_A
Project Location: BLACK & DECKER WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No: Inv. No: MES_AL0341
PWSID No:

Sample ID Sample Description Samp. Date/Time/Temp Sampled by
L5193315-1 BLACK & DECKER 101 07/22/14 09:10am NA C Customer
Received Date/Time 08/04/14 01:00pm

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY							
E. Coli, MPN Cel(Delaware)	<1.0		MPN/100ml	SM 9221F			07/22/14 02:45PM SUB

Sample Comments:

L5193315-1 :
E. coli was analyzed by Chesapeake Environmental Lab, Inc in Stevensville, MD.



PIN: 17237

Serial Number: 3902166

QC Laboratories

Analytical Report

Printed 09/04/14 16:56 DE36

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE A
 259 NAJILES ROAD
 RE: BLACK & DECKER WWTP
 MILLERSVILLE, MD 21108

Order Number: L5214985
 Project Name: BLACK & DECKER WWTP
 Receive Date: 08-26-2014
 Client Code: MES_A
 Project Location: BLACK & DECKER WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
 Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID L5214985-1 Sample Description BTR 201 QRTLY
 Received Date/Time/Temp 08/26/14 04:45pm 0.4 C Iced (Y/N): Y
 Smp. Date/Time/Temp Sampled by 08/26/14 09:03am NA C Customer

Satellite Received Temp 2.3 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES							
1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,1,2,2-Tetrachloroethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,1,2-Trichloroethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,1-Dichloroethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,1-Dichloroethene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,2-Dichlorobenzene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,2-Dichloroethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,2-Dichloropropane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,3-Dichlorobenzene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,4-Dichlorobenzene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
2-Chloroethyl vinyl ether	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Benzene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Bromodichloromethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Bromoform	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Bromomethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Carbon tetrachloride	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Chlorobenzene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Chloroethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Chloroform	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Chloromethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
cis-1,3-Dichloropropene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Dibromochloromethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Ethylbenzene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Methylene chloride	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Tetrachloroethene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Toluene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
trans-1,2-Dichloroethene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
trans-1,3-Dichloropropene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Trichloroethene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD

PIN: 17237

Serial Number: 4006097

QC Laboratories

Analytical Report

Printed 09/04/14 16:56

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample ID Sample Description
L5214985-1 BTR 201 QRTLY

Samp. Date/Time/Temp Sampled by
08/26/14 09:03am NA C Customer

Received Date/Time/Temp 08/26/14 04:45pm 0.4 C Iced (Y/N): Y

Satellite Received Temp 2.3 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES continued

Trichlorofluoromethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Vinyl chloride	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD



PIN: 17237

Serial Number: 4006097

QC Laboratories

Analytical Report

Printed 09/10/14 12:56 DE36

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE A
 259 NAJOLAS ROAD
 RE: BLACK & DECKER WWTP
 MILLERSVILLE, MD 21108

Order Number: L5203439
 Project Name: BLACK & DECKER WWTP
 Receive Date: 09-03-2014
 Client Code: MES_A
 Project Location: BLACK & DECKER WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
 Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID L5203439-1 Sample Description BTR 001 GRAB
 Received Date/Time/Temp 09/03/14 04:30pm 4.7 C Iced (Y/N): Y
 Samp. Date/Time/Temp Sampled by 09/03/14 09:50am NA C Customer
 Satellite Received Temp 3.3 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
GENERAL CHEMISTRY							
Hexane Ext. Material-HEM (oil+grease)	ND	5.00	mg/l	1664B HEM	1		09/08/14 04:00PM RSK
Total Suspended Solids (Delaware)	4.80	4.00	mg/l	SM 2540D	1		09/04/14 01:25PM MS3
Biochemical Oxygen Demand, 5 Day (DE)	5.00	2.00	mg/l	SM 5210B	1.5		09/04/14 10:30AM SKJ
GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES							
1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		09/06/14 04:39AM JAD
Tetrachloroethene	ND	1.00	ug/l	EPA 624	1		09/06/14 04:39AM JAD
Trichloroethene	ND	1.00	ug/l	EPA 624	1		09/06/14 04:39AM JAD

Sample ID L5203439-2 Sample Description BTR 001 COMP
 Received Date/Time/Temp 09/03/14 04:30pm 4.7 C Iced (Y/N): Y
 Satellite Received Temp 3.3 C Iced (Y/N): Y

Samp. Date/Time/Temp Sampled by 09/03/14 09:50am NA C Customer

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

PIN: 17237

Serial Number: 4018385

QC Laboratories

Analytical Report

Printed 09/18/14 11:28 DE36

CHERYL GRIFFIN
MARYLAND ENVIRONMENTAL SERVICE A
259 NAJOLES ROAD
RE: BLACK & DECKER WWTP
MILLERSVILLE, MD 21108

Order Number: L5246047
Project Name: BLACK & DECKER WWTP
Receive Date: 09-16-2014
Client Code: MES_A
Project Location: BLACK & DECKER WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID	Sample Description	Samp. Date/Time/Temp Sampled by				
L5246047-1	BLACK & DECKER 101 Received Date/Time 09/16/14 11:30am	09/03/14 09:08am NA C Customer				
Parameter	Result	RL	Units	Method	DF	Qual Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY						
E. Coll, MPN Cel(Delaware)	<1.0		MPN/100ml	SM 9221F		09/03/14 02:46PM SUB

Sample Comments:

L5246047-1 :
E. coll was analyzed by Chesapeake Environmental Lab, Inc in Stevensville, MD.



PIN: 17237

Serial Number: 4045325

**APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(AUGUST 2014)**

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.
TestAmerica Chicago
2417 Bond Street
University Park, IL 60484
Tel: (708)534-5200

TestAmerica Job ID: 500-83243-1
Client Project/Site: Black and Decker

For:
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, Pennsylvania 19380

Attn: Mr. Tom Cornuet



Authorized for release by:
9/8/2014 1:21:14 PM

Richard Wright, Senior Project Manager
(708)534-5200
richard.wright@testamericainc.com

LINKS

Review your project
results through

Total Access

Have a Question?

Ask
The
Expert

Visit us at:

www.testamericainc.com

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

Table of Contents

Cover Page	1
Table of Contents	2
Case Narrative	3
Detection Summary	4
Method Summary	8
Sample Summary	9
Client Sample Results	10
Definitions	62
QC Association	63
Surrogate Summary	64
QC Sample Results	65
Chronicle	78
Certification Summary	83
Chain of Custody	84
Receipt Checklists	87



Case Narrative

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Job ID: 500-83243-1

Laboratory: TestAmerica Chicago

Narrative

Job Narrative
500-83243-1

Comments

No additional comments.

Receipt

The samples were received on 8/29/2014 10:30 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 3.4° C.

GC/MS VOA

Method(s) 8260B: The laboratory control sample (LCS) for batch 25282 recovered outside control limits for the following analytes: Chloroethane. These analytes were biased high in the LCS and were not detected in the associated samples; therefore, the data have been reported.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-83243-1

No Detections.

Client Sample ID: RFW-1B

Lab Sample ID: 500-83243-2

No Detections.

Client Sample ID: RFW-2A

Lab Sample ID: 500-83243-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.26	J	0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-2B

Lab Sample ID: 500-83243-4

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.33	J	0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-3B

Lab Sample ID: 500-83243-5

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloroethane	1.6		1.0	0.34	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	1.2		1.0	0.12	ug/L	1		8260B	Total/NA
Tetrachloroethene	0.71	J	1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-4A

Lab Sample ID: 500-83243-6

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.94	J	1.0	0.12	ug/L	1		8260B	Total/NA
Chloroform	0.55	J	1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	34		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	28		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-4A Dup

Lab Sample ID: 500-83243-7

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.92	J	1.0	0.12	ug/L	1		8260B	Total/NA
Chloroform	0.53	J	1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	33		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	28		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-4B

Lab Sample ID: 500-83243-8

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	3.0		1.0	0.12	ug/L	1		8260B	Total/NA
Chloroform	1.2		1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	48		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	84		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-6

Lab Sample ID: 500-83243-9

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.46	J	0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	0.72	J	1.0	0.17	ug/L	1		8260B	Total/NA

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-7

Lab Sample ID: 500-83243-10

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Benzene	0.20	J	0.50	0.074	ug/L	1		8260B	Total/NA
Trichloroethene	2.1		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-9

Lab Sample ID: 500-83243-11

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethene	0.63	J	1.0	0.31	ug/L	1		8260B	Total/NA
1,1-Dichloroethane	0.65	J	1.0	0.19	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	15		1.0	0.12	ug/L	1		8260B	Total/NA
1,1,1-Trichloroethane	0.60	J	1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	7.5		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	4.2		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-11B

Lab Sample ID: 500-83243-12

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	1.8		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-12B

Lab Sample ID: 500-83243-13

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	1.6		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	60		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	4.5		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-13

Lab Sample ID: 500-83243-14

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.67	J	1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	2.5		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	15		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-17

Lab Sample ID: 500-83243-15

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Benzene	0.62		0.50	0.074	ug/L	1		8260B	Total/NA

Client Sample ID: Trip Blank

Lab Sample ID: 500-83243-16

No Detections.

Client Sample ID: EW-2

Lab Sample ID: 500-83243-17

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	3.0		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	130		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	51		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-3

Lab Sample ID: 500-83243-18

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-3 (Continued)

Lab Sample ID: 500-83243-18

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	1.8		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	34		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	1.4		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-4

Lab Sample ID: 500-83243-19

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Tetrachloroethene	11		1.0	0.17	ug/L	1		8260B	Total/NA
Trichloroethene - DL	540		5.0	1.9	ug/L	10		8260B	Total/NA

Client Sample ID: EW-5

Lab Sample ID: 500-83243-20

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	100		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	3.6		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-6

Lab Sample ID: 500-83243-21

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	4.6		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	10		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-7

Lab Sample ID: 500-83243-22

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	2.9		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	2.0		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	5.1		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-8

Lab Sample ID: 500-83243-23

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethane	0.76	J	1.0	0.19	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	23		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	6.8		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	73		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-9

Lab Sample ID: 500-83243-24

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.43	J	0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	98		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-9 Dup

Lab Sample ID: 500-83243-25

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.49	J	0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	99		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-10

Lab Sample ID: 500-83243-26

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-10 (Continued)

Lab Sample ID: 500-83243-26

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Tetrachloroethene	2.0		1.0	0.17	ug/L	1		8260B	Total/NA

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Method Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Method	Method Description	Protocol	Laboratory
8260B	VOC	SW846	TAL CHI

Protocol References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200



Sample Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
500-83243-1	RFW-1A	Water	08/27/14 09:25	08/29/14 10:30
500-83243-2	RFW-1B	Water	08/27/14 16:55	08/29/14 10:30
500-83243-3	RFW-2A	Water	08/27/14 10:40	08/29/14 10:30
500-83243-4	RFW-2B	Water	08/27/14 10:50	08/29/14 10:30
500-83243-5	RFW-3B	Water	08/27/14 16:45	08/29/14 10:30
500-83243-6	RFW-4A	Water	08/28/14 08:45	08/29/14 10:30
500-83243-7	RFW-4A Dup	Water	08/28/14 08:45	08/29/14 10:30
500-83243-8	RFW-4B	Water	08/28/14 07:45	08/29/14 10:30
500-83243-9	RFW-6	Water	08/27/14 12:50	08/29/14 10:30
500-83243-10	RFW-7	Water	08/27/14 11:04	08/29/14 10:30
500-83243-11	RFW-9	Water	08/27/14 16:00	08/29/14 10:30
500-83243-12	RFW-11B	Water	08/28/14 10:40	08/29/14 10:30
500-83243-13	RFW-12B	Water	08/28/14 12:15	08/29/14 10:30
500-83243-14	RFW-13	Water	08/27/14 14:05	08/29/14 10:30
500-83243-15	RFW-17	Water	08/27/14 15:10	08/29/14 10:30
500-83243-16	Trip Blank	Water	08/27/14 06:00	08/29/14 10:30
500-83243-17	EW-2	Water	08/28/14 12:00	08/29/14 10:30
500-83243-18	EW-3	Water	08/28/14 10:30	08/29/14 10:30
500-83243-19	EW-4	Water	08/28/14 10:20	08/29/14 10:30
500-83243-20	EW-5	Water	08/27/14 09:35	08/29/14 10:30
500-83243-21	EW-6	Water	08/27/14 12:10	08/29/14 10:30
500-83243-22	EW-7	Water	08/27/14 12:15	08/29/14 10:30
500-83243-23	EW-8	Water	08/27/14 12:25	08/29/14 10:30
500-83243-24	EW-9	Water	08/27/14 12:40	08/29/14 10:30
500-83243-25	EW-9 Dup	Water	08/27/14 12:40	08/29/14 10:30
500-83243-26	EW-10	Water	08/27/14 12:50	08/29/14 10:30

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-83243-1

Date Collected: 08/27/14 09:25

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 04:47	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 04:47	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 04:47	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 04:47	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 04:47	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 04:47	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 04:47	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 04:47	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 04:47	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 04:47	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 04:47	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 04:47	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 04:47	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 04:47	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 04:47	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 04:47	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 04:47	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 04:47	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 04:47	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 04:47	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 04:47	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 04:47	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/04/14 04:47	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 04:47	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 04:47	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 04:47	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 04:47	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 04:47	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 04:47	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 04:47	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 04:47	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 04:47	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 04:47	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 04:47	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 04:47	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 04:47	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 04:47	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 04:47	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 04:47	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 04:47	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 04:47	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 04:47	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 04:47	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 04:47	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 04:47	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 04:47	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 04:47	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 04:47	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 04:47	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-83243-1

Date Collected: 08/27/14 09:25

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 04:47	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 04:47	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 04:47	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 04:47	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 04:47	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 04:47	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 04:47	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 04:47	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 04:47	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 04:47	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 04:47	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 04:47	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 04:47	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 04:47	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 04:47	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	105		75 - 125		09/04/14 04:47	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 04:47	1
4-Bromofluorobenzene (Surr)	84		75 - 120		09/04/14 04:47	1
Dibromofluoromethane	100		75 - 120		09/04/14 04:47	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-83243-2

Date Collected: 08/27/14 16:55

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 05:12	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 05:12	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 05:12	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 05:12	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 05:12	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 05:12	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 05:12	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 05:12	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 05:12	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 05:12	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 05:12	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 05:12	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 05:12	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 05:12	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 05:12	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 05:12	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 05:12	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 05:12	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 05:12	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 05:12	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 05:12	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 05:12	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/04/14 05:12	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 05:12	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 05:12	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 05:12	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 05:12	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 05:12	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 05:12	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 05:12	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 05:12	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 05:12	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 05:12	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 05:12	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 05:12	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 05:12	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:12	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 05:12	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 05:12	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 05:12	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 05:12	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 05:12	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 05:12	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:12	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 05:12	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 05:12	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 05:12	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 05:12	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 05:12	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-83243-2

Date Collected: 08/27/14 16:55

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 05:12	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 05:12	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:12	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:12	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 05:12	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 05:12	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 05:12	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 05:12	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 05:12	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 05:12	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 05:12	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 05:12	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 05:12	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 05:12	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 05:12	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	107		75 - 125		09/04/14 05:12	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 05:12	1
4-Bromofluorobenzene (Surr)	84		75 - 120		09/04/14 05:12	1
Dibromofluoromethane	99		75 - 120		09/04/14 05:12	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-83243-3

Date Collected: 08/27/14 10:40

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 05:37	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 05:37	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 05:37	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 05:37	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 05:37	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 05:37	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 05:37	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 05:37	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 05:37	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 05:37	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 05:37	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 05:37	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 05:37	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 05:37	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 05:37	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 05:37	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 05:37	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 05:37	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 05:37	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 05:37	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 05:37	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 05:37	1
Trichloroethene	0.26	J	0.50	0.19	ug/L			09/04/14 05:37	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 05:37	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 05:37	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 05:37	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 05:37	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 05:37	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 05:37	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 05:37	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 05:37	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 05:37	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 05:37	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 05:37	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 05:37	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 05:37	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:37	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 05:37	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 05:37	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 05:37	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 05:37	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 05:37	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 05:37	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:37	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 05:37	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 05:37	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 05:37	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 05:37	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 05:37	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-83243-3

Date Collected: 08/27/14 10:40

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 05:37	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 05:37	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:37	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:37	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 05:37	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 05:37	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 05:37	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 05:37	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 05:37	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 05:37	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 05:37	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 05:37	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 05:37	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 05:37	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 05:37	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		75 - 125		09/04/14 05:37	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 05:37	1
4-Bromofluorobenzene (Surr)	84		75 - 120		09/04/14 05:37	1
Dibromofluoromethane	99		75 - 120		09/04/14 05:37	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-83243-4

Date Collected: 08/27/14 10:50

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 06:02	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 06:02	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 06:02	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 06:02	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 06:02	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 06:02	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 06:02	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 06:02	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 06:02	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 06:02	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 06:02	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 06:02	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 06:02	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 06:02	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 06:02	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 06:02	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 06:02	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 06:02	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 06:02	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 06:02	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 06:02	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 06:02	1
Trichloroethene	0.33	J	0.50	0.19	ug/L			09/04/14 06:02	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 06:02	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 06:02	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 06:02	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 06:02	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 06:02	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 06:02	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 06:02	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 06:02	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 06:02	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 06:02	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 06:02	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 06:02	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 06:02	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:02	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 06:02	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 06:02	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 06:02	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 06:02	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 06:02	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 06:02	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:02	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 06:02	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 06:02	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 06:02	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 06:02	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 06:02	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-83243-4

Date Collected: 08/27/14 10:50

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 06:02	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 06:02	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:02	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:02	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:02	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:02	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 06:02	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:02	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 06:02	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 06:02	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 06:02	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 06:02	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 06:02	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 06:02	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 06:02	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		75 - 125		09/04/14 06:02	1
Toluene-d8 (Surr)	95		75 - 120		09/04/14 06:02	1
4-Bromofluorobenzene (Surr)	83		75 - 120		09/04/14 06:02	1
Dibromofluoromethane	99		75 - 120		09/04/14 06:02	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-83243-5

Date Collected: 08/27/14 16:45

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 06:27	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 06:27	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 06:27	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 06:27	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 06:27	1
Chloroethane	1.6		1.0	0.34	ug/L			09/04/14 06:27	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 06:27	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 06:27	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 06:27	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 06:27	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 06:27	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 06:27	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 06:27	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 06:27	1
cis-1,2-Dichloroethene	1.2		1.0	0.12	ug/L			09/04/14 06:27	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 06:27	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 06:27	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 06:27	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 06:27	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 06:27	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 06:27	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 06:27	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/04/14 06:27	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 06:27	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 06:27	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 06:27	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 06:27	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 06:27	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 06:27	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 06:27	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 06:27	1
Tetrachloroethene	0.71	J	1.0	0.17	ug/L			09/04/14 06:27	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 06:27	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 06:27	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 06:27	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 06:27	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:27	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 06:27	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 06:27	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 06:27	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 06:27	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 06:27	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 06:27	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:27	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 06:27	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 06:27	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 06:27	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 06:27	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 06:27	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-83243-5

Date Collected: 08/27/14 16:45

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 06:27	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 06:27	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:27	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:27	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:27	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:27	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 06:27	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:27	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 06:27	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 06:27	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 06:27	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 06:27	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 06:27	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 06:27	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 06:27	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		75 - 125		09/04/14 06:27	1
Toluene-d8 (Surr)	95		75 - 120		09/04/14 06:27	1
4-Bromofluorobenzene (Surr)	84		75 - 120		09/04/14 06:27	1
Dibromofluoromethane	99		75 - 120		09/04/14 06:27	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-4A

Lab Sample ID: 500-83243-6

Date Collected: 08/28/14 08:45

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 06:52	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 06:52	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 06:52	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 06:52	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 06:52	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 06:52	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 06:52	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 06:52	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 06:52	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 06:52	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 06:52	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 06:52	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 06:52	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 06:52	1
cis-1,2-Dichloroethene	0.94	J	1.0	0.12	ug/L			09/04/14 06:52	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 06:52	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 06:52	1
Chloroform	0.55	J	1.0	0.20	ug/L			09/04/14 06:52	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 06:52	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 06:52	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 06:52	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 06:52	1
Trichloroethene	34		0.50	0.19	ug/L			09/04/14 06:52	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 06:52	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 06:52	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 06:52	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 06:52	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 06:52	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 06:52	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 06:52	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 06:52	1
Tetrachloroethene	28		1.0	0.17	ug/L			09/04/14 06:52	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 06:52	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 06:52	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 06:52	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 06:52	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:52	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 06:52	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 06:52	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 06:52	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 06:52	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 06:52	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 06:52	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:52	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 06:52	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 06:52	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 06:52	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 06:52	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 06:52	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-4A

Lab Sample ID: 500-83243-6

Date Collected: 08/28/14 08:45

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 06:52	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 06:52	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:52	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:52	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:52	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:52	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 06:52	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:52	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 06:52	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 06:52	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 06:52	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 06:52	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 06:52	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 06:52	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 06:52	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	105		75 - 125					09/04/14 06:52	1
Toluene-d8 (Surr)	95		75 - 120					09/04/14 06:52	1
4-Bromofluorobenzene (Surr)	83		75 - 120					09/04/14 06:52	1
Dibromofluoromethane	99		75 - 120					09/04/14 06:52	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-4A Dup

Lab Sample ID: 500-83243-7

Date Collected: 08/28/14 08:45

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 07:17	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 07:17	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 07:17	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 07:17	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 07:17	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 07:17	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 07:17	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 07:17	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 07:17	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 07:17	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 07:17	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 07:17	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 07:17	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 07:17	1
cis-1,2-Dichloroethene	0.92	J	1.0	0.12	ug/L			09/04/14 07:17	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 07:17	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 07:17	1
Chloroform	0.53	J	1.0	0.20	ug/L			09/04/14 07:17	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 07:17	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 07:17	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 07:17	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 07:17	1
Trichloroethene	33		0.50	0.19	ug/L			09/04/14 07:17	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 07:17	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 07:17	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 07:17	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 07:17	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 07:17	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 07:17	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 07:17	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 07:17	1
Tetrachloroethene	28		1.0	0.17	ug/L			09/04/14 07:17	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 07:17	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 07:17	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 07:17	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 07:17	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 07:17	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 07:17	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 07:17	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 07:17	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 07:17	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 07:17	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 07:17	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 07:17	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 07:17	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 07:17	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 07:17	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 07:17	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 07:17	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-4A Dup

Lab Sample ID: 500-83243-7

Date Collected: 08/28/14 08:45

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 07:17	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 07:17	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 07:17	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 07:17	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 07:17	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 07:17	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 07:17	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 07:17	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 07:17	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 07:17	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 07:17	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 07:17	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 07:17	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 07:17	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 07:17	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		75 - 125		09/04/14 07:17	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 07:17	1
4-Bromofluorobenzene (Surr)	83		75 - 120		09/04/14 07:17	1
Dibromofluoromethane	100		75 - 120		09/04/14 07:17	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-4B

Lab Sample ID: 500-83243-8

Date Collected: 08/28/14 07:45

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 13:29	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 13:29	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 13:29	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 13:29	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 13:29	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 13:29	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 13:29	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 13:29	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 13:29	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 13:29	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 13:29	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 13:29	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 13:29	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 13:29	1
cis-1,2-Dichloroethene	3.0		1.0	0.12	ug/L			09/04/14 13:29	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 13:29	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 13:29	1
Chloroform	1.2		1.0	0.20	ug/L			09/04/14 13:29	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 13:29	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 13:29	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 13:29	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 13:29	1
Trichloroethene	48		0.50	0.19	ug/L			09/04/14 13:29	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 13:29	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 13:29	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 13:29	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 13:29	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 13:29	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 13:29	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 13:29	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 13:29	1
Tetrachloroethene	84		1.0	0.17	ug/L			09/04/14 13:29	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 13:29	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 13:29	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 13:29	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 13:29	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:29	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 13:29	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 13:29	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 13:29	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 13:29	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 13:29	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 13:29	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:29	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 13:29	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 13:29	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 13:29	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 13:29	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 13:29	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-4B

Lab Sample ID: 500-83243-8

Date Collected: 08/28/14 07:45

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 13:29	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 13:29	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:29	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:29	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 13:29	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 13:29	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 13:29	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 13:29	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 13:29	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 13:29	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 13:29	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 13:29	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 13:29	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 13:29	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 13:29	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		75 - 125		09/04/14 13:29	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 13:29	1
4-Bromofluorobenzene (Surr)	84		75 - 120		09/04/14 13:29	1
Dibromofluoromethane	98		75 - 120		09/04/14 13:29	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-6

Lab Sample ID: 500-83243-9

Date Collected: 08/27/14 12:50

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 13:54	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 13:54	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 13:54	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 13:54	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 13:54	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 13:54	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 13:54	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 13:54	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 13:54	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 13:54	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 13:54	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 13:54	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 13:54	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 13:54	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 13:54	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 13:54	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 13:54	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 13:54	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 13:54	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 13:54	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 13:54	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 13:54	1
Trichloroethene	0.46	J	0.50	0.19	ug/L			09/04/14 13:54	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 13:54	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 13:54	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 13:54	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 13:54	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 13:54	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 13:54	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 13:54	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 13:54	1
Tetrachloroethene	0.72	J	1.0	0.17	ug/L			09/04/14 13:54	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 13:54	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 13:54	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 13:54	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 13:54	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:54	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 13:54	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 13:54	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 13:54	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 13:54	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 13:54	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 13:54	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:54	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 13:54	1
1,1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 13:54	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 13:54	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 13:54	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 13:54	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-6

Lab Sample ID: 500-83243-9

Date Collected: 08/27/14 12:50

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 13:54	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 13:54	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:54	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:54	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 13:54	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 13:54	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 13:54	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 13:54	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 13:54	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 13:54	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 13:54	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 13:54	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 13:54	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 13:54	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 13:54	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		75 - 125		09/04/14 13:54	1
Toluene-d8 (Surr)	95		75 - 120		09/04/14 13:54	1
4-Bromofluorobenzene (Surr)	86		75 - 120		09/04/14 13:54	1
Dibromofluoromethane	99		75 - 120		09/04/14 13:54	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-7

Lab Sample ID: 500-83243-10

Date Collected: 08/27/14 11:04

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	0.20	J	0.50	0.074	ug/L			09/04/14 14:19	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 14:19	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 14:19	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 14:19	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 14:19	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 14:19	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 14:19	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 14:19	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 14:19	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 14:19	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 14:19	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 14:19	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 14:19	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 14:19	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 14:19	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 14:19	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 14:19	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 14:19	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 14:19	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 14:19	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 14:19	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 14:19	1
Trichloroethene	2.1		0.50	0.19	ug/L			09/04/14 14:19	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 14:19	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 14:19	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 14:19	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 14:19	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 14:19	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 14:19	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 14:19	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 14:19	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 14:19	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 14:19	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 14:19	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 14:19	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 14:19	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:19	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 14:19	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 14:19	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 14:19	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 14:19	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 14:19	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 14:19	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:19	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 14:19	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 14:19	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 14:19	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 14:19	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 14:19	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-7

Lab Sample ID: 500-83243-10

Date Collected: 08/27/14 11:04

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 14:19	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 14:19	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:19	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:19	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 14:19	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 14:19	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 14:19	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 14:19	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 14:19	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 14:19	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 14:19	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 14:19	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 14:19	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 14:19	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 14:19	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		75 - 125		09/04/14 14:19	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 14:19	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 14:19	1
Dibromofluoromethane	99		75 - 120		09/04/14 14:19	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-9

Lab Sample ID: 500-83243-11

Date Collected: 08/27/14 16:00

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 14:44	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 14:44	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 14:44	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 14:44	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 14:44	1
Chloroethane	<1.0	*	1.0	0.34	ug/L			09/04/14 14:44	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 14:44	1
1,1-Dichloroethene	0.63	J	1.0	0.31	ug/L			09/04/14 14:44	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 14:44	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 14:44	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 14:44	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 14:44	1
1,1-Dichloroethane	0.65	J	1.0	0.19	ug/L			09/04/14 14:44	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 14:44	1
cis-1,2-Dichloroethene	15		1.0	0.12	ug/L			09/04/14 14:44	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 14:44	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 14:44	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 14:44	1
1,1,1-Trichloroethane	0.60	J	1.0	0.20	ug/L			09/04/14 14:44	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 14:44	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 14:44	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 14:44	1
Trichloroethene	7.5		0.50	0.19	ug/L			09/04/14 14:44	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 14:44	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 14:44	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 14:44	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 14:44	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 14:44	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 14:44	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 14:44	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 14:44	1
Tetrachloroethene	4.2		1.0	0.17	ug/L			09/04/14 14:44	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 14:44	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 14:44	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 14:44	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 14:44	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:44	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 14:44	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 14:44	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 14:44	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 14:44	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 14:44	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 14:44	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:44	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 14:44	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 14:44	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 14:44	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 14:44	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 14:44	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-9

Lab Sample ID: 500-83243-11

Date Collected: 08/27/14 16:00

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 14:44	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 14:44	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:44	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:44	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 14:44	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 14:44	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 14:44	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 14:44	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 14:44	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 14:44	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 14:44	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 14:44	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 14:44	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 14:44	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 14:44	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	103		75 - 125		09/04/14 14:44	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 14:44	1
4-Bromofluorobenzene (Surr)	86		75 - 120		09/04/14 14:44	1
Dibromofluoromethane	98		75 - 120		09/04/14 14:44	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-11B

Lab Sample ID: 500-83243-12

Date Collected: 08/28/14 10:40

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 15:09	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 15:09	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 15:09	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 15:09	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 15:09	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 15:09	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 15:09	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 15:09	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 15:09	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 15:09	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 15:09	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 15:09	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 15:09	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 15:09	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 15:09	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 15:09	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 15:09	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 15:09	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 15:09	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 15:09	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 15:09	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 15:09	1
Trichloroethene	1.8		0.50	0.19	ug/L			09/04/14 15:09	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 15:09	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 15:09	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 15:09	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 15:09	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 15:09	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 15:09	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 15:09	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 15:09	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 15:09	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 15:09	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 15:09	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 15:09	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 15:09	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:09	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 15:09	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 15:09	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 15:09	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 15:09	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 15:09	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 15:09	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:09	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 15:09	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 15:09	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 15:09	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 15:09	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 15:09	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-11B

Lab Sample ID: 500-83243-12

Date Collected: 08/28/14 10:40

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 15:09	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 15:09	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:09	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:09	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:09	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:09	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 15:09	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:09	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 15:09	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 15:09	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 15:09	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 15:09	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 15:09	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 15:09	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 15:09	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		75 - 125		09/04/14 15:09	1
Toluene-d8 (Surr)	95		75 - 120		09/04/14 15:09	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 15:09	1
Dibromofluoromethane	99		75 - 120		09/04/14 15:09	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-12B

Lab Sample ID: 500-83243-13

Date Collected: 08/28/14 12:15

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 15:34	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 15:34	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 15:34	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 15:34	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 15:34	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 15:34	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 15:34	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 15:34	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 15:34	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 15:34	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 15:34	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 15:34	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 15:34	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 15:34	1
cis-1,2-Dichloroethene	1.6		1.0	0.12	ug/L			09/04/14 15:34	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 15:34	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 15:34	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 15:34	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 15:34	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 15:34	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 15:34	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 15:34	1
Trichloroethene	60		0.50	0.19	ug/L			09/04/14 15:34	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 15:34	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 15:34	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 15:34	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 15:34	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 15:34	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 15:34	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 15:34	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 15:34	1
Tetrachloroethene	4.5		1.0	0.17	ug/L			09/04/14 15:34	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 15:34	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 15:34	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 15:34	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 15:34	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:34	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 15:34	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 15:34	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 15:34	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 15:34	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 15:34	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 15:34	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:34	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 15:34	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 15:34	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 15:34	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 15:34	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 15:34	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-12B

Lab Sample ID: 500-83243-13

Date Collected: 08/28/14 12:15

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 15:34	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 15:34	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:34	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:34	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:34	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:34	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 15:34	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:34	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 15:34	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 15:34	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 15:34	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 15:34	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 15:34	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 15:34	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 15:34	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		75 - 125		09/04/14 15:34	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 15:34	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 15:34	1
Dibromofluoromethane	98		75 - 120		09/04/14 15:34	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-13

Lab Sample ID: 500-83243-14

Date Collected: 08/27/14 14:05

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 15:58	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 15:58	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 15:58	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 15:58	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 15:58	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 15:58	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 15:58	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 15:58	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 15:58	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 15:58	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 15:58	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 15:58	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 15:58	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 15:58	1
cis-1,2-Dichloroethene	0.67	J	1.0	0.12	ug/L			09/04/14 15:58	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 15:58	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 15:58	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 15:58	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 15:58	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 15:58	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 15:58	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 15:58	1
Trichloroethene	2.5		0.50	0.19	ug/L			09/04/14 15:58	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 15:58	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 15:58	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 15:58	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 15:58	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 15:58	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 15:58	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 15:58	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 15:58	1
Tetrachloroethene	15		1.0	0.17	ug/L			09/04/14 15:58	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 15:58	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 15:58	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 15:58	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 15:58	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:58	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 15:58	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 15:58	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 15:58	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 15:58	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 15:58	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 15:58	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:58	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 15:58	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 15:58	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 15:58	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 15:58	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 15:58	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-13

Lab Sample ID: 500-83243-14

Date Collected: 08/27/14 14:05

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 15:58	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 15:58	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:58	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:58	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:58	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:58	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 15:58	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:58	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 15:58	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 15:58	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 15:58	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 15:58	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 15:58	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 15:58	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 15:58	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	103		75 - 125		09/04/14 15:58	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 15:58	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 15:58	1
Dibromofluoromethane	97		75 - 120		09/04/14 15:58	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-17

Lab Sample ID: 500-83243-15

Date Collected: 08/27/14 15:10

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	0.62		0.50	0.074	ug/L			09/04/14 16:23	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 16:23	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 16:23	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 16:23	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 16:23	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 16:23	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 16:23	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 16:23	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 16:23	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 16:23	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 16:23	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 16:23	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 16:23	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 16:23	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 16:23	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 16:23	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 16:23	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 16:23	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 16:23	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 16:23	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 16:23	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 16:23	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/04/14 16:23	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 16:23	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 16:23	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 16:23	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 16:23	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 16:23	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 16:23	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 16:23	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 16:23	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 16:23	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 16:23	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 16:23	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 16:23	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 16:23	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:23	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 16:23	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 16:23	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 16:23	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 16:23	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 16:23	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 16:23	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:23	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 16:23	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 16:23	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 16:23	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 16:23	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 16:23	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-17

Lab Sample ID: 500-83243-15

Date Collected: 08/27/14 15:10

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 16:23	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 16:23	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:23	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:23	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 16:23	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 16:23	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 16:23	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 16:23	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 16:23	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 16:23	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 16:23	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 16:23	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 16:23	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 16:23	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 16:23	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	105		75 - 125		09/04/14 16:23	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 16:23	1
4-Bromofluorobenzene (Surr)	84		75 - 120		09/04/14 16:23	1
Dibromofluoromethane	99		75 - 120		09/04/14 16:23	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: Trip Blank

Lab Sample ID: 500-83243-16

Date Collected: 08/27/14 06:00

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 16:48	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 16:48	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 16:48	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 16:48	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 16:48	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 16:48	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 16:48	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 16:48	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 16:48	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 16:48	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 16:48	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 16:48	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 16:48	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 16:48	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 16:48	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 16:48	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 16:48	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 16:48	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 16:48	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 16:48	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 16:48	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 16:48	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/04/14 16:48	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 16:48	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 16:48	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 16:48	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 16:48	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 16:48	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 16:48	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 16:48	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 16:48	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 16:48	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 16:48	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 16:48	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 16:48	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 16:48	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:48	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 16:48	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 16:48	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 16:48	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 16:48	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 16:48	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 16:48	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:48	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 16:48	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 16:48	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 16:48	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 16:48	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 16:48	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: Trip Blank

Lab Sample ID: 500-83243-16

Date Collected: 08/27/14 06:00

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 16:48	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 16:48	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:48	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:48	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 16:48	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 16:48	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 16:48	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 16:48	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 16:48	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 16:48	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 16:48	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 16:48	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 16:48	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 16:48	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 16:48	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	105		75 - 125		09/04/14 16:48	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 16:48	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 16:48	1
Dibromofluoromethane	99		75 - 120		09/04/14 16:48	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-2

Lab Sample ID: 500-83243-17

Date Collected: 08/28/14 12:00

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 17:13	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 17:13	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 17:13	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 17:13	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 17:13	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 17:13	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 17:13	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 17:13	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 17:13	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 17:13	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 17:13	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 17:13	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 17:13	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 17:13	1
cis-1,2-Dichloroethene	3.0		1.0	0.12	ug/L			09/04/14 17:13	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 17:13	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 17:13	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 17:13	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 17:13	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 17:13	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 17:13	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 17:13	1
Trichloroethene	130		0.50	0.19	ug/L			09/04/14 17:13	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 17:13	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 17:13	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 17:13	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 17:13	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 17:13	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 17:13	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 17:13	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 17:13	1
Tetrachloroethene	51		1.0	0.17	ug/L			09/04/14 17:13	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 17:13	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 17:13	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 17:13	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 17:13	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 17:13	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 17:13	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 17:13	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 17:13	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 17:13	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 17:13	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 17:13	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 17:13	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 17:13	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 17:13	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 17:13	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 17:13	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 17:13	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-2

Lab Sample ID: 500-83243-17

Date Collected: 08/28/14 12:00

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 17:13	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 17:13	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 17:13	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 17:13	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 17:13	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 17:13	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 17:13	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 17:13	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 17:13	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 17:13	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 17:13	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 17:13	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 17:13	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 17:13	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 17:13	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	105		75 - 125		09/04/14 17:13	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 17:13	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 17:13	1
Dibromofluoromethane	98		75 - 120		09/04/14 17:13	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-3

Lab Sample ID: 500-83243-18

Date Collected: 08/28/14 10:30

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 17:38	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 17:38	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 17:38	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 17:38	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 17:38	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 17:38	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 17:38	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 17:38	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 17:38	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 17:38	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 17:38	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 17:38	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 17:38	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 17:38	1
cis-1,2-Dichloroethene	1.8		1.0	0.12	ug/L			09/04/14 17:38	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 17:38	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 17:38	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 17:38	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 17:38	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 17:38	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 17:38	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 17:38	1
Trichloroethene	34		0.50	0.19	ug/L			09/04/14 17:38	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 17:38	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 17:38	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 17:38	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 17:38	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 17:38	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 17:38	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 17:38	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 17:38	1
Tetrachloroethene	1.4		1.0	0.17	ug/L			09/04/14 17:38	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 17:38	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 17:38	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 17:38	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 17:38	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 17:38	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 17:38	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 17:38	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 17:38	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 17:38	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 17:38	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 17:38	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 17:38	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 17:38	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 17:38	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 17:38	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 17:38	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 17:38	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-3

Lab Sample ID: 500-83243-18

Date Collected: 08/28/14 10:30

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 17:38	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 17:38	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 17:38	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 17:38	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 17:38	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 17:38	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 17:38	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 17:38	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 17:38	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 17:38	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 17:38	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 17:38	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 17:38	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 17:38	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 17:38	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		75 - 125		09/04/14 17:38	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 17:38	1
4-Bromofluorobenzene (Sum)	84		75 - 120		09/04/14 17:38	1
Dibromofluoromethane	101		75 - 120		09/04/14 17:38	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-4

Lab Sample ID: 500-83243-19

Date Collected: 08/28/14 10:20

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 18:03	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 18:03	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 18:03	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 18:03	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 18:03	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 18:03	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 18:03	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 18:03	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 18:03	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 18:03	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 18:03	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 18:03	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 18:03	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 18:03	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 18:03	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 18:03	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 18:03	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 18:03	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 18:03	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 18:03	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 18:03	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 18:03	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 18:03	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 18:03	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 18:03	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 18:03	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 18:03	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 18:03	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 18:03	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 18:03	1
Tetrachloroethene	11		1.0	0.17	ug/L			09/04/14 18:03	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 18:03	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 18:03	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 18:03	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 18:03	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 18:03	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 18:03	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 18:03	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 18:03	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 18:03	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 18:03	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 18:03	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 18:03	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 18:03	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 18:03	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 18:03	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 18:03	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 18:03	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 18:03	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-4

Lab Sample ID: 500-83243-19

Date Collected: 08/28/14 10:20

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 18:03	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 18:03	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 18:03	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 18:03	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 18:03	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 18:03	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 18:03	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 18:03	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 18:03	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 18:03	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 18:03	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 18:03	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 18:03	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 18:03	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		75 - 125		09/04/14 18:03	1
Toluene-d8 (Surr)	95		75 - 120		09/04/14 18:03	1
4-Bromofluorobenzene (Surr)	84		75 - 120		09/04/14 18:03	1
Dibromofluoromethane	98		75 - 120		09/04/14 18:03	1

Method: 8260B - VOC - DL

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Trichloroethene	540		5.0	1.9	ug/L			09/04/14 18:28	10

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		75 - 125		09/04/14 18:28	10
Toluene-d8 (Surr)	95		75 - 120		09/04/14 18:28	10
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 18:28	10
Dibromofluoromethane	100		75 - 120		09/04/14 18:28	10

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-5

Lab Sample ID: 500-83243-20

Date Collected: 08/27/14 09:35

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 18:53	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 18:53	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 18:53	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 18:53	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 18:53	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 18:53	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 18:53	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 18:53	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 18:53	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 18:53	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 18:53	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 18:53	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 18:53	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 18:53	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 18:53	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 18:53	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 18:53	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 18:53	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 18:53	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 18:53	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 18:53	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 18:53	1
Trichloroethene	100		0.50	0.19	ug/L			09/04/14 18:53	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 18:53	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 18:53	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 18:53	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 18:53	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 18:53	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 18:53	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 18:53	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 18:53	1
Tetrachloroethene	3.6		1.0	0.17	ug/L			09/04/14 18:53	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 18:53	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 18:53	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 18:53	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 18:53	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 18:53	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 18:53	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 18:53	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 18:53	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 18:53	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 18:53	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 18:53	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 18:53	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 18:53	1
1,1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 18:53	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 18:53	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 18:53	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 18:53	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-5

Lab Sample ID: 500-83243-20

Date Collected: 08/27/14 09:35

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 18:53	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 18:53	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 18:53	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 18:53	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 18:53	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 18:53	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 18:53	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 18:53	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 18:53	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 18:53	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 18:53	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 18:53	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 18:53	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 18:53	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 18:53	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		75 - 125		09/04/14 18:53	1
Toluene-d8 (Surr)	95		75 - 120		09/04/14 18:53	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 18:53	1
Dibromofluoromethane	99		75 - 120		09/04/14 18:53	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-6

Lab Sample ID: 500-83243-21

Date Collected: 08/27/14 12:10

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 19:18	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 19:18	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 19:18	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 19:18	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 19:18	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 19:18	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 19:18	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 19:18	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 19:18	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 19:18	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 19:18	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 19:18	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 19:18	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 19:18	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 19:18	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 19:18	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 19:18	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 19:18	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 19:18	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 19:18	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 19:18	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 19:18	1
Trichloroethene	4.6		0.50	0.19	ug/L			09/04/14 19:18	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 19:18	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 19:18	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 19:18	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 19:18	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 19:18	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 19:18	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 19:18	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 19:18	1
Tetrachloroethene	10		1.0	0.17	ug/L			09/04/14 19:18	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 19:18	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 19:18	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 19:18	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 19:18	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 19:18	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 19:18	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 19:18	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 19:18	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 19:18	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 19:18	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 19:18	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 19:18	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 19:18	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 19:18	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 19:18	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 19:18	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 19:18	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-6

Lab Sample ID: 500-83243-21

Date Collected: 08/27/14 12:10

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 19:18	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 19:18	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 19:18	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 19:18	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 19:18	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 19:18	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 19:18	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 19:18	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 19:18	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 19:18	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 19:18	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 19:18	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 19:18	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 19:18	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 19:18	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	107		75 - 125		09/04/14 19:18	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 19:18	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 19:18	1
Dibromofluoromethane	100		75 - 120		09/04/14 19:18	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-7

Lab Sample ID: 500-83243-22

Date Collected: 08/27/14 12:15

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 19:43	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 19:43	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 19:43	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 19:43	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 19:43	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 19:43	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 19:43	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 19:43	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 19:43	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 19:43	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 19:43	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 19:43	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 19:43	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 19:43	1
cis-1,2-Dichloroethene	2.9		1.0	0.12	ug/L			09/04/14 19:43	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 19:43	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 19:43	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 19:43	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 19:43	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 19:43	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 19:43	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 19:43	1
Trichloroethene	2.0		0.50	0.19	ug/L			09/04/14 19:43	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 19:43	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 19:43	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 19:43	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 19:43	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 19:43	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 19:43	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 19:43	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 19:43	1
Tetrachloroethene	5.1		1.0	0.17	ug/L			09/04/14 19:43	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 19:43	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 19:43	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 19:43	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 19:43	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 19:43	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 19:43	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 19:43	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 19:43	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 19:43	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 19:43	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 19:43	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 19:43	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 19:43	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 19:43	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 19:43	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 19:43	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 19:43	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-7

Lab Sample ID: 500-83243-22

Date Collected: 08/27/14 12:15

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 19:43	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 19:43	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 19:43	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 19:43	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 19:43	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 19:43	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 19:43	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 19:43	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 19:43	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 19:43	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 19:43	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 19:43	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 19:43	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 19:43	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 19:43	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	105		75 - 125		09/04/14 19:43	1
Toluene-d8 (Surr)	95		75 - 120		09/04/14 19:43	1
4-Bromofluorobenzene (Surr)	84		75 - 120		09/04/14 19:43	1
Dibromofluoromethane	99		75 - 120		09/04/14 19:43	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-8

Lab Sample ID: 500-83243-23

Date Collected: 08/27/14 12:25

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 23:36	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 23:36	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 23:36	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 23:36	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 23:36	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 23:36	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 23:36	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 23:36	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 23:36	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 23:36	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 23:36	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 23:36	1
1,1-Dichloroethane	0.76	J	1.0	0.19	ug/L			09/04/14 23:36	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 23:36	1
cis-1,2-Dichloroethene	23		1.0	0.12	ug/L			09/04/14 23:36	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 23:36	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 23:36	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 23:36	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 23:36	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 23:36	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 23:36	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 23:36	1
Trichloroethene	6.8		0.50	0.19	ug/L			09/04/14 23:36	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 23:36	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 23:36	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 23:36	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 23:36	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 23:36	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 23:36	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 23:36	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 23:36	1
Tetrachloroethene	73		1.0	0.17	ug/L			09/04/14 23:36	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 23:36	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 23:36	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 23:36	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 23:36	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 23:36	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 23:36	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 23:36	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 23:36	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 23:36	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 23:36	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 23:36	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 23:36	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 23:36	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 23:36	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 23:36	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 23:36	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 23:36	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-8

Lab Sample ID: 500-83243-23

Date Collected: 08/27/14 12:25

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 23:36	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 23:36	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 23:36	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 23:36	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 23:36	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 23:36	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 23:36	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 23:36	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 23:36	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 23:36	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 23:36	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 23:36	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 23:36	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 23:36	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 23:36	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	100		75 - 125		09/04/14 23:36	1
Toluene-d8 (Surr)	95		75 - 120		09/04/14 23:36	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 23:36	1
Dibromofluoromethane	97		75 - 120		09/04/14 23:36	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-9

Lab Sample ID: 500-83243-24

Date Collected: 08/27/14 12:40

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/05/14 00:01	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/05/14 00:01	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/05/14 00:01	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/05/14 00:01	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/05/14 00:01	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/05/14 00:01	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/05/14 00:01	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/05/14 00:01	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/05/14 00:01	1
Acetone	<5.0		5.0	1.3	ug/L			09/05/14 00:01	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/05/14 00:01	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/05/14 00:01	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/05/14 00:01	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/05/14 00:01	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/05/14 00:01	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/05/14 00:01	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/05/14 00:01	1
Chloroform	<1.0		1.0	0.20	ug/L			09/05/14 00:01	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/05/14 00:01	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/05/14 00:01	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/05/14 00:01	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/05/14 00:01	1
Trichloroethene	0.43	J	0.50	0.19	ug/L			09/05/14 00:01	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/05/14 00:01	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/05/14 00:01	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/05/14 00:01	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/05/14 00:01	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/05/14 00:01	1
Toluene	<0.50		0.50	0.11	ug/L			09/05/14 00:01	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/05/14 00:01	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/05/14 00:01	1
Tetrachloroethene	98		1.0	0.17	ug/L			09/05/14 00:01	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/05/14 00:01	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/05/14 00:01	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/05/14 00:01	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/05/14 00:01	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/05/14 00:01	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/05/14 00:01	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/05/14 00:01	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/05/14 00:01	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/05/14 00:01	1
Styrene	<1.0		1.0	0.10	ug/L			09/05/14 00:01	1
Bromoform	<1.0		1.0	0.28	ug/L			09/05/14 00:01	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/05/14 00:01	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/05/14 00:01	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/05/14 00:01	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/05/14 00:01	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/05/14 00:01	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/05/14 00:01	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-9

Lab Sample ID: 500-83243-24

Date Collected: 08/27/14 12:40

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/05/14 00:01	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/05/14 00:01	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/05/14 00:01	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/05/14 00:01	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/05/14 00:01	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/05/14 00:01	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/05/14 00:01	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/05/14 00:01	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/05/14 00:01	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/05/14 00:01	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/05/14 00:01	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/05/14 00:01	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/05/14 00:01	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/05/14 00:01	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/05/14 00:01	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		75 - 125		09/05/14 00:01	1
Toluene-d8 (Surr)	96		75 - 120		09/05/14 00:01	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/05/14 00:01	1
Dibromofluoromethane	97		75 - 120		09/05/14 00:01	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-9 Dup

Lab Sample ID: 500-83243-25

Date Collected: 08/27/14 12:40

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/05/14 00:26	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/05/14 00:26	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/05/14 00:26	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/05/14 00:26	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/05/14 00:26	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/05/14 00:26	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/05/14 00:26	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/05/14 00:26	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/05/14 00:26	1
Acetone	<5.0		5.0	1.3	ug/L			09/05/14 00:26	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/05/14 00:26	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/05/14 00:26	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/05/14 00:26	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/05/14 00:26	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/05/14 00:26	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/05/14 00:26	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/05/14 00:26	1
Chloroform	<1.0		1.0	0.20	ug/L			09/05/14 00:26	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/05/14 00:26	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/05/14 00:26	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/05/14 00:26	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/05/14 00:26	1
Trichloroethene	0.49	J	0.50	0.19	ug/L			09/05/14 00:26	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/05/14 00:26	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/05/14 00:26	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/05/14 00:26	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/05/14 00:26	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/05/14 00:26	1
Toluene	<0.50		0.50	0.11	ug/L			09/05/14 00:26	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/05/14 00:26	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/05/14 00:26	1
Tetrachloroethene	99		1.0	0.17	ug/L			09/05/14 00:26	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/05/14 00:26	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/05/14 00:26	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/05/14 00:26	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/05/14 00:26	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/05/14 00:26	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/05/14 00:26	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/05/14 00:26	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/05/14 00:26	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/05/14 00:26	1
Styrene	<1.0		1.0	0.10	ug/L			09/05/14 00:26	1
Bromoform	<1.0		1.0	0.28	ug/L			09/05/14 00:26	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/05/14 00:26	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/05/14 00:26	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/05/14 00:26	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/05/14 00:26	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/05/14 00:26	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/05/14 00:26	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-9 Dup

Lab Sample ID: 500-83243-25

Date Collected: 08/27/14 12:40

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/05/14 00:26	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/05/14 00:26	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/05/14 00:26	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/05/14 00:26	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/05/14 00:26	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/05/14 00:26	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/05/14 00:26	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/05/14 00:26	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/05/14 00:26	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/05/14 00:26	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/05/14 00:26	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/05/14 00:26	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/05/14 00:26	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/05/14 00:26	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/05/14 00:26	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		75 - 125		09/05/14 00:26	1
Toluene-d8 (Surr)	95		75 - 120		09/05/14 00:26	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/05/14 00:26	1
Dibromofluoromethane	98		75 - 120		09/05/14 00:26	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-10

Lab Sample ID: 500-83243-26

Date Collected: 08/27/14 12:50

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/05/14 00:51	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/05/14 00:51	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/05/14 00:51	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/05/14 00:51	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/05/14 00:51	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/05/14 00:51	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/05/14 00:51	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/05/14 00:51	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/05/14 00:51	1
Acetone	<5.0		5.0	1.3	ug/L			09/05/14 00:51	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/05/14 00:51	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/05/14 00:51	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/05/14 00:51	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/05/14 00:51	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/05/14 00:51	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/05/14 00:51	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/05/14 00:51	1
Chloroform	<1.0		1.0	0.20	ug/L			09/05/14 00:51	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/05/14 00:51	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/05/14 00:51	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/05/14 00:51	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/05/14 00:51	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/05/14 00:51	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/05/14 00:51	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/05/14 00:51	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/05/14 00:51	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/05/14 00:51	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/05/14 00:51	1
Toluene	<0.50		0.50	0.11	ug/L			09/05/14 00:51	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/05/14 00:51	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/05/14 00:51	1
Tetrachloroethene	2.0		1.0	0.17	ug/L			09/05/14 00:51	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/05/14 00:51	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/05/14 00:51	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/05/14 00:51	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/05/14 00:51	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/05/14 00:51	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/05/14 00:51	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/05/14 00:51	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/05/14 00:51	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/05/14 00:51	1
Styrene	<1.0		1.0	0.10	ug/L			09/05/14 00:51	1
Bromoform	<1.0		1.0	0.28	ug/L			09/05/14 00:51	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/05/14 00:51	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/05/14 00:51	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/05/14 00:51	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/05/14 00:51	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/05/14 00:51	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/05/14 00:51	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-10

Lab Sample ID: 500-83243-26

Date Collected: 08/27/14 12:50

Matrix: Water

Date Received: 08/29/14 10:30

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/05/14 00:51	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/05/14 00:51	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/05/14 00:51	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/05/14 00:51	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/05/14 00:51	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/05/14 00:51	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/05/14 00:51	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/05/14 00:51	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/05/14 00:51	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/05/14 00:51	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/05/14 00:51	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/05/14 00:51	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/05/14 00:51	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/05/14 00:51	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/05/14 00:51	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	103		75 - 125		09/05/14 00:51	1
Toluene-d8 (Surr)	96		75 - 120		09/05/14 00:51	1
4-Bromofluorobenzene (Surr)	83		75 - 120		09/05/14 00:51	1
Dibromofluoromethane	99		75 - 120		09/05/14 00:51	1

Definitions/Glossary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Qualifiers

GC/MS VOA

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
*	LCS or LCSD exceeds the control limits

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
▫	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CNF	Contains no Free Liquid
DER	Duplicate error ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision level concentration
MDA	Minimum detectable activity
EDL	Estimated Detection Limit
MDC	Minimum detectable concentration
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
NC	Not Calculated
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative error ratio
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

QC Association Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

GC/MS VOA

Analysis Batch: 252749

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-83243-1	RFW-1A	Total/NA	Water	8260B	
500-83243-2	RFW-1B	Total/NA	Water	8260B	
500-83243-3	RFW-2A	Total/NA	Water	8260B	
500-83243-4	RFW-2B	Total/NA	Water	8260B	
500-83243-5	RFW-3B	Total/NA	Water	8260B	
500-83243-6	RFW-4A	Total/NA	Water	8260B	
500-83243-7	RFW-4A Dup	Total/NA	Water	8260B	
LCS 500-252749/4	Lab Control Sample	Total/NA	Water	8260B	
MB 500-252749/6	Method Blank	Total/NA	Water	8260B	

Analysis Batch: 252882

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-83243-8	RFW-4B	Total/NA	Water	8260B	
500-83243-9	RFW-6	Total/NA	Water	8260B	
500-83243-10	RFW-7	Total/NA	Water	8260B	
500-83243-11	RFW-9	Total/NA	Water	8260B	
500-83243-12	RFW-11B	Total/NA	Water	8260B	
500-83243-13	RFW-12B	Total/NA	Water	8260B	
500-83243-14	RFW-13	Total/NA	Water	8260B	
500-83243-15	RFW-17	Total/NA	Water	8260B	
500-83243-16	Trip Blank	Total/NA	Water	8260B	
500-83243-17	EW-2	Total/NA	Water	8260B	
500-83243-18	EW-3	Total/NA	Water	8260B	
500-83243-19	EW-4	Total/NA	Water	8260B	
500-83243-19 - DL	EW-4	Total/NA	Water	8260B	
500-83243-20	EW-5	Total/NA	Water	8260B	
500-83243-21	EW-6	Total/NA	Water	8260B	
500-83243-22	EW-7	Total/NA	Water	8260B	
500-83243-22 MS	EW-7	Total/NA	Water	8260B	
500-83243-22 MSD	EW-7	Total/NA	Water	8260B	
LCS 500-252882/4	Lab Control Sample	Total/NA	Water	8260B	
MB 500-252882/6	Method Blank	Total/NA	Water	8260B	

Analysis Batch: 252958

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-83243-23	EW-8	Total/NA	Water	8260B	
500-83243-24	EW-9	Total/NA	Water	8260B	
500-83243-25	EW-9 Dup	Total/NA	Water	8260B	
500-83243-26	EW-10	Total/NA	Water	8260B	
LCS 500-252958/4	Lab Control Sample	Total/NA	Water	8260B	
MB 500-252958/6	Method Blank	Total/NA	Water	8260B	

Surrogate Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Method: 8260B - VOC

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		12DCE (75-125)	TOL (75-120)	BFB (75-120)	DBFM (75-120)
500-83243-1	RFW-1A	105	96	84	100
500-83243-2	RFW-1B	107	96	84	99
500-83243-3	RFW-2A	106	96	84	99
500-83243-4	RFW-2B	104	95	83	99
500-83243-5	RFW-3B	104	95	84	99
500-83243-6	RFW-4A	105	95	83	99
500-83243-7	RFW-4A Dup	102	96	83	100
500-83243-8	RFW-4B	102	96	84	98
500-83243-9	RFW-6	104	95	86	99
500-83243-10	RFW-7	104	96	85	99
500-83243-11	RFW-9	103	96	86	98
500-83243-12	RFW-11B	104	95	85	99
500-83243-13	RFW-12B	106	96	85	98
500-83243-14	RFW-13	103	96	85	97
500-83243-15	RFW-17	105	96	84	99
500-83243-16	Trip Blank	105	96	85	99
500-83243-17	EW-2	105	96	85	98
500-83243-18	EW-3	106	96	84	101
500-83243-19	EW-4	106	95	84	98
500-83243-19 - DL	EW-4	106	95	85	100
500-83243-20	EW-5	104	95	85	99
500-83243-21	EW-6	107	96	85	100
500-83243-22	EW-7	105	95	84	99
500-83243-22 MS	EW-7	102	95	89	97
500-83243-22 MSD	EW-7	104	95	90	97
500-83243-23	EW-8	100	95	85	97
500-83243-24	EW-9	104	96	85	97
500-83243-25	EW-9 Dup	104	95	85	98
500-83243-26	EW-10	103	96	83	99
LCS 500-252749/4	Lab Control Sample	99	96	91	96
LCS 500-252882/4	Lab Control Sample	100	95	91	95
LCS 500-252958/4	Lab Control Sample	100	95	90	96
MB 500-252749/6	Method Blank	102	96	86	97
MB 500-252882/6	Method Blank	103	95	85	97
MB 500-252958/6	Method Blank	103	96	84	99

Surrogate Legend

- 12DCE = 1,2-Dichloroethane-d4 (Surr)
- TOL = Toluene-d8 (Surr)
- BFB = 4-Bromofluorobenzene (Surr)
- DBFM = Dibromofluoromethane

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Method: 8260B - VOC

Lab Sample ID: MB 500-252749/6

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 252749

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Benzene	<0.50		0.50	0.074	ug/L			09/03/14 23:25	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/03/14 23:25	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/03/14 23:25	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/03/14 23:25	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/03/14 23:25	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/03/14 23:25	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/03/14 23:25	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/03/14 23:25	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/03/14 23:25	1
Acetone	<5.0		5.0	1.3	ug/L			09/03/14 23:25	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/03/14 23:25	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/03/14 23:25	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/03/14 23:25	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/03/14 23:25	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/03/14 23:25	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/03/14 23:25	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/03/14 23:25	1
Chloroform	<1.0		1.0	0.20	ug/L			09/03/14 23:25	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/03/14 23:25	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/03/14 23:25	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/03/14 23:25	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/03/14 23:25	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/03/14 23:25	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/03/14 23:25	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/03/14 23:25	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/03/14 23:25	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/03/14 23:25	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/03/14 23:25	1
Toluene	<0.50		0.50	0.11	ug/L			09/03/14 23:25	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/03/14 23:25	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/03/14 23:25	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/03/14 23:25	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/03/14 23:25	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/03/14 23:25	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/03/14 23:25	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/03/14 23:25	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/03/14 23:25	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/03/14 23:25	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/03/14 23:25	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/03/14 23:25	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/03/14 23:25	1
Styrene	<1.0		1.0	0.10	ug/L			09/03/14 23:25	1
Bromoform	<1.0		1.0	0.28	ug/L			09/03/14 23:25	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/03/14 23:25	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/03/14 23:25	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/03/14 23:25	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/03/14 23:25	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/03/14 23:25	1

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Method: 8260B - VOC (Continued)

Lab Sample ID: MB 500-252749/6

Matrix: Water

Analysis Batch: 252749

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/03/14 23:25	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/03/14 23:25	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/03/14 23:25	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/03/14 23:25	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/03/14 23:25	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/03/14 23:25	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/14 23:25	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/03/14 23:25	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/03/14 23:25	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/03/14 23:25	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/03/14 23:25	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/03/14 23:25	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/03/14 23:25	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/03/14 23:25	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/03/14 23:25	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/03/14 23:25	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
1,2-Dichloroethane-d4 (Surr)	102		75 - 125		09/03/14 23:25	1
Toluene-d8 (Surr)	96		75 - 120		09/03/14 23:25	1
4-Bromofluorobenzene (Surr)	86		75 - 120		09/03/14 23:25	1
Dibromofluoromethane	97		75 - 120		09/03/14 23:25	1

Lab Sample ID: LCS 500-252749/4

Matrix: Water

Analysis Batch: 252749

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Dichlorodifluoromethane	50.0	64.2		ug/L		128	41 - 146
Chloromethane	50.0	50.5		ug/L		101	63 - 133
Vinyl chloride	50.0	54.2		ug/L		108	72 - 123
Bromomethane	50.0	62.9		ug/L		126	45 - 169
Chloroethane	50.0	52.1		ug/L		104	58 - 147
Trichlorofluoromethane	50.0	58.5		ug/L		117	71 - 130
1,1-Dichloroethene	50.0	49.6		ug/L		99	69 - 120
Carbon disulfide	50.0	46.9		ug/L		94	56 - 130
Acetone	50.0	45.3		ug/L		91	48 - 149
Methylene Chloride	50.0	48.1		ug/L		96	73 - 130
trans-1,2-Dichloroethene	50.0	50.5		ug/L		101	77 - 120
1,1-Dichloroethane	50.0	53.8		ug/L		108	75 - 120
2,2-Dichloropropane	50.0	48.5		ug/L		97	65 - 132
cis-1,2-Dichloroethene	50.0	50.4		ug/L		101	75 - 120
Methyl Ethyl Ketone	50.0	45.8		ug/L		92	53 - 142
Bromochloromethane	50.0	50.5		ug/L		101	76 - 120
Chloroform	50.0	49.6		ug/L		99	76 - 120
1,1,1-Trichloroethane	50.0	54.2		ug/L		108	72 - 130
1,1-Dichloropropene	50.0	53.7		ug/L		107	75 - 130

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-252749/4

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 252749

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Carbon tetrachloride	50.0	59.6		ug/L		119	70 - 130
1,2-Dichloroethane	50.0	54.4		ug/L		109	69 - 130
Trichloroethene	50.0	53.7		ug/L		107	75 - 120
1,2-Dichloropropane	50.0	52.9		ug/L		106	75 - 120
Dibromomethane	50.0	49.3		ug/L		99	75 - 120
Bromodichloromethane	50.0	50.5		ug/L		101	77 - 121
cis-1,3-Dichloropropene	50.0	47.7		ug/L		95	78 - 130
methyl isobutyl ketone	50.0	43.4		ug/L		87	58 - 135
Toluene	50.0	50.9		ug/L		102	75 - 120
trans-1,3-Dichloropropene	50.0	48.1		ug/L		96	74 - 130
1,1,2-Trichloroethane	50.0	49.5		ug/L		99	75 - 120
Tetrachloroethene	50.0	56.3		ug/L		113	75 - 120
1,3-Dichloropropane	50.0	49.5		ug/L		99	77 - 124
2-Hexanone	50.0	42.9		ug/L		86	55 - 140
Dibromochloromethane	50.0	52.2		ug/L		104	71 - 126
1,2-Dibromoethane	50.0	49.3		ug/L		99	78 - 122
Chlorobenzene	50.0	52.2		ug/L		104	75 - 120
1,1,1,2-Tetrachloroethane	50.0	54.2		ug/L		108	75 - 122
Ethylbenzene	50.0	56.4		ug/L		113	75 - 120
m&p-Xylene	50.0	53.3		ug/L		107	75 - 120
o-Xylene	50.0	53.5		ug/L		107	75 - 120
Styrene	50.0	54.2		ug/L		108	75 - 120
Bromoform	50.0	55.1		ug/L		110	68 - 126
Isopropylbenzene	50.0	57.2		ug/L		114	75 - 121
Bromobenzene	50.0	56.1		ug/L		112	75 - 120
1,1,2,2-Tetrachloroethane	50.0	48.6		ug/L		97	72 - 130
1,2,3-Trichloropropane	50.0	43.2		ug/L		86	65 - 132
N-Propylbenzene	50.0	56.0		ug/L		112	75 - 120
2-Chlorotoluene	50.0	53.5		ug/L		107	75 - 120
1,3,5-Trimethylbenzene	50.0	56.9		ug/L		114	75 - 121
4-Chlorotoluene	50.0	54.5		ug/L		109	75 - 120
tert-Butylbenzene	50.0	59.7		ug/L		119	75 - 123
1,2,4-Trimethylbenzene	50.0	56.4		ug/L		113	75 - 121
sec-Butylbenzene	50.0	58.1		ug/L		116	75 - 120
1,3-Dichlorobenzene	50.0	53.5		ug/L		107	75 - 120
p-Isopropyltoluene	50.0	59.9		ug/L		120	75 - 121
1,4-Dichlorobenzene	50.0	52.9		ug/L		106	75 - 120
n-Butylbenzene	50.0	55.7		ug/L		111	75 - 121
1,2-Dichlorobenzene	50.0	53.1		ug/L		106	75 - 120
1,2-Dibromo-3-Chloropropane	50.0	48.4		ug/L		97	62 - 130
1,2,4-Trichlorobenzene	50.0	48.9		ug/L		98	73 - 130
Hexachlorobutadiene	50.0	60.4		ug/L		121	71 - 131
Naphthalene	50.0	44.9		ug/L		90	69 - 135
1,2,3-Trichlorobenzene	50.0	47.7		ug/L		95	69 - 131

Surrogate	LCS LCS		Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	99		75 - 125
Toluene-d8 (Surr)	96		75 - 120

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-252749/4

Matrix: Water

Analysis Batch: 252749

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Surrogate	LCS %Recovery	LCS Qualifier	Limits
4-Bromofluorobenzene (Surr)	91		75 - 120
Dibromofluoromethane	96		75 - 120

Lab Sample ID: MB 500-252882/6

Matrix: Water

Analysis Batch: 252882

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 10:36	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 10:36	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 10:36	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 10:36	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 10:36	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 10:36	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 10:36	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 10:36	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 10:36	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 10:36	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 10:36	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 10:36	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 10:36	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 10:36	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 10:36	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 10:36	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 10:36	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 10:36	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 10:36	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 10:36	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 10:36	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 10:36	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/04/14 10:36	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 10:36	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 10:36	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 10:36	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 10:36	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 10:36	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 10:36	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 10:36	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 10:36	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 10:36	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 10:36	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 10:36	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 10:36	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 10:36	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 10:36	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 10:36	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 10:36	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 10:36	1

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Method: 8260B - VOC (Continued)

Lab Sample ID: MB 500-252882/6
Matrix: Water
Analysis Batch: 252882

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 10:36	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 10:36	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 10:36	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 10:36	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 10:36	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 10:36	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 10:36	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 10:36	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 10:36	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 10:36	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 10:36	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 10:36	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 10:36	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 10:36	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 10:36	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 10:36	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 10:36	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 10:36	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 10:36	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 10:36	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 10:36	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 10:36	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 10:36	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 10:36	1

Surrogate	MB MB		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
1,2-Dichloroethane-d4 (Surr)	103		75 - 125		09/04/14 10:36	1
Toluene-d8 (Surr)	95		75 - 120		09/04/14 10:36	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 10:36	1
Dibromofluoromethane	97		75 - 120		09/04/14 10:36	1

Lab Sample ID: LCS 500-252882/4
Matrix: Water
Analysis Batch: 252882

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS LCS		Unit	D	%Rec	%Rec. Limits
		Result	Qualifier				
Benzene	50.0	45.8		ug/L		92	75 - 120
Dichlorodifluoromethane	50.0	59.1		ug/L		118	41 - 146
Chloromethane	50.0	46.9		ug/L		94	63 - 133
Vinyl chloride	50.0	50.3		ug/L		101	72 - 123
Bromomethane	50.0	62.0		ug/L		124	45 - 169
Chloroethane	50.0	75.2		ug/L		150	58 - 147
Trichlorofluoromethane	50.0	53.3		ug/L		107	71 - 130
1,1-Dichloroethene	50.0	44.6		ug/L		89	69 - 120
Carbon disulfide	50.0	42.2		ug/L		84	56 - 130
Acetone	50.0	48.9		ug/L		98	48 - 149
Methylene Chloride	50.0	43.2		ug/L		86	73 - 130
trans-1,2-Dichloroethene	50.0	46.1		ug/L		92	77 - 120

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-252882/4

Matrix: Water

Analysis Batch: 252882

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
1,1-Dichloroethane	50.0	49.7		ug/L		99	75 - 120
2,2-Dichloropropane	50.0	45.2		ug/L		90	65 - 132
cis-1,2-Dichloroethene	50.0	45.7		ug/L		91	75 - 120
Methyl Ethyl Ketone	50.0	44.8		ug/L		90	53 - 142
Bromochloromethane	50.0	46.8		ug/L		94	76 - 120
Chloroform	50.0	45.3		ug/L		91	76 - 120
1,1,1-Trichloroethane	50.0	49.4		ug/L		99	72 - 130
1,1-Dichloropropene	50.0	49.2		ug/L		98	75 - 130
Carbon tetrachloride	50.0	54.1		ug/L		108	70 - 130
1,2-Dichloroethane	50.0	51.2		ug/L		102	69 - 130
Trichloroethene	50.0	49.5		ug/L		99	75 - 120
1,2-Dichloropropane	50.0	48.7		ug/L		97	75 - 120
Dibromomethane	50.0	45.4		ug/L		91	75 - 120
Bromodichloromethane	50.0	46.0		ug/L		92	77 - 121
cis-1,3-Dichloropropene	50.0	44.4		ug/L		89	78 - 130
methyl isobutyl ketone	50.0	40.6		ug/L		81	58 - 135
Toluene	50.0	46.7		ug/L		93	75 - 120
trans-1,3-Dichloropropene	50.0	44.7		ug/L		89	74 - 130
1,1,2-Trichloroethane	50.0	45.3		ug/L		91	75 - 120
Tetrachloroethene	50.0	51.9		ug/L		104	75 - 120
1,3-Dichloropropane	50.0	45.8		ug/L		92	77 - 124
2-Hexanone	50.0	40.7		ug/L		81	55 - 140
Dibromochloromethane	50.0	47.7		ug/L		95	71 - 126
1,2-Dibromoethane	50.0	46.0		ug/L		92	78 - 122
Chlorobenzene	50.0	48.2		ug/L		96	75 - 120
1,1,1,2-Tetrachloroethane	50.0	49.7		ug/L		99	75 - 122
Ethylbenzene	50.0	52.3		ug/L		105	75 - 120
m&p-Xylene	50.0	49.6		ug/L		99	75 - 120
o-Xylene	50.0	48.9		ug/L		98	75 - 120
Styrene	50.0	49.7		ug/L		99	75 - 120
Bromoform	50.0	50.1		ug/L		100	68 - 126
Isopropylbenzene	50.0	50.0		ug/L		100	75 - 121
Bromobenzene	50.0	49.4		ug/L		99	75 - 120
1,1,2,2-Tetrachloroethane	50.0	43.4		ug/L		87	72 - 130
1,2,3-Trichloropropane	50.0	37.9		ug/L		76	65 - 132
N-Propylbenzene	50.0	49.8		ug/L		100	75 - 120
2-Chlorotoluene	50.0	47.6		ug/L		95	75 - 120
1,3,5-Trimethylbenzene	50.0	50.7		ug/L		101	75 - 121
4-Chlorotoluene	50.0	49.2		ug/L		98	75 - 120
tert-Butylbenzene	50.0	51.4		ug/L		103	75 - 123
1,2,4-Trimethylbenzene	50.0	50.2		ug/L		100	75 - 121
sec-Butylbenzene	50.0	51.2		ug/L		102	75 - 120
1,3-Dichlorobenzene	50.0	48.5		ug/L		97	75 - 120
p-Isopropyltoluene	50.0	53.2		ug/L		106	75 - 121
1,4-Dichlorobenzene	50.0	47.9		ug/L		96	75 - 120
n-Butylbenzene	50.0	50.6		ug/L		101	75 - 121
1,2-Dichlorobenzene	50.0	47.7		ug/L		95	75 - 120
1,2-Dibromo-3-Chloropropane	50.0	42.0		ug/L		84	62 - 130

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-252882/4

Matrix: Water

Analysis Batch: 252882

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
1,2,4-Trichlorobenzene	50.0	47.0		ug/L		94	73 - 130
Hexachlorobutadiene	50.0	54.4		ug/L		109	71 - 131
Naphthalene	50.0	40.9		ug/L		82	69 - 135
1,2,3-Trichlorobenzene	50.0	45.6		ug/L		91	69 - 131

Surrogate	LCS %Recovery	LCS Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	100		75 - 125
Toluene-d8 (Surr)	95		75 - 120
4-Bromofluorobenzene (Surr)	91		75 - 120
Dibromofluoromethane	95		75 - 120

Lab Sample ID: 500-83243-22 MS

Matrix: Water

Analysis Batch: 252882

Client Sample ID: EW-7

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Benzene	<0.50		50.0	45.2		ug/L		90	75 - 120
Dichlorodifluoromethane	<1.0		50.0	58.8		ug/L		118	41 - 146
Chloromethane	<1.0		50.0	47.0		ug/L		94	63 - 133
Vinyl chloride	<0.50		50.0	49.9		ug/L		100	72 - 123
Bromomethane	<1.0		50.0	54.8		ug/L		110	45 - 169
Chloroethane	<1.0		50.0	60.6		ug/L		121	58 - 147
Trichlorofluoromethane	<1.0		50.0	53.6		ug/L		107	71 - 130
1,1-Dichloroethene	<1.0		50.0	44.0		ug/L		88	69 - 120
Carbon disulfide	<5.0		50.0	41.4		ug/L		83	56 - 130
Acetone	<5.0		50.0	43.1		ug/L		86	48 - 149
Methylene Chloride	<5.0		50.0	43.0		ug/L		86	73 - 130
trans-1,2-Dichloroethene	<1.0		50.0	45.0		ug/L		90	77 - 120
1,1-Dichloroethane	<1.0		50.0	49.2		ug/L		98	75 - 120
2,2-Dichloropropane	<1.0		50.0	42.9		ug/L		86	65 - 132
cis-1,2-Dichloroethene	2.9		50.0	48.6		ug/L		91	75 - 120
Methyl Ethyl Ketone	<5.0		50.0	43.0		ug/L		86	53 - 142
Bromochloromethane	<1.0		50.0	45.6		ug/L		91	76 - 120
Chloroform	<1.0		50.0	45.1		ug/L		90	76 - 120
1,1,1-Trichloroethane	<1.0		50.0	48.6		ug/L		97	72 - 130
1,1-Dichloropropene	<1.0		50.0	47.9		ug/L		96	75 - 130
Carbon tetrachloride	<1.0		50.0	53.1		ug/L		106	70 - 130
1,2-Dichloroethane	<1.0		50.0	51.0		ug/L		102	69 - 130
Trichloroethene	2.0		50.0	50.4		ug/L		97	75 - 120
1,2-Dichloropropane	<1.0		50.0	48.1		ug/L		96	75 - 120
Dibromomethane	<1.0		50.0	45.6		ug/L		91	75 - 120
Bromodichloromethane	<1.0		50.0	46.4		ug/L		93	77 - 121
cis-1,3-Dichloropropene	<1.0		50.0	42.6		ug/L		85	78 - 130
methyl isobutyl ketone	<5.0		50.0	42.6		ug/L		85	58 - 135
Toluene	<0.50		50.0	45.5		ug/L		91	75 - 120
trans-1,3-Dichloropropene	<1.0		50.0	42.6		ug/L		85	74 - 130
1,1,2-Trichloroethane	<1.0		50.0	44.7		ug/L		89	75 - 120
Tetrachloroethene	5.1		50.0	53.9		ug/L		97	75 - 120

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Method: 8260B - VOC (Continued)

Lab Sample ID: 500-83243-22 MS

Matrix: Water

Analysis Batch: 252882

Client Sample ID: EW-7

Prep Type: Total/NA

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec.
	Result	Qualifier	Added	Result	Qualifier				Limits
1,3-Dichloropropane	<1.0		50.0	45.5		ug/L		91	77 - 124
2-Hexanone	<5.0		50.0	40.7		ug/L		81	55 - 140
Dibromochloromethane	<1.0		50.0	47.3		ug/L		95	71 - 126
1,2-Dibromoethane	<1.0		50.0	46.1		ug/L		92	78 - 122
Chlorobenzene	<1.0		50.0	46.8		ug/L		94	75 - 120
1,1,1,2-Tetrachloroethane	<1.0		50.0	49.5		ug/L		99	75 - 122
Ethylbenzene	<0.50		50.0	50.3		ug/L		101	75 - 120
m&p-Xylene	<1.0		50.0	47.2		ug/L		94	75 - 120
o-Xylene	<0.50		50.0	47.5		ug/L		95	75 - 120
Styrene	<1.0		50.0	47.9		ug/L		96	75 - 120
Bromoform	<1.0		50.0	50.4		ug/L		101	68 - 126
Isopropylbenzene	<1.0		50.0	50.2		ug/L		100	75 - 121
Bromobenzene	<1.0		50.0	50.1		ug/L		100	75 - 120
1,1,2,2-Tetrachloroethane	<1.0		50.0	45.8		ug/L		92	72 - 130
1,2,3-Trichloropropane	<1.0		50.0	39.8		ug/L		80	65 - 132
N-Propylbenzene	<1.0		50.0	49.2		ug/L		98	75 - 120
2-Chlorotoluene	<1.0		50.0	47.5		ug/L		95	75 - 120
1,3,5-Trimethylbenzene	<1.0		50.0	50.6		ug/L		101	75 - 121
4-Chlorotoluene	<1.0		50.0	48.6		ug/L		97	75 - 120
tert-Butylbenzene	<1.0		50.0	52.4		ug/L		105	75 - 123
1,2,4-Trimethylbenzene	<1.0		50.0	49.9		ug/L		100	75 - 121
sec-Butylbenzene	<1.0		50.0	51.3		ug/L		103	75 - 120
1,3-Dichlorobenzene	<1.0		50.0	48.3		ug/L		97	75 - 120
p-Isopropyltoluene	<1.0		50.0	52.3		ug/L		105	75 - 121
1,4-Dichlorobenzene	<1.0		50.0	47.6		ug/L		95	75 - 120
n-Butylbenzene	<1.0		50.0	47.5		ug/L		95	75 - 121
1,2-Dichlorobenzene	<1.0		50.0	48.5		ug/L		97	75 - 120
1,2-Dibromo-3-Chloropropane	<2.0		50.0	45.5		ug/L		91	62 - 130
1,2,4-Trichlorobenzene	<1.0		50.0	42.2		ug/L		84	73 - 130
Hexachlorobutadiene	<1.0		50.0	52.8		ug/L		106	71 - 131
Naphthalene	<1.0		50.0	40.1		ug/L		80	69 - 135
1,2,3-Trichlorobenzene	<1.0		50.0	43.8		ug/L		88	69 - 131

Surrogate	MS	MS	Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	102		75 - 125
Toluene-d8 (Surr)	95		75 - 120
4-Bromofluorobenzene (Surr)	89		75 - 120
Dibromofluoromethane	97		75 - 120

Lab Sample ID: 500-83243-22 MSD

Matrix: Water

Analysis Batch: 252882

Client Sample ID: EW-7

Prep Type: Total/NA

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec.	RPD	
	Result	Qualifier	Added	Result	Qualifier				Limits	RPD	Limit
Benzene	<0.50		50.0	43.9		ug/L		88	75 - 120	3	20
Dichlorodifluoromethane	<1.0		50.0	58.1		ug/L		116	41 - 146	1	20
Chloromethane	<1.0		50.0	46.2		ug/L		92	63 - 133	2	20
Vinyl chloride	<0.50		50.0	49.6		ug/L		99	72 - 123	1	20

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Method: 8260B - VOC (Continued)

Lab Sample ID: 500-83243-22 MSD

Client Sample ID: EW-7

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 252882

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec.	RPD	RPD
	Result	Qualifier	Added	Result	Qualifier				Limits		Limit
Bromomethane	<1.0		50.0	55.9		ug/L		112	45 - 169	2	20
Chloroethane	<1.0		50.0	63.1		ug/L		126	58 - 147	4	20
Trichlorofluoromethane	<1.0		50.0	53.2		ug/L		106	71 - 130	1	20
1,1-Dichloroethene	<1.0		50.0	42.4		ug/L		85	69 - 120	4	20
Carbon disulfide	<5.0		50.0	39.9		ug/L		80	56 - 130	4	20
Acetone	<5.0		50.0	43.4		ug/L		87	48 - 149	1	20
Methylene Chloride	<5.0		50.0	41.6		ug/L		83	73 - 130	3	20
trans-1,2-Dichloroethene	<1.0		50.0	44.1		ug/L		88	77 - 120	2	20
1,1-Dichloroethane	<1.0		50.0	47.8		ug/L		96	75 - 120	3	20
2,2-Dichloropropane	<1.0		50.0	41.5		ug/L		83	65 - 132	3	20
cis-1,2-Dichloroethene	2.9		50.0	47.7		ug/L		89	75 - 120	2	20
Methyl Ethyl Ketone	<5.0		50.0	42.7		ug/L		85	53 - 142	1	20
Bromochloromethane	<1.0		50.0	45.5		ug/L		91	76 - 120	0	20
Chloroform	<1.0		50.0	44.0		ug/L		88	76 - 120	3	20
1,1,1-Trichloroethane	<1.0		50.0	46.8		ug/L		94	72 - 130	4	20
1,1-Dichloropropene	<1.0		50.0	46.3		ug/L		93	75 - 130	3	20
Carbon tetrachloride	<1.0		50.0	51.6		ug/L		103	70 - 130	3	20
1,2-Dichloroethane	<1.0		50.0	49.9		ug/L		100	69 - 130	2	20
Trichloroethene	2.0		50.0	48.9		ug/L		94	75 - 120	3	20
1,2-Dichloropropane	<1.0		50.0	47.5		ug/L		95	75 - 120	1	20
Dibromomethane	<1.0		50.0	44.6		ug/L		89	75 - 120	2	20
Bromodichloromethane	<1.0		50.0	45.3		ug/L		91	77 - 121	2	20
cis-1,3-Dichloropropene	<1.0		50.0	42.3		ug/L		85	78 - 130	1	20
methyl isobutyl ketone	<5.0		50.0	41.5		ug/L		83	58 - 135	3	20
Toluene	<0.50		50.0	44.6		ug/L		89	75 - 120	2	20
trans-1,3-Dichloropropene	<1.0		50.0	43.1		ug/L		86	74 - 130	1	20
1,1,2-Trichloroethane	<1.0		50.0	46.4		ug/L		93	75 - 120	4	20
Tetrachloroethene	5.1		50.0	53.2		ug/L		96	75 - 120	1	20
1,3-Dichloropropane	<1.0		50.0	45.5		ug/L		91	77 - 124	0	20
2-Hexanone	<5.0		50.0	40.0		ug/L		80	55 - 140	2	20
Dibromochloromethane	<1.0		50.0	48.5		ug/L		97	71 - 126	3	20
1,2-Dibromoethane	<1.0		50.0	46.5		ug/L		93	78 - 122	1	20
Chlorobenzene	<1.0		50.0	46.6		ug/L		93	75 - 120	1	20
1,1,1,2-Tetrachloroethane	<1.0		50.0	49.1		ug/L		98	75 - 122	1	20
Ethylbenzene	<0.50		50.0	49.9		ug/L		100	75 - 120	1	20
m&p-Xylene	<1.0		50.0	47.2		ug/L		94	75 - 120	0	20
o-Xylene	<0.50		50.0	47.1		ug/L		94	75 - 120	1	20
Styrene	<1.0		50.0	47.3		ug/L		95	75 - 120	1	20
Bromoform	<1.0		50.0	51.1		ug/L		102	68 - 126	1	20
Isopropylbenzene	<1.0		50.0	49.7		ug/L		99	75 - 121	1	20
Bromobenzene	<1.0		50.0	50.8		ug/L		102	75 - 120	1	20
1,1,2,2-Tetrachloroethane	<1.0		50.0	47.1		ug/L		94	72 - 130	3	20
1,2,3-Trichloropropane	<1.0		50.0	40.4		ug/L		81	65 - 132	2	20
N-Propylbenzene	<1.0		50.0	48.6		ug/L		97	75 - 120	1	20
2-Chlorotoluene	<1.0		50.0	47.5		ug/L		95	75 - 120	0	20
1,3,5-Trimethylbenzene	<1.0		50.0	49.8		ug/L		100	75 - 121	2	20
4-Chlorotoluene	<1.0		50.0	48.2		ug/L		96	75 - 120	1	20
tert-Butylbenzene	<1.0		50.0	51.9		ug/L		104	75 - 123	1	20

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Method: 8260B - VOC (Continued)

Lab Sample ID: 500-83243-22 MSD

Matrix: Water

Analysis Batch: 252882

Client Sample ID: EW-7

Prep Type: Total/NA

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec.	RPD	RPD
	Result	Qualifier	Added	Result	Qualifier				Limits		Limit
1,2,4-Trimethylbenzene	<1.0		50.0	49.5		ug/L		99	75 - 121	1	20
sec-Butylbenzene	<1.0		50.0	50.5		ug/L		101	75 - 120	2	20
1,3-Dichlorobenzene	<1.0		50.0	47.8		ug/L		96	75 - 120	1	20
p-Isopropyltoluene	<1.0		50.0	51.7		ug/L		103	75 - 121	1	20
1,4-Dichlorobenzene	<1.0		50.0	47.6		ug/L		95	75 - 120	0	20
n-Butylbenzene	<1.0		50.0	47.4		ug/L		95	75 - 121	0	20
1,2-Dichlorobenzene	<1.0		50.0	48.5		ug/L		97	75 - 120	0	20
1,2-Dibromo-3-Chloropropane	<2.0		50.0	47.3		ug/L		95	62 - 130	4	20
1,2,4-Trichlorobenzene	<1.0		50.0	44.6		ug/L		89	73 - 130	6	20
Hexachlorobutadiene	<1.0		50.0	52.8		ug/L		106	71 - 131	0	20
Naphthalene	<1.0		50.0	44.2		ug/L		88	69 - 135	10	20
1,2,3-Trichlorobenzene	<1.0		50.0	46.8		ug/L		94	69 - 131	7	20

Surrogate	MSD	MSD	Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	104		75 - 125
Toluene-d8 (Surr)	95		75 - 120
4-Bromofluorobenzene (Surr)	90		75 - 120
Dibromofluoromethane	97		75 - 120

Lab Sample ID: MB 500-252958/6

Matrix: Water

Analysis Batch: 252958

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 23:11	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 23:11	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 23:11	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 23:11	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 23:11	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 23:11	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 23:11	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 23:11	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 23:11	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 23:11	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 23:11	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 23:11	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 23:11	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 23:11	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 23:11	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 23:11	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 23:11	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 23:11	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 23:11	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 23:11	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 23:11	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 23:11	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/04/14 23:11	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 23:11	1

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Method: 8260B - VOC (Continued)

Lab Sample ID: MB 500-252958/6
Matrix: Water
Analysis Batch: 252958

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 23:11	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 23:11	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 23:11	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 23:11	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 23:11	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 23:11	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 23:11	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 23:11	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 23:11	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 23:11	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 23:11	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 23:11	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 23:11	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 23:11	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 23:11	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 23:11	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 23:11	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 23:11	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 23:11	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 23:11	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 23:11	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 23:11	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 23:11	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 23:11	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 23:11	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 23:11	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 23:11	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 23:11	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 23:11	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 23:11	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 23:11	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 23:11	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 23:11	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 23:11	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 23:11	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 23:11	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 23:11	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 23:11	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 23:11	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 23:11	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
1,2-Dichloroethane-d4 (Surr)	103		75 - 125		09/04/14 23:11	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 23:11	1
4-Bromofluorobenzene (Surr)	84		75 - 120		09/04/14 23:11	1
Dibromofluoromethane	99		75 - 120		09/04/14 23:11	1

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-252958/4
Matrix: Water
Analysis Batch: 252958

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec.
	Added	Result	Qualifier				
Benzene	50.0	47.2		ug/L		94	75 - 120
Dichlorodifluoromethane	50.0	59.3		ug/L		119	41 - 146
Chloromethane	50.0	47.5		ug/L		95	63 - 133
Vinyl chloride	50.0	50.6		ug/L		101	72 - 123
Bromomethane	50.0	60.3		ug/L		121	45 - 169
Chloroethane	50.0	69.2		ug/L		138	58 - 147
Trichlorofluoromethane	50.0	53.8		ug/L		108	71 - 130
1,1-Dichloroethene	50.0	45.5		ug/L		91	69 - 120
Carbon disulfide	50.0	42.8		ug/L		86	56 - 130
Acetone	50.0	45.8		ug/L		92	48 - 149
Methylene Chloride	50.0	44.3		ug/L		89	73 - 130
trans-1,2-Dichloroethene	50.0	47.4		ug/L		95	77 - 120
1,1-Dichloroethane	50.0	51.6		ug/L		103	75 - 120
2,2-Dichloropropane	50.0	45.4		ug/L		91	65 - 132
cis-1,2-Dichloroethene	50.0	47.7		ug/L		95	75 - 120
Methyl Ethyl Ketone	50.0	45.2		ug/L		90	53 - 142
Bromochloromethane	50.0	48.7		ug/L		97	76 - 120
Chloroform	50.0	47.0		ug/L		94	76 - 120
1,1,1-Trichloroethane	50.0	50.7		ug/L		101	72 - 130
1,1-Dichloropropene	50.0	50.1		ug/L		100	75 - 130
Carbon tetrachloride	50.0	55.1		ug/L		110	70 - 130
1,2-Dichloroethane	50.0	52.4		ug/L		105	69 - 130
Trichloroethene	50.0	50.2		ug/L		100	75 - 120
1,2-Dichloropropane	50.0	50.9		ug/L		102	75 - 120
Dibromomethane	50.0	46.6		ug/L		93	75 - 120
Bromodichloromethane	50.0	48.2		ug/L		96	77 - 121
cis-1,3-Dichloropropene	50.0	45.5		ug/L		91	78 - 130
methyl isobutyl ketone	50.0	45.4		ug/L		91	58 - 135
Toluene	50.0	48.0		ug/L		96	75 - 120
trans-1,3-Dichloropropene	50.0	45.5		ug/L		91	74 - 130
1,1,2-Trichloroethane	50.0	47.0		ug/L		94	75 - 120
Tetrachloroethene	50.0	51.8		ug/L		104	75 - 120
1,3-Dichloropropane	50.0	47.5		ug/L		95	77 - 124
2-Hexanone	50.0	43.9		ug/L		88	55 - 140
Dibromochloromethane	50.0	49.4		ug/L		99	71 - 126
1,2-Dibromoethane	50.0	47.7		ug/L		95	78 - 122
Chlorobenzene	50.0	48.9		ug/L		98	75 - 120
1,1,1,2-Tetrachloroethane	50.0	51.1		ug/L		102	75 - 122
Ethylbenzene	50.0	53.1		ug/L		106	75 - 120
m&p-Xylene	50.0	49.9		ug/L		100	75 - 120
o-Xylene	50.0	49.7		ug/L		99	75 - 120
Styrene	50.0	49.9		ug/L		100	75 - 120
Bromoform	50.0	52.1		ug/L		104	68 - 126
Isopropylbenzene	50.0	52.5		ug/L		105	75 - 121
Bromobenzene	50.0	52.4		ug/L		105	75 - 120
1,1,2,2-Tetrachloroethane	50.0	47.3		ug/L		95	72 - 130
1,2,3-Trichloropropane	50.0	41.8		ug/L		84	65 - 132
N-Propylbenzene	50.0	51.6		ug/L		103	75 - 120

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-252958/4
Matrix: Water
Analysis Batch: 252958

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec.
	Added	Result	Qualifier				
2-Chlorotoluene	50.0	49.9		ug/L		100	75 - 120
1,3,5-Trimethylbenzene	50.0	53.0		ug/L		106	75 - 121
4-Chlorotoluene	50.0	50.7		ug/L		101	75 - 120
tert-Butylbenzene	50.0	54.7		ug/L		109	75 - 123
1,2,4-Trimethylbenzene	50.0	52.4		ug/L		105	75 - 121
sec-Butylbenzene	50.0	53.5		ug/L		107	75 - 120
1,3-Dichlorobenzene	50.0	50.2		ug/L		100	75 - 120
p-Isopropyltoluene	50.0	55.0		ug/L		110	75 - 121
1,4-Dichlorobenzene	50.0	49.8		ug/L		100	75 - 120
n-Butylbenzene	50.0	50.8		ug/L		102	75 - 121
1,2-Dichlorobenzene	50.0	50.3		ug/L		101	75 - 120
1,2-Dibromo-3-Chloropropane	50.0	46.4		ug/L		93	62 - 130
1,2,4-Trichlorobenzene	50.0	46.8		ug/L		94	73 - 130
Hexachlorobutadiene	50.0	54.7		ug/L		109	71 - 131
Naphthalene	50.0	44.4		ug/L		89	69 - 135
1,2,3-Trichlorobenzene	50.0	47.4		ug/L		95	69 - 131

Surrogate	LCS LCS		Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	100		75 - 125
Toluene-d8 (Surr)	95		75 - 120
4-Bromofluorobenzene (Surr)	90		75 - 120
Dibromofluoromethane	96		75 - 120

Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-83243-1

Date Collected: 08/27/14 09:25

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252749	09/04/14 04:47	BDA	TAL CHI

Client Sample ID: RFW-1B

Lab Sample ID: 500-83243-2

Date Collected: 08/27/14 16:55

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252749	09/04/14 05:12	BDA	TAL CHI

Client Sample ID: RFW-2A

Lab Sample ID: 500-83243-3

Date Collected: 08/27/14 10:40

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252749	09/04/14 05:37	BDA	TAL CHI

Client Sample ID: RFW-2B

Lab Sample ID: 500-83243-4

Date Collected: 08/27/14 10:50

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252749	09/04/14 06:02	BDA	TAL CHI

Client Sample ID: RFW-3B

Lab Sample ID: 500-83243-5

Date Collected: 08/27/14 16:45

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252749	09/04/14 06:27	BDA	TAL CHI

Client Sample ID: RFW-4A

Lab Sample ID: 500-83243-6

Date Collected: 08/28/14 08:45

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252749	09/04/14 06:52	BDA	TAL CHI

TestAmerica Chicago

Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-4A Dup

Lab Sample ID: 500-83243-7

Date Collected: 08/28/14 08:45

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252749	09/04/14 07:17	BDA	TAL CHI

Client Sample ID: RFW-4B

Lab Sample ID: 500-83243-8

Date Collected: 08/28/14 07:45

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252882	09/04/14 13:29	BDA	TAL CHI

Client Sample ID: RFW-6

Lab Sample ID: 500-83243-9

Date Collected: 08/27/14 12:50

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252882	09/04/14 13:54	BDA	TAL CHI

Client Sample ID: RFW-7

Lab Sample ID: 500-83243-10

Date Collected: 08/27/14 11:04

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252882	09/04/14 14:19	BDA	TAL CHI

Client Sample ID: RFW-9

Lab Sample ID: 500-83243-11

Date Collected: 08/27/14 16:00

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252882	09/04/14 14:44	BDA	TAL CHI

Client Sample ID: RFW-11B

Lab Sample ID: 500-83243-12

Date Collected: 08/28/14 10:40

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252882	09/04/14 15:09	BDA	TAL CHI

TestAmerica Chicago

Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-12B

Lab Sample ID: 500-83243-13

Date Collected: 08/28/14 12:15

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252882	09/04/14 15:34	BDA	TAL CHI

Client Sample ID: RFW-13

Lab Sample ID: 500-83243-14

Date Collected: 08/27/14 14:05

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252882	09/04/14 15:58	BDA	TAL CHI

Client Sample ID: RFW-17

Lab Sample ID: 500-83243-15

Date Collected: 08/27/14 15:10

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252882	09/04/14 16:23	BDA	TAL CHI

Client Sample ID: Trip Blank

Lab Sample ID: 500-83243-16

Date Collected: 08/27/14 06:00

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252882	09/04/14 16:48	BDA	TAL CHI

Client Sample ID: EW-2

Lab Sample ID: 500-83243-17

Date Collected: 08/28/14 12:00

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252882	09/04/14 17:13	BDA	TAL CHI

Client Sample ID: EW-3

Lab Sample ID: 500-83243-18

Date Collected: 08/28/14 10:30

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252882	09/04/14 17:38	BDA	TAL CHI

TestAmerica Chicago

Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-4

Lab Sample ID: 500-83243-19

Date Collected: 08/28/14 10:20

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252882	09/04/14 18:03	BDA	TAL CHI
Total/NA	Analysis	8260B	DL	10	252882	09/04/14 18:28	BDA	TAL CHI

Client Sample ID: EW-5

Lab Sample ID: 500-83243-20

Date Collected: 08/27/14 09:35

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252882	09/04/14 18:53	BDA	TAL CHI

Client Sample ID: EW-6

Lab Sample ID: 500-83243-21

Date Collected: 08/27/14 12:10

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252882	09/04/14 19:18	BDA	TAL CHI

Client Sample ID: EW-7

Lab Sample ID: 500-83243-22

Date Collected: 08/27/14 12:15

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252882	09/04/14 19:43	BDA	TAL CHI

Client Sample ID: EW-8

Lab Sample ID: 500-83243-23

Date Collected: 08/27/14 12:25

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252958	09/04/14 23:36	BDA	TAL CHI

Client Sample ID: EW-9

Lab Sample ID: 500-83243-24

Date Collected: 08/27/14 12:40

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252958	09/05/14 00:01	BDA	TAL CHI

TestAmerica Chicago

Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-9 Dup

Lab Sample ID: 500-83243-25

Date Collected: 08/27/14 12:40

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252958	09/05/14 00:26	BDA	TAL CHI

Client Sample ID: EW-10

Lab Sample ID: 500-83243-26

Date Collected: 08/27/14 12:50

Matrix: Water

Date Received: 08/29/14 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	252958	09/05/14 00:51	BDA	TAL CHI

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200

TestAmerica Chicago

Certification Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Laboratory: TestAmerica Chicago

All certifications held by this laboratory are listed. Not all certifications are applicable to this report.

Authority	Program	EPA Region	Certification ID	Expiration Date
Alabama	State Program	4	40461	04-30-15
California	State Program	9	2903	04-30-15
Georgia	State Program	4	N/A	04-30-15
Georgia	State Program	4	939	04-30-15
Hawaii	State Program	9	N/A	04-30-15
Illinois	NELAP	5	100201	04-30-15
Indiana	State Program	5	C-IL-02	04-30-15
Iowa	State Program	7	82	04-30-14 *
Kansas	NELAP	7	E-10161	10-31-14 *
Kentucky (UST)	State Program	4	66	04-30-15
Kentucky (WWW)	State Program	4	KY90023	12-31-14
Massachusetts	State Program	1	M-IL035	06-30-15
Mississippi	State Program	4	N/A	04-30-15
New York	NELAP	2	IL00035	03-31-15
North Carolina (WWW/SW)	State Program	4	291	12-31-14
North Dakota	State Program	8	R-194	04-30-14 *
Oklahoma	State Program	6	8908	08-31-15
South Carolina	State Program	4	77001	04-30-15
USDA	Federal		P330-12-00038	02-06-15
Wisconsin	State Program	5	999580010	08-31-15 *
Wyoming	State Program	8	8TMS-Q	04-30-15

* Certification renewal pending - certification considered valid.

TestAmerica Chicago

TestAmerica

THE LEADER IN ENVIRONMENTAL

2417 Bond Street, University Park, IL 60
Phone: 708.534.5200 Fax: 708.534



500-83243 COC

Report To (optional)
Contact: W.
Company: western Solutions
Address: _____
Address: _____
Phone: 610.701.3779
Fax: _____
E-Mail: _____

Bill To (optional)
Contact: _____
Company: _____
Address: _____
Address: _____
Phone: _____
Fax: _____
PO#/Reference#: _____

Chain of Custody Record

Lab Job #: 500-83243
Chain of Custody Number: _____
Page 1 of 3
Temperature °C of Cooler: 34

Client		Client Project #		Preservative		Parameter		Preservative Key	
<u>western Solutions</u>		<u>02501.004.005</u>						1. HCL, Cool to 4° 2. H2SO4, Cool to 4° 3. HNO3, Cool to 4° 4. NaOH, Cool to 4° 5. NaOH/Zn, Cool to 4° 6. NaHSO4 7. Cool to 4° 8. None 9. Other	
Project Name		Lab Project #		Sampler		Lab PM		Comments	
<u>Black + Decker</u>				<u>Greg Flasusk</u>		<u>Dick Wright</u>			
Project Location/State		Sampling		# of Containers		Matrix			
<u>hampstead MD</u>		Date Time		3 W		<u>VOC</u>			
Lab ID	MS/MSD	Sample ID	Date	Time	# of Containers	Matrix			
<u>1</u>		<u>RFW-1A</u>	<u>8/27/14</u>	<u>925</u>	<u>3</u>	<u>W</u>			
<u>2</u>		<u>RFW-1B</u>	<u>I</u>	<u>1655</u>	<u>I</u>	<u>I</u>			
<u>3</u>		<u>RFW-2A</u>	<u>I</u>	<u>1040</u>	<u>I</u>	<u>I</u>			
<u>4</u>		<u>RFW-2B</u>	<u>I</u>	<u>1050</u>	<u>I</u>	<u>I</u>			
<u>5</u>		<u>RFW-3B</u>	<u>I</u>	<u>1645</u>	<u>I</u>	<u>I</u>			
<u>6</u>		<u>RFW-4A</u>	<u>8/28/14</u>	<u>845</u>	<u>I</u>	<u>I</u>			
<u>7</u>		<u>RFW-4A Dup</u>	<u>8/28/14</u>	<u>845</u>	<u>I</u>	<u>I</u>			
<u>8</u>		<u>RFW-4B</u>	<u>8/28/14</u>	<u>745</u>	<u>I</u>	<u>I</u>			
<u>9</u>		<u>RFW-6</u>	<u>8/27/14</u>	<u>1250</u>	<u>I</u>	<u>I</u>			
<u>10</u>		<u>RFW-7</u>	<u>8/27/14</u>	<u>1145</u>	<u>I</u>	<u>I</u>			

Turnaround Time Required (Business Days)

1 Day 2 Days 5 Days 7 Days 10 Days 15 Days Other

Sample Disposal

Return to Client Disposal by Lab Archive for _____ Months (A fee may be assessed if samples are retained longer than 1 month)

Relinquished By: <u>[Signature]</u> Company: <u>western</u> Date: <u>8/28/14</u> Time: <u>1600</u>	Received By: <u>[Signature]</u> Company: <u>TestAmerica</u> Date: <u>8/29/14</u> Time: <u>1030</u>
Relinquished By: _____ Company: _____ Date: _____ Time: _____	Received By: _____ Company: _____ Date: _____ Time: _____
Relinquished By: _____ Company: _____ Date: _____ Time: _____	Received By: _____ Company: _____ Date: _____ Time: _____

Lab Courier: _____
Shipped: [Signature]
Hand Delivered: _____

- Matrix Key
- WW - Wastewater
 - W - Water
 - S - Soil
 - SL - Sludge
 - MS - Miscellaneous
 - OL - Oil
 - A - Air
 - SE - Sediment
 - SO - Soil
 - L - Leachate
 - WI - Wipe
 - DW - Drinking Water
 - O - Other

Client Comments: _____

Lab Comments: _____

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

2417 Bond Street, University Park, IL 60484
 Phone: 708.534.5200 Fax: 708.534.5211

Report To _____ (optional)
 Contact: _____
 Company: _____
 Address: _____
 Address: _____
 Phone: _____
 Fax: _____
 E-Mail: _____

Bill To _____ (optional)
 Contact: _____
 Company: _____
 Address: _____
 Address: _____
 Phone: _____
 Fax: _____
 PO#/Reference# _____

Chain of Custody Record

Lab Job #: 500-83243
 Chain of Custody Number: _____
 Page 2 of 3
 Temperature °C of Cooler: 3.4

Client		Client Project #		Preservative		Parameter		Matrix		Preservative Key 1. HCL, Cool to 4° 2. H2SO4, Cool to 4° 3. HNO3, Cool to 4° 4. NaOH, Cool to 4° 5. NaOH/Zn, Cool to 4° 6. NaHSO4 7. Cool to 4° 8. None 9. Other
Project Name		Lab Project #		Sampling		Matrix		Comments		
Project Location/State		Sampler		Date	Time	# of Containers	Matrix			
Lab ID	MS/MSD	Sample ID								
Weston Solutions										V O C
Black + Decker										
		Lab PM								
Greg Fasuski		Dick Wright								
11		RFW-9	8/27/14	1600	3	W				
12		RFW-11B	8/28/14	1640	1					
13		RFW-12B	8/28/14	1215	1					
14		RFW-13	8/27/14	1405	1					
15		RFW-17	8/27/14	1510	1					
16		Trip Blank	8/27/14	0600	2					

Turnaround Time Required (Business Days)

___ 1 Day ___ 2 Days ___ 5 Days ___ 7 Days ___ 10 Days ___ 15 Days ___ Other

Sample Disposal

Return to Client Disposal by Lab Archive for ___ Months (A fee may be assessed if samples are retained longer than 1 month)

Relinquished By: <u>[Signature]</u>	Company: <u>Weston</u>	Date: <u>8/28/14</u>	Time: <u>1600</u>	Received By: <u>[Signature]</u>	Company: <u>TA-CHE</u>	Date: <u>8/29/14</u>	Time: <u>1030</u>
Relinquished By:	Company:	Date:	Time:	Received By:	Company:	Date:	Time:
Relinquished By:	Company:	Date:	Time:	Received By:	Company:	Date:	Time:

Lab Courier: _____
 Shipped: FedEx
 Hand Delivered: _____

Matrix Key

WW - Wastewater SE - Sediment
 W - Water SO - Soil
 S - Soil L - Leachate
 SL - Sludge WI - Wipe
 MS - Miscellaneous DW - Drinking Water
 OL - Oil O - Other
 A - Air

Client Comments:

Lab Comments:

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

2417 Bond Street, University Park, IL 60484
 Phone: 708.534.5200 Fax: 708.534.5211

Report To (optional)
 Contact: _____
 Company: _____
 Address: _____
 Address: _____
 Phone: 610-701-9779
 Fax: _____
 E-Mail: _____

Bill To (optional)
 Contact: _____
 Company: _____
 Address: _____
 Address: _____
 Phone: _____
 Fax: _____
 PO#/Reference# _____

Chain of Custody Record

Lab Job #: 500-83243
 Chain of Custody Number: _____
 Page 3 of 3
 Temperature °C of Cooler: 3.4

Client		Client Project #		Preservative		Parameter		Matrix		Preservative Key
Weston										
Project Name		Lab Project #								
Black + Decker										1. HCL, Cool to 4° 2. H2SO4, Cool to 4° 3. HNO3, Cool to 4° 4. NaOH, Cool to 4° 5. NaOH/Zn, Cool to 4° 6. NaHSO4 7. Cool to 4° 8. None 9. Other
Project Location/State		Lab Project #								
Hampstead, MD										
Sampler		Lab PM								Comments
Greg Flaszuski		Dick Wright								
Lab ID	MS/MSD	Sample ID	Date	Time	# of Containers	Matrix				
17		EW-2	8/28/14	1200	3	W				
18		EW-3		1030						
19		EW-4		1020						
20		EW-5	8/27/14	935						
21		EW-6		1210						
22		EW-7		1215						
23		EW-8		1225						
24		EW-9		1240						
25		EW-9 Dup		1240						
26		EW-10		1250						

Turnaround Time Required (Business Days)

1 Day 2 Days 5 Days 7 Days 10 Days 15 Days Other

Sample Disposal

Return to Client Disposal by Lab Archive for _____ Months (A fee may be assessed if samples are retained longer than 1 month)

Requested By: <u>[Signature]</u>	Company: <u>Weston</u>	Date: <u>8/28/14</u>	Time: <u>1600</u>	Received By: <u>[Signature]</u>	Company: <u>TH-CAT</u>	Date: <u>8/29/14</u>	Time: <u>1030</u>
Relinquished By: _____	Company: _____	Date: _____	Time: _____	Received By: _____	Company: _____	Date: _____	Time: _____
Relinquished By: _____	Company: _____	Date: _____	Time: _____	Received By: _____	Company: _____	Date: _____	Time: _____

Lab Courier: _____
 Shipped: FedEx
 Hand Delivered: _____

Matrix Key
 WW - Wastewater SE - Sediment
 W - Water SO - Soil
 S - Soil L - Leachate
 SL - Sludge WI - Wipe
 MS - Miscellaneous DW - Drinking Water
 OL - Oil O - Other
 A - Air

Client Comments: _____

Lab Comments: _____

Login Sample Receipt Checklist

Client: Weston Solutions, Inc.

Job Number: 500-83243-1

Login Number: 83243

List Source: TestAmerica Chicago

List Number: 1

Creator: Scott, Sherri L

Question	Answer	Comment
Radioactivity wasn't checked or is \leq background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	3.4
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.
TestAmerica Savannah
5102 LaRoche Avenue
Savannah, GA 31404
Tel: (912)354-7858

TestAmerica Job ID: 680-104781-1
Client Project/Site: Black & Decker

For:
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, Pennsylvania 19380

Attn: Greg Flasiński



Authorized for release by:
9/10/2014 12:43:22 PM

Lisa Harvey, Project Manager II
(912)354-7858 e.3221
lisa.harvey@testamericainc.com

LINKS

Review your project
results through

Total Access

Have a Question?



Ask
The
Expert

Visit us at:

www.testamericainc.com

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

Case Narrative

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Job ID: 680-104781-1

Laboratory: TestAmerica Savannah

Narrative

CASE NARRATIVE
Client: Weston Solutions, Inc.
Project: Black & Decker
Report Number: 680-104781-1

With the exceptions noted as flags or footnotes, standard analytical protocols were followed in the analysis of the samples and no problems were encountered or anomalies observed. In addition all laboratory quality control samples were within established control limits, with any exceptions noted below. Each sample was analyzed to achieve the lowest possible reporting limit within the constraints of the method. In the event of interference or analytes present at high concentrations, samples may be diluted. For diluted samples, the reporting limits are adjusted relative to the dilution required.

RECEIPT

The samples were received on 08/29/2014; the samples arrived in good condition, properly preserved and on ice. The temperature of the coolers at receipt was 2.6 C.

VOLATILE ORGANIC COMPOUNDS (GC-MS)

Samples Trip Blank (680-104781-1), RFW-20 (680-104781-2), RFW-21 (680-104781-3), HAMP-22 (680-104781-4) and HAMP-23 (680-104781-5) were analyzed for Volatile organic Compounds (GC-MS) in accordance with EPA Method 524.2. The samples were analyzed on 09/03/2014.

No analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

Sample Summary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
680-104781-1	Trip Blank	Water	08/27/14 06:00	08/29/14 09:36
680-104781-2	RFW-20	Water	08/27/14 17:05	08/29/14 09:36
680-104781-3	RFW-21	Water	08/27/14 07:35	08/29/14 09:36
680-104781-4	HAMP-22	Water	08/28/14 09:10	08/29/14 09:36
680-104781-5	HAMP-23	Water	08/28/14 09:15	08/29/14 09:36

Method Summary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Method	Method Description	Protocol	Laboratory
524.2	Volatile Organic Compounds (GC/MS)	EPA-DW	TAL SAV

Protocol References:

EPA-DW = "Methods For The Determination Of Organic Compounds In Drinking Water", EPA/600/4-88/039, December 1988 And Its Supplements.

Laboratory References:

TAL SAV = TestAmerica Savannah, 5102 LaRoche Avenue, Savannah, GA 31404, TEL (912)354-7858

TestAmerica Savannah

Definitions/Glossary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Qualifiers

GC/MS VOA

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
□	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CNF	Contains no Free Liquid
DER	Duplicate error ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision level concentration
MDA	Minimum detectable activity
EDL	Estimated Detection Limit
MDC	Minimum detectable concentration
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
NC	Not Calculated
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative error ratio
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-104781-1

Date Collected: 08/27/14 06:00

Matrix: Water

Date Received: 08/29/14 09:36

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			09/03/14 15:44	1
Benzene	<0.50		0.50	0.18	ug/L			09/03/14 15:44	1
Bromobenzene	<0.50		0.50	0.42	ug/L			09/03/14 15:44	1
Bromoform	<0.50		0.50	0.39	ug/L			09/03/14 15:44	1
Bromomethane	<1.0		1.0	0.45	ug/L			09/03/14 15:44	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			09/03/14 15:44	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			09/03/14 15:44	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/03/14 15:44	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			09/03/14 15:44	1
Chloroethane	<1.0		1.0	0.33	ug/L			09/03/14 15:44	1
Chloroform	<0.50		0.50	0.29	ug/L			09/03/14 15:44	1
Chloromethane	<0.50		0.50	0.32	ug/L			09/03/14 15:44	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			09/03/14 15:44	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			09/03/14 15:44	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			09/03/14 15:44	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			09/03/14 15:44	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/03/14 15:44	1
Dibromomethane	<0.50		0.50	0.38	ug/L			09/03/14 15:44	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			09/03/14 15:44	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			09/03/14 15:44	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			09/03/14 15:44	1
Dichlorobromomethane	<0.50		0.50	0.10	ug/L			09/03/14 15:44	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/03/14 15:44	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			09/03/14 15:44	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			09/03/14 15:44	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			09/03/14 15:44	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			09/03/14 15:44	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			09/03/14 15:44	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			09/03/14 15:44	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			09/03/14 15:44	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			09/03/14 15:44	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/03/14 15:44	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			09/03/14 15:44	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/03/14 15:44	1
Freon 113	<0.50		0.50	0.15	ug/L			09/03/14 15:44	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/03/14 15:44	1
2-Hexanone	<10		10	5.0	ug/L			09/03/14 15:44	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/03/14 15:44	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/03/14 15:44	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			09/03/14 15:44	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/03/14 15:44	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/03/14 15:44	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			09/03/14 15:44	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/03/14 15:44	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 15:44	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 15:44	1
o-Xylene	<0.50		0.50	0.27	ug/L			09/03/14 15:44	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/03/14 15:44	1
Styrene	<0.50		0.50	0.28	ug/L			09/03/14 15:44	1

TestAmerica Savannah

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-104781-1

Date Collected: 08/27/14 06:00

Matrix: Water

Date Received: 08/29/14 09:36

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/03/14 15:44	1
tert-Butyl alcohol	<10		10	1.6	ug/L			09/03/14 15:44	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/03/14 15:44	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/03/14 15:44	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			09/03/14 15:44	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			09/03/14 15:44	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			09/03/14 15:44	1
Toluene	<0.50		0.50	0.23	ug/L			09/03/14 15:44	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			09/03/14 15:44	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			09/03/14 15:44	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/03/14 15:44	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			09/03/14 15:44	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			09/03/14 15:44	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			09/03/14 15:44	1
Trichloroethene	<0.50		0.50	0.37	ug/L			09/03/14 15:44	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/03/14 15:44	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			09/03/14 15:44	1
Trihalomethanes, Total	<0.50		0.50	0.10	ug/L			09/03/14 15:44	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 15:44	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/03/14 15:44	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			09/03/14 15:44	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			09/03/14 15:44	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	101		70 - 130		09/03/14 15:44	1
1,2-Dichlorobenzene-d4	101		70 - 130		09/03/14 15:44	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Client Sample ID: RFW-20

Lab Sample ID: 680-104781-2

Date Collected: 08/27/14 17:05

Matrix: Water

Date Received: 08/29/14 09:36

Method: 524.2 - Volatile Organic Compounds (GC/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			09/03/14 18:03	1
Benzene	<0.50		0.50	0.18	ug/L			09/03/14 18:03	1
Bromobenzene	<0.50		0.50	0.42	ug/L			09/03/14 18:03	1
Bromoform	<0.50		0.50	0.39	ug/L			09/03/14 18:03	1
Bromomethane	<1.0		1.0	0.45	ug/L			09/03/14 18:03	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			09/03/14 18:03	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			09/03/14 18:03	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/03/14 18:03	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			09/03/14 18:03	1
Chloroethane	<1.0		1.0	0.33	ug/L			09/03/14 18:03	1
Chloroform	<0.50		0.50	0.29	ug/L			09/03/14 18:03	1
Chloromethane	<0.50		0.50	0.32	ug/L			09/03/14 18:03	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			09/03/14 18:03	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			09/03/14 18:03	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			09/03/14 18:03	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			09/03/14 18:03	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/03/14 18:03	1
Dibromomethane	<0.50		0.50	0.38	ug/L			09/03/14 18:03	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			09/03/14 18:03	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			09/03/14 18:03	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			09/03/14 18:03	1
Dichlorobromomethane	<0.50		0.50	0.10	ug/L			09/03/14 18:03	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/03/14 18:03	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			09/03/14 18:03	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			09/03/14 18:03	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			09/03/14 18:03	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			09/03/14 18:03	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			09/03/14 18:03	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			09/03/14 18:03	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			09/03/14 18:03	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			09/03/14 18:03	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/03/14 18:03	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			09/03/14 18:03	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/03/14 18:03	1
Freon 113	<0.50		0.50	0.15	ug/L			09/03/14 18:03	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/03/14 18:03	1
2-Hexanone	<10		10	5.0	ug/L			09/03/14 18:03	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/03/14 18:03	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/03/14 18:03	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			09/03/14 18:03	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/03/14 18:03	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/03/14 18:03	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			09/03/14 18:03	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/03/14 18:03	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 18:03	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 18:03	1
o-Xylene	<0.50		0.50	0.27	ug/L			09/03/14 18:03	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/03/14 18:03	1
Styrene	<0.50		0.50	0.28	ug/L			09/03/14 18:03	1

TestAmerica Savannah

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Client Sample ID: RFW-20

Lab Sample ID: 680-104781-2

Date Collected: 08/27/14 17:05

Matrix: Water

Date Received: 08/29/14 09:36

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/03/14 18:03	1
tert-Butyl alcohol	<10		10	1.6	ug/L			09/03/14 18:03	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/03/14 18:03	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/03/14 18:03	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			09/03/14 18:03	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			09/03/14 18:03	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			09/03/14 18:03	1
Toluene	<0.50		0.50	0.23	ug/L			09/03/14 18:03	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			09/03/14 18:03	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			09/03/14 18:03	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/03/14 18:03	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			09/03/14 18:03	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			09/03/14 18:03	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			09/03/14 18:03	1
Trichloroethene	0.49	J	0.50	0.37	ug/L			09/03/14 18:03	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/03/14 18:03	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			09/03/14 18:03	1
Trihalomethanes, Total	<0.50		0.50	0.10	ug/L			09/03/14 18:03	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 18:03	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/03/14 18:03	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			09/03/14 18:03	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			09/03/14 18:03	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	101		70 - 130		09/03/14 18:03	1
1,2-Dichlorobenzene-d4	104		70 - 130		09/03/14 18:03	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Client Sample ID: RFW-21

Lab Sample ID: 680-104781-3

Date Collected: 08/27/14 07:35

Matrix: Water

Date Received: 08/29/14 09:36

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			09/03/14 18:26	1
Benzene	<0.50		0.50	0.18	ug/L			09/03/14 18:26	1
Bromobenzene	<0.50		0.50	0.42	ug/L			09/03/14 18:26	1
Bromoform	<0.50		0.50	0.39	ug/L			09/03/14 18:26	1
Bromomethane	<1.0		1.0	0.45	ug/L			09/03/14 18:26	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			09/03/14 18:26	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			09/03/14 18:26	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/03/14 18:26	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			09/03/14 18:26	1
Chloroethane	<1.0		1.0	0.33	ug/L			09/03/14 18:26	1
Chloroform	<0.50		0.50	0.29	ug/L			09/03/14 18:26	1
Chloromethane	<0.50		0.50	0.32	ug/L			09/03/14 18:26	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			09/03/14 18:26	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			09/03/14 18:26	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			09/03/14 18:26	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			09/03/14 18:26	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/03/14 18:26	1
Dibromomethane	<0.50		0.50	0.38	ug/L			09/03/14 18:26	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			09/03/14 18:26	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			09/03/14 18:26	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			09/03/14 18:26	1
Dichlorobromomethane	<0.50		0.50	0.10	ug/L			09/03/14 18:26	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/03/14 18:26	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			09/03/14 18:26	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			09/03/14 18:26	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			09/03/14 18:26	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			09/03/14 18:26	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			09/03/14 18:26	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			09/03/14 18:26	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			09/03/14 18:26	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			09/03/14 18:26	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/03/14 18:26	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			09/03/14 18:26	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/03/14 18:26	1
Freon 113	<0.50		0.50	0.15	ug/L			09/03/14 18:26	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/03/14 18:26	1
2-Hexanone	<10		10	5.0	ug/L			09/03/14 18:26	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/03/14 18:26	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/03/14 18:26	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			09/03/14 18:26	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/03/14 18:26	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/03/14 18:26	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			09/03/14 18:26	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/03/14 18:26	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 18:26	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 18:26	1
o-Xylene	<0.50		0.50	0.27	ug/L			09/03/14 18:26	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/03/14 18:26	1
Styrene	<0.50		0.50	0.28	ug/L			09/03/14 18:26	1

TestAmerica Savannah

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Client Sample ID: RFW-21

Lab Sample ID: 680-104781-3

Date Collected: 08/27/14 07:35

Matrix: Water

Date Received: 08/29/14 09:36

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/03/14 18:26	1
tert-Butyl alcohol	<10		10	1.6	ug/L			09/03/14 18:26	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/03/14 18:26	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/03/14 18:26	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			09/03/14 18:26	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			09/03/14 18:26	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			09/03/14 18:26	1
Toluene	<0.50		0.50	0.23	ug/L			09/03/14 18:26	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			09/03/14 18:26	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			09/03/14 18:26	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/03/14 18:26	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			09/03/14 18:26	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			09/03/14 18:26	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			09/03/14 18:26	1
Trichloroethene	<0.50		0.50	0.37	ug/L			09/03/14 18:26	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/03/14 18:26	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			09/03/14 18:26	1
Trihalomethanes, Total	<0.50		0.50	0.10	ug/L			09/03/14 18:26	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 18:26	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/03/14 18:26	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			09/03/14 18:26	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			09/03/14 18:26	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	100		70 - 130		09/03/14 18:26	1
1,2-Dichlorobenzene-d4	102		70 - 130		09/03/14 18:26	1

TestAmerica Savannah

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Client Sample ID: HAMP-22

Lab Sample ID: 680-104781-4

Date Collected: 08/28/14 09:10

Matrix: Water

Date Received: 08/29/14 09:36

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			09/03/14 18:49	1
Benzene	<0.50		0.50	0.18	ug/L			09/03/14 18:49	1
Bromobenzene	<0.50		0.50	0.42	ug/L			09/03/14 18:49	1
Bromoform	<0.50		0.50	0.39	ug/L			09/03/14 18:49	1
Bromomethane	<1.0		1.0	0.45	ug/L			09/03/14 18:49	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			09/03/14 18:49	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			09/03/14 18:49	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/03/14 18:49	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			09/03/14 18:49	1
Chloroethane	<1.0		1.0	0.33	ug/L			09/03/14 18:49	1
Chloroform	<0.50		0.50	0.29	ug/L			09/03/14 18:49	1
Chloromethane	<0.50		0.50	0.32	ug/L			09/03/14 18:49	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			09/03/14 18:49	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			09/03/14 18:49	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			09/03/14 18:49	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			09/03/14 18:49	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/03/14 18:49	1
Dibromomethane	<0.50		0.50	0.38	ug/L			09/03/14 18:49	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			09/03/14 18:49	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			09/03/14 18:49	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			09/03/14 18:49	1
Dichlorobromomethane	<0.50		0.50	0.10	ug/L			09/03/14 18:49	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/03/14 18:49	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			09/03/14 18:49	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			09/03/14 18:49	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			09/03/14 18:49	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			09/03/14 18:49	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			09/03/14 18:49	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			09/03/14 18:49	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			09/03/14 18:49	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			09/03/14 18:49	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/03/14 18:49	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			09/03/14 18:49	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/03/14 18:49	1
Freon 113	<0.50		0.50	0.15	ug/L			09/03/14 18:49	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/03/14 18:49	1
2-Hexanone	<10		10	5.0	ug/L			09/03/14 18:49	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/03/14 18:49	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/03/14 18:49	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			09/03/14 18:49	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/03/14 18:49	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/03/14 18:49	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			09/03/14 18:49	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/03/14 18:49	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 18:49	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 18:49	1
o-Xylene	<0.50		0.50	0.27	ug/L			09/03/14 18:49	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/03/14 18:49	1
Styrene	<0.50		0.50	0.28	ug/L			09/03/14 18:49	1

TestAmerica Savannah

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Client Sample ID: HAMP-22

Lab Sample ID: 680-104781-4

Date Collected: 08/28/14 09:10

Matrix: Water

Date Received: 08/29/14 09:36

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/03/14 18:49	1
tert-Butyl alcohol	<10		10	1.6	ug/L			09/03/14 18:49	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/03/14 18:49	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/03/14 18:49	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			09/03/14 18:49	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			09/03/14 18:49	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			09/03/14 18:49	1
Toluene	<0.50		0.50	0.23	ug/L			09/03/14 18:49	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			09/03/14 18:49	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			09/03/14 18:49	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/03/14 18:49	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			09/03/14 18:49	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			09/03/14 18:49	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			09/03/14 18:49	1
Trichloroethene	<0.50		0.50	0.37	ug/L			09/03/14 18:49	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/03/14 18:49	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			09/03/14 18:49	1
Trihalomethanes, Total	<0.50		0.50	0.10	ug/L			09/03/14 18:49	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 18:49	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/03/14 18:49	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			09/03/14 18:49	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			09/03/14 18:49	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	103		70 - 130		09/03/14 18:49	1
1,2-Dichlorobenzene-d4	102		70 - 130		09/03/14 18:49	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Client Sample ID: HAMP-23

Lab Sample ID: 680-104781-5

Date Collected: 08/28/14 09:15

Matrix: Water

Date Received: 08/29/14 09:36

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			09/03/14 19:13	1
Benzene	<0.50		0.50	0.18	ug/L			09/03/14 19:13	1
Bromobenzene	<0.50		0.50	0.42	ug/L			09/03/14 19:13	1
Bromoform	<0.50		0.50	0.39	ug/L			09/03/14 19:13	1
Bromomethane	<1.0		1.0	0.45	ug/L			09/03/14 19:13	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			09/03/14 19:13	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			09/03/14 19:13	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/03/14 19:13	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			09/03/14 19:13	1
Chloroethane	<1.0		1.0	0.33	ug/L			09/03/14 19:13	1
Chloroform	<0.50		0.50	0.29	ug/L			09/03/14 19:13	1
Chloromethane	<0.50		0.50	0.32	ug/L			09/03/14 19:13	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			09/03/14 19:13	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			09/03/14 19:13	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			09/03/14 19:13	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			09/03/14 19:13	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/03/14 19:13	1
Dibromomethane	<0.50		0.50	0.38	ug/L			09/03/14 19:13	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			09/03/14 19:13	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			09/03/14 19:13	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			09/03/14 19:13	1
Dichlorobromomethane	<0.50		0.50	0.10	ug/L			09/03/14 19:13	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/03/14 19:13	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			09/03/14 19:13	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			09/03/14 19:13	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			09/03/14 19:13	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			09/03/14 19:13	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			09/03/14 19:13	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			09/03/14 19:13	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			09/03/14 19:13	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			09/03/14 19:13	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/03/14 19:13	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			09/03/14 19:13	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/03/14 19:13	1
Freon 113	<0.50		0.50	0.15	ug/L			09/03/14 19:13	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/03/14 19:13	1
2-Hexanone	<10		10	5.0	ug/L			09/03/14 19:13	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/03/14 19:13	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/03/14 19:13	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			09/03/14 19:13	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/03/14 19:13	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/03/14 19:13	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			09/03/14 19:13	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/03/14 19:13	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 19:13	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 19:13	1
o-Xylene	<0.50		0.50	0.27	ug/L			09/03/14 19:13	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/03/14 19:13	1
Styrene	<0.50		0.50	0.28	ug/L			09/03/14 19:13	1

TestAmerica Savannah

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Client Sample ID: HAMP-23

Lab Sample ID: 680-104781-5

Date Collected: 08/28/14 09:15

Matrix: Water

Date Received: 08/29/14 09:36

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/03/14 19:13	1
tert-Butyl alcohol	<10		10	1.6	ug/L			09/03/14 19:13	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/03/14 19:13	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/03/14 19:13	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			09/03/14 19:13	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			09/03/14 19:13	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			09/03/14 19:13	1
Toluene	<0.50		0.50	0.23	ug/L			09/03/14 19:13	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			09/03/14 19:13	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			09/03/14 19:13	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/03/14 19:13	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			09/03/14 19:13	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			09/03/14 19:13	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			09/03/14 19:13	1
Trichloroethene	<0.50		0.50	0.37	ug/L			09/03/14 19:13	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/03/14 19:13	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			09/03/14 19:13	1
Trihalomethanes, Total	<0.50		0.50	0.10	ug/L			09/03/14 19:13	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 19:13	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/03/14 19:13	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			09/03/14 19:13	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			09/03/14 19:13	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	101		70 - 130		09/03/14 19:13	1
1,2-Dichlorobenzene-d4	99		70 - 130		09/03/14 19:13	1

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Lab Sample ID: MB 680-347026/18

Matrix: Water

Analysis Batch: 347026

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Acetone	<10		10	5.0	ug/L			09/03/14 14:57	1
Benzene	<0.50		0.50	0.18	ug/L			09/03/14 14:57	1
Bromobenzene	<0.50		0.50	0.42	ug/L			09/03/14 14:57	1
Bromoform	<0.50		0.50	0.39	ug/L			09/03/14 14:57	1
Bromomethane	<1.0		1.0	0.45	ug/L			09/03/14 14:57	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			09/03/14 14:57	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			09/03/14 14:57	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			09/03/14 14:57	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			09/03/14 14:57	1
Chloroethane	<1.0		1.0	0.33	ug/L			09/03/14 14:57	1
Chloroform	<0.50		0.50	0.29	ug/L			09/03/14 14:57	1
Chloromethane	<0.50		0.50	0.32	ug/L			09/03/14 14:57	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			09/03/14 14:57	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			09/03/14 14:57	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			09/03/14 14:57	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			09/03/14 14:57	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			09/03/14 14:57	1
Dibromomethane	<0.50		0.50	0.38	ug/L			09/03/14 14:57	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			09/03/14 14:57	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			09/03/14 14:57	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			09/03/14 14:57	1
Dichlorobromomethane	<0.50		0.50	0.10	ug/L			09/03/14 14:57	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			09/03/14 14:57	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			09/03/14 14:57	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			09/03/14 14:57	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			09/03/14 14:57	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			09/03/14 14:57	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			09/03/14 14:57	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			09/03/14 14:57	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			09/03/14 14:57	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			09/03/14 14:57	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			09/03/14 14:57	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			09/03/14 14:57	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			09/03/14 14:57	1
Freon 113	<0.50		0.50	0.15	ug/L			09/03/14 14:57	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			09/03/14 14:57	1
2-Hexanone	<10		10	5.0	ug/L			09/03/14 14:57	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			09/03/14 14:57	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			09/03/14 14:57	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			09/03/14 14:57	1
2-Butanone (MEK)	<10		10	5.0	ug/L			09/03/14 14:57	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			09/03/14 14:57	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			09/03/14 14:57	1
Naphthalene	<1.0		1.0	0.43	ug/L			09/03/14 14:57	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 14:57	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 14:57	1
o-Xylene	<0.50		0.50	0.27	ug/L			09/03/14 14:57	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			09/03/14 14:57	1

TestAmerica Savannah

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 680-347026/18

Matrix: Water

Analysis Batch: 347026

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Styrene	<0.50		0.50	0.28	ug/L			09/03/14 14:57	1
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			09/03/14 14:57	1
tert-Butyl alcohol	<10		10	1.6	ug/L			09/03/14 14:57	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			09/03/14 14:57	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			09/03/14 14:57	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			09/03/14 14:57	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			09/03/14 14:57	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			09/03/14 14:57	1
Toluene	<0.50		0.50	0.23	ug/L			09/03/14 14:57	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			09/03/14 14:57	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			09/03/14 14:57	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			09/03/14 14:57	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			09/03/14 14:57	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			09/03/14 14:57	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			09/03/14 14:57	1
Trichloroethene	<0.50		0.50	0.37	ug/L			09/03/14 14:57	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			09/03/14 14:57	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			09/03/14 14:57	1
Trihalomethanes, Total	<0.50		0.50	0.10	ug/L			09/03/14 14:57	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			09/03/14 14:57	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			09/03/14 14:57	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			09/03/14 14:57	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			09/03/14 14:57	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
4-Bromofluorobenzene	99		70 - 130		09/03/14 14:57	1
1,2-Dichlorobenzene-d4	99		70 - 130		09/03/14 14:57	1

Lab Sample ID: LCS 680-347026/13

Matrix: Water

Analysis Batch: 347026

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Benzene	20.0	20.2		ug/L		101	70 - 130
Bromobenzene	20.0	21.2		ug/L		106	70 - 130
Bromoform	20.0	21.7		ug/L		109	70 - 130
Bromomethane	20.0	24.9		ug/L		124	70 - 130
Carbon tetrachloride	20.0	22.8		ug/L		114	70 - 130
Chlorobenzene	20.0	21.6		ug/L		108	70 - 130
Chlorobromomethane	20.0	20.5		ug/L		103	70 - 130
Chlorodibromomethane	20.0	21.5		ug/L		107	70 - 130
Chloroethane	20.0	21.9		ug/L		109	70 - 130
Chloroform	20.0	21.2		ug/L		106	70 - 130
Chloromethane	20.0	19.7		ug/L		99	70 - 130
2-Chlorotoluene	20.0	22.2		ug/L		111	70 - 130
4-Chlorotoluene	20.0	21.7		ug/L		109	70 - 130
cis-1,2-Dichloroethene	20.0	21.9		ug/L		109	70 - 130

TestAmerica Savannah

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 680-347026/13

Matrix: Water

Analysis Batch: 347026

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec.
	Added	Result	Qualifier				
cis-1,3-Dichloropropene	20.0	21.3		ug/L		107	70 - 130
1,2-Dibromo-3-Chloropropane	20.0	19.3		ug/L		97	70 - 130
Dibromomethane	20.0	20.4		ug/L		102	70 - 130
1,2-Dichlorobenzene	20.0	21.0		ug/L		105	70 - 130
1,3-Dichlorobenzene	20.0	21.4		ug/L		107	70 - 130
1,4-Dichlorobenzene	20.0	21.2		ug/L		106	70 - 130
Dichlorobromomethane	20.0	21.3		ug/L		107	70 - 130
Dichlorodifluoromethane	20.0	20.6		ug/L		103	70 - 130
1,1-Dichloroethane	20.0	21.4		ug/L		107	70 - 130
1,2-Dichloroethane	20.0	21.8		ug/L		109	70 - 130
1,1-Dichloroethene	20.0	20.5		ug/L		102	70 - 130
1,2-Dichloropropane	20.0	21.1		ug/L		105	70 - 130
1,3-Dichloropropane	20.0	20.5		ug/L		102	70 - 130
2,2-Dichloropropane	20.0	23.1		ug/L		116	70 - 130
1,1-Dichloropropene	20.0	21.2		ug/L		106	70 - 130
1,3-Dichloropropene, Total	40.0	43.0		ug/L		108	70 - 130
Ethylbenzene	20.0	21.9		ug/L		109	70 - 130
Ethylene Dibromide	20.0	20.4		ug/L		102	70 - 130
Freon 113	20.0	22.3		ug/L		112	70 - 130
Hexachlorobutadiene	20.0	22.7		ug/L		114	70 - 130
2-Hexanone	100	102		ug/L		102	70 - 130
Isopropylbenzene	20.0	22.4		ug/L		112	70 - 130
4-Isopropyltoluene	20.0	23.2		ug/L		116	70 - 130
Methylene Chloride	20.0	19.3		ug/L		96	70 - 130
2-Butanone (MEK)	100	106		ug/L		106	70 - 130
4-Methyl-2-pentanone (MIBK)	100	103		ug/L		103	70 - 130
m-Xylene & p-Xylene	20.0	22.1		ug/L		111	70 - 130
Naphthalene	20.0	21.4		ug/L		107	70 - 130
n-Butylbenzene	20.0	22.9		ug/L		114	70 - 130
N-Propylbenzene	20.0	22.2		ug/L		111	70 - 130
o-Xylene	20.0	22.2		ug/L		111	70 - 130
sec-Butylbenzene	20.0	22.9		ug/L		115	70 - 130
Styrene	20.0	22.3		ug/L		112	70 - 130
tert-Butyl alcohol	200	198		ug/L		99	70 - 130
tert-Butylbenzene	20.0	23.3		ug/L		116	70 - 130
1,1,1,2-Tetrachloroethane	20.0	21.2		ug/L		106	70 - 130
1,1,2,2-Tetrachloroethane	20.0	19.6		ug/L		98	70 - 130
Tetrachloroethene	20.0	22.9		ug/L		115	70 - 130
Toluene	20.0	20.6		ug/L		103	70 - 130
trans-1,2-Dichloroethene	20.0	20.5		ug/L		103	70 - 130
trans-1,3-Dichloropropene	20.0	21.7		ug/L		108	70 - 130
1,2,3-Trichlorobenzene	20.0	21.4		ug/L		107	70 - 130
1,2,4-Trichlorobenzene	20.0	21.7		ug/L		108	70 - 130
1,1,1-Trichloroethane	20.0	22.3		ug/L		112	70 - 130
1,1,2-Trichloroethane	20.0	20.7		ug/L		104	70 - 130
Trichloroethene	20.0	21.2		ug/L		106	70 - 130
Trichlorofluoromethane	20.0	23.4		ug/L		117	70 - 130
1,2,3-Trichloropropane	20.0	19.5		ug/L		98	70 - 130

TestAmerica Savannah

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 680-347026/13

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 347026

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec.	
							Limits	
Trihalomethanes, Total	80.0	85.7		ug/L		107	70 - 130	
1,2,4-Trimethylbenzene	20.0	22.7		ug/L		114	70 - 130	
1,3,5-Trimethylbenzene	20.0	22.4		ug/L		112	70 - 130	
Vinyl chloride	20.0	21.1		ug/L		105	70 - 130	
Xylenes, Total	40.0	44.4		ug/L		111	70 - 130	

Surrogate	LCS LCS		Limits
	%Recovery	Qualifier	
4-Bromofluorobenzene	107		70 - 130
1,2-Dichlorobenzene-d4	103		70 - 130

Lab Sample ID: LCS 680-347026/15

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 347026

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec.	
							Limits	
Diisopropyl ether	20.0	22.3		ug/L		112	70 - 130	
Tert-amyl methyl ether	20.0	22.9		ug/L		115	70 - 130	
tert-Butyl alcohol	100	106		ug/L		106	70 - 130	
Tert-butyl ethyl ether	20.0	22.4		ug/L		112	70 - 130	

Surrogate	LCS LCS		Limits
	%Recovery	Qualifier	
4-Bromofluorobenzene	108		70 - 130
1,2-Dichlorobenzene-d4	111		70 - 130

Lab Sample ID: LCSD 680-347026/14

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 347026

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec.		RPD	
							Limits		RPD	Limit
Acetone	100	96.2		ug/L		96	70 - 130	1	30	
Benzene	20.0	20.3		ug/L		102	70 - 130	0	30	
Bromobenzene	20.0	21.7		ug/L		109	70 - 130	2	30	
Bromoform	20.0	21.8		ug/L		109	70 - 130	1	30	
Bromomethane	20.0	25.5		ug/L		128	70 - 130	3	30	
Carbon tetrachloride	20.0	23.1		ug/L		116	70 - 130	2	30	
Chlorobenzene	20.0	21.7		ug/L		108	70 - 130	0	30	
Chlorobromomethane	20.0	21.7		ug/L		108	70 - 130	5	30	
Chlorodibromomethane	20.0	21.7		ug/L		108	70 - 130	1	30	
Chloroethane	20.0	22.9		ug/L		114	70 - 130	4	30	
Chloroform	20.0	21.3		ug/L		107	70 - 130	1	30	
Chloromethane	20.0	20.3		ug/L		102	70 - 130	3	30	
2-Chlorotoluene	20.0	22.5		ug/L		112	70 - 130	1	30	
4-Chlorotoluene	20.0	22.0		ug/L		110	70 - 130	1	30	
cis-1,2-Dichloroethene	20.0	22.1		ug/L		111	70 - 130	1	30	
cis-1,3-Dichloropropene	20.0	21.2		ug/L		106	70 - 130	1	30	
1,2-Dibromo-3-Chloropropane	20.0	19.9		ug/L		99	70 - 130	3	30	
Dibromomethane	20.0	21.0		ug/L		105	70 - 130	3	30	
1,2-Dichlorobenzene	20.0	21.2		ug/L		106	70 - 130	1	30	

TestAmerica Savannah

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 680-347026/14

Matrix: Water

Analysis Batch: 347026

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike	LCSD	LCSD	Unit	D	%Rec	%Rec.	RPD	RPD
	Added	Result	Qualifier				Limits		Limit
1,3-Dichlorobenzene	20.0	21.6		ug/L		108	70 - 130	1	30
1,4-Dichlorobenzene	20.0	21.2		ug/L		106	70 - 130	0	30
Dichlorobromomethane	20.0	21.9		ug/L		110	70 - 130	3	30
Dichlorodifluoromethane	20.0	19.8		ug/L		99	70 - 130	4	30
1,1-Dichloroethane	20.0	21.3		ug/L		107	70 - 130	1	30
1,2-Dichloroethane	20.0	22.3		ug/L		111	70 - 130	2	30
1,1-Dichloroethene	20.0	20.0		ug/L		100	70 - 130	2	30
1,2-Dichloropropane	20.0	20.8		ug/L		104	70 - 130	1	30
1,3-Dichloropropane	20.0	20.8		ug/L		104	70 - 130	2	30
2,2-Dichloropropane	20.0	22.9		ug/L		114	70 - 130	1	30
1,1-Dichloropropene	20.0	21.3		ug/L		106	70 - 130	1	30
1,3-Dichloropropene, Total	40.0	43.1		ug/L		108	70 - 130	0	30
Ethylbenzene	20.0	22.3		ug/L		111	70 - 130	2	30
Ethylene Dibromide	20.0	20.7		ug/L		104	70 - 130	2	30
Freon 113	20.0	20.8		ug/L		104	70 - 130	7	30
Hexachlorobutadiene	20.0	23.6		ug/L		118	70 - 130	4	30
2-Hexanone	100	103		ug/L		103	70 - 130	2	30
Isopropylbenzene	20.0	22.3		ug/L		112	70 - 130	0	30
4-Isopropyltoluene	20.0	23.4		ug/L		117	70 - 130	1	30
Methylene Chloride	20.0	19.0		ug/L		95	70 - 130	1	30
2-Butanone (MEK)	100	104		ug/L		104	70 - 130	1	30
4-Methyl-2-pentanone (MIBK)	100	105		ug/L		105	70 - 130	2	30
m-Xylene & p-Xylene	20.0	22.2		ug/L		111	70 - 130	0	30
Naphthalene	20.0	21.9		ug/L		110	70 - 130	2	30
n-Butylbenzene	20.0	23.2		ug/L		116	70 - 130	2	30
N-Propylbenzene	20.0	22.5		ug/L		113	70 - 130	1	30
o-Xylene	20.0	22.6		ug/L		113	70 - 130	2	30
sec-Butylbenzene	20.0	22.8		ug/L		114	70 - 130	0	30
Styrene	20.0	22.3		ug/L		112	70 - 130	0	30
tert-Butyl alcohol	200	204		ug/L		102	70 - 130	3	30
tert-Butylbenzene	20.0	23.1		ug/L		116	70 - 130	1	30
1,1,1,2-Tetrachloroethane	20.0	21.1		ug/L		106	70 - 130	0	30
1,1,2,2-Tetrachloroethane	20.0	19.6		ug/L		98	70 - 130	0	30
Tetrachloroethene	20.0	23.0		ug/L		115	70 - 130	0	30
Toluene	20.0	21.0		ug/L		105	70 - 130	2	30
trans-1,2-Dichloroethene	20.0	20.1		ug/L		100	70 - 130	2	30
trans-1,3-Dichloropropene	20.0	21.9		ug/L		109	70 - 130	1	30
1,2,3-Trichlorobenzene	20.0	21.6		ug/L		108	70 - 130	1	30
1,2,4-Trichlorobenzene	20.0	21.6		ug/L		108	70 - 130	0	30
1,1,1-Trichloroethane	20.0	22.0		ug/L		110	70 - 130	2	30
1,1,2-Trichloroethane	20.0	20.6		ug/L		103	70 - 130	1	30
Trichloroethene	20.0	20.8		ug/L		104	70 - 130	2	30
Trichlorofluoromethane	20.0	23.2		ug/L		116	70 - 130	1	30
1,2,3-Trichloropropane	20.0	19.7		ug/L		99	70 - 130	1	30
Trihalomethanes, Total	80.0	86.7		ug/L		108	70 - 130	1	30
1,2,4-Trimethylbenzene	20.0	23.1		ug/L		116	70 - 130	2	30
1,3,5-Trimethylbenzene	20.0	22.7		ug/L		113	70 - 130	1	30
Vinyl chloride	20.0	21.0		ug/L		105	70 - 130	0	30

TestAmerica Savannah

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 680-347026/14

Matrix: Water

Analysis Batch: 347026

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Xylenes, Total	40.0	44.9		ug/L		112	70 - 130	1	30

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
4-Bromofluorobenzene	109		70 - 130
1,2-Dichlorobenzene-d4	104		70 - 130

Lab Sample ID: LCSD 680-347026/16

Matrix: Water

Analysis Batch: 347026

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Diisopropyl ether	20.0	21.8		ug/L		109	70 - 130	2	30
Tert-amyl methyl ether	20.0	22.3		ug/L		111	70 - 130	3	30
tert-Butyl alcohol	100	102		ug/L		102	70 - 130	5	30
Tert-butyl ethyl ether	20.0	21.7		ug/L		108	70 - 130	3	30

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
4-Bromofluorobenzene	99		70 - 130
1,2-Dichlorobenzene-d4	99		70 - 130

QC Association Summary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

GC/MS VOA

Analysis Batch: 347026

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
680-104781-1	Trip Blank	Total/NA	Water	524.2	
680-104781-2	RFW-20	Total/NA	Water	524.2	
680-104781-3	RFW-21	Total/NA	Water	524.2	
680-104781-4	HAMP-22	Total/NA	Water	524.2	
680-104781-5	HAMP-23	Total/NA	Water	524.2	
LCS 680-347026/13	Lab Control Sample	Total/NA	Water	524.2	
LCS 680-347026/15	Lab Control Sample	Total/NA	Water	524.2	
LCSD 680-347026/14	Lab Control Sample Dup	Total/NA	Water	524.2	
LCSD 680-347026/16	Lab Control Sample Dup	Total/NA	Water	524.2	
MB 680-347026/18	Method Blank	Total/NA	Water	524.2	

TestAmerica Savannah

Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-104781-1

Date Collected: 08/27/14 06:00

Matrix: Water

Date Received: 08/29/14 09:36

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	5 mL	5 mL	347026	09/03/14 15:44	CAR	TAL SAV
Instrument ID: CMSS										

Client Sample ID: RFW-20

Lab Sample ID: 680-104781-2

Date Collected: 08/27/14 17:05

Matrix: Water

Date Received: 08/29/14 09:36

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	5 mL	5 mL	347026	09/03/14 18:03	CAR	TAL SAV
Instrument ID: CMSS										

Client Sample ID: RFW-21

Lab Sample ID: 680-104781-3

Date Collected: 08/27/14 07:35

Matrix: Water

Date Received: 08/29/14 09:36

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	5 mL	5 mL	347026	09/03/14 18:26	CAR	TAL SAV
Instrument ID: CMSS										

Client Sample ID: HAMP-22

Lab Sample ID: 680-104781-4

Date Collected: 08/28/14 09:10

Matrix: Water

Date Received: 08/29/14 09:36

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	5 mL	5 mL	347026	09/03/14 18:49	CAR	TAL SAV
Instrument ID: CMSS										

Client Sample ID: HAMP-23

Lab Sample ID: 680-104781-5

Date Collected: 08/28/14 09:15

Matrix: Water

Date Received: 08/29/14 09:36

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	5 mL	5 mL	347026	09/03/14 19:13	CAR	TAL SAV
Instrument ID: CMSS										

Laboratory References:

TAL SAV = TestAmerica Savannah, 5102 LaRoche Avenue, Savannah, GA 31404, TEL (912)354-7858

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

TestAmerica Savannah
5102 LaRoche Avenue
Savannah, GA 31404

Website: www.testamericainc.com
Phone: (912) 354-7858
Fax: (912) 352-0165

Alternate Laboratory Name/Location

Phone:
Fax:

PROJECT REFERENCE 02501-004.005		PROJECT NO.	PROJECT LOCATION (STATE) MD	MATRIX TYPE	REQUIRED ANALYSIS										PAGE 1	OF 1			
TAL (LAB) PROJECT MANAGER Lisa Harvey		P.O. NUMBER	CONTRACT NO.	COMPOSITE (C) OR GRAB (G) INDICATE AQUEOUS (WATER) SOLID OR SEMISOLID AIR NONAQUEOUS LIQUID (OIL, SOLVENT, ...)	5 2 4 . 2	Hcr	PRESERVATIVE	STANDARD REPORT DELIVERY <input checked="" type="radio"/>										DATE DUE _____	
CLIENT (SITE) PM Tom Carnot		CLIENT PHONE 610.701.3776	CLIENT FAX					EXPEDITED REPORT DELIVERY (SURCHARGE) <input type="radio"/>										DATE DUE _____	
CLIENT NAME Black + Decker		CLIENT E-MAIL						NUMBER OF COOLERS SUBMITTED PER SHIPMENT:											
CLIENT ADDRESS Hampstead MD		COMPANY CONTRACTING THIS WORK (if applicable) Weston Solutions						NUMBER OF CONTAINERS SUBMITTED										REMARKS	
SAMPLE		SAMPLE IDENTIFICATION																	
DATE	TIME																		
8/27/14	1600	Trip Blank																	
8/27/14	1705	RFW-20																	
8/27/14	735	RFW-21																	
8/28/14	910	HAMP-22																	
8/28/14	915	HAMP-23																	

RELINQUISHED BY: (SIGNATURE) <i>[Signature]</i>	DATE 8/28/14	TIME 1600	RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RELINQUISHED BY: (SIGNATURE)	DATE	TIME
RECEIVED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE) <i>[Signature]</i>	DATE 08/27/14	TIME 0936	CUSTODY INTACT YES <input checked="" type="radio"/> NO <input type="radio"/>	CUSTODY SEAL NO.	SAVANNAH LOG NO. 680 104781	LAB
---	-------------------------	---------------------	--	------------------	--	-----



680-104781 Chain of Custody

2loc

Login Sample Receipt Checklist

Client: Weston Solutions, Inc.

Job Number: 680-104781-1

Login Number: 104781

List Source: TestAmerica Savannah

List Number: 1

Creator: Banda, Christy S

Question	Answer	Comment
Radioactivity wasn't checked or is \leq background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	N/A	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

Certification Summary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-104781-1

Laboratory: TestAmerica Savannah

The certifications listed below are applicable to this report.

Authority	Program	EPA Region	Certification ID	Expiration Date
Maryland	State Program	3	250	12-31-14

