

Quarterly Groundwater Monitoring Report

Prepared for
Black & Decker (U.S.) Inc.
Hampstead, Maryland
April 2008

Prepared by

WESTON SOLUTIONS, INC.
West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 1st Quarter 2008	2-2
Table 2-2 Groundwater Elevation Data – 1st Quarter 2008	2-3
Table 2-3 Effluent Characteristics Summary – 1st Quarter 2008	2-4
Table 2-4 Summary of Groundwater Analytical Results - February 2008.....	2-5
Table 3-1 Treatment System Maintenance Activities – 1st Quarter 2008.....	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of January through March 2008.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of January through March 2008, the extraction wells were pumping at an average combined rate of approximately 162 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of January through March 2008 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of January through March 2008, approximately 16.3 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (82 %) and tetrachloroethene (PCE) (18 %). Analytical results of the groundwater collected from the air stripper for the period of January through March 2008 are included in Appendix C.

A summary of the analytical results from the first quarter (February 2008) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 1st Quarter 2008
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
January 2008	6,534,090
February 2008	5,852,190
March 2008	5,961,384

Table 2-2
Groundwater Elevation Data - 1st Quarter 2008
Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV.	TOTAL DEPTH	1/9/2008		2/19/2008		3/25/2008	
			DTW	ELEV.	DTW	ELEV.	DTW	ELEV.
EW-1	847.21	55	DRY	NA	DRY	NA	DRY	NA
EW-2	849.21	110	78.91	770.30	82.80	766.41	78.94	770.27
EW-3	846.64	118	92.93	753.71	93.63	753.01	95.11	751.53
EW-4	858.01	97.5	NA	NA	NA	NA	NA	NA
EW-5	864.17	98	81.73	782.44	85.12	779.05	80.04	784.13
EW-6	831.98	115	102.60	729.38	101.84	730.14	99.23	732.75
EW-7	818.38	78	63.30	755.08	55.71	762.67	57.40	760.98
EW-8	811.13	98	93.20	717.93	92.64	718.49	89.74	721.39
EW-9	811.35	141	102.61	708.74	101.64	709.71	102.10	709.25
EW-10	807.74	NA	63.47	744.27	62.98	744.76	63.40	744.34
RFW-1A	864.37	78	54.47	809.90	54.91	809.46	55.07	809.30
RFW-1B	864.23	200	54.50	809.73	54.75	809.48	54.94	809.29
RFW-2A	857.41	35	20.85	836.56	18.01	839.40	17.47	839.94
RFW-2B	857.73	75	21.22	836.51	18.65	839.08	17.88	839.85
RFW-3B	839.21	153	41.38	797.83	40.04	799.17	41.10	798.11
RFW-4A	830.37	62	39.14	791.23	38.94	791.43	39.07	791.30
RFW-4B	830.37	120	39.06	791.31	39.18	791.19	39.41	790.96
RFW-5A	817.50	30	DRY	NA	DRY	NA	DRY	NA
RFW-6	785.04	120	4.61	780.43	4.59	780.45	3.99	781.05
RFW-7	805.14	29	7.94	797.20	6.37	798.77	7.41	797.73
RFW-8	860.07	56	DRY	NA	DRY	NA	DRY	NA
RFW-9	862.02	49	30.27	831.75	28.35	833.67	30.07	831.95
RFW-10	852.06	58	DRY	NA	DRY	NA	NA	NA
RFW-11A	849.32	72	NA	NA	NA	NA	NA	NA
RFW-11B	849.62	116	69.83	779.79	69.29	780.33	70.10	779.52
RFW-12B	844.87	264	55.71	789.16	52.66	792.21	54.17	790.70
RFW-13	849.11	150	65.73	783.38	66.08	783.03	64.36	784.75
RFW-14B	812.39	281	NA	NA	NA	NA	NA	812.39
RFW-16	856.14	41	DRY	NA	DRY	NA	DRY	NA
RFW-17	834.66	60.5	30.34	804.32	29.54	805.12	29.47	805.19
RFW-20	842.49	142	39.26	803.23	38.05	804.44	39.41	803.08
RFW-21	832.65	102	25.61	807.04	24.51	808.14	24.54	808.11
PH-7	805.94	89	41.07	764.87	40.74	765.20	39.42	766.52
PH-9	814.94	98	47.11	767.83	47.84	767.10	47.17	767.77
PH-11	820.68	78	48.84	771.84	50.01	770.67	49.11	771.57
PH-12	828.35	87	51.73	776.62	52.76	775.59	50.61	777.74
B-3	803.02	83	NA	NA	NA	NA	9.90	793.12
Amoco	842.29	NA	NA	NA	NA	NA	NA	NA
Hamp. Town #22	804.96	NA	24.61	780.35	26.11	778.85	31.14	773.82
Pembroke #1	NA	NA	17.12	NA	16.94	NA	15.33	NA
Pembroke #2	NA	NA	NA	NA	NA	NA	NA	NA
N. Houcks. Rd.	NA	NA	10.30	NA	9.88	NA	9.94	NA
E. Century St.	NA	NA	17.41	NA	19.63	NA	23.41	NA
Lwr. Beckleys. Rd.	NA	NA	51.48	NA	52.06	NA	53.02	NA

NA - Not Available/Not Accessible

Table 2-3
Effluent Characteristics Summary - 1st Quarter 2008
Black & Decker
Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE		
				January 2008	February 2008	March 2008
001	FLOW average maximum	MGD	NA	0.194	0.199	0.192
		MGD	NA	0.273	0.301	0.315
	1,1,1-Trichloroethane	ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene	ug/l	5	< 1	< 1	< 1
	Trichloroethylene	ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine	mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease maximum monthly average	mg/l	15	6	< 5	15*
		mg/l	10	6	< 5	15*
	pH minimum maximum	STD	6.0	6.00	6.10	6.30
		STD	8.5	6.60	6.70	6.50
	BOD	mg/l	15	2.0	2.0	< 2
	TSS maximum monthly average	mg/l	30	5.0	< 4	7.0
		mg/l	20	5.0	< 4	7.0
101 (Monitoring Point)	FLOW average maximum	MGD	NA	0.203	0.261	0.325
		MGD	NA	0.790	0.464	0.399
	Fecal Coliform	MPN/100ml	200	< 1.8	< 2	< 1.8
201 (Monitoring Point)	FLOW average maximum	MGD	NA	NR	NR	0.192
		MGD	NA	NR	NR	0.225
	1,1,1-Trichloroethane	ug/l	NA	< 1	NR	NR
	Tetrachloroethylene	ug/l	NA	< 1	NR	NR
	Trichloroethylene	ug/l	NA	< 1	NR	NR

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

* - See the Non-Compliance Report Form in Appendix B for the cause of the non-compliance and the preventative measures that will be taken in the future.

Table 2-4
Summary of Groundwater Analytical Results - February 2008
Black & Decker
Hampstead, Maryland

PARAMETER	UNITS	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1.2	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3	1.6	1 U	1 U	1 U	6.4	18	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	350	130	830	150	8.7	5.4	9.2	1.4	1.4	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	57	3.4	18	4.4	15	11	62	160	170	4.2
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

Table 2-4
Summary of Groundwater Analytical Results - February 2008
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10	
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
Methylene Chloride	ug/L	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	NS	2 U	2 U	NS	2 U	NS	
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	5	1 U	1 U	5.5	NS	1 U	1 U	NS	11	NS	
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1.1	1	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.1	NS	
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
Trichloroethene	ug/L	1 U	1 U	2	1.6	1 U	28	27	11	NS	3.4	3.4	NS	16	NS	
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	1.7	22	21	51	NS	2.9	1 U	NS	6.6	NS	
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS	

Notes: DUP = Duplicate sample

NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

Table 2-4
Summary of Groundwater Analytical Results - February 2008
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	RFW-20	RFW-21	Town #22	Town #23	Trip Blank
		USEPA drinking water method 524.2														
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	NS	2 U	2 U	2 U	NS	2 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	NA	NA	NA	NA	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	1.6	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trichloroethene	ug/L	NS	10	560	3.3	NS	1 U	1 U	1 U	NS	1 U	0.9	0.5 U	0.5 U	0.5 U	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	1.6	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	1 U	40	16	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division. Samples from all of the other wells are analyzed with USEPA Method 8260.

NS = Not sampled

U = Compound was analyzed but not detected.

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from wells RFW-4B and EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (January through March 2008) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 1st Quarter 2008
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Jan-08	Alarm at air stripper. High column, reset the system everything back online.
Jan-08	Alarm at the stripper. EW-6 went down due to faulty heater. The heater was replaced well back online.
Feb-08	Alarm at the stripper. EW-7 went down due to faulty heater. The heater was replaced well back online.
Mar-08	2 Short power outages. The system was reset and is back online.
Mar-08	Alarm at stripper. High wet well, checked and reset the system, everything back online.
Mar-08	The pump in EW-3 was drawing high amps. The well was run during the day and turned off at night during the last week of March. The pump has been replaced and the well is back up and running all day.

4. RECOMMENDATIONS

For the reporting period of January through March 2008, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(JANUARY - MARCH 2008)

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operator Earle Villarreal, ESS Certification # 1017

Black & Decker WTP

PWSID # 106-0004

County: Carroll

Month: January

Operated by:

Maryland Environmental Service

Address: BTR CAPITAL GROUP, Hampstead, MD 21073

625 Hanover Pike, Hampstead, Carroll County, Maryland

Year: 2008

GENERAL (DOMESTIC WATER)				CHEMICAL					MONITORING		DISTRIBUTION			RAW WATER				
Date	Day	Weather	Flow meter reading o	MGD	pH	Free Cl2	Na2CO3 Level	Na2CO3 (gpd)	NaOCL Level	VOC'S (ppb)	Bacti Pos/Neg	pH su	TRC mg/l	DISTRIBUTION LOCATION	Operator Initials	pH su	TOTAL RAW WATER WELL (mgd)	Comments
1	tue	clr	0	0.0029	7.3	1.54	39.00	0.00	60.00	1.00					djones		0.217659	Jan
2	wed	cldy	0	0.0058	7.0	1.50	39.00	1.00	59.00	0.00		6.80	1.30	Eng Lab	djones	5.00	0.208581	
3	thur	clr	0	0.0056	6.9	1.45	38.00	2.00	59.00	0.00					djones		0.207409	
4	fri	clr	0	0.0027	6.9	1.48	36.00	1.00	59.00	0.00		6.7	1.20	Admin Bldg 1st fl	djones		0.215103	
5	sat	clr	0	0.0024	7.3	1.38	35.00	0.00	59.00	0.00					bc		0.208359	
6	sun	cldy	0	0.0026	7.0	1.37	35.00	2.00	59.00	0.00					bc		0.190723	
7	mon	clr	0	0.0066	7.4	1.48	33.00	2.00	59.00	0.00		7.3	1.20	Loading Dock	djones		0.212234	
8	tue	clr	0	0.0067	7.4	1.55	31.00	2.00	59.00	0.00					djones		0.203872	
9	wed	clr	0	0.0058	7.4	1.53	29.00	2.00	59.00	0.00		7.4	1.30	Eng Lab	djones	5.10	0.212678	
10	thur	clr	0	0.0054	7.4	1.39	27.00	2.00	59.00	0.00					djones		0.214263	
11	fri	rain	0	0.0051	7.0	1.63	45.00	2.00	59.00	0.00		7.0	1.40	Admin Bldg 1st fl	djones		0.220867	
12	sat	clr	0	0.0000	7.2	1.51	43.00	0.00	59.00	0.00					djones		0.208915	
13	sun	clr	0	0.0024	7.3	1.36	43.00	1.00	59.00	0.00					djones		0.197202	
14	mon	rain	0	0.0081	7.3	1.50	42.00	1.00	59.00	0.00		7.0	1.40	Eng Lab	bc		0.231873	
15	tue	snow	0	0.0051	7.2	1.43	41.00	1.00	59.00	0.00					ss		0.198425	
16	wed	clr	0	0.0051	7.4	1.62	40.00	2.00	59.00	0.00		7.1	1.40	Loading Dock	djones	5.20	0.200270	
17	thur	cldy	0	0.0054	7.5	1.64	38.00	1.00	59.00	0.00					djones		0.236780	
18	fri	clr	0	0.0026	7.8	1.56	37.00	1.00	59.00	0.00		7.4	1.30	Admin Bldg 1st fl	djones		0.192312	
19	sat	cldy	0	0.0023	7.3	1.29	36.00	1.00	59.00	0.00					ss		0.209022	
20	sun	cldy	0	0.0028	7.2	1.40	35.00	1.00	59.00	0.00					ss		0.231290	
21	mon	clr	0	0.0059	7.5	1.46	34.00	2.00	59.00	0.00					djones		0.189296	
22	tue	cldy	0	0.0057	7.8	1.54	32.00	2.00	59.00	0.00		7.4	1.30	Eng Lab	djones	4.90	0.226944	
23	wed	clr	0	0.0028	7.5	1.51	30.00	1.00	59.00	0.00		7.0	1.30	Loading Dock	djones		0.201547	
24	thur	cldy	0	0.0049	7.3	1.52	29.00	1.00	59.00	0.00					djones		0.216145	
25	fri	clr	0	0.0053	7.4	1.44	28.00	3.00	59.00	0.00		7.0	1.40	Admin Bldg 1st fl	djones		0.242970	
26	sat	clr	0	0.0019	7.5	1.61	45.00	0.00	59.00	0.00					bc		0.194979	
27	sun	clr	0	0.0036	7.5	1.41	45.00	1.00	59.00	0.00					bc		0.207925	
28	mon	clr	0	0.0038	7.1	1.32	91.00	1.00	59.00	0.00		7.6	1.50	Loading Dock	gd		0.210892	
29	tue	rain	0	0.0065	7.4	1.08	90.00	2.00	59.00	0.00					djones		0.214753	
30	wed	clr	0	0.0054	7.5	1.45	88.00	2.00	59.00	0.00		7.2	1.20		djones	5.20	0.214929	
31	thur	clr	0	0.0034	7.7	1.32	86.00	1.00	59.00	0.00					djones		0.195871	
Total				0.1346	227.4	45.27	1340.0	41.00	1830.0	1.00	0.0	0.0	92.9	17.2			6.534088	
Average				0.0043	7.3	1.46	43.23	1.32	59.03	0.03	0.0	0.0	7.15	1.32			0.210777	
Minimum				0.0000	6.9	1.08	27.00	0.00	59.00	0.00	0.0	0.0	6.70	1.20			0.189296	MOR
Maximum				0.0081	7.8	1.64	91.00	3.00	60.00	1.00	0.0	0.0	7.60	1.50			0.242970	04/09/07

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:

Maryland Environmental Service
259 Najeles Road, Millersville MD

Facility: BTR Capital Group

Address: 626 Hanover Pike, Hampstead Maryland

Permit Number: 02-DP-0022

Operator: Dorraine Jones, Scott Steadman

Certification # 763

Month: February

Year: # 2008

Final Effluent outfall 001												Outfall 101					Outfall 201					Comments	
Date	Appearance	Discharge MGD	pH	Cl ₂ mg/l	TetraChloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal Coli mpn	Basis: Inches	Alum Grd	Hypochlorite Grd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	Discharge mgd			
1.	clear	0.1120									0.39600		10.0	10.0	3.0	1.2					0.190055		
2.	clear	0.1710									0.40400		5.0	10.0	3.0	5.0					0.207695		
3.	clear	0.2690									0.00000		9.0			5.0					0.212504		
4.	clear	0.2490	6.5	0.00							0.00000		6.0								0.176950		
5.	clear	0.2100									0.00000		3.0								0.216714		
6.	clear	0.1910									0.40600	< 2	0.5	5.0	3.0	5.0					0.196407		
7.	clear	0.1950	6.2	0.00							0.40500		3.0	10.0	3.0	5.0					0.200007		
8.	clear	0.3010									0.46400		6.0	10.0	3.0	5.0					0.219400		
9.	clear	0.2560									0.40300		9.0	5.0	3.0	4.3					0.199473		
10.	clear	0.2240									0.00000		12.0			1.5					0.186118		
11.	clear	0.2640									0.34600		10.0	10.0	2.0	5.0					0.198923		
12.	clear	0.2860	6.1	0.00							0.37400		13.0	10.0	2.0	5.0					0.229673		
13.	clear	0.2250									0.28800		14.0	10.0	3.0	1.6					0.167731		
14.	clear	0.2700									0.37300	< 2	14.0	10.0	3.0	5.0					0.228119		
15.	clear	0.2480	6.2	0.00							0.17100		14.0								0.166856		
16.	clear	0.2480									0.00000		12.0								0.198046		
17.	clear	0.2170									0.00000		9.0								0.227103		
18.	clear	0.1730									0.00000		4.0								0.203280		
19.	clear	0.1890	6.7	0.00							0.00000		1.0								0.191971		
20.	clear	0.1520		< 1.00	< 1.00	< 1.00	2.0	< 4.0	< 5.0	0.34200	< 2	0.0	10.0	2.0	5.0						0.199945		
21.	clear	0.1530	6.1	0.00							0.40400	< 2	2.0	10.0	3.0	4.2					0.199069		
22.	clear	0.1360									0.37100		5.0	10.0	3.0	4.6					0.220762		
23.	clear	0.1220									0.39500		5.0	10.0	2.0	5.0					0.202782		
24.	clear	0.2430									0.33400		9.0	10.0	3.0	5.0					0.212152		
25.	clear	0.1360									0.33800		10.0	10.0	3.0	5.0					0.204732		
26.	clear	0.1300	6.5	0.00							0.26600		11.0	5.0	2.0	5.0					0.185619		
27.	clear	0.1280									0.40300	< 2	13.0	5.0	2.0	5.0					0.197020		
28.	clear	0.1290	6.2	0.00							0.32600		14.0	10.0	3.0	4.8					0.203348		
29.	clear	0.1480									0.36500		14.0	10.0	3.0	5.0					0.209740		
30.																							
31.																							
Total		5.7750	50.5	0.00	0.0	0.0	2	0	0	7.57400	5	237.5	180.0	34.0	97.2	0.00	0.00	0.00	5.85219				
Average		0.1991	6.3	<0.10	#DIV/0!	#DIV/0!	#DIV/0!	1.2	###	0.26117	1	8.2	9.0	2.7	4.4	#DIV/0!	#DIV/0!	#####	0.20180				
Minimum		0.11	6.1	0.00	0.0	0.0	2	0	0	0.00000	1	0.0	5.0	2.0	1.2	0.00	0.00	0.00	0.16686				
Maximum		0.30	6.7	<0.10	#DIV/0!	#DIV/0!	#DIV/0!	###	###	0.46400	1	14.0	10.0	3.0	5.0	0.00	0.00	0.00	0.22967	MOR 3-15-07			

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:

Maryland Environmental Service
259 Najiols Road, Millersville MD

Facility: BTR Capital Group

Address: 626 Hanover Pike, Hampstead Maryland

Permit Number: 02-DP-0022

Month: March

Operator: Dorrance Jones, Scott Steadman

Year: # 2008

Certification # 763

Date	Appearance	Final Effluent outfall 001								Outfall 101						Outfall 201					
		Discharge MGD	pH	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	Discharge mgd	
1	clear	0.1210																		0.179738	
2	clear	0.1350																		0.206183	
3	clear	0.1360									0.31300									0.203500	
4	clear	0.1490	6.3	0.00							0.34600									0.204112	
5	clear	0.1460			< 1.00	< 1.00	< 1.00	< 2.0	7.0	15.2	0.34300	< 1.8								0.200956	
6	clear	0.1500	6.1	0.00							0.35500									0.201534	
7	clear	0.2060									0.39900									0.217053	
8	clear	0.1550									0.33700									0.168879	
9	clear	0.1660																		0.203457	
10	clear	0.1890									0.31500									0.197989	
11	clear	0.2090	6.3	0.00							0.29200									0.206169	
12	clear	0.1860									0.30900	< 1.8								0.192638	
13	clear	0.1990	6.0	0.00							0.30200									0.198943	
14	clear	0.2230									0.38300									0.204455	
15	clear	0.2390									0.39900									0.196908	
16	clear	0.2850																		0.200021	
17	clear	0.3150																		0.186826	
18	clear	0.2990	6.5	0.00																0.188581	
19	clear	0.2050									0.31900									0.192346	
20	clear	0.1990	6.4	0.00							13.9	0.34200	< 2.0								0.201075
21	clear	0.2060										0.39200								0.212681	
22	clear	0.1560										0.19000								0.169615	
23	clear	0.1990										0.25900								0.225461	
24	clear	0.1930										0.29400								0.178742	
25	clear	0.2310	6.2	0.00								0.35000								0.178298	
26	clear	0.1750										0.31400	< 1.8								0.171904
27	clear	0.2050	6.3	0.00								0.31900								0.198155	
28	clear	0.1980										0.26800								0.157920	
29	clear	0.1950																		0.166825	
30	clear	0.1820																		0.169728	
31	clear	0.0990										0.33000								0.180686	
Total		5.9510	50.1	0.00	0.0	0.0	0.0	0	7	29.1	7.47000	4	0.0	0.0	0.0	0.0	0.00	0.00	0.00	5.96138	
Average		0.1920	6.3	<0.10	0.0	0.0	0.0	0	7	14.6	0.32478	1	#####	#####	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	0.19230	
Minimim		0.0990	6.0	0.00	0.0	0.0	0.0	0	7	13.9	0.19000	1	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.15792	
Maximim		0.3150	6.5	<0.10	0.0	0.0	0.0	0	7	15.2	0.39900	1	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.22546	

APPENDIX B
DISCHARGE MONITORING REPORTS
(JANUARY - MARCH 2008)

PERMITTEE NAME/ADDRESS (Include
Facility Name/Location if different)
NAME AG/GFI Hampstead, Inc

ADDRESS 626 Hanover Pike

Hampstead, MD 21074

FACILITY Black and Decker WWTP

LOCATION 626 Hanover Pike

ATTN:

PARAMETER (32-37)	(3 Card Only) (46-53)		QUANTITY OR LOADING (34-61)		(4 Card Only) (38-45)		QUANTITY OR CONCENTRATION (46-53)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	2	(19)	0	ONE/ MONTH	GRAB	
	PERMIT REQUIREMENTS	*****	*****	*****	*****	15	MG/L	0	ONE/ MONTH	GRAB	
pH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	6.0	*****	6.6	(12)	0	TWO/ WEEK	GRAB
	PERMIT REQUIREMENTS	*****	*****	*****	6.0	*****	8.5	SU	0	TWO/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	5	5	(19)	0	ONE/ MONTH	GRAB	
	PERMIT REQUIREMENTS	*****	*****	*****	20	30	MG/L	0	ONE/ MONTH	GRAB	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	193839	273000	(07) GPD	*****	*****	*****	0	MEASURED	RECORD	
	PERMIT REQUIREMENTS	REPORT	REPORT	*****	*****	*****	*****	0	MEASURED	RECORD	
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	<0.1	<0.1	(19)	0	ONE/ MONTH	GRAB	
	PERMIT REQUIREMENTS	*****	*****	*****	0.011	0.019	MG/L	0	ONE/ MONTH	GRAB	
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	0	0	0	0	ONE/ MONTH	GRAB	
	PERMIT REQUIREMENTS	*****	*****	*****	5	5	ug/l	0	ONE/ MONTH	GRAB	
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	0	0	0	0	ONE/ MONTH	GRAB	
	PERMIT REQUIREMENTS	*****	*****	*****	5	5	ug/l	0	ONE/ MONTH	GRAB	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry, of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.				TELEPHONE		DATE			
Jim Harkins, Director MES						410 729-8350		08	02	25	
TYPED OR PRINTED						SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE			

COMMENT AND EXPLANATION OF ANY VIOLATIONS/ Reference all attachments here)

State Discharge Permit
02-DP-0022

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

*** NO DISCHARGE ***
NOTE: Read Instructions before completing this form.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
NAME AG/GFI Hampstead, Inc

ADDRESS 626 Hanover Pike

Hampstead, MD 21074

FACILITY Black and Decker WWTP

LOCATION 626 Hanover Pike

ATTN:

PARAMETER (J2-37)	(3 Card Only) (46-53)		QUANTITY OR LOADING (54-61)		(4 Card Only) (38-45)		QUANTITY OR CONCENTRATION (46-53)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS					
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT REPORT PERMIT REQUIREMENT	203097	790000	(07) GPD	***** ***** *****	***** ***** *****	***** 1 200	0 *****	ONE/ MONTH ONE/ MONTH	GRAB GRAB		
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT REPORT PERMIT REQUIREMENT	***** *****	*****	*****	***** ***** *****	***** ***** *****	1 200	(30) MPN	ONE/ WEEK ONE/ WEEK	GRAB GRAB		
	SAMPLE MEASUREMENT REPORT PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT REPORT PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT REPORT PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT REPORT PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT REPORT PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT REPORT PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.						TELEPHONE		DATE		
Jim Harkins, Director MES								410- 729-8350		08	02	25
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS(Reference all attachments here)

State Discharge Permit
02-DP-0022

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME AG/GFI Hampstead, Inc
 ADDRESS 626 Hanover Pike

Hampstead, MD 21074
 FACILITY Black and Decker WWTP
 LOCATION 626 Hanover Pike

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) DISCHARGE MONITORING REPORT (DMR)									State Discharge Permit 02-DP-0022			
(2-16)				(17-19)								
MD0001881			001									
PERMIT NUMBER			DISCHARGE NUMBER									
MONITORING PERIOD												
FROM		YEAR	MO	DAY	TO	YEAR	MO	DAY				
		08	02	01		08	02	29				
		(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)				
*** NO DISCHARGE <input type="checkbox"/> ***												
NOTE: Read instructions before completing this form.												
PARAMETER (32-37)	(3 Card Only) (46-53)	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (46-53)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM					
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	2	(19)	0	ONE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****		15	MG/L	0	ONE/ MONTH
pH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	6.1	*****	6.7	(12)	0		TWO/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	6.0	*****		8.5	SU	0	TWO/ WEEK
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	0	0	(19)	0		ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	*****	20		30	MG/L	0	ONE/ MONTH
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	199138	301000	(07)	*****	*****	*****	*****	0		MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT		GPD	*****	*****		*****	*****	0	MEASURED
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	(19)	0		ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	*****	0.011		0.019	MG/L	0	ONE/ MONTH
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0	ug/l	0		ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****		5	ug/l	0	ONE/ MONTH
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0	ug/l	0		ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****		5	ug/l	0	ONE/ MONTH
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.			TELEPHONE			DATE				
Jim Harkins, Director MES												
TYPED OR PRINTED					SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include
Facility Name/Location if different)
NAME AG/GFI Hampstead, Inc

ADDRESS 626 Hanover Pike

Hampstead, MD 21074

FACILITY Black and Decker WWTP

LOCATION 626 Hanover Pike

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

State Discharge Permit
02-DP-0022

Form Approved. 12345
OMB No. 2040-0004.
Approval expires 05-31-98

MD0001881
PERMIT NUMBER

001
DISCHARGE NUMBER

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	08	02	01	TO	08	02	29
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(3 Card Only) (46-53)		QUANTITY OR LOADING (54-61)		(4 Card Only) (38-45)		QUANTITY OR CONCENTRATION (46-53) (54-61)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)		
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS						
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	*****	*****	0			0	ONE/ MONTH	GRAB		
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	5			ug/l	ONE/ MONTH	GRAB		
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****	*****	*****	0	0		(19)	0	ONE/ MONTH	GRAB	
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	10	15		MG/L	ONE/ MONTH	GRAB		
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.						TELEPHONE		DATE			
Jim Harkins, Director MES								410	729-8350	08	03	24	
TYPED OR PRINTED								SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS(Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include
Facility Name/Location if different)
NAME AG/GFI Hampstead, Inc

ADDRESS 626 Hanover Pike

Hampstead, MD 21074

FACILITY Black and Decker WWTP

LOCATION 626 Hanover Pike

ATTN:

PARAMETER (32-37)			QUANTITY OR LOADING (34-61)			QUANTITY OR CONCENTRATION (34-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS					
	SAMPLE MEASUREMENT	REPORT	GPD	*****	*****	*****	*****					
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	261172	464000	(07)	*****	*****	*****	0	ONE/ MONTH	GRAB		
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	1	(30)	0	ONE/ WEEK	GRAB		
	PERMIT REQUIREMENT	*****	*****	*****	*****	200	MPN		ONE/ WEEK	GRAB		
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		<p>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</p>						TELEPHONE		DATE		
Jim Harkins, Director MES								410	729-8350	08	03	24
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

MD0001881

PERMIT NUMBER

101

DISCHARGE NUMBER

State Discharge Permit
02-DP-0022

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PERMITTEE NAME/ADDRESS (Include
Facility Name/Location if different)
NAME AG/GFI Hampstead, Inc

ADDRESS 626 Hanover Pike

Hampstead, MD 21074

FACILITY Black and Decker WWTP

LOCATION 626 Hanover Pike

ATTN:

PARAMETER (32-37)	(3 Card Only) (46-53)		QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45)		QUANTITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS						
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	0	(19)	0	ONE/ MONTH	GRAB			
pH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	6.0	*****	6.5	(12)	0	TWO/ WEEK	GRAB		
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	6.0	*****	8.5	SU	ONE/ WEEK	GRAB			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	191968	315000	(07)	*****	*****	*****	(19)	0	ONE/ MONTH	GRAB		
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	(19)	0	ONE/ MONTH	GRAB		
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	0	ug/l	0	ONE/ MONTH	GRAB			
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	0	ug/l	0	ONE/ MONTH	GRAB			
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.						TELEPHONE		DATE			
Jim Harkins, Director MES								410	729-8350	08	04	28	
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MO	DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

State Discharge Permit
02-DP-0022


Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

*** NO DISCHARGE ***

NOTE: Read Instructions before completing this form.


SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

PERMITTEE NAME/ADDRESS (Include
Facility Name/Location if different)
NAME AG/GFI Hampstead, Inc

ADDRESS 626 Hanover Pike

Hampstead, MD 21074

FACILITY Black and Decker WWTP

LOCATION 626 Hanover Pike

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

State Discharge Permit
02-DP-0022

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

MD0001881

PERMIT NUMBER


001

DISCHARGE NUMBER

FROM			TO			MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY	(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)
08	03	01	08	03	31						

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) (46-53)		QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45)			QUANTITY OR CONCENTRATION (46-53) (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****		*****	*****	0						0	ONE/ MONTH	GRAB
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENTS	*****	*****		*****	*****	*****		*****	*****	*****			ONE/ MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****		*****	15	15						(19)	ONE/ MONTH	GRAB
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENTS	*****	*****		*****	10	15		*****	*****	*****		MG/L	ONE/ MONTH	GRAB
	SAMPLE MEASUREMENT														
	PERMIT REQUIREMENTS														
	SAMPLE MEASUREMENT														
	PERMIT REQUIREMENTS														
	SAMPLE MEASUREMENT														
	PERMIT REQUIREMENTS														
	SAMPLE MEASUREMENT														
	PERMIT REQUIREMENTS														
	SAMPLE MEASUREMENT														
	PERMIT REQUIREMENTS														
	SAMPLE MEASUREMENT														
	PERMIT REQUIREMENTS														

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Jim Harkins, Director MES

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

410 729-8350 08 04 28

AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include
Facility Name/Location if different)
NAME AG/GFI Hampstead, Inc

ADDRESS 626 Hanover Pike

Hampstead, MD 21074

FACILITY Black and Decker WWTP

LOCATION 626 Hanover Pike

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

State Discharge Permit
02-DP-0022

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

MD0001881

PERMIT NUMBER

101

DISCHARGE NUMBER

MONITORING PERIOD					
FROM	YEAR	MO	DAY	TO	YEAR
	08	03	01	TO	08
	(20-21)	(22-23)	(24-25)	(26-27)	(28-29)
				(30-31)	

*** NO DISCHARGE ***

NOTE: Read Instructions before completing this form.


PARAMETER (32-37)	(3 Card Only) (46-53)		QUANTITY OR LOADING (54-61)		(4 Card Only) (38-45)		QUANTITY OR CONCENTRATION (46-53)		(54-61)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS						
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	240968	399000	(07)	*****	*****	*****				0	ONE/ MONTH	GRAB
COLIFORM, FECAL. GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*	*****	*****	1	(30)			0	ONE/ WEEK	GRAB
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENTS												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENTS												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENTS												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENTS												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENTS												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENTS												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENTS												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENTS												

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Jim Harkins, Director MES

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE DATE

410 729-8350 08 04 28

AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Maryland Environmental Service
259 Najoles Road
Millersville, Maryland 21108

Non-Compliance
Report Form

Date: April 28, 2008

To: MDE- Compliance and Inspection Division
From: (Name) Earle-Villarreal
(Title) ESS
Subject: Non-complying discharge
Facility: Black and Decker WWTP
Permit No (State) 02 -DP- 0022 (Federal) MD0001881

Non-complying Month/ Year March-08

1. A non-complying discharge of Oil & Grease at outfall 001 occurred on March-08

2. The impact on the receiving stream was

No visible impact

3. The cause of the non-compliance was

The client washed the roof of the building. This caused the run-off to flow directly into the lagoons.

4. The non-complying discharge continued for a period of

03/01 - 03/31/08

5. The following action (is being) (was) (will be) taken to correct the problem causing the non compliance

In the future the client will let operations know when major cleaning is being accomplished so different measures can be taken to minimize the chances of a non-compliance occurring.

6. The following action is being taken to prevent recurrence of a non-complying discharge of this nature

See above

7. The following analysis were performed to determine the nature and impact on the receiving stream

All other NPDES permit requirements were met daily and for the Month

8. Comments:

All other NPDES permit requirements were met daily and for the Month

Parameter	Monthly		
Limit	10 mg/l		
Unit	Oil&Grease		
Date			
1			
2			
3			
4			
5	15.2		
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20	13.9		
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
Average	15		

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(JANUARY - MARCH 2008)



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Attention: Mr. Jay Janney

Order Number: A08010431
Project Name: Black & Decker WWTP
Receive Date: 1/9/2008
Client Code: MES_A
Project Location: Black & Decker WWTP

Sample # A08010431-01

Sample Date: 1/9/2008 10:30

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	2	mg/L	2	SM 5210 B	1/10/2008 12:30:00 PM	JMcGuire
Total Suspended Solids	5	mg/L	4	SM 2540D	1/11/2008 3:00:00 PM	JMcGuire

Sample # A08010431-01A

Sample Date: 1/9/2008 10:30

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID: A

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	6.0	mg/L	5	EPA 1664	1/18/2008 1:00:00 PM	SHess

Sample # A08010431-01B

Sample Date: 1/9/2008 10:30

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID: B

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	1/15/2008 11:13:00 PM	IMcMullen
Tetrachloroethene	<1	ug/L	1	EPA 8260B	1/15/2008 11:13:00 PM	IMcMullen
Trichloroethene	<1	ug/L	1	EPA 8260B	1/15/2008 11:13:00 PM	IMcMullen

Approved: *Warren Van Andell*
Quality Assurance Manager

Reported: 1/30/2008 8:09:33 AM

RDL = Reporting Detection Limit

N/A = Not Applicable

Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.AtlanticCoastLabs.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Attention: Mr. Jay Janney

Order Number: A08010432
Project Name: Black & Decker WWTP
Receive Date: 1/9/2008
Client Code: MES_A
Project Location: Black & Decker WWTP

Sample # A08010432-01

Sample Date: 1/9/2008 10:15

Site: Black & Decker 201

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	1/15/2008 11:45:00 PM	IMcMullen
Tetrachloroethene	<1	ug/L	1	EPA 8260B	1/15/2008 11:45:00 PM	IMcMullen
Trichlorofluoromethane	<1	ug/L	1	EPA 8260B	1/15/2008 11:45:00 PM	IMcMullen

Approved: *Warren Van Andell*
Quality Assurance Manager

Reported: 1/22/2008 8:17:55 AM

RDL = Reporting Detection Limit

N/A = Not Applicable

Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.AtlanticCoastLabs.com

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Attention: Mr. Jay Janney

Order Number: A08021019
Project Name: Black & Decker WWTP
Receive Date: 2/20/2008
Client Code: MES_A
Project Location: Black & Decker WWTP

Sample # A08021019-01

Sample Date: 2/20/2008 11:20

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	2	mg/L	2	SM 5210 B	2/21/2008 11:45:00 AM	JMcGuire
Total Suspended Solids	<4	mg/L	4	SM 2540D	2/25/2008 2:55:00 PM	JMcGuire

Sample # A08021019-01A

Sample Date: 2/20/2008 11:20

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID: A

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	<5	mg/L	5	EPA 1664	2/21/2008 2:45:00 PM	SHess

Sample # A08021019-01B

Sample Date: 2/20/2008 11:20

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID: B

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	3/2/2008 9:07:00 AM	JKozlowski
Tetrachloroethene	<1	ug/L	1	EPA 8260B	3/2/2008 9:07:00 AM	JKozlowski
Trichloroethene	<1	ug/L	1	EPA 8260B	3/2/2008 9:07:00 AM	JKozlowski

Approved: *Warren Van Andale*
Quality Assurance Manager

Reported: 3/10/2008 7:28:19 AM

RDL = Reporting Detection Limit N/A = Not Applicable

Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.AtlanticCoastLabs.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najeles Road
Millersville, MD 21108

Attention: Mr. Jay Janney

Order Number: A08030269
Project Name: Black & Decker WWTP
Receive Date: 3/5/2008
Client Code: MES_A
Project Location: Black & Decker WWTP

Sample # A08030269-01

Sample Date: 3/5/2008 10:55

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	<2	mg/L	2	SM 5210 B	3/6/2008 11:15:00 AM	JMcGuire
Total Suspended Solids	7	mg/L	4	SM 2540D	3/10/2008 7:04:00 PM	JMcGuire

Sample # A08030269-01A

Sample Date: 3/5/2008 10:55

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID: A

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	15.2	mg/L	5	EPA 1664	3/6/2008 4:05:00 PM	SHess

Sample # A08030269-01B

Sample Date: 3/5/2008 10:55

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID: B

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	3/13/2008 1:31:00 AM	JKozlowski
Tetrachloroethene	<1	ug/L	1	EPA 8260B	3/13/2008 1:31:00 AM	JKozlowski
Trichloroethene	<1	ug/L	1	EPA 8260B	3/13/2008 1:31:00 AM	JKozlowski

Approved:

Quality Assurance Manager

Reported:

3/14/2008 2:08:13 PM

RDL = Reporting Detection Limit N/A = Not Applicable

Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.AtlanticCoastLabs.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Attention: Mr. Jay Janney

Order Number: A08031077
Project Name: Black & Decker WWTP
Receive Date: 3/20/2008
Client Code: MES_A
Project Location: Black & Decker WWTP

Sample # A08031077-01

Sample Date: 3/20/2008 12:15

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	13.9	mg/L	5	EPA 1664	3/20/2008 5:23:00 PM	SHess

Approved: *Warren Van Androll*
Quality Assurance Manager

Reported: 3/27/2008 12:17:34 PM

RDL = Reporting Detection Limit

N/A = Not Applicable

Laboratory Certification Numbers: Delaware - DE00011 Maryland - #J38 Pennsylvania - 68-335 New Jersey - DE568

APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(FEBRUARY 2008)

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

Job Number: 500-9643-1

Job Description: Black and Decker

For:

Weston Solutions, Inc.

1400 Weston Way

PO BOX 2653

West Chester, PA 19380

Attention: Mr. Tom Cornuet



Richard C Wright
Project Manager II
richard.wright@testamericainc.com
02/27/2008

cc: Greg Flasinski

These test results meet all the requirements of NELAC for accredited parameters.

The Lab Certification ID# is 100201.

All questions regarding this test report should be directed to the TestAmerica Project Manager whose signature appears on this report. All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.

Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.

TestAmerica Laboratories, Inc.

TestAmerica Chicago 2417 Bond Street, University Park, IL 60466

Tel (708) 534-5200 Fax (708) 534-5211 www.testamericainc.com



**Job Narrative
500-J9643-1**

Comments

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

GC/MS VOA

No analytical or quality issues were noted.

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-9643-3	RFW-2A				
Trichloroethene		2.0	1.0	ug/L	8260B
500-9643-4	RFW-2B				
Trichloroethene		1.6	1.0	ug/L	8260B
500-9643-5	RFW-3B				
cis-1,2-Dichloroethene		5.0	1.0	ug/L	8260B
Tetrachloroethene		1.7	1.0	ug/L	8260B
500-9643-6	RFW-4A				
Chloroform		1.1	1.0	ug/L	8260B
Trichloroethene		28	1.0	ug/L	8260B
Tetrachloroethene		22	1.0	ug/L	8260B
500-9643-7	RFW-4A DUP				
Chloroform		1.0	1.0	ug/L	8260B
Trichloroethene		27	1.0	ug/L	8260B
Tetrachloroethene		21	1.0	ug/L	8260B
500-9643-8	RFW-4B				
cis-1,2-Dichloroethene		5.5	1.0	ug/L	8260B
Trichloroethene		11	1.0	ug/L	8260B
Tetrachloroethene		51	1.0	ug/L	8260B
500-9643-9	RFW-6				
Trichloroethene		3.4	1.0	ug/L	8260B
Tetrachloroethene		2.9	1.0	ug/L	8260B
500-9643-10	RFW-7				
Trichloroethene		3.4	1.0	ug/L	8260B

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-9643-11	RFW-9				
cis-1,2-Dichloroethene		11	1.0	ug/L	8260B
1,1,1-Trichloroethane		1.1	1.0	ug/L	8260B
Trichloroethene		16	1.0	ug/L	8260B
Tetrachloroethene		6.6	1.0	ug/L	8260B
500-9643-12	RFW-11B				
Trichloroethene		10	1.0	ug/L	8260B
500-9643-13	RFW-12B				
cis-1,2-Dichloroethene		1.6	1.0	ug/L	8260B
Trichloroethene		560	10	ug/L	8260B
Tetrachloroethene		40	1.0	ug/L	8260B
500-9643-14	RFW-13				
Trichloroethene		3.3	1.0	ug/L	8260B
Tetrachloroethene		16	1.0	ug/L	8260B
500-9643-15	RFW-17				
Benzene		1.6	1.0	ug/L	8260B
500-9643-19	EW-2				
cis-1,2-Dichloroethene		3.0	1.0	ug/L	8260B
Trichloroethene		350	10	ug/L	8260B
Tetrachloroethene		57	1.0	ug/L	8260B
500-9643-20	EW-3				
cis-1,2-Dichloroethene		1.6	1.0	ug/L	8260B
Trichloroethene		130	10	ug/L	8260B
Tetrachloroethene		3.4	1.0	ug/L	8260B
500-9643-21	EW-4				
Trichloroethene		830	10	ug/L	8260B
Tetrachloroethene		18	1.0	ug/L	8260B

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-9643-22	EW-5				
Trichloroethene		150	10	ug/L	8260B
Tetrachloroethene		4.4	1.0	ug/L	8260B
500-9643-23	EW-6				
Trichloroethene		8.7	1.0	ug/L	8260B
Tetrachloroethene		15	1.0	ug/L	8260B
500-9643-24	EW-7				
cis-1,2-Dichloroethene		6.4	1.0	ug/L	8260B
Trichloroethene		5.4	1.0	ug/L	8260B
Tetrachloroethene		11	1.0	ug/L	8260B
500-9643-25	EW-8				
cis-1,2-Dichloroethene		18	1.0	ug/L	8260B
Trichloroethene		9.2	1.0	ug/L	8260B
Tetrachloroethene		62	1.0	ug/L	8260B
500-9643-26	EW-9				
Trichloroethene		1.4	1.0	ug/L	8260B
Tetrachloroethene		160	10	ug/L	8260B
500-9643-27	EW-9 DUP				
Trichloroethene		1.4	1.0	ug/L	8260B
Tetrachloroethene		170	10	ug/L	8260B
500-9643-28	EW-10				
Tetrachloroethene		4.2	1.0	ug/L	8260B

METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Description	Lab Location	Method	Preparation Method
Matrix: Water			
VOC	TAL CHI	SW846 8260B	
Purge-and-Trap	TAL CHI		SW846 5030B

Lab References:

TAL CHI = TestAmerica Chicago

Method References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
500-9643-1	RFW-1A	Water	02/19/2008 0915	02/22/2008 1000
500-9643-2	RFW-1B	Water	02/20/2008 0730	02/22/2008 1000
500-9643-3	RFW-2A	Water	02/19/2008 0755	02/22/2008 1000
500-9643-4	RFW-2B	Water	02/19/2008 0840	02/22/2008 1000
500-9643-5	RFW-3B	Water	02/20/2008 0815	02/22/2008 1000
500-9643-6	RFW-4A	Water	02/20/2008 1110	02/22/2008 1000
500-9643-7	RFW-4A Dup	Water	02/20/2008 1110	02/22/2008 1000
500-9643-8	RFW-4B	Water	02/20/2008 1145	02/22/2008 1000
500-9643-9	RFW-6	Water	02/20/2008 0745	02/22/2008 1000
500-9643-10	RFW-7	Water	02/19/2008 0950	02/22/2008 1000
500-9643-11	RFW-9	Water	02/20/2008 0745	02/22/2008 1000
500-9643-12	RFW-11B	Water	02/20/2008 1100	02/22/2008 1000
500-9643-13	RFW-12B	Water	02/20/2008 1015	02/22/2008 1000
500-9643-14	RFW-13	Water	02/19/2008 1615	02/22/2008 1000
500-9643-15	RFW-17	Water	02/19/2008 1030	02/22/2008 1000
500-9643-16	Leister-1	Water	02/19/2008 1730	02/22/2008 1000
500-9643-17	Leister-Dairy	Water	02/19/2008 1735	02/22/2008 1000
500-9643-18	Trip Blank	Water	02/19/2008 0700	02/22/2008 1000
500-9643-19	EW-2	Water	02/20/2008 1110	02/22/2008 1000
500-9643-20	EW-3	Water	02/19/2008 0915	02/22/2008 1000
500-9643-21	EW-4	Water	02/20/2008 0900	02/22/2008 1000
500-9643-22	EW-5	Water	02/19/2008 0910	02/22/2008 1000
500-9643-23	EW-6	Water	02/20/2008 1020	02/22/2008 1000
500-9643-24	EW-7	Water	02/20/2008 0710	02/22/2008 1000
500-9643-25	EW-8	Water	02/20/2008 0700	02/22/2008 1000
500-9643-26	EW-9	Water	02/20/2008 0650	02/22/2008 1000
500-9643-27	EW-9 Dup	Water	02/20/2008 0650	02/22/2008 1000
500-9643-28	EW-10	Water	02/20/2008 0645	02/22/2008 1000

SAMPLE RESULTS

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-1A
Lab Sample ID: 500-9643-1

Date Sampled: 02/19/2008 0915
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/25/2008 1553	
Prep Method: 5030B			Date Prepared:	02/25/2008 1553	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	<1.0	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-1A
Lab Sample ID: 500-9643-1

Date Sampled: 02/19/2008 0915
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate					Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	100	%			70 - 125
Toluene-d8 (Surr)	96	%			75 - 120
4-Bromofluorobenzene (Surr)	95	%			75 - 120
Dibromofluoromethane	96	%			75 - 120

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-1B
Lab Sample ID: 500-9643-2

Date Sampled: 02/20/2008 0730
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/25/2008 1616	
Prep Method: 5030B			Date Prepared:	02/25/2008 1616	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	<1.0	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-1B
Lab Sample ID: 500-9643-2

Date Sampled: 02/20/2008 0730
 Date Received: 02/22/2008 1000
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	99	%		70 - 125	
Toluene-d8 (Surr)	97	%		75 - 120	
4-Bromofluorobenzene (Surr)	94	%		75 - 120	
Dibromofluoromethane	94	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-2A
Lab Sample ID: 500-9643-3

Date Sampled: 02/19/2008 0755
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1156	
Prep Method: 5030B			Date Prepared:	02/26/2008 1156	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	2.0	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-2A
Lab Sample ID: 500-9643-3

Date Sampled: 02/19/2008 0755
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	99	%		70 - 125	
Toluene-d8 (Surr)	95	%		75 - 120	
4-Bromofluorobenzene (Surr)	92	%		75 - 120	
Dibromofluoromethane	98	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-2B
Lab Sample ID: 500-9643-4

Date Sampled: 02/19/2008 0840
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1219	
Prep Method: 5030B			Date Prepared:	02/26/2008 1219	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorodifluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromoform	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	1.6	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-2B
Lab Sample ID: 500-9643-4

Date Sampled: 02/19/2008 0840
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	100	%		70 - 125	
Toluene-d8 (Surr)	94	%		75 - 120	
4-Bromofluorobenzene (Surr)	94	%		75 - 120	
Dibromofluoromethane	96	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-3B
Lab Sample ID: 500-9643-5

Date Sampled: 02/20/2008 0815
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/25/2008 1810	
Prep Method: 5030B			Date Prepared:	02/25/2008 1810	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	5.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	<1.0	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	1.7	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-3B
Lab Sample ID: 500-9643-5

Date Sampled: 02/20/2008 0815
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		70 - 125	
Toluene-d8 (Surr)	95	%		75 - 120	
4-Bromofluorobenzene (Surr)	95	%		75 - 120	
Dibromofluoromethane	96	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-4A
Lab Sample ID: 500-9643-6

Date Sampled: 02/20/2008 1110
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/25/2008 1856	
Prep Method: 5030B			Date Prepared:	02/25/2008 1856	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	1.1	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	28	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	22	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-4A
 Lab Sample ID: 500-9643-6

Date Sampled: 02/20/2008 1110
 Date Received: 02/22/2008 1000
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		70 - 125	
Toluene-d8 (Surr)	94	%		75 - 120	
4-Bromofluorobenzene (Surr)	95	%		75 - 120	
Dibromofluoromethane	100	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-4A Dup
Lab Sample ID: 500-9643-7

Date Sampled: 02/20/2008 1110
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/25/2008 1919	
Prep Method: 5030B			Date Prepared:	02/25/2008 1919	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	27	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	21	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-4A Dup
Lab Sample ID: 500-9643-7

Date Sampled: 02/20/2008 1110
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		70 - 125	
Toluene-d8 (Surr)	96	%		75 - 120	
4-Bromofluorobenzene (Surr)	91	%		75 - 120	
Dibromofluoromethane	96	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-4B
Lab Sample ID: 500-9643-8

Date Sampled: 02/20/2008 1145
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/25/2008 1942	
Prep Method: 5030B			Date Prepared:	02/25/2008 1942	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorodifluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	5.5	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	11	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	51	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-4B
Lab Sample ID: 500-9643-8

Date Sampled: 02/20/2008 1145
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	105	%		70 - 125	
Toluene-d8 (Surr)	97	%		75 - 120	
4-Bromofluorobenzene (Surr)	93	%		75 - 120	
Dibromofluoromethane	102	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-6
Lab Sample ID: 500-9643-9

Date Sampled: 02/20/2008 0745
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/25/2008	2004
Prep Method: 5030B			Date Prepared:	02/25/2008	2004
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromoform	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	3.4	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	2.9	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-6
Lab Sample ID: 500-9643-9

Date Sampled: 02/20/2008 0745
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	104	%		70 - 125	
Toluene-d8 (Surr)	95	%		75 - 120	
4-Bromofluorobenzene (Surr)	95	%		75 - 120	
Dibromofluoromethane	100	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-7
Lab Sample ID: 500-9643-10

Date Sampled: 02/19/2008 0950
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/25/2008	2027
Prep Method: 5030B			Date Prepared:	02/25/2008	2027
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorodifluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromoform	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	3.4	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-7
 Lab Sample ID: 500-9643-10

Date Sampled: 02/19/2008 0950
 Date Received: 02/22/2008 1000
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	107	%		70 - 125	
Toluene-d8 (Surr)	96	%		75 - 120	
4-Bromofluorobenzene (Surr)	93	%		75 - 120	
Dibromofluoromethane	101	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-9
Lab Sample ID: 500-9643-11

Date Sampled: 02/20/2008 0745
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/25/2008	2050
Prep Method: 5030B			Date Prepared:	02/25/2008	2050
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	11	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	1.1	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	16	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	6.6	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-9
Lab Sample ID: 500-9643-11

Date Sampled: 02/20/2008 0745
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	106	%		70 - 125	
Toluene-d8 (Surr)	97	%		75 - 120	
4-Bromofluorobenzene (Surr)	92	%		75 - 120	
Dibromofluoromethane	100	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-11B
Lab Sample ID: 500-9643-12

Date Sampled: 02/20/2008 1100
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1241	
Prep Method: 5030B			Date Prepared:	02/26/2008 1241	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorodifluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	10	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromo-chloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-11B
 Lab Sample ID: 500-9643-12

Date Sampled: 02/20/2008 1100
 Date Received: 02/22/2008 1000
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate					Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	100	%		70 - 125	
Toluene-d8 (Surr)	95	%		75 - 120	
4-Bromofluorobenzene (Surr)	93	%		75 - 120	
Dibromofluoromethane	96	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-12B
Lab Sample ID: 500-9643-13

Date Sampled: 02/20/2008 1015
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1304	
Prep Method: 5030B			Date Prepared:	02/26/2008 1304	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorodifluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	1.6	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromoform	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	40	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-12B
 Lab Sample ID: 500-9643-13

Date Sampled: 02/20/2008 1015
 Date Received: 02/22/2008 1000
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		70 - 125	
Toluene-d8 (Surr)	96	%		75 - 120	
4-Bromofluorobenzene (Surr)	95	%		75 - 120	
Dibromofluoromethane	96	%		75 - 120	
Method: 8260B Run Type: DL			Date Analyzed:	02/27/2008 1016	
Prep Method: 5030B			Date Prepared:	02/27/2008 1016	
Trichloroethene	560	ug/L	2.0	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		70 - 125	
Toluene-d8 (Surr)	96	%		75 - 120	
4-Bromofluorobenzene (Surr)	91	%		75 - 120	
Dibromofluoromethane	99	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-13
Lab Sample ID: 500-9643-14

Date Sampled: 02/19/2008 1615
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1327	
Prep Method: 5030B			Date Prepared:	02/26/2008 1327	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	3.3	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	16	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-13
Lab Sample ID: 500-9643-14

Date Sampled: 02/19/2008 1615
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	103	%		70 - 125	
Toluene-d8 (Surr)	95	%		75 - 120	
4-Bromofluorobenzene (Surr)	92	%		75 - 120	
Dibromofluoromethane	97	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-17
Lab Sample ID: 500-9643-15

Date Sampled: 02/19/2008 1030
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1350	
Prep Method: 5030B			Date Prepared:	02/26/2008 1350	
Benzene	1.6	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	<1.0	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: RFW-17
 Lab Sample ID: 500-9643-15

Date Sampled: 02/19/2008 1030
 Date Received: 02/22/2008 1000
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		70 - 125	
Toluene-d8 (Surr)	95	%		75 - 120	
4-Bromofluorobenzene (Surr)	96	%		75 - 120	
Dibromofluoromethane	96	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: Leister-1
Lab Sample ID: 500-9643-16

Date Sampled: 02/19/2008 1730
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1413	
Prep Method: 5030B			Date Prepared:	02/26/2008 1413	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	<1.0	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: Leister-1
Lab Sample ID: 500-9643-16

Date Sampled: 02/19/2008 1730
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	103	%		70 - 125	
Toluene-d8 (Surr)	96	%		75 - 120	
4-Bromofluorobenzene (Surr)	91	%		75 - 120	
Dibromofluoromethane	96	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: Lester-Dairy
Lab Sample ID: 500-9643-17

Date Sampled: 02/19/2008 1735
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1436	
Prep Method: 5030B			Date Prepared:	02/26/2008 1436	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	<1.0	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromo-chloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: Leister-Dairy
Lab Sample ID: 500-9643-17

Date Sampled: 02/19/2008 1735
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	104	%		70 - 125	
Toluene-d8 (Surr)	94	%		75 - 120	
4-Bromofluorobenzene (Surr)	93	%		75 - 120	
Dibromofluoromethane	100	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: Trip Blank
Lab Sample ID: 500-9643-18

Date Sampled: 02/19/2008 0700
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1459	
Prep Method: 5030B			Date Prepared:	02/26/2008 1459	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromoform	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	<1.0	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: Trip Blank
 Lab Sample ID: 500-9643-18

Date Sampled: 02/19/2008 0700
 Date Received: 02/22/2008 1000
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	104	%		70 - 125	
Toluene-d8 (Surr)	96	%		75 - 120	
4-Bromofluorobenzene (Surr)	94	%		75 - 120	
Dibromofluoromethane	100	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-2
Lab Sample ID: 500-9643-19

Date Sampled: 02/20/2008 1110
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1522	
Prep Method: 5030B			Date Prepared:	02/26/2008 1522	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	3.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	57	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-2
 Lab Sample ID: 500-9643-19

Date Sampled: 02/20/2008 1110
 Date Received: 02/22/2008 1000
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	106	%		70 - 125	
Toluene-d8 (Surr)	96	%		75 - 120	
4-Bromofluorobenzene (Surr)	92	%		75 - 120	
Dibromofluoromethane	103	%		75 - 120	
Method: 8260B Run Type: DL			Date Analyzed:	02/27/2008 1039	
Prep Method: 5030B			Date Prepared:	02/27/2008 1039	
Trichloroethene	350	ug/L	2.0	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	103	%		70 - 125	
Toluene-d8 (Surr)	94	%		75 - 120	
4-Bromofluorobenzene (Surr)	91	%		75 - 120	
Dibromofluoromethane	101	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-3
Lab Sample ID: 500-9643-20

Date Sampled: 02/19/2008 0915
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1545	
Prep Method: 5030B			Date Prepared:	02/26/2008 1545	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	1.6	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	3.4	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-3
 Lab Sample ID: 500-9643-20

Date Sampled: 02/19/2008 0915
 Date Received: 02/22/2008 1000
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate					
1,2-Dichloroethane-d4 (Surr)	104	%		70 - 125	
Toluene-d8 (Surr)	98	%		75 - 120	
4-Bromofluorobenzene (Surr)	94	%		75 - 120	
Dibromofluoromethane	97	%		75 - 120	
Acceptance Limits					
Method: 8260B Run Type: DL					
Prep Method: 5030B					
Trichloroethene	130	ug/L	2.0	10	10
Acceptance Limits					
Surrogate					
1,2-Dichloroethane-d4 (Surr)	104	%		70 - 125	
Toluene-d8 (Surr)	96	%		75 - 120	
4-Bromofluorobenzene (Surr)	91	%		75 - 120	
Dibromofluoromethane	105	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-4
Lab Sample ID: 500-9643-21

Date Sampled: 02/20/2008 0900
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008	1608
Prep Method: 5030B			Date Prepared:	02/26/2008	1608
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorodifluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	18	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-4
 Lab Sample ID: 500-9643-21

Date Sampled: 02/20/2008 0900
 Date Received: 02/22/2008 1000
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	107	%		70 - 125	
Toluene-d8 (Surr)	97	%		75 - 120	
4-Bromofluorobenzene (Surr)	93	%		75 - 120	
Dibromofluoromethane	97	%		75 - 120	
Method: 8260B Run Type: DL			Date Analyzed:	02/26/2008 1631	
Prep Method: 5030B			Date Prepared:	02/26/2008 1631	
Trichloroethene	830	ug/L	2.0	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		70 - 125	
Toluene-d8 (Surr)	91	%		75 - 120	
4-Bromofluorobenzene (Surr)	92	%		75 - 120	
Dibromofluoromethane	101	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-5
Lab Sample ID: 500-9643-22

Date Sampled: 02/19/2008 0910
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1653	
Prep Method: 5030B			Date Prepared:	02/26/2008 1653	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromoform	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	4.4	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-5
Lab Sample ID: 500-9643-22

Date Sampled: 02/19/2008 0910
 Date Received: 02/22/2008 1000
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	107	%		70 - 125	
Toluene-d8 (Surr)	97	%		75 - 120	
4-Bromofluorobenzene (Surr)	94	%		75 - 120	
Dibromofluoromethane	99	%		75 - 120	
Method: 8260B Run Type: DL			Date Analyzed:	02/27/2008 1125	
Prep Method: 5030B			Date Prepared:	02/27/2008 1125	
Trichloroethene	150	ug/L	2.0	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	106	%		70 - 125	
Toluene-d8 (Surr)	96	%		75 - 120	
4-Bromofluorobenzene (Surr)	92	%		75 - 120	
Dibromofluoromethane	101	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-6
Lab Sample ID: 500-9643-23

Date Sampled: 02/20/2008 1020
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1716	
Prep Method: 5030B			Date Prepared:	02/26/2008 1716	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorodifluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromoform	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	8.7	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	15	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-6
Lab Sample ID: 500-9643-23

Date Sampled: 02/20/2008 1020
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	107	%		70 - 125	
Toluene-d8 (Surr)	96	%		75 - 120	
4-Bromofluorobenzene (Surr)	93	%		75 - 120	
Dibromofluoromethane	102	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-7
Lab Sample ID: 500-9643-24

Date Sampled: 02/20/2008 0710
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1739	
Prep Method: 5030B			Date Prepared:	02/26/2008 1739	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	6.4	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromoform	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	5.4	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	11	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-7
Lab Sample ID: 500-9643-24

Date Sampled: 02/20/2008 0710
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	108	%		70 - 125	
Toluene-d8 (Surr)	96	%		75 - 120	
4-Bromofluorobenzene (Surr)	91	%		75 - 120	
Dibromofluoromethane	104	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-8
Lab Sample ID: 500-9643-25

Date Sampled: 02/20/2008 0700
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1802	
Prep Method: 5030B			Date Prepared:	02/26/2008 1802	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	18	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	9.2	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	62	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-8
Lab Sample ID: 500-9643-25

Date Sampled: 02/20/2008 0700
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	108	%		70 - 125	
Toluene-d8 (Surr)	94	%		75 - 120	
4-Bromofluorobenzene (Surr)	92	%		75 - 120	
Dibromofluoromethane	99	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-9
Lab Sample ID: 500-9643-26

Date Sampled: 02/20/2008 0650
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1825	
Prep Method: 5030B			Date Prepared:	02/26/2008 1825	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	1.4	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-9
 Lab Sample ID: 500-9643-26

Date Sampled: 02/20/2008 0650
 Date Received: 02/22/2008 1000
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		70 - 125	
Toluene-d8 (Surr)	95	%		75 - 120	
4-Bromofluorobenzene (Surr)	91	%		75 - 120	
Dibromofluoromethane	101	%		75 - 120	
Method: 8260B Run Type: DL			Date Analyzed:	02/27/2008 1148	
Prep Method: 5030B			Date Prepared:	02/27/2008 1148	
Tetrachloroethene	160	ug/L	1.4	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	107	%		70 - 125	
Toluene-d8 (Surr)	94	%		75 - 120	
4-Bromofluorobenzene (Surr)	91	%		75 - 120	
Dibromofluoromethane	104	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-9 Dup
Lab Sample ID: 500-9643-27

Date Sampled: 02/20/2008 0650
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	02/26/2008 1848	
Prep Method: 5030B			Date Prepared:	02/26/2008 1848	
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	1.4	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-9 Dup
 Lab Sample ID: 500-9643-27

Date Sampled: 02/20/2008 0650
 Date Received: 02/22/2008 1000
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	111	%		70 - 125	
Toluene-d8 (Surr)	95	%		75 - 120	
4-Bromofluorobenzene (Surr)	91	%		75 - 120	
Dibromofluoromethane	102	%		75 - 120	
Method: 8260B Run Type: DL			Date Analyzed:	02/27/2008 1211	
Prep Method: 5030B			Date Prepared:	02/27/2008 1211	
Tetrachloroethene	170	ug/L	1.4	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	107	%		70 - 125	
Toluene-d8 (Surr)	95	%		75 - 120	
4-Bromofluorobenzene (Surr)	91	%		75 - 120	
Dibromofluoromethane	103	%		75 - 120	

Mr. Tom Cornuet
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-10
Lab Sample ID: 500-9643-28

Date Sampled: 02/20/2008 0645
Date Received: 02/22/2008 1000
Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed: 02/26/2008 1911		
Prep Method: 5030B			Date Prepared: 02/26/2008 1911		
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	<1.0	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	4.2	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-9643-1

Client Sample ID: EW-10
 Lab Sample ID: 500-9643-28

Date Sampled: 02/20/2008 0645
 Date Received: 02/22/2008 1000
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		70 - 125	
Toluene-d8 (Surr)	95	%		75 - 120	
4-Bromofluorobenzene (Surr)	92	%		75 - 120	
Dibromofluoromethane	101	%		75 - 120	

DATA REPORTING QUALIFIERS

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Lab Section	Qualifier	Description
GC/MS VOA	F	MS or MSD exceeds the control limits
	F	RPD of the MS and MSD exceeds the control limits

QUALITY CONTROL RESULTS

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

QC Association Summary

Lab Sample ID	Client Sample ID	Report Basis	Client Matrix	Method	Prep Batch
GC/MS VOA					
Analysis Batch:500-32818					
LCS 500-32818/8	Lab Control Spike	T	Water	8260B	
MB 500-32818/7	Method Blank	T	Water	8260B	
500-9643-1	RFW-1A	T	Water	8260B	
500-9643-2	RFW-1B	T	Water	8260B	
500-9643-5	RFW-3B	T	Water	8260B	
500-9643-6	RFW-4A	T	Water	8260B	
500-9643-7	RFW-4A Dup	T	Water	8260B	
500-9643-8	RFW-4B	T	Water	8260B	
500-9643-9	RFW-6	T	Water	8260B	
500-9643-10	RFW-7	T	Water	8260B	
500-9643-11	RFW-9	T	Water	8260B	
Analysis Batch:500-32928					
LCS 500-32928/5	Lab Control Spike	T	Water	8260B	
MB 500-32928/4	Method Blank	T	Water	8260B	
500-9643-3	RFW-2A	T	Water	8260B	
500-9643-4	RFW-2B	T	Water	8260B	
500-9643-12	RFW-11B	T	Water	8260B	
500-9643-13	RFW-12B	T	Water	8260B	
500-9643-14	RFW-13	T	Water	8260B	
500-9643-15	RFW-17	T	Water	8260B	
500-9643-16	Leister-1	T	Water	8260B	
500-9643-17	Leister-Dairy	T	Water	8260B	
500-9643-18	Trip Blank	T	Water	8260B	
500-9643-19	EW-2	T	Water	8260B	
500-9643-20	EW-3	T	Water	8260B	
500-9643-21	EW-4	T	Water	8260B	
500-9643-21DL	EW-4	T	Water	8260B	
500-9643-22	EW-5	T	Water	8260B	
500-9643-23	EW-6	T	Water	8260B	
500-9643-24	EW-7	T	Water	8260B	
500-9643-25	EW-8	T	Water	8260B	
500-9643-26	EW-9	T	Water	8260B	
500-9643-27	EW-9 Dup	T	Water	8260B	
500-9643-28	EW-10	T	Water	8260B	
500-9643-28MS	Matrix Spike	T	Water	8260B	
500-9643-28MSD	Matrix Spike Duplicate	T	Water	8260B	

TestAmerica Chicago

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

QC Association Summary

Lab Sample ID	Client Sample ID	Report Basis	Client Matrix	Method	Prep Batch
GC/MS VOA					
Analysis Batch:500-32961					
LCS 500-32961/5	Lab Control Spike	T	Water	8260B	
MB 500-32961/4	Method Blank	T	Water	8260B	
500-9643-13DL	RFW-12B	T	Water	8260B	
500-9643-19DL	EW-2	T	Water	8260B	
500-9643-20DL	EW-3	T	Water	8260B	
500-9643-22DL	EW-5	T	Water	8260B	
500-9643-26DL	EW-9	T	Water	8260B	
500-9643-27DL	EW-9 Dup	T	Water	8260B	

Report Basis

T = Total

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Surrogate Recovery Report**8260B VOC****Client Matrix: Water**

Lab Sample ID	Client Sample ID	12DCE %Rec	TOL %Rec	BFB %Rec	DBFM %Rec
500-9643-1	RFW-1A	100	96	95	96
500-9643-2	RFW-1B	99	97	94	94
500-9643-3	RFW-2A	99	95	92	98
500-9643-4	RFW-2B	100	94	94	96
500-9643-5	RFW-3B	102	95	95	96
500-9643-6	RFW-4A	102	94	95	100
500-9643-7	RFW-4A Dup	101	96	91	96
500-9643-8	RFW-4B	105	97	93	102
500-9643-9	RFW-6	104	95	95	100
500-9643-10	RFW-7	107	96	93	101
500-9643-11	RFW-9	106	97	92	100
500-9643-12	RFW-11B	100	95	93	96
500-9643-13	RFW-12B	101	96	95	96
500-9643-13 DL	RFW-12B DL	101	96	91	99
500-9643-14	RFW-13	103	95	92	97
500-9643-15	RFW-17	101	95	96	96
500-9643-16	Leister-1	103	96	91	96
500-9643-17	Leister-Dairy	104	94	93	100
500-9643-18	Trip Blank	104	96	94	100
500-9643-19	EW-2	106	96	92	103
500-9643-19 DL	EW-2 DL	103	94	91	101
500-9643-20	EW-3	104	98	94	97
500-9643-20 DL	EW-3 DL	104	96	91	105
500-9643-21	EW-4	107	97	93	97
500-9643-21 DL	EW-4 DL	98	91	92	101
500-9643-22	EW-5	107	97	94	99
500-9643-22 DL	EW-5 DL	106	96	92	101
500-9643-23	EW-6	107	96	93	102
500-9643-24	EW-7	108	96	91	104

Surrogate	Acceptance Limits
12DCE = 1,2-Dichloroethane-d4 (Surr)	70-125
TOL = Toluene-d8 (Surr)	75-120
BFB = 4-Bromofluorobenzene (Surr)	75-120
DBFM = Dibromofluoromethane	75-120

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Surrogate Recovery Report**8260B VOC****Client Matrix: Water**

Lab Sample ID	Client Sample ID	12DCE %Rec	TOL %Rec	BFB %Rec	DBFM %Rec
500-9643-25	EW-8	108	94	92	99
500-9643-26	EW-9	109	95	91	101
500-9643-26 DL	EW-9 DL	107	94	91	104
500-9643-27	EW-9 Dup	111	95	91	102
500-9643-27 DL	EW-9 Dup DL	107	95	91	103
500-9643-28	EW-10	109	95	92	101
MB 500-32818/7		94	95	94	96
MB 500-32928/4		101	95	96	98
MB 500-32961/4		103	96	93	99
LCS 500-32818/8		96	99	101	97
LCS 500-32928/5		96	96	100	96
LCS 500-32961/5		101	96	101	99
500-9643-28 MS	EW-10 MS	104	97	97	105
500-9643-28 MSD	EW-10 MSD	104	96	100	99

Surrogate	Acceptance Limits
12DCE = 1,2-Dichloroethane-d4 (Surr)	70-125
TOL = Toluene-d8 (Surr)	75-120
BFB = 4-Bromofluorobenzene (Surr)	75-120
DBFM = Dibromofluoromethane	75-120

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Method Blank - Batch: 500-32818

Method: 8260B

Preparation: 5030B

Lab Sample ID: MB 500-32818/7

Client Matrix: Water

Dilution: 1.0

Date Analyzed: 02/25/2008 1010

Date Prepared: 02/25/2008 1010

Analysis Batch: 500-32818

Prep Batch: N/A

Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N

Lab File ID: 6M0225.D

Initial Weight/Volume: 10 mL

Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.16	1.0
Dichlorodifluoromethane	<1.0		0.29	1.0
Chloromethane	<1.0		0.33	1.0
Vinyl chloride	<1.0		0.23	1.0
Bromomethane	<1.0		0.44	1.0
Chloroethane	<1.0		0.45	1.0
Trichlorofluoromethane	<1.0		0.32	1.0
1,1-Dichloroethene	<1.0		0.22	1.0
Carbon disulfide	<5.0		0.39	5.0
Acetone	<5.0		1.2	5.0
Methylene Chloride	<2.0		0.99	2.0
trans-1,2-Dichloroethene	<1.0		0.17	1.0
1,1-Dichloroethane	<1.0		0.18	1.0
2,2-Dichloropropane	<1.0		0.30	1.0
cis-1,2-Dichloroethene	<1.0		0.21	1.0
Methyl Ethyl Ketone	<5.0		0.83	5.0
Bromochloromethane	<1.0		0.33	1.0
Chloroform	<1.0		0.13	1.0
1,1,1-Trichloroethane	<1.0		0.23	1.0
1,1-Dichloropropene	<1.0		0.17	1.0
Carbon tetrachloride	<1.0		0.21	1.0
1,2-Dichloroethane	<1.0		0.22	1.0
Trichloroethene	<1.0		0.20	1.0
1,2-Dichloropropane	<1.0		0.23	1.0
Dibromomethane	<1.0		0.31	1.0
Bromodichloromethane	<1.0		0.18	1.0
cis-1,3-Dichloropropene	<1.0		0.16	1.0
methyl isobutyl ketone	<5.0		0.58	5.0
Toluene	<1.0		0.16	1.0
trans-1,3-Dichloropropene	<1.0		0.13	1.0
1,1,2-Trichloroethane	<1.0		0.32	1.0
Tetrachloroethene	<1.0		0.14	1.0
1,3-Dichloropropane	<1.0		0.17	1.0
2-Hexanone	<5.0		0.77	5.0
Dibromochloromethane	<1.0		0.19	1.0
1,2-Dibromoethane	<1.0		0.24	1.0
Chlorobenzene	<1.0		0.17	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.18	1.0
Ethylbenzene	<1.0		0.17	1.0
m&p-Xylene	<2.0		0.23	2.0
o-Xylene	<1.0		0.12	1.0

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Method Blank - Batch: 500-32818

Lab Sample ID: MB 500-32818/7
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/25/2008 1010
Date Prepared: 02/25/2008 1010

Analysis Batch: 500-32818
Prep Batch: N/A
Units: ug/L

Method: 8260B
Preparation: 5030B

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 6M0225.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Styrene	<1.0		0.15	1.0
Bromoform	<1.0		0.30	1.0
Isopropylbenzene	<1.0		0.14	1.0
Bromobenzene	<1.0		0.15	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.25	1.0
1,2,3-Trichloropropane	<1.0		0.39	1.0
N-Propylbenzene	<1.0		0.11	1.0
2-Chlorotoluene	<1.0		0.16	1.0
1,3,5-Trimethylbenzene	<1.0		0.14	1.0
4-Chlorotoluene	<1.0		0.14	1.0
tert-Butylbenzene	<1.0		0.13	1.0
1,2,4-Trimethylbenzene	<1.0		0.12	1.0
sec-Butylbenzene	<1.0		0.14	1.0
1,3-Dichlorobenzene	<1.0		0.19	1.0
p-Isopropyltoluene	<1.0		0.12	1.0
1,4-Dichlorobenzene	<1.0		0.15	1.0
n-Butylbenzene	<1.0		0.13	1.0
1,2-Dichlorobenzene	<1.0		0.15	1.0
1,2-Dibromo-3-Chloropropane	<2.0		0.85	2.0
1,2,4-Trichlorobenzene	<1.0		0.20	1.0
Hexachlorobutadiene	<1.0		0.27	1.0
Naphthalene	<1.0		0.32	1.0
1,2,3-Trichlorobenzene	<1.0		0.20	1.0
Surrogate	% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	94		70 - 125	
Toluene-d8 (Surr)	95		75 - 120	
4-Bromofluorobenzene (Surr)	94		75 - 120	
Dibromofluoromethane	96		75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Lab Control Spike - Batch: 500-32818

Method: 8260B

Preparation: 5030B

Lab Sample ID: LCS 500-32818/8
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/25/2008 1033
Date Prepared: 02/25/2008 1033

Analysis Batch: 500-32818
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 6S0225.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	25.0	25.7	103	68 - 120	
Dichlorodifluoromethane	25.0	32.9	131	21 - 178	
Chloromethane	25.0	28.1	113	50 - 140	
Vinyl chloride	25.0	29.7	119	57 - 135	
Bromomethane	25.0	36.3	145	61 - 172	
Chloroethane	25.0	28.5	114	56 - 152	
Trichlorofluoromethane	25.0	23.1	92	58 - 147	
1,1-Dichloroethene	25.0	24.4	98	50 - 121	
Carbon disulfide	25.0	19.8	79	33 - 120	
Acetone	25.0	22.8	91	22 - 175	
Methylene Chloride	25.0	25.4	102	52 - 126	
trans-1,2-Dichloroethene	25.0	26.5	106	57 - 122	
1,1-Dichloroethane	25.0	26.0	104	63 - 121	
2,2-Dichloropropane	25.0	28.4	113	56 - 134	
cis-1,2-Dichloroethene	25.0	27.9	112	62 - 127	
Methyl Ethyl Ketone	25.0	18.8	75	36 - 157	
Bromoform	25.0	21.1	84	61 - 125	
Chloroform	25.0	27.2	109	65 - 127	
1,1,1-Trichloroethane	25.0	26.7	107	65 - 129	
1,1-Dichloropropene	25.0	27.2	109	62 - 122	
Carbon tetrachloride	25.0	26.8	107	67 - 121	
1,2-Dichloroethane	25.0	26.2	105	68 - 120	
Trichloroethene	25.0	27.1	108	73 - 120	
1,2-Dichloropropane	25.0	27.1	108	72 - 120	
Dibromomethane	25.0	25.9	104	71 - 120	
Bromodichloromethane	25.0	28.8	115	71 - 131	
cis-1,3-Dichloropropene	26.9	25.8	96	60 - 120	
methyl isobutyl ketone	25.0	26.4	106	65 - 128	
Toluene	25.0	28.0	112	75 - 120	
trans-1,3-Dichloropropene	24.3	22.7	93	61 - 120	
1,1,2-Trichloroethane	25.0	28.1	113	59 - 135	
Tetrachloroethene	25.0	27.4	110	65 - 120	
1,3-Dichloropropane	25.0	27.1	109	73 - 120	
2-Hexanone	25.0	23.0	92	54 - 139	
Dibromoform	25.0	25.2	101	57 - 132	
1,2-Dibromoethane	25.0	28.1	112	68 - 125	
Chlorobenzene	25.0	25.4	101	75 - 120	
1,1,1,2-Tetrachloroethane	25.0	28.7	115	72 - 120	
Ethylbenzene	25.0	27.4	110	75 - 120	
m&p-Xylene	50.0	57.1	114	75 - 120	
o-Xylene	25.0	29.3	117	75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Lab Control Spike - Batch: 500-32818

Method: 8260B

Preparation: 5030B

Lab Sample ID: LCS 500-32818/8

Client Matrix: Water

Dilution: 1.0

Date Analyzed: 02/25/2008 1033

Date Prepared: 02/25/2008 1033

Analysis Batch: 500-32818

Prep Batch: N/A

Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N

Lab File ID: 6S0225.D

Initial Weight/Volume: 10 mL

Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Styrene	25.0	26.2	105	77 - 120	
Bromoform	25.0	24.7	99	55 - 120	
Isopropylbenzene	25.0	25.9	104	68 - 120	
Bromobenzene	25.0	26.7	107	76 - 120	
1,1,2,2-Tetrachloroethane	25.0	26.4	106	68 - 120	
1,2,3-Trichloropropane	25.0	24.8	99	70 - 120	
N-Propylbenzene	25.0	26.1	104	74 - 120	
2-Chlorotoluene	25.0	28.0	112	74 - 120	
1,3,5-Trimethylbenzene	25.0	26.2	105	76 - 120	
4-Chlorotoluene	25.0	27.5	110	75 - 120	
tert-Butylbenzene	25.0	27.0	108	75 - 120	
1,2,4-Trimethylbenzene	25.0	26.3	105	76 - 120	
sec-Butylbenzene	25.0	28.9	116	73 - 120	
1,3-Dichlorobenzene	25.0	25.3	101	76 - 120	
p-Isopropyltoluene	25.0	25.5	102	71 - 120	
1,4-Dichlorobenzene	25.0	24.5	98	74 - 120	
n-Butylbenzene	25.0	29.1	116	68 - 120	
1,2-Dichlorobenzene	25.0	26.3	105	74 - 120	
1,2-Dibromo-3-Chloropropane	25.0	26.2	105	60 - 120	
1,2,4-Trichlorobenzene	25.0	27.5	110	63 - 120	
Hexachlorobutadiene	25.0	27.4	110	54 - 131	
Naphthalene	25.0	23.9	96	50 - 120	
1,2,3-Trichlorobenzene	25.0	27.2	109	62 - 120	
Surrogate		% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)		96		70 - 125	
Toluene-d8 (Surr)		99		75 - 120	
4-Bromofluorobenzene (Surr)		101		75 - 120	
Dibromofluoromethane		97		75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Method Blank - Batch: 500-32928

Method: 8260B

Preparation: 5030B

Lab Sample ID: MB 500-32928/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/26/2008 0915
Date Prepared: 02/26/2008 0915

Analysis Batch: 500-32928
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 6M0226.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.16	1.0
Dichlorodifluoromethane	<1.0		0.29	1.0
Chloromethane	<1.0		0.33	1.0
Vinyl chloride	<1.0		0.23	1.0
Bromomethane	<1.0		0.44	1.0
Chloroethane	<1.0		0.45	1.0
Trichlorofluoromethane	<1.0		0.32	1.0
1,1-Dichloroethene	<1.0		0.22	1.0
Carbon disulfide	<5.0		0.39	5.0
Acetone	<5.0		1.2	5.0
Methylene Chloride	<2.0		0.99	2.0
trans-1,2-Dichloroethene	<1.0		0.17	1.0
1,1-Dichloroethane	<1.0		0.18	1.0
2,2-Dichloropropane	<1.0		0.30	1.0
cis-1,2-Dichloroethene	<1.0		0.21	1.0
Methyl Ethyl Ketone	<5.0		0.83	5.0
Bromochloromethane	<1.0		0.33	1.0
Chloroform	<1.0		0.13	1.0
1,1,1-Trichloroethane	<1.0		0.23	1.0
1,1-Dichloropropene	<1.0		0.17	1.0
Carbon tetrachloride	<1.0		0.21	1.0
1,2-Dichloroethane	<1.0		0.22	1.0
Trichloroethene	<1.0		0.20	1.0
1,2-Dichloropropane	<1.0		0.23	1.0
Dibromomethane	<1.0		0.31	1.0
Bromodichloromethane	<1.0		0.18	1.0
cis-1,3-Dichloropropene	<1.0		0.16	1.0
methyl isobutyl ketone	<5.0		0.58	5.0
Toluene	<1.0		0.16	1.0
trans-1,3-Dichloropropene	<1.0		0.13	1.0
1,1,2-Trichloroethane	<1.0		0.32	1.0
Tetrachloroethene	<1.0		0.14	1.0
1,3-Dichloropropane	<1.0		0.17	1.0
2-Hexanone	<5.0		0.77	5.0
Dibromochloromethane	<1.0		0.19	1.0
1,2-Dibromoethane	<1.0		0.24	1.0
Chlorobenzene	<1.0		0.17	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.18	1.0
Ethylbenzene	<1.0		0.17	1.0
m&p-Xylene	<2.0		0.23	2.0
o-Xylene	<1.0		0.12	1.0

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Method Blank - Batch: 500-32928

Lab Sample ID: MB 500-32928/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/26/2008 0915
Date Prepared: 02/26/2008 .0915

Analysis Batch: 500-32928
Prep Batch: N/A
Units: ug/L

Method: 8260B
Preparation: 5030B

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 6M0226.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Styrene	<1.0		0.15	1.0
Bromoform	<1.0		0.30	1.0
Isopropylbenzene	<1.0		0.14	1.0
Bromobenzene	<1.0		0.15	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.25	1.0
1,2,3-Trichloropropane	<1.0		0.39	1.0
N-Propylbenzene	<1.0		0.11	1.0
2-Chlorotoluene	<1.0		0.16	1.0
1,3,5-Trimethylbenzene	<1.0		0.14	1.0
4-Chlorotoluene	<1.0		0.14	1.0
tert-Butylbenzene	<1.0		0.13	1.0
1,2,4-Trimethylbenzene	<1.0		0.12	1.0
sec-Butylbenzene	<1.0		0.14	1.0
1,3-Dichlorobenzene	<1.0		0.19	1.0
p-Isopropyltoluene	<1.0		0.12	1.0
1,4-Dichlorobenzene	<1.0		0.15	1.0
n-Butylbenzene	<1.0		0.13	1.0
1,2-Dichlorobenzene	<1.0		0.15	1.0
1,2-Dibromo-3-Chloropropane	<2.0		0.85	2.0
1,2,4-Trichlorobenzene	<1.0		0.20	1.0
Hexachlorobutadiene	<1.0		0.27	1.0
Naphthalene	<1.0		0.32	1.0
1,2,3-Trichlorobenzene	<1.0		0.20	1.0
Surrogate	% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101		70 - 125	
Toluene-d8 (Surr)	95		75 - 120	
4-Bromofluorobenzene (Surr)	96		75 - 120	
Dibromofluoromethane	98		75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Lab Control Spike - Batch: 500-32928

Method: 8260B

Preparation: 5030B

Lab Sample ID: LCS 500-32928/5
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/26/2008 0938
Date Prepared: 02/26/2008 0938

Analysis Batch: 500-32928
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 6S0226.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	25.0	19.8	79	68 - 120	
Dichlorodifluoromethane	25.0	32.6	131	21 - 178	
Chloromethane	25.0	28.0	112	50 - 140	
Vinyl chloride	25.0	29.1	116	57 - 135	
Bromomethane	25.0	33.8	135	61 - 172	
Chloroethane	25.0	27.5	110	56 - 152	
Trichlorofluoromethane	25.0	22.0	88	58 - 147	
1,1-Dichloroethene	25.0	16.9	67	50 - 121	
Carbon disulfide	25.0	14.0	56	33 - 120	
Acetone	25.0	18.2	73	22 - 175	
Methylene Chloride	25.0	18.7	75	52 - 126	
trans-1,2-Dichloroethene	25.0	19.4	78	57 - 122	
1,1-Dichloroethane	25.0	19.6	78	63 - 121	
2,2-Dichloropropane	25.0	20.8	83	56 - 134	
cis-1,2-Dichloroethene	25.0	20.9	84	62 - 127	
Methyl Ethyl Ketone	25.0	19.7	79	36 - 157	
Bromochloromethane	25.0	17.8	71	61 - 125	
Chloroform	25.0	20.4	81	65 - 127	
1,1,1-Trichloroethane	25.0	19.8	79	65 - 129	
1,1-Dichloropropene	25.0	20.7	83	62 - 122	
Carbon tetrachloride	25.0	20.0	80	67 - 121	
1,2-Dichloroethane	25.0	20.4	82	68 - 120	
Trichloroethene	25.0	20.9	83	73 - 120	
1,2-Dichloropropane	25.0	20.7	83	72 - 120	
Dibromomethane	25.0	21.0	84	71 - 120	
Bromodichloromethane	25.0	22.2	89	71 - 131	
cis-1,3-Dichloropropene	26.9	19.7	73	60 - 120	
methyl isobutyl ketone	25.0	20.4	82	65 - 128	
Toluene	25.0	21.7	87	75 - 120	
trans-1,3-Dichloropropene	24.3	17.6	72	61 - 120	
1,1,2-Trichloroethane	25.0	21.4	86	59 - 135	
Tetrachloroethene	25.0	21.8	87	65 - 120	
1,3-Dichloropropane	25.0	22.0	88	73 - 120	
2-Hexanone	25.0	20.0	80	54 - 139	
Dibromochloromethane	25.0	19.9	80	57 - 132	
1,2-Dibromoethane	25.0	21.2	85	68 - 125	
Chlorobenzene	25.0	20.8	83	75 - 120	
1,1,1,2-Tetrachloroethane	25.0	22.4	89	72 - 120	
Ethylbenzene	25.0	22.3	89	75 - 120	
m&p-Xylene	50.0	45.6	91	75 - 120	
o-Xylene	25.0	23.4	94	75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Lab Control Spike - Batch: 500-32928

Method: 8260B

Preparation: 5030B

Lab Sample ID: LCS 500-32928/5
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/26/2008 0938
Date Prepared: 02/26/2008 0938

Analysis Batch: 500-32928
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 6S0226.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Styrene	25.0	21.1	84	77 - 120	
Bromoform	25.0	18.4	74	55 - 120	
Isopropylbenzene	25.0	20.8	83	68 - 120	
Bromobenzene	25.0	21.7	87	76 - 120	
1,1,2,2-Tetrachloroethane	25.0	21.1	84	68 - 120	
1,2,3-Trichloropropane	25.0	20.0	80	70 - 120	
N-Propylbenzene	25.0	21.3	85	74 - 120	
2-Chlorotoluene	25.0	22.8	91	74 - 120	
1,3,5-Trimethylbenzene	25.0	21.1	85	76 - 120	
4-Chlorotoluene	25.0	22.7	91	75 - 120	
tert-Butylbenzene	25.0	21.4	86	75 - 120	
1,2,4-Trimethylbenzene	25.0	21.6	86	76 - 120	
sec-Butylbenzene	25.0	23.2	93	73 - 120	
1,3-Dichlorobenzene	25.0	20.8	83	76 - 120	
p-Isopropyltoluene	25.0	20.7	83	71 - 120	
1,4-Dichlorobenzene	25.0	20.3	81	74 - 120	
n-Butylbenzene	25.0	23.2	93	68 - 120	
1,2-Dichlorobenzene	25.0	21.5	86	74 - 120	
1,2-Dibromo-3-Chloropropane	25.0	19.8	79	60 - 120	
1,2,4-Trichlorobenzene	25.0	20.2	81	63 - 120	
Hexachlorobutadiene	25.0	20.8	83	54 - 131	
Naphthalene	25.0	17.6	70	50 - 120	
1,2,3-Trichlorobenzene	25.0	19.9	79	62 - 120	
Surrogate		% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)		96		70 - 125	
Toluene-d8 (Surr)		96		75 - 120	
4-Bromofluorobenzene (Surr)		100		75 - 120	
Dibromofluoromethane		96		75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Matrix Spike/ Matrix Spike Duplicate Recovery Report - Batch: 500-32928

**Method: 8260B
Preparation: 5030B**

MS Lab Sample ID: 500-9643-28 Analysis Batch: 500-32928
 Client Matrix: Water Prep Batch: N/A
 Dilution: 1.0
 Date Analyzed: 02/26/2008 1934
 Date Prepared: 02/26/2008 1934

Instrument ID: Agilent 6890N GC - 5973I
 Lab File ID: 9643-28S.D
 Initial Weight/Volume: 10 mL
 Final Weight/Volume: 10 mL

MSD Lab Sample ID: 500-9643-28 Analysis Batch: 500-32928
 Client Matrix: Water Prep Batch: N/A
 Dilution: 1.0
 Date Analyzed: 02/26/2008 1957
 Date Prepared: 02/26/2008 1957

Instrument ID: Agilent 6890N GC - 5973N
 Lab File ID: 9643-28T.D
 Initial Weight/Volume: 10 mL
 Final Weight/Volume: 10 mL

Analyte	% Rec.		RPD	RPD Limit	MS Qual	MSD Qual
	MS	MSD				
Benzene	89	84	68 - 120	6	20	
Dichlorodifluoromethane	119	118	21 - 178	1	20	
Chloromethane	109	104	50 - 140	5	20	
Vinyl chloride	105	104	57 - 135	0	20	
Bromomethane	99	94	61 - 172	6	20	
Chloroethane	76	74	56 - 152	3	20	
Trichlorofluoromethane	74	56	58 - 147	28	20	
1,1-Dichloroethene	74	64	50 - 121	15	20	
Carbon disulfide	71	64	33 - 120	11	20	
Acetone	89	75	22 - 175	17	20	
Methylene Chloride	92	81	52 - 126	13	20	
trans-1,2-Dichloroethene	91	82	57 - 122	11	20	
1,1-Dichloroethane	93	84	63 - 121	10	20	
2,2-Dichloropropane	94	83	56 - 134	13	20	
cis-1,2-Dichloroethene	98	91	62 - 127	8	20	
Methyl Ethyl Ketone	94	83	36 - 157	12	20	
Bromoform	78	81	61 - 125	4	20	
1,1,1-Trichloroethane	99	90	65 - 127	10	20	
1,1-Dichloropropene	93	83	65 - 129	11	20	
Carbon tetrachloride	85	82	67 - 121	4	20	
1,2-Dichloroethane	98	92	68 - 120	6	20	
Trichloroethene	92	88	73 - 120	5	20	
1,2-Dichloropropane	93	89	72 - 120	5	20	
Dibromomethane	93	88	71 - 120	6	20	
Bromodichloromethane	99	94	71 - 131	5	20	
cis-1,3-Dichloropropene	77	73	60 - 120	6	20	
methyl isobutyl ketone	88	87	65 - 128	2	20	
Toluene	98	92	75 - 120	6	20	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Matrix Spike/ Matrix Spike Duplicate Recovery Report - Batch: 500-32928

Method: 8260B
Preparation: 5030B

MS Lab Sample ID: 500-9643-28 Analysis Batch: 500-32928
Client Matrix: Water Prep Batch: N/A
Dilution: 1.0
Date Analyzed: 02/26/2008 1934
Date Prepared: 02/26/2008 1934

Instrument ID: Agilent 6890N GC - 5973I
Lab File ID: 9643-28S.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

MSD Lab Sample ID: 500-9643-28 Analysis Batch: 500-32928
Client Matrix: Water Prep Batch: N/A
Dilution: 1.0
Date Analyzed: 02/26/2008 1957
Date Prepared: 02/26/2008 1957

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 9643-28T.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	MS	MSD	% Rec.	Limit	RPD	RPD Limit	MS Qual	MSD Qual
trans-1,3-Dichloropropene	79	77		61 - 120	3	20		
1,1,2-Trichloroethane	101	95		59 - 135	6	20		
Tetrachloroethene	90	88		65 - 120	2	20		
1,3-Dichloropropane	98	95		73 - 120	3	20		
2-Hexanone	85	80		54 - 139	7	20		
Dibromochloromethane	87	83		57 - 132	4	20		
1,2-Dibromoethane	98	95		68 - 125	3	20		
Chlorobenzene	92	87		75 - 120	5	20		
1,1,1,2-Tetrachloroethane	99	93		72 - 120	6	20		
Ethylbenzene	97	94		75 - 120	3	20		
m&p-Xylene	101	96		75 - 120	5	20		
o-Xylene	103	98		75 - 120	5	20		
Styrene	90	88		77 - 120	2	20		
Bromoform	81	80		55 - 120	2	20		
Isopropylbenzene	90	86		68 - 120	4	20		
Bromobenzene	98	93		76 - 120	5	20		
1,1,2,2-Tetrachloroethane	96	94		68 - 120	2	20		
1,2,3-Trichloropropane	101	98		70 - 120	3	20		
N-Propylbenzene	93	91		74 - 120	3	20		
2-Chlorotoluene	100	96		74 - 120	4	20		
1,3,5-Trimethylbenzene	94	90		76 - 120	4	20		
4-Chlorotoluene	100	96		75 - 120	4	20		
tert-Butylbenzene	95	90		75 - 120	5	20		
1,2,4-Trimethylbenzene	96	91		76 - 120	5	20		
sec-Butylbenzene	101	96		73 - 120	5	20		
1,3-Dichlorobenzene	92	88		76 - 120	4	20		
p-Isopropyltoluene	92	87		71 - 120	5	20		
1,4-Dichlorobenzene	90	85		74 - 120	5	20		
n-Butylbenzene	101	99		68 - 120	2	20		

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Matrix Spike/ Matrix Spike Duplicate Recovery Report - Batch: 500-32928

Method: 8260B
Preparation: 5030B

MS Lab Sample ID: 500-9643-28 Analysis Batch: 500-32928
Client Matrix: Water Prep Batch: N/A
Dilution: 1.0
Date Analyzed: 02/26/2008 1934
Date Prepared: 02/26/2008 1934

Instrument ID: Agilent 6890N GC - 5973I
Lab File ID: 9643-28S.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

MSD Lab Sample ID: 500-9643-28 Analysis Batch: 500-32928
Client Matrix: Water Prep Batch: N/A
Dilution: 1.0
Date Analyzed: 02/26/2008 1957
Date Prepared: 02/26/2008 1957

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 9643-28T.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	MS	MSD	Limit	RPD	RPD Limit	MS Qual	MSD Qual
1,2-Dichlorobenzene	98	93	74 - 120	5	20		
1,2-Dibromo-3-Chloropropane	88	89	60 - 120	1	20		
1,2,4-Trichlorobenzene	95	93	63 - 120	2	20		
Hexachlorobutadiene	99	94	54 - 131	5	20		
Naphthalene	87	85	50 - 120	3	20		
1,2,3-Trichlorobenzene	96	92	62 - 120	4	20		
Surrogate	MS % Rec	MSD % Rec				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	104	104				70 - 125	
Toluene-d8 (Surr)	97	96				75 - 120	
4-Bromofluorobenzene (Surr)	97	100				75 - 120	
Dibromofluoromethane	105	99				75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Method Blank - Batch: 500-32961

Lab Sample ID: MB 500-32961/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/27/2008 0930
Date Prepared: 02/27/2008 0930

Analysis Batch: 500-32961
Prep Batch: N/A
Units: ug/L

Method: 8260B
Preparation: 5030B

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 6M0227.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.16	1.0
Dichlorodifluoromethane	<1.0		0.29	1.0
Chloromethane	<1.0		0.33	1.0
Vinyl chloride	<1.0		0.23	1.0
Bromomethane	<1.0		0.44	1.0
Chloroethane	<1.0		0.45	1.0
Trichlorofluoromethane	<1.0		0.32	1.0
1,1-Dichloroethene	<1.0		0.22	1.0
Carbon disulfide	<5.0		0.39	5.0
Acetone	<5.0		1.2	5.0
Methylene Chloride	<2.0		0.99	2.0
trans-1,2-Dichloroethene	<1.0		0.17	1.0
1,1-Dichloroethane	<1.0		0.18	1.0
2,2-Dichloropropane	<1.0		0.30	1.0
cis-1,2-Dichloroethene	<1.0		0.21	1.0
Methyl Ethyl Ketone	<5.0		0.83	5.0
Bromochloromethane	<1.0		0.33	1.0
Chloroform	<1.0		0.13	1.0
1,1,1-Trichloroethane	<1.0		0.23	1.0
1,1-Dichloropropene	<1.0		0.17	1.0
Carbon tetrachloride	<1.0		0.21	1.0
1,2-Dichloroethane	<1.0		0.22	1.0
Trichloroethene	<1.0		0.20	1.0
1,2-Dichloropropane	<1.0		0.23	1.0
Dibromomethane	<1.0		0.31	1.0
Bromodichloromethane	<1.0		0.18	1.0
cis-1,3-Dichloropropene	<1.0		0.16	1.0
methyl isobutyl ketone	<5.0		0.58	5.0
Toluene	<1.0		0.16	1.0
trans-1,3-Dichloropropene	<1.0		0.13	1.0
1,1,2-Trichloroethane	<1.0		0.32	1.0
Tetrachloroethene	<1.0		0.14	1.0
1,3-Dichloropropane	<1.0		0.17	1.0
2-Hexanone	<5.0		0.77	5.0
Dibromochloromethane	<1.0		0.19	1.0
1,2-Dibromoethane	<1.0		0.24	1.0
Chlorobenzene	<1.0		0.17	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.18	1.0
Ethylbenzene	<1.0		0.17	1.0
m&p-Xylene	<2.0		0.23	2.0
o-Xylene	<1.0		0.12	1.0

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Method Blank - Batch: 500-32961

Method: 8260B

Preparation: 5030B

Lab Sample ID: MB 500-32961/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/27/2008 0930
Date Prepared: 02/27/2008 0930

Analysis Batch: 500-32961
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 6M0227.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Styrene	<1.0		0.15	1.0
Bromoform	<1.0		0.30	1.0
Isopropylbenzene	<1.0		0.14	1.0
Bromobenzene	<1.0		0.15	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.25	1.0
1,2,3-Trichloropropane	<1.0		0.39	1.0
N-Propylbenzene	<1.0		0.11	1.0
2-Chlorotoluene	<1.0		0.16	1.0
1,3,5-Trimethylbenzene	<1.0		0.14	1.0
4-Chlorotoluene	<1.0		0.14	1.0
tert-Butylbenzene	<1.0		0.13	1.0
1,2,4-Trimethylbenzene	<1.0		0.12	1.0
sec-Butylbenzene	<1.0		0.14	1.0
1,3-Dichlorobenzene	<1.0		0.19	1.0
p-Isopropyltoluene	<1.0		0.12	1.0
1,4-Dichlorobenzene	<1.0		0.15	1.0
n-Butylbenzene	<1.0		0.13	1.0
1,2-Dichlorobenzene	<1.0		0.15	1.0
1,2-Dibromo-3-Chloropropane	<2.0		0.85	2.0
1,2,4-Trichlorobenzene	<1.0		0.20	1.0
Hexachlorobutadiene	<1.0		0.27	1.0
Naphthalene	<1.0		0.32	1.0
1,2,3-Trichlorobenzene	<1.0		0.20	1.0
Surrogate	% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	103		70 - 125	
Toluene-d8 (Surr)	96		75 - 120	
4-Bromofluorobenzene (Surr)	93		75 - 120	
Dibromofluoromethane	99		75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Lab Control Spike - Batch: 500-32961

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-32961/5
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/27/2008 0953
Date Prepared: 02/27/2008 0953

Analysis Batch: 500-32961
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 6S0227.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	25.0	21.8	87	68 - 120	
Dichlorodifluoromethane	25.0	30.1	120	21 - 178	
Chloromethane	25.0	25.8	103	50 - 140	
Vinyl chloride	25.0	26.6	107	57 - 135	
Bromomethane	25.0	32.3	129	61 - 172	
Chloroethane	25.0	27.4	109	56 - 152	
Trichlorodifluoromethane	25.0	17.1	68	58 - 147	
1,1-Dichloroethene	25.0	19.2	77	50 - 121	
Carbon disulfide	25.0	14.6	58	33 - 120	
Acetone	25.0	21.9	87	22 - 175	
Methylene Chloride	25.0	21.1	85	52 - 126	
trans-1,2-Dichloroethene	25.0	21.2	85	57 - 122	
1,1-Dichloroethane	25.0	21.2	85	63 - 121	
2,2-Dichloropropane	25.0	23.4	94	56 - 134	
cis-1,2-Dichloroethene	25.0	23.0	92	62 - 127	
Methyl Ethyl Ketone	25.0	16.0	64	36 - 157	
Bromochloromethane	25.0	20.8	83	61 - 125	
Chloroform	25.0	23.2	93	65 - 127	
1,1,1-Trichloroethane	25.0	22.4	90	65 - 129	
1,1-Dichloropropene	25.0	22.6	90	62 - 122	
Carbon tetrachloride	25.0	23.2	93	67 - 121	
1,2-Dichloroethane	25.0	23.6	94	68 - 120	
Trichloroethene	25.0	23.4	94	73 - 120	
1,2-Dichloropropane	25.0	22.8	91	72 - 120	
Dibromomethane	25.0	22.7	91	71 - 120	
Bromodichloromethane	25.0	24.7	99	71 - 131	
cis-1,3-Dichloropropene	26.9	21.8	81	60 - 120	
methyl isobutyl ketone	25.0	22.1	89	65 - 128	
Toluene	25.0	24.1	96	75 - 120	
trans-1,3-Dichloropropene	24.3	20.1	83	61 - 120	
1,1,2-Trichloroethane	25.0	23.4	94	59 - 135	
Tetrachloroethene	25.0	24.5	98	65 - 120	
1,3-Dichloropropane	25.0	24.6	98	73 - 120	
2-Hexanone	25.0	20.1	80	54 - 139	
Dibromochloromethane	25.0	22.7	91	57 - 132	
1,2-Dibromoethane	25.0	24.3	97	68 - 125	
Chlorobenzene	25.0	23.1	93	75 - 120	
1,1,1,2-Tetrachloroethane	25.0	25.3	101	72 - 120	
Ethylbenzene	25.0	24.4	98	75 - 120	
m&p-Xylene	50.0	51.1	102	75 - 120	
o-Xylene	25.0	25.7	103	75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Lab Control Spike - Batch: 500-32961

Method: 8260B

Preparation: 5030B

Lab Sample ID: LCS 500-32961/5
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/27/2008 0953
Date Prepared: 02/27/2008 0953

Analysis Batch: 500-32961
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 6S0227.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Styrene	25.0	23.0	92	77 - 120	
Bromoform	25.0	22.6	90	55 - 120	
Isopropylbenzene	25.0	22.9	92	68 - 120	
Bromobenzene	25.0	24.0	96	76 - 120	
1,1,2,2-Tetrachloroethane	25.0	23.6	94	68 - 120	
1,2,3-Trichloropropane	25.0	23.8	95	70 - 120	
N-Propylbenzene	25.0	23.6	95	74 - 120	
2-Chlorotoluene	25.0	24.8	99	74 - 120	
1,3,5-Trimethylbenzene	25.0	23.8	95	76 - 120	
4-Chlorotoluene	25.0	25.0	100	75 - 120	
tert-Butylbenzene	25.0	24.4	98	75 - 120	
1,2,4-Trimethylbenzene	25.0	24.2	97	76 - 120	
sec-Butylbenzene	25.0	26.0	104	73 - 120	
1,3-Dichlorobenzene	25.0	23.1	93	76 - 120	
p-Isopropyltoluene	25.0	23.5	94	71 - 120	
1,4-Dichlorobenzene	25.0	22.6	90	74 - 120	
n-Butylbenzene	25.0	26.7	107	68 - 120	
1,2-Dichlorobenzene	25.0	23.8	95	74 - 120	
1,2-Dibromo-3-Chloropropane	25.0	22.8	91	60 - 120	
1,2,4-Trichlorobenzene	25.0	24.2	97	63 - 120	
Hexachlorobutadiene	25.0	24.7	99	54 - 131	
Naphthalene	25.0	20.4	82	50 - 120	
1,2,3-Trichlorobenzene	25.0	24.1	96	62 - 120	
Surrogate		% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)		101		70 - 125	
Toluene-d8 (Surr)		96		75 - 120	
4-Bromofluorobenzene (Surr)		101		75 - 120	
Dibromofluoromethane		99		75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

TestAmerica

TestAmerica
2417 Bond Street
University Park, IL 60466
708.534.5200
THE LEADER IN ENVIRONMENTAL TESTING

Sample ID

Temperature on Receipt 23°Drinking Water? Yes No **Chain of Custody Record**

02/27/2008

500-9643

TAL-4124-500 (107)

Client Black + Decker / Western

Address

Project Manager

Tom Carnuct

Date

2/21/08

Chain of Custody Number

Telephone Number (Area Code)/Fax Number

610.701.7360

Lab Number

City

HAMPSTEAD

State

MD

Zip Code

Site Contact

Greg Flasinski

Lab Contact

Dick Wright

Analysis (Attach list if more space is needed)

Project Name and Location (State)

Black + Decker, Hampstead, MD

Contract/Purchase Order/Quote No.

Page 1 of 3Special Instructions/
Conditions of Receipt

Carrier/Waybill Number

Sample I.D. No. and Description
(Containers for each sample may be combined on one line)

Date

Time

AP

ARROWS

Sed.

S3

Under.

H2SO4

HNO3

HCl

NaOH

ZnAc2/
NaOH

VOC

1 RFW-1A

2/19/08 915

2 RFW-1B

2/20/08 0730

3 RFW-2A

2/19/08 0755

4 RFW-2B

2/19/08 0840

5 RFW-3B

2/20/08 0815

6 RFW-4A

2/20/08 1110

7 RFW-4A Dup

2/20/08 1110

8 RFW-4B

2/20/08 1145

9 RFW-6

2/20/08 0745

10 RFW-7

2/19/08 0750

11 RFW-9

2/20/08 0745

12 RFW-11B

2/20/08 1100

Possible Hazard Identification

 Non-Hazard Flammable Skin Irritant Poison B Unknown

Sample Disposal

 Return To Client Disposal By Lab Archive For _____ Months

(A fee may be assessed if samples are retained longer than 1 month)

Turn Around Time Required

 24 Hours 48 Hours 7 Days 14 Days 21 Days Other

1. Relinquished By

Date

2/21/08 1600

Time

2. Relinquished By

Date

Time

3. Relinquished By

Date

Time

Comments

DISTRIBUTION: WHITE - Returned to Client with Report; CANARY - Stays with the Sample; PINK - Field Copy

TAL 02/22/08 1000

Date Time

Date Time

TestAmerica

TestAmerica
2417 Bond Street
University Park, IL 60466
THE LEADER IN ENVIRONMENTAL TESTING
708.534.5200

TAL-4124-500 (1107)

Sampler ID _____

Temperature on Receipt 73°Drinking Water? Yes No **Chain of Custody Record**

500-9643

02/27/2008

Client
Black + Decker / Weston

Address

City

State

Zip Code

Project Manager

Telephone Number (Area Code)/Fax Number

Date

Chain of Custody Number

Page 2 of 3

Project Name and Location (State)

Carrier/Waybill Number

Black + Decker, Hampstead, MD

Contract/Purchase Order/Quote No.

Special Instructions/
Conditions of ReceiptSample I.D. No. and Description
(Containers for each sample may be combined on one line)

Date

Time

A/F

Aqueous

Sed.

Soil

Unspec.

H2SO4

HNO3

HCl

NaOH

ZnO/Hg

NaOH

VOC

13

RFW-12B

2/20/08 1015

14

RFW-13

2/19/08 1615

15

RFW-17

2/15/08 1030

16

Leister - 1

2/15/08 1730

17

Leister - Dairy

2/16/08 1735

18

Trip Blank

2/19/08 0700

Page 87 of 89

Possible Hazard Identification

Non-Hazard Flammable Skin Irritant Poison B Unknown Return To Client Disposal By Lab Archive For _____ Months (A fee may be assessed if samples are retained longer than 1 month)

Turn Around Time Required

24 Hours 48 Hours 7 Days 14 Days 21 Days Other

1. Relinquished By _____ Date 2/21/08 Time 1600 1. Received By _____ Date TAL Time 02 22 08 1000

2. Relinquished By _____ Date _____ Time _____ 2. Received By _____ Date _____ Time _____

3. Relinquished By _____ Date _____ Time _____ 3. Received By _____ Date _____ Time _____

Comments

DISTRIBUTION: WHITE - Returned to Client with Report; CANARY - Stays with the Sample; PINK - Field Copy

TestAmerica

TestAmerica
2417 Bond Street
University Park, IL 60466
708.534.5200
THE LEADER IN ENVIRONMENTAL TESTING

Sample ID

Temperature on Receipt 21.5 °C

Drinking Water? Yes No

500-9643

Chain of Custody Record

TAL-4124-500 (1107)

Client

Black + Decker / Weston

Address

Project Manager

Tom Cornwell

Telephone Number (Area Code)/Fax Number

610.701.7360

Date

Chain of Custody Number

02/27/2008

Lab Number

Page 3 of 3

City

State

Zip Code

Site Contact

Lab Contact

Analysis (Attach list if more space is needed)

Project Name and Location (State)

Black + Decker MD

Contract/Purchase Order/Quote No.

Sample I.D. No. and Description
(Containers for each sample may be combined on one line)

Date

Time

19 EW-2

2/20/08 1110

20 EW-3

2/19 915

21 EW-4

2/20/08 900

22 EW-5

2/20/08 910

23 EW-6

2/20/08 1020

24 EW-7

2/20/08 0710

25 EW-8

2/20/08 0700

26 EW-9

2/20 0650

27 EW-9 Dup

2/20 0650

28 EW-10


2/20/08 0645

Possible Hazard Identification

Non-Hazard Flammable Skin Irritant Poison B Unknown Return To Client

Turn Around Time Required

24 Hours 48 Hours 7 Days 14 Days 21 Days Other

1. Relinquished By 


Date 2/21/08 Time 1600

2. Relinquished By 

Date Time

3. Relinquished By

Date Time

1. Received By 

2. Received By

Date TAL 02/21/08 Time 1600

Date Time

3. Received By

Date Time

Comments

DISTRIBUTION: WHITE - Returned to Client with Report; CANARY - Stays with the Sample; PINK - Field Copy

Page 88 of 89

Login Sample Receipt Check List

Client: Weston Solutions, Inc.

Job Number: 500-9643-1

Login Number: 9643
Creator: Kelsey, Shawn M
List Number: 1

List Source: TestAmerica Chicago

Question	T / F / NA	Comment
Radioactivity either was not measured or, if measured, is at or below background	True	
The cooler's custody seal, if present, is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	True	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

Job Number: 680-34426-1

Job Description: Black & Decker

For:

Weston Solutions, Inc.

1400 Weston Way

PO BOX 2653

West Chester, PA 19380

Attention: Mr. Tom Cornuet

Abbie Page

Abbie Page

Project Manager I

abbie.page@testamericainc.com

02/28/2008

The test results in this report meet all NELAP requirements for parameters for which accreditation is required or available. Any exceptions to NELAP requirements are noted in this report. Pursuant to NELAP, this report may not be reproduced, except in full, without the written approval of the laboratory. All questions regarding this report should be directed to the TestAmerica Project Manager who signed this report.

TestAmerica Laboratories, Inc.

TestAmerica Savannah 5102 LaRoche Avenue, Savannah, GA 31404

Tel (912) 354-7858 Fax (912) 352-0165 www.testamericainc.com



METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Description	Lab Location	Method	Preparation Method
Matrix Water	TAL SAV	EPA-DW 524.2	

Lab References:

TAL SAV = TestAmerica Savannah

Method References:

EPA-DW = "Methods For The Determination Of Organic Compounds In Drinking Water", EPA/600/4-88/039, December 1988 And Its Supplements.

SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
680-34426-1	RFW-20	Drinking Water	02/19/2008 1730	02/22/2008 1013
680-34426-2	RFW-21	Drinking Water	02/19/2008 1140	02/22/2008 1013
680-34426-3	HAMP-22	Drinking Water	02/20/2008 0810	02/22/2008 1013
680-34426-4	HAMP-23	Drinking Water	02/20/2008 0815	02/22/2008 1013
680-34426-5	Trip Blank	Drinking Water	02/19/2008 0800	02/22/2008 1013

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Client Sample ID: RFW-20

Lab Sample ID: 680-34426-1

Date Sampled: 02/19/2008 1730

Client Matrix: Drinking Water

Date Received: 02/22/2008 1013

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch:	680-98750	Instrument ID:	GC/MS Volatiles - S
Preparation:	N/A			Lab File ID:	s022206.d
Dilution:	1.0			Initial Weight/Volume:	5 mL
Date Analyzed:	02/23/2008 0003			Final Weight/Volume:	5 mL
Date Prepared:	N/A				

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0		0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.13	1.0

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Client Sample ID: RFW-20

Lab Sample ID: 680-34426-1
Client Matrix: Drinking Water

Date Sampled: 02/19/2008 1730
Date Received: 02/22/2008 1013

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch:	680-98750	Instrument ID:	GC/MS Volatiles - S
Preparation:	N/A			Lab File ID:	s022206.d
Dilution:	1.0			Initial Weight/Volume:	5 mL
Date Analyzed:	02/23/2008 0003			Final Weight/Volume:	5 mL
Date Prepared:	N/A				

Analyte	Result (ug/L)	Qualifier	MDL	RL
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0	*	1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,3-Trichlorobenzene	<0.50		0.12	0.50
1,2,4-Trichlorobenzene	<0.50		0.10	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
Trichloroethene	0.86		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50
Surrogate	%Rec		Acceptance Limits	
4-Bromofluorobenzene	100		70 - 130	
1,2-Dichlorobenzene-d4	88		70 - 130	

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Client Sample ID: RFW-21

Lab Sample ID: 680-34426-2
Client Matrix: Drinking WaterDate Sampled: 02/19/2008 1140
Date Received: 02/22/2008 1013**524.2 Purgeable Organic Compounds in Water by GC/MS**

Method:	524.2	Analysis Batch:	680-98750	Instrument ID:	GC/MS Volatiles - S
Preparation:	N/A			Lab File ID:	s022207.d
Dilution:	1.0			Initial Weight/Volume:	5 mL
Date Analyzed:	02/23/2008 0025			Final Weight/Volume:	5 mL
Date Prepared:	N/A				

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0		0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.13	1.0

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Client Sample ID: RFW-21

Lab Sample ID: 680-34426-2

Date Sampled: 02/19/2008 1140

Client Matrix: Drinking Water

Date Received: 02/22/2008 1013

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch:	680-98750	Instrument ID:	GC/MS Volatiles - S
Preparation:	N/A			Lab File ID:	s022207.d
Dilution:	1.0			Initial Weight/Volume:	5 mL
Date Analyzed:	02/23/2008 0025			Final Weight/Volume:	5 mL
Date Prepared:	N/A				

Analyte	Result (ug/L)	Qualifier	MDL	RL
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0	*	1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,3-Trichlorobenzene	<0.50		0.12	0.50
1,2,4-Trichlorobenzene	<0.50		0.10	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
Trichloroethene	<0.50		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50
Surrogate	%Rec			Acceptance Limits
4-Bromofluorobenzene	96			70 - 130
1,2-Dichlorobenzene-d4	88			70 - 130

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Client Sample ID: HAMP-22

Lab Sample ID: 680-34426-3

Client Matrix: Drinking Water

Date Sampled: 02/20/2008 0810

Date Received: 02/22/2008 1013

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch:	680-98750	Instrument ID:	GC/MS Volatiles - S
Preparation:	N/A			Lab File ID:	s022208.d
Dilution:	1.0			Initial Weight/Volume:	5 mL
Date Analyzed:	02/23/2008 0047			Final Weight/Volume:	5 mL
Date Prepared:	N/A				

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0		0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethylene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.13	1.0

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Client Sample ID: HAMP-22

Lab Sample ID: 680-34426-3

Date Sampled: 02/20/2008 0810

Client Matrix: Drinking Water

Date Received: 02/22/2008 1013

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch:	680-98750	Instrument ID:	GC/MS Volatiles - S
Preparation:	N/A			Lab File ID:	s022208.d
Dilution:	1.0			Initial Weight/Volume:	5 mL
Date Analyzed:	02/23/2008 0047			Final Weight/Volume:	5 mL
Date Prepared:	N/A				

Analyte	Result (ug/L)	Qualifier	MDL	RL
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0	*	1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,3-Trichlorobenzene	<0.50		0.12	0.50
1,2,4-Trichlorobenzene	<0.50		0.10	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
Trichloroethene	<0.50		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50
Surrogate	%Rec		Acceptance Limits	
4-Bromofluorobenzene	96		70 - 130	
1,2-Dichlorobenzene-d4	84		70 - 130	

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Client Sample ID: HAMP-23

Lab Sample ID: 680-34426-4

Client Matrix: Drinking Water

Date Sampled: 02/20/2008 0815

Date Received: 02/22/2008 1013

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch:	680-98750	Instrument ID:	GC/MS Volatiles - S
Preparation:	N/A			Lab File ID:	s022209.d
Dilution:	1.0			Initial Weight/Volume:	5 mL
Date Analyzed:	02/23/2008 0109			Final Weight/Volume:	5 mL
Date Prepared:	N/A				

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0		0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.13	1.0

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Client Sample ID: HAMP-23

Lab Sample ID: 680-34426-4

Date Sampled: 02/20/2008 0815

Client Matrix: Drinking Water

Date Received: 02/22/2008 1013

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch:	680-98750	Instrument ID:	GC/MS Volatiles - S
Preparation:	N/A			Lab File ID:	s022209.d
Dilution:	1.0			Initial Weight/Volume:	5 mL
Date Analyzed:	02/23/2008 0109			Final Weight/Volume:	5 mL
Date Prepared:	N/A				

Analyte	Result (ug/L)	Qualifier	MDL	RL
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0	*	1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,3-Trichlorobenzene	<0.50		0.12	0.50
1,2,4-Trichlorobenzene	<0.50		0.10	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
Trichloroethene	<0.50		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50
Surrogate	%Rec		Acceptance Limits	
4-Bromofluorobenzene	98		70 - 130	
1,2-Dichlorobenzene-d4	85		70 - 130	

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-34426-5

Client Matrix: Drinking Water

Date Sampled: 02/19/2008 0800

Date Received: 02/22/2008 1013

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch:	680-98750	Instrument ID:	GC/MS Volatiles - S
Preparation:	N/A			Lab File ID:	s022201.d
Dilution:	1.0			Initial Weight/Volume:	5 mL
Date Analyzed:	02/22/2008 2213			Final Weight/Volume:	5 mL
Date Prepared:	N/A				

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0		0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.13	1.0

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-34426-5
Client Matrix: Drinking Water

Date Sampled: 02/19/2008 0800
Date Received: 02/22/2008 1013

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch:	680-98750	Instrument ID:	GC/MS Volatiles - S
Preparation:	N/A			Lab File ID:	s022201.d
Dilution:	1.0			Initial Weight/Volume:	5 mL
Date Analyzed:	02/22/2008 2213			Final Weight/Volume:	5 mL
Date Prepared:	N/A				

Analyte	Result (ug/L)	Qualifier	MDL	RL
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0	*	1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,3-Trichlorobenzene	<0.50		0.12	0.50
1,2,4-Trichlorobenzene	<0.50		0.10	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
Trichloroethene	<0.50		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50
Surrogate	%Rec		Acceptance Limits	
4-Bromofluorobenzene	101		70 - 130	
1,2-Dichlorobenzene-d4	86		70 - 130	

DATA REPORTING QUALIFIERS

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Lab Section	Qualifier	Description
--------------------	------------------	--------------------

GC/MS VOA	*	LCS or LCSD exceeds the control limits
-----------	---	--

Quality Control Results

Client: Weston Solutions, Inc..

Job Number: 680-34426-1

Surrogate Recovery Report**524.2 Purgeable Organic Compounds in Water by GC/MS****Client Matrix: Water**

Lab Sample ID	Client Sample ID	BFB	12DCB
		%Rec	%Rec
680-34426-1	RFW-20	100	88
680-34426-2	RFW-21	96	88
680-34426-3	HAMP-22	96	84
680-34426-4	HAMP-23	98	85
680-34426-5	Trip Blank	101	86
MB 680-98750/13		98	84
LCS 680-98750/12		107	102

Surrogate	Acceptance Limits
BFB = 4-Bromofluorobenzene	70-130
12DCB = 1,2-Dichlorobenzene-d4	70-130

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Method Blank - Batch: 680-98750

Method: 524.2

Preparation: N/A

Lab Sample ID: MB 680-98750/13
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/22/2008 2151
Date Prepared: N/A

Analysis Batch: 680-98750
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq086.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	Result	Qual	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0		0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
2-Butanone (MEK)	<10		5.0	10

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Method Blank - Batch: 680-98750

Method: 524.2

Preparation: N/A

Lab Sample ID: MB 680-98750/13
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/22/2008 2151
Date Prepared: N/A

Analysis Batch: 680-98750
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq086.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	Result	Qual	MDL	RL
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.13	1.0
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0		1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,3-Trichlorobenzene	<0.50		0.12	0.50
1,2,4-Trichlorobenzene	<0.50		0.10	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
Trichloroethene	<0.50		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50
Surrogate	% Rec	Acceptance Limits		
4-Bromofluorobenzene	98	70 - 130		
1,2-Dichlorobenzene-d4	84	70 - 130		

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Lab Control Spike - Batch: 680-98750

Method: 524.2

Preparation: N/A

Lab Sample ID: LCS 680-98750/12
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/22/2008 2023
Date Prepared: N/A

Analysis Batch: 680-98750
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq085.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Acetone	40.0	40.5	101	70 - 130	
Benzene	20.0	17.9	89	70 - 130	
Bromobenzene	20.0	16.8	84	70 - 130	
Bromoform	20.0	18.7	94	70 - 130	
Bromomethane	20.0	21.2	106	70 - 130	
Carbon tetrachloride	20.0	20.7	104	70 - 130	
Chlorobenzene	20.0	17.5	88	70 - 130	
Chlorobromomethane	20.0	17.7	89	70 - 130	
Chlorodibromomethane	20.0	19.2	96	70 - 130	
Chloroethane	20.0	20.7	104	70 - 130	
Chloroform	20.0	19.6	98	70 - 130	
Chloromethane	20.0	17.8	89	70 - 130	
2-Chlorotoluene	20.0	19.3	96	70 - 130	
4-Chlorotoluene	20.0	19.2	96	70 - 130	
cis-1,2-Dichloroethene	20.0	18.2	91	70 - 130	
cis-1,3-Dichloropropene	20.0	19.5	97	70 - 130	
1,2-Dibromo-3-Chloropropane	20.0	23.8	119	70 - 130	
Dibromomethane	20.0	18.4	92	70 - 130	
1,2-Dichlorobenzene	20.0	17.3	87	70 - 130	
1,3-Dichlorobenzene	20.0	16.6	83	70 - 130	
1,4-Dichlorobenzene	20.0	17.1	86	70 - 130	
Dichlorobromomethane	20.0	20.3	101	70 - 130	
Dichlorodifluoromethane	20.0	18.6	93	70 - 130	
1,1-Dichloroethane	20.0	18.9	95	70 - 130	
1,2-Dichloroethane	20.0	20.2	101	70 - 130	
1,1-Dichloroethene	20.0	18.3	92	70 - 130	
1,2-Dichloropropane	20.0	18.2	91	70 - 130	
1,3-Dichloropropane	20.0	18.2	91	70 - 130	
2,2-Dichloropropane	20.0	21.1	105	70 - 130	
1,1-Dichloropropene	20.0	19.4	97	70 - 130	
1,3-Dichloropropene, Total	40.0	39.6	99	70 - 130	
Diisopropyl ether	16.0	15.6	97	70 - 130	
Ethylbenzene	20.0	19.5	98	70 - 130	
Ethylene-Dibromide	20.0	17.5	88	70 - 130	
Freon 113	16.0	13.4	84	70 - 130	
Hexachlorobutadiene	20.0	19.1	95	70 - 130	
2-Hexanone	40.0	44.2	111	70 - 130	
Isopropylbenzene	20.0	19.0	95	70 - 130	
4-Isopropyltoluene	20.0	19.6	98	70 - 130	
Methylene Chloride	20.0	16.9	85	70 - 130	
2-Butanone (MEK)	40.0	41.4	103	70 - 130	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-34426-1

Lab Control Spike - Batch: 680-98750

Method: 524.2

Preparation: N/A

Lab Sample ID: LCS 680-98750/12
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 02/22/2008 2023
Date Prepared: N/A

Analysis Batch: 680-98750
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq085.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
4-Methyl-2-pentanone (MIBK)	40.0	48.1	120	70 - 130	
m-Xylene & p-Xylene	40.0	36.9	92	70 - 130	
Naphthalene	20.0	17.1	85	70 - 130	
n-Butylbenzene	20.0	15.3	77	70 - 130	
N-Propylbenzene	20.0	19.3	97	70 - 130	
o-Xylene	20.0	18.6	93	70 - 130	
sec-Butylbenzene	20.0	19.1	95	70 - 130	
Styrene	20.0	18.9	95	70 - 130	
Tert-amyl methyl ether	16.0	17.0	106	70 - 130	
tert-Butyl alcohol	80.0	105	131	70 - 130	
tert-Butylbenzene	20.0	19.1	96	70 - 130	
Tert-butyl ethyl ether	16.0	16.5	103	70 - 130	
1,1,1,2-Tetrachloroethane	20.0	18.3	91	70 - 130	
1,1,2,2-Tetrachloroethane	20.0	19.8	99	70 - 130	
Tetrachloroethene	20.0	16.6	83	70 - 130	
Toluene	20.0	18.5	92	70 - 130	
trans-1,2-Dichloroethene	20.0	18.4	92	70 - 130	
trans-1,3-Dichloropropene	20.0	20.1	101	70 - 130	
1,2,3-Trichlorobenzene	20.0	17.8	89	70 - 130	
1,2,4-Trichlorobenzene	20.0	16.5	83	70 - 130	
1,1,1-Trichloroethane	20.0	21.3	107	70 - 130	
1,1,2-Trichloroethane	20.0	17.7	88	70 - 130	
Trichloroethene	20.0	19.2	96	70 - 130	
Trichlorofluoromethane	20.0	23.1	115	70 - 130	
1,2,3-Trichloropropane	20.0	18.5	93	70 - 130	
Trihalomethanes, Total	80.0	78.0	98	70 - 130	
1,2,4-Trimethylbenzene	20.0	19.1	96	70 - 130	
1,3,5-Trimethylbenzene	20.0	19.1	96	70 - 130	
Vinyl chloride	20.0	20.2	101	70 - 130	
Xylenes, Total	60.0	55.5	92	70 - 130	
Surrogate		% Rec		Acceptance Limits	
4-Bromofluorobenzene		107		70 - 130	
1,2-Dichlorobenzene-d4		102		70 - 130	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Serial Number 001075

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

TestAmerica Savannah
5102 LaRoche Avenue
Savannah, GA 31404

Website: www.testamericainc.com
Phone: (912) 354-7858
Fax: (912) 352-0165

Alternate Laboratory Name/Location

Phone:
Fax:

PROJECT REFERENCE <i>Black + Decker</i>	PROJECT NO. 02501.004.004.	PROJECT LOCATION (STATE) MD	MATRIX TYPE	REQUIRED ANALYSIS								PAGE 1	OF 1				
TAL (LAB) PROJECT MANAGER <i>Abbie Page</i>	P.O. NUMBER 0700	CONTRACT NO.									STANDARD REPORT DELIVERY						
CLIENT (SITE) PM <i>Tom Cornuet</i>	CLIENT PHONE 610.701.7360	CLIENT FAX 610.701.7401									DATE DUE _____						
CLIENT NAME <i>Weston</i>	CLIENT E-MAIL									EXPEDITED REPORT DELIVERY (SURCHARGE)							
CLIENT ADDRESS <i>1400 Weston Way, W.Chester PA 19380</i>											DATE DUE _____						
COMPANY CONTRACTING THIS WORK (if applicable)											NUMBER OF COOLERS SUBMITTED PER SHIPMENT:						
SAMPLE	SAMPLE IDENTIFICATION		COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	SOLID OR SEMI-SOLID	AIR	NONAQUEOUS LIQUID (OIL, SOLVENT,...)	NUMBER OF CONTAINERS SUBMITTED								REMARKS	
DATE	TIME							✓									
2/19/08	1730	RFW-20						✓									
2/19/08	1140	RFW-21						✓									
2/20/08	810	HAMP-22						✓									
2/20/08	815	HAMP-23						✓									
2/19/08	800	Trip Blank						✓									
RELINQUISHED BY: (SIGNATURE) <i>Abbie Page</i>		DATE 2/21/08	TIME 1600	RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RELINQUISHED BY: (SIGNATURE)		DATE	TIME						
RECEIVED BY: (SIGNATURE) <i>John Glass</i>		DATE 2/21/08	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME						
LABORATORY USE ONLY																	
RECEIVED FOR LABORATORY BY (SIGNATURE) <i>John Glass</i>		DATE 02/22/08	TIME 10:13	CUSTODY INTACT YES <input type="radio"/> NO <input checked="" type="radio"/>	CUSTODY SEAL NO.	SAVANNAH LOG NO. 1080.34426		LABORATORY REMARKS									



Weston Solutions, Inc.
1400 Weston Way
P.O. Box 2653
West Chester, Pennsylvania 19380
610-701-3000 • Fax 610-701-3186
www.westonsolutions.com

29 April 2008

Mr. Arthur O'Connell
Waste Management Administration
Maryland Department of the Environment
1800 Washington Blvd
Baltimore, MD 21230

Re: Black & Decker Hampstead Facility

Dear Mr. O'Connell

On behalf of our client, Black & Decker (U.S.) Inc. (Black & Decker), Weston Solutions, Inc. (WESTON®) provides enclosed with this letter two copies of the Quarterly Groundwater Monitoring Report for the period of January through March 2008. This report has been drafted for your review pursuant to the Administrative Consent Order of 13 April 1995.

If you have any questions regarding the enclosure, please contact me at (610) 701-7360.

Very truly yours,

WESTON SOLUTIONS, INC.

A handwritten signature in cursive script that reads "Thomas Cornuet".

Thomas Cornuet, P.G.
Project Manager

Enclosure

cc: L. Biagioni, B&D
J. Freed, B&D
T. Lynch III, M&S
K. Decker, Town of Hampstead
L. Bove, WESTON (w/o encl.)
B. Dietz, MDE (w/o encl.)





Weston Solutions, Inc.
1400 Weston Way
P.O. Box 2653
West Chester, Pennsylvania 19380
610-701-3000 • Fax 610-701-3186
www.westonsolutions.com

29 April 2008

Mr. Charlie Zeleski
Carroll County Health Department
Bureau of Environmental Health
P.O. Box 845
290 S. Center St.
Westminster, MD 21158

Re: Black & Decker Hampstead Facility

Dear Mr. Zeleski:

On behalf of our client, Black & Decker (U.S.) Inc. (Black & Decker), Weston Solutions, Inc. (WESTON®) provides enclosed with this letter a copy of the Quarterly Groundwater Monitoring Report for the period of January through March 2008.

If you have any questions regarding the enclosure, please contact me at (610) 701-7360.

Very truly yours,

WESTON SOLUTIONS, INC.

Thomas Cornuet

Thomas Cornuet, P.G.
Project Manager

Enclosure

cc: L. Biagioni, B&D
J. Freed, B&D
T. Lynch III, M&S
L. Bove, WESTON (w/o encl.)

