

Quarterly Groundwater Monitoring Report

Prepared for
Black & Decker (U.S.) Inc.

Hampstead, Maryland

January 2007

Prepared by

WESTON SOLUTIONS, INC.
West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 4 th Quarter 2006.....	2-2
Table 2-2 Groundwater Elevation Data – 4 th Quarter 2006.....	2-3
Table 2-3 Effluent Characteristics Summary – 4 th Quarter 2006.....	2-4
Table 2-4 Summary of Groundwater Analytical Results - November 2006	2-5
Table 3-1 Treatment System Maintenance Activities – 4 th Quarter 2006	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of October through December 2006.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of October through December 2006, the extraction wells were pumping at an average combined rate of approximately 162 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of October through December 2006 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of October through December 2006, approximately 24 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (58 %) and tetrachloroethene (PCE) (42 %). Analytical results of the groundwater collected at the inlet to the air stripper for the period of October through December 2006 are included in Appendix C.

A summary of the analytical results from the fourth quarter (November 2006) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 4th Quarter 2006
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
October 2006	6,331,362
November 2006	6,299,879
December 2006	6,160,966

Table 2-2
Groundwater Elevation Data - 4th Quarter 2006
Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV	TOTAL DEPTH	10/18/2006		11/20/2006		12/15/2006	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NA	DRY	NA	DRY	NA
EW-2	849.21	110	94.12	755.09	93.06	756.15	74.71	774.50
EW-3	846.64	118	88.91	757.73	87.47	759.17	88.04	758.60
EW-4	858.01	97.5	NA	NA	NA	NA	NA	NA
EW-5	864.17	98	71.13	793.04	70.57	793.60	96.00	768.17
EW-6	831.98	115	98.90	733.08	95.95	736.03	97.11	734.87
EW-7	818.38	78	48.46	769.92	46.80	771.58	55.29	763.09
EW-8	811.13	98	47.11	764.02	91.70	719.43	68.08	743.05
EW-9	811.35	141	102.00	709.35	101.50	709.85	98.96	712.39
EW-10	807.74	NA	58.74	749.00	55.22	752.52	61.22	746.52
RFW-1A	864.37	78	51.33	813.04	51.11	813.26	50.96	813.41
RFW-1B	864.23	200	51.35	812.88	51.15	813.08	51.00	813.23
RFW-2A	857.41	35	15.67	841.74	15.82	841.59	14.91	842.50
RFW-2B	857.73	75	16.28	841.45	16.62	841.11	15.43	842.30
RFW-3B	839.21	153	34.17	805.04	35.62	803.59	36.41	802.80
RFW-4A	830.37	62	40.83	789.54	38.87	791.50	39.94	790.43
RFW-4B	830.37	120	40.76	789.61	38.69	791.68	39.88	790.49
RFW-5A	817.50	30	DRY	NA	DRY	NA	DRY	NA
RFW-6	785.04	120	3.61	781.43	3.86	781.18	2.94	782.10
RFW-7	805.14	29	7.43	797.71	6.35	798.79	7.87	797.27
RFW-8	860.07	56	DRY	NA	DRY	NA	DRY	NA
RFW-9	862.02	49	29.46	832.56	27.00	835.02	30.27	831.75
RFW-10	852.06	58	DRY	NA	DRY	NA	DRY	NA
RFW-11A	849.32	72	NA	NA	NA	NA	NA	NA
RFW-11B	849.62	116	71.40	778.22	69.48	780.14	73.14	776.48
RFW-12B	844.87	264	54.65	790.22	52.37	792.50	62.06	782.81
RFW-13	849.11	150	63.60	785.51	64.08	785.03	63.81	785.30
RFW-14B	812.39	281	48.27	764.12	50.10	762.29	52.62	759.77
RFW-16	856.14	41	DRY	NA	DRY	NA	DRY	NA
RFW-17	834.66	60.5	30.17	804.49	28.61	806.05	30.43	804.23
RFW-20	842.49	142	37.08	805.41	36.65	805.84	37.61	804.88
RFW-21	832.65	102	22.94	809.71	23.33	809.32	23.67	808.98
PH-7	805.94	89	32.16	773.78	33.77	772.17	34.03	771.91
PH-9	814.94	98	40.58	774.36	40.51	774.43	40.63	774.31
PH-11	820.68	78	45.43	775.25	42.96	777.72	46.81	773.87
PH-12	828.35	87	48.87	779.48	47.89	780.46	49.03	779.32
B-3	803.02	83	NA	NA	NA	NA	NA	NA
Amoco	842.29	NA	NA	NA	NA	NA	NA	NA
Hamp. Town #22	804.96	NA	29.56	775.40	27.11	777.85	27.43	777.53
Pembroke #1	NA	NA	NA	NA	11.93	NA	12.13	NA
Pembroke #2	NA	NA	NA	NA	NA	NA	NA	NA
N. Houcks. Rd.	NA	NA	8.49	NA	9.17	NA	10.08	NA
E. Century St.	NA	NA	12.99	NA	22.61	NA	28.11	NA
Lwr. Beckleys. Rd.	NA	NA	56.41	NA	55.86	NA	55.06	NA

NA - Not Available/Not Accessible

Table 2-3
 Effluent Characteristics Summary - 4th Quarter 2006
 Black & Decker
 Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				October 2006	November 2006	December 2006	
001	FLOW	average	MGD	NA	0.182	0.251	0.219
		maximum	MGD	NA	0.657	0.988	0.630
	1,1,1-Trichloroethane		ug/l	5	< 5	< 5	< 5
	Tetrachloroethylene		ug/l	5	< 5	< 5	< 5
	Trichloroethylene		ug/l	5	< 5	< 5	< 5
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		quarterly average	mg/l	10	NR	NR	< 5
	pH	minimum	STD	6.0	6.00	6.10	6.10
		maximum	STD	8.5	6.40	6.40	6.40
	BOD		mg/l	15	5.3	6.0	< 2
TSS	maximum	mg/l	30	14.0	7.0	< 5	
	quarterly average	mg/l	20	NR	NR	< 5	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.344	0.282	0.294
		maximum	MGD	NA	0.383	0.288	0.320
	Fecal Coliform		MPN/100ml	200	< 2	< 2	< 2
201 (Monitoring Point)	FLOW	average	MGD	NA	0.204	0.210	0.308
		maximum	MGD	NA	0.242	0.238	1.020
	1,1,1-Trichloroethane		ug/l	NA	< 5	< 5	< 5
	Tetrachloroethylene		ug/l	NA	< 5	< 5	< 5
	Trichloroethylene		ug/l	NA	< 5	< 5	< 5

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

Table 2-4

Summary of Groundwater Analytical Results - November 2006

Black & Decker

Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1.4
Acetone	ug/L	NS	5 U	6.4	5 U	5 U	5.7	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 J	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3.6	2.2	1 U	1 U	1 U	8.8	35	1.4	1.4	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	420	180	840	230	11	6.9	16	2.1	1.9	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	56	4.6	16	10	21	14	100	230	220	5.4
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

Table 2-4
 Summary of Groundwater Analytical Results - November 2006
 Black & Decker
 Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4B	RFW-4B (DUP)	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1.7	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	1 U	1 U	1 U	1 U	1.3	7.2	1	1 U	NS	1 U	1 U	NS	1 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5	8	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.1	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	8.4	1.2	8.5	7.4	NS	1	1 U	NS	13	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	1.2	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	2.2	1.6	1 U	36	9	8.8	NS	4.9	3.4	NS	16	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 J	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	3	33	60	66	NS	4.1	1 U	NS	6.7	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicate sample
 NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
 J = Indicates an estimated value.

Table 2-4
 Summary of Groundwater Analytical Results - November 2006
 Black & Decker
 Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	USEPA drinking water method 524.2				
												RFW-20	RFW-21	Town #22	Town #23	Trip Blank
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.66	0.5 U	1.5
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Acetone	ug/L	NS	5 U	5 U	8.2	NS	5 U	5 U	5 U	NS	5 U	40	48	71	73	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	NA	NA	NA	NA	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	3.7	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trichloroethene	ug/L	NS	19	560	3.3	NS	1 U	1 U	1 U	NS	1 U	0.6	0.5 U	0.5 U	0.5 U	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	1 U	41	15	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.3 J	0.2 J	0.29 J	0.44 J	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division. Samples from all of the other wells are analyzed with USEPA Method 8260.

NS = Not sampled

U = Compound was analyzed but not detected.

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from well EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (October through December 2006) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 4th Quarter 2006
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Oct-06	Replaced the pump in well EW-8. Bleached the well, the well is back in service.
Oct-06	Replaced the pump in well EW-7. Bleached the well, the well is back in service.
Dec-06	Low wet well alarm. Substation tripped out. Restored power to substation.
Dec-06	Pump in well EW-3 is surging between 0-30 GPM. A new pump is installed and the well is pumping 38 GPM. The well was down for two days.
Dec-06	Pump in well EW-2 went down. A new pump and motor was installed. The well was down for six days. The well is now back online.
Dec-06	Alarm at the air stripper. High column and blower failure. Switch blowers and the air stripper back online.

4. RECOMMENDATIONS

For the reporting period of October through December 2006, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(OCTOBER – DECEMBER 2006)

MONTH / YEAR

Oct. 2006

**BLACK & DECKER
AIR STRIPPER # 2
OPERATING RECORD**

PAST MONTH READING

137457233

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	S	1015	137854858	235449	31420	31386
2	M	1330	138090347	200987	31447	31386
3	T	1255	138291334	205857	31447	31410
4	W	1255	138497191	212907	31447	31434
5	T	1410	138710098	191366	31447	31459
6	F	1255	138901464	↑	31447	31482
7						
8				610493		
9	M	1320	139511957	205671	31447	31554
10	T	1340	139717628	202263	31472	31554
11	W	1345	139919891	207043	31496	31554
12	T	1420	140126934	192359	31520	31554
13	F	1310	140319293	↓	31543	31554
14						
15				600991		
16	M	1240	140920284	196172	31615	31554
17	T	1205	141116456	185350	31615	31578
18	W	1215	141301806	199789	31615	31600
19	T	1425	141501595	165019	31615	31626
20	F	1225	141666614	↑	31615	31648
21						
22				657069		
23	M	1240	142323683	213892	31615	31721
24	T	1220	142537575	219630	31638	31721
25	W	1245	142751205	187017	31663	31721
26	T	1220	142944222	187317	31686	31721
27	F	1140	143131539	↑	31710	31721
28						
29				579281		
30	M	1040	143710820	241705	31782	31721
31	T	1145	143952525	233735	31782	31746
Total				6331362		
Average				204237		

NEXT MONTH READING 144186260

DATE 11-1-06

MONTH / YEAR

Nov. 2006

**BLACK & DECKER
AIR STRIPPER # 2
OPERATING RECORD**

PAST MONTH READING

143952525

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	W	1255	144186260	222243	31782	31771
2	T	1340	144408503	220122	31782	31796
3	F	1215	144608625	↑	31782	31818
4						
5				629015		
6	M	1230	145237640	187203	31782	31890
7	T	1020	145424843	220373	31782	31912
8	W	1040	145645216	237562	31806	31912
9	T	1330	145822778	211391	31833	31912
10	F	1330	146094169	↑	31857	31912
11						
12				617957		
13	M	1150	146712126	208965	31927	31912
14	T	1135	146921091	204727	31927	31936
15	W	1100	147125818	230341	31927	31959
16	T	1210	147356159	210729	31927	31985
17	F	1200	147566888	↑	31927	32008
18						
19				647569		
20	M	1335	148214457	211872	31927	32082
21	T	1250	148426329	200302	31950	32082
22	W	1120	148626629	↑	31913	32082
23	T	Thanksgiving				
24	F	"				
25						
26				1032859		
27	M	1045	149659488	233904	32092	32082
28	T	1405	149893392	183345	32092	32110
29	W	1145	150076737	220051	32092	32131
30	T	1210	150296788	183351	32092	32153
31						
Total				6299879		
Average				209996		

NEXT MONTH READING 150691956

DATE 12-2-06

MONTH / YEAR

BLACK & DECKER
AIR STRIPPER # 2
OPERATING RECORD

PAST MONTH READING

Dec. 2006

150296788

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	F			205817		
2	S	1100	150691950	↑	32092	32203
3				394872		
4	M	1110	151086828	177337	32092	32251
5	T	1215	151264165	175479	32092	32276
6	W	1310	151439644	206302	32092	32301
7	T	1200	151645946	212915	32092	32323
8	F	1220	151858861	↑	32092	32348
9						
10				607986		
11	M	1115	152466847	208404	32092	32419
12	T	1245	152675251	187993	32118	32419
13	W	1225	152863244	170743	32141	32419
14	T	0955	153033987	209207	32163	32419
15	F	1200	153243194	↑	32189	32419
16						
17				625154		
18	M	1055	153868348	205507	32260	32419
19	T	0850	154073855	245907	32260	32441
20	W	1120	154319757	218994	32260	32467
21	T	1205	154538753	220338	32260	32492
22	F	1320	154759091	↑	32285	32492
23						
24						
25	M					
26	T			1018683		
27	W	1120	155777114	* 218790	32403	32492
28	T	1250	* 105372	85449	32403	32513
29	F	1140	190821	218790 ↑	32403	32534
30						
31				565,092		
Total				6160966		
Average				198,740.83		

* E103 down
* E102 down
* E102 up

Totalizer reset itself from power outage. Flow figured @ 143 gpm x clock.

NEXT MONTH READING _____

DATE _____

**APPENDIX B
DISCHARGE MONITORING REPORTS
(OCTOBER - DECEMBER 2006)**

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)
 NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**


NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No.2040-0004

MD0001881 **001**
 PERMIT NUMBER DISCHARGE NUMBER
 (2-16) (17-19)

MONITORING PERIOD
 FROM YEAR MO DAY TO YEAR MO DAY
 2006 10 01 TO 06 10 31
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)					
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS				
FLOW	SAMPLE MEASUREMENT	0.182	0.657	MGD				0	Measured/Recorded						
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT												
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT					<5	ppb	0	1/MONTH	GRAB					
	PERMIT REQUIREMENT					5									
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT					<5	ppb	0	1/MONTH	GRAB					
	PERMIT REQUIREMENT					5									
TRICHLOROETHYLENE	SAMPLE MEASUREMENT					<5	ppb	0	1/MONTH	GRAB					
	PERMIT REQUIREMENT					5									
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT					<0.1	mg/l	0	1/MONTH	GRAB					
	PERMIT REQUIREMENT					0.011 0.019									
OIL & GREASE	SAMPLE MEASUREMENT					<5	mg/l	0	1/MONTH	GRAB					
	PERMIT REQUIREMENT					10 <5									
pH	SAMPLE MEASUREMENT				6.00	6.40	STD	0	2/WEEK	GRAB					
	PERMIT REQUIREMENT				6.00	8.50									
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		<small>I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THIS INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)</small>						TELEPHONE	DATE						
Michael A. Clark Principal								 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						410-374-9025	06 11 02
TYPED OR PRINTED														AREA CODE-NUMBER	YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881 **001**
 PERMIT NUMBER DISCHARGE NUMBER
 (2-16) (17-19)

FORM APPROVED
 OMB No.2040-0004

MONITORING PERIOD					
FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
2006	10	01	06	10	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	QUANTITY OR LOADING (3 Card Only) (46-53)			QUALITY OR CONCENTRATION (4 Card Only) (46-53)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-66)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM					
BOD	SAMPLE MEASUREMENT							5.3	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT							15		1/MONTH	GRAB	
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT							14.0	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT							20 30		1/MONTH	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER								TELEPHONE	DATE			
Michael A. Clark Principal								410-374-9025	06 11 02			
TYPED OR PRINTED									AREA CODE-NUMBER	YEAR MO DAY		
I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)								SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
 Washington, DC 20004

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881 **101**
 PERMIT NUMBER DISCHARGE NUMBER

(2-16) (17-19)

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2006	10	01	06	10	31

FROM

TO

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	QUANTITY OR LOADING (3 Card Only (46-53) (54-61) (24-25))			QUALITY OR CONCENTRATION (4 Card Only (38-45) (46-53) (54-61) (28-27) (28-29) (30-31))			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW	SAMPLE MEASUREMENT	0.344	0.383	MGD				0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT						Cont Measure/Record	
FECAL COLIFORM	SAMPLE MEASUREMENT					<2	MPN/100ml	0	1/WEEK GRAB	
	PERMIT REQUIREMENT					200			1/WEEK GRAB	
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Weddlee
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: 410-374-9025
 DATE: 06 | 11 | 02
 AREA CODE-NUMBER YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)


DISCHARGE MONITORING REPORT (DMR)

MD0001881 **201**
 PERMIT NUMBER DISCHARGE NUMBER

FORM APPROVED
 OMB No.2040-0004

MONITORING PERIOD								
FROM			TO					
YEAR	MO	DAY	YEAR	MO	DAY			
2006	10	01	06	10	31			

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only (46-53) (54-61))			QUALITY OR CONCENTRATION (4 Card Only (38-45) (46-53) (54-61))			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
FLOW	SAMPLE MEASUREMENT	0.204	0.242	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record	
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH GRAB	
	PERMIT REQUIREMENT						N/A			1/MONTH GRAB	
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH GRAB	
	PERMIT REQUIREMENT						N/A			1/MONTH GRAB	
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH GRAB	
	PERMIT REQUIREMENT						N/A			1/MONTH GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN. AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)								TELEPHONE	DATE	
Michael A. Clark Principal	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT								410-374-9025	06 11 02	
TYPED OR PRINTED									AREA CODE-NUMBER	YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No.2040-0004

MD0001881 **001**
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD
 FROM YEAR 2006 MO 11 DAY 01 TO YEAR 06 MO 11 DAY 30

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLI TYPE (69-71)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.251	0.988	MGD					0	Measured/Recorder	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Measured/Recorder	
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH GRA	
	PERMIT REQUIREMENT						5			1/MONTH GRA	
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH GRA	
	PERMIT REQUIREMENT						5			1/MONTH GRA	
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH GRA	
	PERMIT REQUIREMENT						5			1/MONTH GRA	
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT						<0.1	mg/l	0	1/MONTH GRA	
	PERMIT REQUIREMENT					0.011	0.019			1/MONTH GRA	
OIL & GREASE	SAMPLE MEASUREMENT						<5	mg/l	0	1/MONTH GRA	
	PERMIT REQUIREMENT					10	<5			1/MONTH GRA	
pH	SAMPLE MEASUREMENT				6.10		6.40	STD	0	2/WEEK GRA	
	PERMIT REQUIREMENT				6.00		6.50			2/WEEK GRA	

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER: **Michael A. Clark**
 Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT: *Earl Wedder*

TELEPHONE: 410-374-9025
 DATE: 06 | 12 | 05
 AREA CODE-NUMBER: 410-374-9025
 YEAR | MO | DAY: 06 | 12 | 05

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No.2040-0004

MD0001881
 PERMIT NUMBER (2-10)

001
 DISCHARGE NUMBER (17-19)

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	2006	11	01		06	11	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) (46-53)			(4 Card Only)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		QUANTITY OR LOADING (54-61)			QUALITY OR CONCENTRATION						
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD	SAMPLE MEASUREMENT						6.0	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						15				
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT						7.0	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					20	30				
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
 Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN. AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Wedder
 SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE
 410-374-9025
 AREA CODE-NUMBER

DATE
 06 | 12 | 05
 YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.
 EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER
 (2-18)

101
 DISCHARGE NUMBER
 (17-19)

FORM APPROVED
 OMB No.2040-0004

MONITORING PERIOD
 FROM YEAR 2006 MO 11 DAY 01 TO YEAR 06 MO 11 DAY 30
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	QUANTITY OR LOADING (3 Card Only) (46-53)			QUALITY OR CONCENTRATION (4 Card Only)				NO. EX	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-71)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.282	0.288	MGD					0	Cont Measure/Recor	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Recor	
FECAL COLIFORM	SAMPLE MEASUREMENT						<2	MPN/100ml	0	1/WEEK	GRAI
	PERMIT REQUIREMENT						200			1/WEEK	GRAI
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER									TELEPHONE	DATE	
Michael A. Clark Principal TYPED OR PRINTED									410-374-9025	06 12 05	
I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)									AREA CODE-NUMBER	YEAR MO DAY	
OFFICER OR AUTHORIZED AGENT <i>Earl Weddole</i> SIGNATURE OF PRINCIPAL EXECUTIVE											

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No.2040-0004

MD0001881	201
PERMIT NUMBER	DISCHARGE NUMBER
(2-18)	(17-18)

MONITORING PERIOD					
FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
2006	11	01	06	11	30
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) (46-53) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-66)	SAMPLE TYPE (69-71)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.210	0.238	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record	
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Wedde
 SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE: 410-374-9025
 DATE: 06 | 12 | 05
 AREA CODE-NUMBER: 410-374-9025
 YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

MD0001881

PERMIT NUMBER

001

DISCHARGE NUMBER

State Discharge Permit
02-DP-0022

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98


MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
06	12	01		06	12	31	
(20-21)		(22-23)		(24-25)		(26-27)	
				(28-29)		(30-31)	

*** NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER (33-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING (3 Card Only (46-53))			QUANTITY OR CONCENTRATION (4 Card Only (38-45))			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(19)	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15	MG/L		ONE/ MONTH	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	****	6.1	*****	6.4	(12)	0	TWO/ WEEK	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	8.5	SU		TWO/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	20	30	MG/L		ONE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	219218	629600	(07)	*****	*****	*****		0	MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.011	0.019	MG/L		ONE/ MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0		0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0		0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: **410 729-8350**
DATE: **07 01 26**
AREA CODE: **410** NUMBER: **729-8350** YEAR: **07** MO: **01** DAY: **26**

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

STATE POLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

State Discharge Permit
02-DP-0022

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98


MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
06	12	01		06	12	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING (3 Card Only (46-53) (54-61))			QUANTITY OR CONCENTRATION (4 Card Only (38-45) (46-53) (54-61))			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****		*****	*****	0		0	ONE/MONTH	GRAB
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****		*****	0	0	(19)	0	ONE/MONTH	GRAB
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
410	729-8350	07	01	26
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

MD0001881
PERMIT NUMBER

101
DISCHARGE NUMBER

State Discharge Permit
02-DP-0022

Form Approved. 12345


OMB No. 2040-0004.

Approval expires 05-31-98

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
06	12	01	TO	06	12	31
(20-21)		(22-23)		(24-25)		(26-27)
				(28-29)		(30-31)

*** NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT PERMIT REQUIREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-43)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	294286	320000	(07)	*****	*****	*****	*****	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	GPD	*****	*****	*****				
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	TWO/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	MPN	*****	*****	200				
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Jim Harkins, Director MES		 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	410	729-8350	07	01
TYPED OR PRINTED	AREA CODE		NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**
 ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

MD0001881
 PERMIT NUMBER

201
 DISCHARGE NUMBER

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
06	12	01		06	12	31
(20-21)		(22-23)		(24-25)		(26-27)
						(28-29)
						(30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT PERMIT REQUIREMENT	QUANTITY OR LOADING (34-61)			QUANTITY OR CONCENTRATION (38-45) (46-53)			UNITS	NO EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (3 Card Only) (46-53)	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	308047	1018683	(07)	*****	*****	*****	****	0	MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****				
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	ug/l	0	ONE/ QUARTER	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT *****	REPORT *****				
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	ug/l	0	ONE/ QUARTER	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT *****	REPORT				
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	ug/l	0	ONE/ QUARTER	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT *****	REPORT				
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

[Signature]
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: 410 729-8350
 AREA CODE NUMBER
 DATE: 07 01 26
 YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(OCTOBER - DECEMBER 2006)



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street · Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

Certificate of Analysis

Page 3

Client: BTR Hampstead, Inc.
Report No: 0610118
Project: Hampstead-Monthly
Matrix: WASTEWATER

Client Sample ID: Air Stripper 2 (Pre)
Lab ID: 0610118-002
Collection Date: 10/4/2006 10:20

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst: NA

Chloromethane	< 10	10	µg/L	10/9/2006 18:07
Vinyl chloride	< 10	10	µg/L	10/9/2006 18:07
Bromomethane	< 10	10	µg/L	10/9/2006 18:07
Chloroethane	< 10	10	µg/L	10/9/2006 18:07
Acrolein	< 100	100	µg/L	10/9/2006 18:07
1,1-Dichloroethene	< 5.0	5.0	µg/L	10/9/2006 18:07
Methylene chloride	< 5.0	5.0	µg/L	10/9/2006 18:07
Acrylonitrile	< 100	100	µg/L	10/9/2006 18:07
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	10/9/2006 18:07
1,1-Dichloroethane	< 5.0	5.0	µg/L	10/9/2006 18:07
Chloroform	< 5.0	5.0	µg/L	10/9/2006 18:07
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	10/9/2006 18:07
Carbon tetrachloride	< 5.0	5.0	µg/L	10/9/2006 18:07
Benzene	< 5.0	5.0	µg/L	10/9/2006 18:07
1,2-Dichloroethane	< 5.0	5.0	µg/L	10/9/2006 18:07
Trichloroethene	87	5.0	µg/L	10/9/2006 18:07
1,2-Dichloropropane	< 5.0	5.0	µg/L	10/9/2006 18:07
Bromodichloromethane	< 5.0	5.0	µg/L	10/9/2006 18:07
2-Chloroethyl vinyl ether	< 10	10	µg/L	10/9/2006 18:07
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	10/9/2006 18:07
Toluene	< 5.0	5.0	µg/L	10/9/2006 18:07
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	10/9/2006 18:07
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	10/9/2006 18:07
Tetrachloroethene	68	5.0	µg/L	10/9/2006 18:07
Dibromochloromethane	< 5.0	5.0	µg/L	10/9/2006 18:07
Chlorobenzene	< 5.0	5.0	µg/L	10/9/2006 18:07
Ethylbenzene	< 5.0	5.0	µg/L	10/9/2006 18:07
Bromoform	< 5.0	5.0	µg/L	10/9/2006 18:07
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	10/9/2006 18:07
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	10/9/2006 18:07
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	10/9/2006 18:07
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	10/9/2006 18:07



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street · Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

Certificate of Analysis

Page 4

Client: BTR Hampstead, Inc.
 Report No: 0610118
 Project: Hampstead-Monthly
 Matrix: WASTEWATER

Client Sample ID: Outfall 201 (Post)
 Lab ID: 0610118-003
 Collection Date: 10/4/2006 10:19

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst: NA

Chloromethane	< 10	10	µg/L	10/9/2006 18:41
Vinyl chloride	< 10	10	µg/L	10/9/2006 18:41
Bromomethane	< 10	10	µg/L	10/9/2006 18:41
Chloroethane	< 10	10	µg/L	10/9/2006 18:41
Acrolein	< 100	100	µg/L	10/9/2006 18:41
1,1-Dichloroethene	< 5.0	5.0	µg/L	10/9/2006 18:41
Methylene chloride	< 5.0	5.0	µg/L	10/9/2006 18:41
Acrylonitrile	< 100	100	µg/L	10/9/2006 18:41
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	10/9/2006 18:41
1,1-Dichloroethane	< 5.0	5.0	µg/L	10/9/2006 18:41
Chloroform	< 5.0	5.0	µg/L	10/9/2006 18:41
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	10/9/2006 18:41
Carbon tetrachloride	< 5.0	5.0	µg/L	10/9/2006 18:41
Benzene	< 5.0	5.0	µg/L	10/9/2006 18:41
1,2-Dichloroethane	< 5.0	5.0	µg/L	10/9/2006 18:41
Trichloroethene	< 5.0	5.0	µg/L	10/9/2006 18:41
1,2-Dichloropropane	< 5.0	5.0	µg/L	10/9/2006 18:41
Bromodichloromethane	< 5.0	5.0	µg/L	10/9/2006 18:41
2-Chloroethyl vinyl ether	< 10	10	µg/L	10/9/2006 18:41
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	10/9/2006 18:41
Toluene	< 5.0	5.0	µg/L	10/9/2006 18:41
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	10/9/2006 18:41
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	10/9/2006 18:41
Tetrachloroethene	< 5.0	5.0	µg/L	10/9/2006 18:41
Dibromochloromethane	< 5.0	5.0	µg/L	10/9/2006 18:41
Chlorobenzene	< 5.0	5.0	µg/L	10/9/2006 18:41
Ethylbenzene	< 5.0	5.0	µg/L	10/9/2006 18:41
Bromoform	< 5.0	5.0	µg/L	10/9/2006 18:41
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	10/9/2006 18:41
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	10/9/2006 18:41
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	10/9/2006 18:41
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	10/9/2006 18:41



www.microbac.com

Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

2101 Van Deman Street • Baltimore, MD 21224

CERTIFICATE OF ANALYSIS

Page 2 of 6

BTR Hampstead, Inc.
EEMA O&M Services Group
626 Hanover Pike, Suite 800
Hampstead, MD 21074
Attn: Mike Clark

Report No: 0611020
Date Received: 11/1/2006
Date Reported: 11/27/2006

Project: Hampstead-Monthly

Test	Result	Units	Reporting Limit	Date/Time of Analysis	Analyst
Lab ID: 0611020-002					
Client Sample ID: Air Stripper 2 (Pre)					
Collection Date: 11/1/2006 11:53:00 AM					
Matrix: WASTEWATER					
VOLATILE ORGANIC COMPOUNDS (METHOD: EPA 624)					
Prep. Method: NA	Prep. Date: NA		Prep Analyst NA		
Chloromethane	< 10	µg/L	10	11/8/2006 23:50	MLS
Vinyl chloride	< 10	µg/L	10	11/8/2006 23:50	MLS
Bromomethane	< 10	µg/L	10	11/8/2006 23:50	MLS
Chloroethane	< 10	µg/L	10	11/8/2006 23:50	MLS
Acrolein	< 100	µg/L	100	11/8/2006 23:50	MLS
1,1-Dichloroethene	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
Methylene chloride	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
Acrylonitrile	< 100	µg/L	100	11/8/2006 23:50	MLS
trans-1,2-Dichloroethene	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
1,1-Dichloroethane	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
Chloroform	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
1,1,1-Trichloroethane	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
Carbon tetrachloride	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
Benzene	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
1,2-Dichloroethane	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
Trichloroethene	94	µg/L	5.0	11/8/2006 23:50	MLS
1,2-Dichloropropane	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
Bromodichloromethane	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
2-Chloroethyl vinyl ether	< 10	µg/L	10	11/8/2006 23:50	MLS
cis-1,3-Dichloropropene	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
Toluene	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
trans-1,3-Dichloropropene	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
1,1,2-Trichloroethane	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
Tetrachloroethene	76	µg/L	5.0	11/8/2006 23:50	MLS
Dibromochloromethane	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
Chlorobenzene	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
Ethylbenzene	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
Bromoform	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
1,1,2,2-Tetrachloroethane	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
1,3-Dichlorobenzene	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
1,4-Dichlorobenzene	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS
1,2-Dichlorobenzene	< 5.0	µg/L	5.0	11/8/2006 23:50	MLS



Microbac

www.microbac.com

Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

2101 Van Deman Street • Baltimore, MD 21224

CERTIFICATE OF ANALYSIS

Page 3 of 6

BTR Hampstead, Inc.
EEMA O&M Services Group
626 Hanover Pike, Suite 800
Hampstead, MD 21074
Attn: Mike Clark

Report No: 0611020
Date Received: 11/1/2006
Date Reported: 11/27/2006

Project: Hampstead-Monthly

Test	Result	Units	Reporting Limit	Date/Time of Analysis	Analyst
Lab ID: 0611020-003					
Client Sample ID: Outfall 201 (Post)					
Collection Date: 11/1/2006 11:52:00 AM					
Matrix: WASTEWATER					
VOLATILE ORGANIC COMPOUNDS (METHOD : EPA 624)					
Prep. Method: NA		Prep. Date: NA		Prep Analyst NA	
Chloromethane	< 10	µg/L	10	11/9/2006 10:49	MLS
Vinyl chloride	< 10	µg/L	10	11/9/2006 10:49	MLS
Bromomethane	< 10	µg/L	10	11/9/2006 10:49	MLS
Chloroethane	< 10	µg/L	10	11/9/2006 10:49	MLS
Acrolein	< 100	µg/L	100	11/9/2006 10:49	MLS
1,1-Dichloroethene	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
Methylene chloride	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
Acrylonitrile	< 100	µg/L	100	11/9/2006 10:49	MLS
trans-1,2-Dichloroethene	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
1,1-Dichloroethane	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
Chloroform	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
1,1,1-Trichloroethane	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
Carbon tetrachloride	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
Benzene	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
1,2-Dichloroethane	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
Trichloroethene	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
1,2-Dichloropropane	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
Bromodichloromethane	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
2-Chloroethyl vinyl ether	< 10	µg/L	10	11/9/2006 10:49	MLS
cis-1,3-Dichloropropene	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
Toluene	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
trans-1,3-Dichloropropene	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
1,1,2-Trichloroethane	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
Tetrachloroethene	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
Dibromochloromethane	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
Chlorobenzene	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
Ethylbenzene	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
Bromoform	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
1,1,2,2-Tetrachloroethane	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
1,3-Dichlorobenzene	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
1,4-Dichlorobenzene	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS
1,2-Dichlorobenzene	< 5.0	µg/L	5.0	11/9/2006 10:49	MLS



www.microbac.com

Microbac Laboratories, Inc. Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

Test Results

Page 3

Client: BTR Hampstead, Inc. Client Sample ID: Air Stripper 2 (Pre)
 Report No: 0612132
 Project: Hampstead-Monthly Lab ID: 0612132-002
 Matrix: WASTEWATER Collection Date: 12/7/2006 10:18

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst: NA

Chloromethane	< 10	10	µg/L	12/19/2006 17:18
Vinyl chloride	< 10	10	µg/L	12/19/2006 17:18
Bromomethane	< 10	10	µg/L	12/19/2006 17:18
Chloroethane	< 10	10	µg/L	12/19/2006 17:18
Acrolein	< 100	100	µg/L	12/19/2006 17:18
1,1-Dichloroethene	< 5.0	5.0	µg/L	12/19/2006 17:18
Methylene chloride	< 5.0	5.0	µg/L	12/19/2006 17:18
Acrylonitrile	< 100	100	µg/L	12/19/2006 17:18
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	12/19/2006 17:18
1,1-Dichloroethane	< 5.0	5.0	µg/L	12/19/2006 17:18
Chloroform	< 5.0	5.0	µg/L	12/19/2006 17:18
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	12/19/2006 17:18
Carbon tetrachloride	< 5.0	5.0	µg/L	12/19/2006 17:18
Benzene	< 5.0	5.0	µg/L	12/19/2006 17:18
1,2-Dichloroethane	< 5.0	5.0	µg/L	12/19/2006 17:18
Trichloroethene	90	5.0	µg/L	12/19/2006 17:18
1,2-Dichloropropane	< 5.0	5.0	µg/L	12/19/2006 17:18
Bromodichloromethane	< 5.0	5.0	µg/L	12/19/2006 17:18
2-Chloroethyl vinyl ether	< 10	10	µg/L	12/19/2006 17:18
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	12/19/2006 17:18
Toluene	< 5.0	5.0	µg/L	12/19/2006 17:18
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	12/19/2006 17:18
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	12/19/2006 17:18
Tetrachloroethene	52	5.0	µg/L	12/19/2006 17:18
Dibromochloromethane	< 5.0	5.0	µg/L	12/19/2006 17:18
Chlorobenzene	< 5.0	5.0	µg/L	12/19/2006 17:18
Ethylbenzene	< 5.0	5.0	µg/L	12/19/2006 17:18
Bromoform	< 5.0	5.0	µg/L	12/19/2006 17:18
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	12/19/2006 17:18
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	12/19/2006 17:18
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	12/19/2006 17:18



Microbac

www.microbac.com

Microbac Laboratories, Inc. Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

Test Results

Page 4

Client:	BTR Hampstead, Inc.	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0612132	Lab ID:	0612132-002
Project:	Hampstead-Monthly	Collection Date:	12/7/2006 10:18
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	12/19/2006 17:18



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 5

Client:	BTR Hampstead, Inc.	Client Sample ID:	Outfall 201 (Post)
Report No:	0612132	Lab ID:	0612132-003
Project:	Hampstead-Monthly	Collection Date:	12/7/2006 10:17
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst: NA

Chloromethane	< 10	10	µg/L	12/19/2006 17:52
Vinyl chloride	< 10	10	µg/L	12/19/2006 17:52
Bromomethane	< 10	10	µg/L	12/19/2006 17:52
Chloroethane	< 10	10	µg/L	12/19/2006 17:52
Acrolein	< 100	100	µg/L	12/19/2006 17:52
1,1-Dichloroethene	< 5.0	5.0	µg/L	12/19/2006 17:52
Methylene chloride	< 5.0	5.0	µg/L	12/19/2006 17:52
Acrylonitrile	< 100	100	µg/L	12/19/2006 17:52
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	12/19/2006 17:52
1,1-Dichloroethane	< 5.0	5.0	µg/L	12/19/2006 17:52
Chloroform	< 5.0	5.0	µg/L	12/19/2006 17:52
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	12/19/2006 17:52
Carbon tetrachloride	< 5.0	5.0	µg/L	12/19/2006 17:52
Benzene	< 5.0	5.0	µg/L	12/19/2006 17:52
1,2-Dichloroethane	< 5.0	5.0	µg/L	12/19/2006 17:52
Trichloroethene	< 5.0	5.0	µg/L	12/19/2006 17:52
1,2-Dichloropropane	< 5.0	5.0	µg/L	12/19/2006 17:52
Bromodichloromethane	< 5.0	5.0	µg/L	12/19/2006 17:52
2-Chloroethyl vinyl ether	< 10	10	µg/L	12/19/2006 17:52
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	12/19/2006 17:52
Toluene	< 5.0	5.0	µg/L	12/19/2006 17:52
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	12/19/2006 17:52
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	12/19/2006 17:52
Tetrachloroethene	< 5.0	5.0	µg/L	12/19/2006 17:52
Dibromochloromethane	< 5.0	5.0	µg/L	12/19/2006 17:52
Chlorobenzene	< 5.0	5.0	µg/L	12/19/2006 17:52
Ethylbenzene	< 5.0	5.0	µg/L	12/19/2006 17:52
Bromoform	< 5.0	5.0	µg/L	12/19/2006 17:52
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	12/19/2006 17:52
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	12/19/2006 17:52
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	12/19/2006 17:52



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800
Fax: 410-633-6553
www.microbac.com

Test Results

Page 6

Client: BTR Hampstead, Inc. **Client Sample ID:** Outfall 201 (Post)
Report No: 0612132
Project: Hampstead-Monthly **Lab ID:** 0612132-003
Matrix: WASTEWATER **Collection Date:** 12/7/2006 10:17

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	12/19/2006 17:52

APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(NOVEMBER 2006)



STL

STL Chicago
2417 Bond Street
University Park, IL 60466

Tel: 708 534 5200 Fax: 708 534 5211
www.stl-inc.com

ANALYTICAL REPORT

Job Number: 500-1992-1

Job Description: Black and Decker

For:
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380

Attention: Mr. Tom Cornuet

Richard C Wright
Project Manager II
rwright@stl-inc.com
12/07/2006

Project Manager: Richard C Wright

These test results meet all the requirements of NELAC for accredited parameters.

The Lab Certification ID# is 100201.

All questions regarding this test report should be directed to the STL Project Manager whose signature appears on this report. All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.

Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.

Severn Trent Laboratories, Inc.

STL Chicago 2417 Bond Street, University Park, IL 60466
Tel (708) 534-5200 Fax (708) 534-5211 www.stl-inc.com



EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-1992-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-1992-1	EW-2				
cis-1,2-Dichloroethene		3.6	1.0	ug/L	8260B
Trichloroethene		420	10	ug/L	8260B
Tetrachloroethene		56	1.0	ug/L	8260B
500-1992-2	EW-3				
Acetone		6.4	5.0	ug/L	8260B
cis-1,2-Dichloroethene		2.2	1.0	ug/L	8260B
Trichloroethene		180	10	ug/L	8260B
Tetrachloroethene		4.6	1.0	ug/L	8260B
500-1992-3	EW-4				
Trichloroethene		840	10	ug/L	8260B
Tetrachloroethene		16	1.0	ug/L	8260B
500-1992-4	EW-5				
Trichloroethene		230	10	ug/L	8260B
Tetrachloroethene		10	1.0	ug/L	8260B
500-1992-5	EW-6				
Acetone		5.7	5.0	ug/L	8260B
Trichloroethene		11	1.0	ug/L	8260B
Tetrachloroethene		21	1.0	ug/L	8260B
500-1992-6	EW-7				
1,1-Dichloroethane		0.99 J	1.0	ug/L	8260B
cis-1,2-Dichloroethene		8.8	1.0	ug/L	8260B
Trichloroethene		6.9	1.0	ug/L	8260B
Tetrachloroethene		14	1.0	ug/L	8260B
500-1992-7	EW-8				
cis-1,2-Dichloroethene		35	1.0	ug/L	8260B
Trichloroethene		16	1.0	ug/L	8260B
Tetrachloroethene		100	1.0	ug/L	8260B

STL Chicago

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-1992-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-1992-8	EW-9				
cis-1,2-Dichloroethene		1.4	1.0	ug/L	8260B
Trichloroethene		2.1	1.0	ug/L	8260B
Tetrachloroethene		230	10	ug/L	8260B
500-1992-9	EW-9 DUP				
cis-1,2-Dichloroethene		1.4	1.0	ug/L	8260B
Trichloroethene		1.9	1.0	ug/L	8260B
Tetrachloroethene		220	10	ug/L	8260B
500-1992-10	EW-10				
Chloromethane		1.1	1.0	ug/L	8260B
Methylene Chloride		1.4	1.0	ug/L	8260B
Tetrachloroethene		5.4	1.0	ug/L	8260B
500-1992-14	RFW-2A				
Trichloroethene		2.2	1.0	ug/L	8260B
500-1992-15	RFW-2B				
Trichloroethene		1.6	1.0	ug/L	8260B
4-Methyl-2-pentanone (MIBK)		1.0 J	5.0	ug/L	8260B
500-1992-16	RFW-3B				
Methylene Chloride		1.3	1.0	ug/L	8260B
cis-1,2-Dichloroethene		8.4	1.0	ug/L	8260B
Tetrachloroethene		3.0	1.0	ug/L	8260B
500-1992-17	RFW-4A				
Acetone		7.2	5.0	ug/L	8260B
cis-1,2-Dichloroethene		1.2	1.0	ug/L	8260B
Chloroform		1.2	1.0	ug/L	8260B
Trichloroethene		36	1.0	ug/L	8260B
Tetrachloroethene		33	1.0	ug/L	8260B

STL Chicago

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-1992-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-1992-18	RFW-4B				
Acetone		5.0	5.0	ug/L	8260B
Methylene Chloride		1.0	1.0	ug/L	8260B
cis-1,2-Dichloroethene		8.5	1.0	ug/L	8260B
Trichloroethene		9.0	1.0	ug/L	8260B
Tetrachloroethene		60	1.0	ug/L	8260B
500-1992-19	RFW-4BDUP				
Acetone		8.0	5.0	ug/L	8260B
cis-1,2-Dichloroethene		7.4	1.0	ug/L	8260B
Trichloroethene		8.8	1.0	ug/L	8260B
Tetrachloroethene		66	1.0	ug/L	8260B
500-1992-20	RFW-6				
cis-1,2-Dichloroethene		1.0	1.0	ug/L	8260B
Trichloroethene		4.9	1.0	ug/L	8260B
Tetrachloroethene		4.1	1.0	ug/L	8260B
500-1992-21	RFW-7				
Chloromethane		1.7	1.0	ug/L	8260B
Trichloroethene		3.4	1.0	ug/L	8260B
500-1992-22	RFW-9				
1,1-Dichloroethene		1.1	1.0	ug/L	8260B
1,1-Dichloroethane		1.0	1.0	ug/L	8260B
cis-1,2-Dichloroethene		13	1.0	ug/L	8260B
Trichloroethene		16	1.0	ug/L	8260B
Tetrachloroethene		6.7	1.0	ug/L	8260B
500-1992-23	RFW-11B				
Trichloroethene		19	1.0	ug/L	8260B
500-1992-24	RFW-12B				
cis-1,2-Dichloroethene		3.7	1.0	ug/L	8260B
Trichloroethene		560	10	ug/L	8260B
Tetrachloroethene		41	1.0	ug/L	8260B

STL Chicago

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-1992-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-1992-25	RFW-13				
Acetone		8.2	5.0	ug/L	8260B
Trichloroethene		3.3	1.0	ug/L	8260B
Tetrachloroethene		15	1.0	ug/L	8260B

METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-1992-1

Description	Lab Location	Method	Preparation Method
Matrix: Water			
VOC	STL CHI	SW846 8260B	
Purge-and-Trap	STL CHI		SW846 5030B

LAB REFERENCES:

STL CHI = STL Chicago

METHOD REFERENCES:

SW846 - "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986
And Its Updates.

METHOD / ANALYST SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-1992-1

<u>Method</u>	<u>Analyst</u>	<u>Analyst ID</u>
SW846 8260B	Drabek, Dave J	DJD

SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-1992-1

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
500-1992-1	EW-2	Water	11/21/2006 1000	11/22/2006 0930
500-1992-2	EW-3	Water	11/21/2006 1010	11/22/2006 0930
500-1992-3	EW-4	Water	11/21/2006 1025	11/22/2006 0930
500-1992-4	EW-5	Water	11/20/2006 0930	11/22/2006 0930
500-1992-5	EW-6	Water	11/20/2006 1415	11/22/2006 0930
500-1992-6	EW-7	Water	11/20/2006 1530	11/22/2006 0930
500-1992-7	EW-8	Water	11/20/2006 1540	11/22/2006 0930
500-1992-8	EW-9	Water	11/20/2006 1545	11/22/2006 0930
500-1992-9	EW-9 DUP	Water	11/20/2006 1545	11/22/2006 0930
500-1992-10	EW-10	Water	11/20/2006 1550	11/22/2006 0930
500-1992-11	TRIP BLANK	Water	11/20/2006 0700	11/22/2006 0930
500-1992-12	RFW-1A	Water	11/20/2006 0910	11/22/2006 0930
500-1992-13	RFW-1B	Water	11/21/2006 0730	11/22/2006 0930
500-1992-14	RFW-2A	Water	11/20/2006 0815	11/22/2006 0930
500-1992-15	RFW-2B	Water	11/20/2006 0830	11/22/2006 0930
500-1992-16	RFW-3B	Water	11/21/2006 0810	11/22/2006 0930
500-1992-17	RFW-4A	Water	11/21/2006 0810	11/22/2006 0930
500-1992-18	RFW-4B	Water	11/21/2006 0920	11/22/2006 0930
500-1992-19	RFW-4BDUP	Water	11/21/2006 0920	11/22/2006 0930
500-1992-20	RFW-6	Water	11/21/2006 0750	11/22/2006 0930
500-1992-21	RFW-7	Water	11/20/2006 1015	11/22/2006 0930
500-1992-22	RFW-9	Water	11/21/2006 1220	11/22/2006 0930
500-1992-23	RFW-11B	Water	11/21/2006 1235	11/22/2006 0930
500-1992-24	RFW-12B	Water	11/21/2006 1300	11/22/2006 0930
500-1992-25	RFW-13	Water	11/20/2006 1425	11/22/2006 0930
500-1992-26	RFW-17	Water	11/20/2006 1105	11/22/2006 0930
500-1992-27	LEISTER-1	Water	11/20/2006 1755	11/22/2006 0930
500-1992-28	LEISTER-DAIRY	Water	11/20/2006 1800	11/22/2006 0930

SAMPLE RESULTS

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-2
 Lab Sample ID: 500-1992-1

Date Sampled: 11/21/2006 1000
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006 1201			
Prep Method: 5030B	Date Prepared:	11/29/2006 1201			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0 *	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0 *	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	3.6	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0 *	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0 *	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	56	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-2
 Lab Sample ID: 500-1992-1

Date Sampled: 11/21/2006 1000
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006	1201		
Prep Method: 5030B	Date Prepared:	11/29/2006	1201		
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	109	%	62 - 127
Toluene-d8 (Surr)	96	%	81 - 126
4-Bromofluorobenzene (Surr)	94	%	67 - 132
Dibromofluoromethane	110	%	77 - 119

Method: 8260B	Run Type: DL	Date Analyzed:	11/29/2006	1224		
Prep Method: 5030B		Date Prepared:	11/29/2006	1224		
Trichloroethene	420	ug/L	1.3	10	10	

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	112	%	62 - 127
Toluene-d8 (Surr)	98	%	81 - 126
4-Bromofluorobenzene (Surr)	97	%	67 - 132
Dibromofluoromethane	114	%	77 - 119

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-3
 Lab Sample ID: 500-1992-2

Date Sampled: 11/21/2006 1010
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006	1247		
Prep Method: 5030B	Date Prepared:	11/29/2006	1247		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0 *	ug/L	0.15	5.0	1.0
Acetone	6.4	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0 *	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	2.2	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0 *	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0 *	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	4.6	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-3
 Lab Sample ID: 500-1992-2

Date Sampled: 11/21/2006 1010
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	11/29/2006 1247		
Prep Method: 5030B		Date Prepared:	11/29/2006 1247		
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	110	%	62 - 127
Toluene-d8 (Surr)	98	%	81 - 126
4-Bromofluorobenzene (Surr)	96	%	67 - 132
Dibromofluoromethane	112	%	77 - 119

Method: 8260B	Run Type: DL	Date Analyzed:	11/29/2006 1311		
Prep Method: 5030B		Date Prepared:	11/29/2006 1311		
Trichloroethene	180	ug/L	1.3	10	10

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	109	%	62 - 127
Toluene-d8 (Surr)	98	%	81 - 126
4-Bromofluorobenzene (Surr)	97	%	67 - 132
Dibromofluoromethane	112	%	77 - 119

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-4
 Lab Sample ID: 500-1992-3

Date Sampled: 11/21/2006 1025
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006	1334		
Prep Method: 5030B	Date Prepared:	11/29/2006	1334		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0 *	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0 *	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0 *	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0 *	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	16	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-4
 Lab Sample ID: 500-1992-3

Date Sampled: 11/21/2006 1025
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006 1334			
Prep Method: 5030B	Date Prepared:	11/29/2006 1334			
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	107	%	62 - 127
Toluene-d8 (Surr)	95	%	81 - 126
4-Bromofluorobenzene (Surr)	95	%	67 - 132
Dibromofluoromethane	111	%	77 - 119

Method: 8260B	Run Type: DL	Date Analyzed:	11/29/2006 1358		
Prep Method: 5030B		Date Prepared:	11/29/2006 1358		
Trichloroethene	840	ug/L	1.3	10	10

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	109	%	62 - 127
Toluene-d8 (Surr)	96	%	81 - 126
4-Bromofluorobenzene (Surr)	95	%	67 - 132
Dibromofluoromethane	115	%	77 - 119

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-5
 Lab Sample ID: 500-1992-4

Date Sampled: 11/20/2006 0930
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006	1421		
Prep Method: 5030B	Date Prepared:	11/29/2006	1421		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0 *	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0 *	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0 *	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0 *	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	10	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-5
 Lab Sample ID: 500-1992-4

Date Sampled: 11/20/2006 0930
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006 1421			
Prep Method: 5030B	Date Prepared:	11/29/2006 1421			
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	110	%	62 - 127
Toluene-d8 (Surr)	95	%	81 - 126
4-Bromofluorobenzene (Surr)	96	%	67 - 132
Dibromofluoromethane	111	%	77 - 119

Method: 8260B Run Type: DL	Date Analyzed:	11/29/2006 1444			
Prep Method: 5030B	Date Prepared:	11/29/2006 1444			
Trichloroethene	230	ug/L	1.3	10	10

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	111	%	62 - 127
Toluene-d8 (Surr)	98	%	81 - 126
4-Bromofluorobenzene (Surr)	94	%	67 - 132
Dibromofluoromethane	117	%	77 - 119

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-6
 Lab Sample ID: 500-1992-5

Date Sampled: 11/20/2006 1415
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006	1507		
Prep Method: 5030B	Date Prepared:	11/29/2006	1507		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0 *	ug/L	0.15	5.0	1.0
Acetone	5.7	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0 *	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0 *	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0 *	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	11	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	21	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-6
 Lab Sample ID: 500-1992-5

Date Sampled: 11/20/2006 1415
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006	1507		
Prep Method: 5030B	Date Prepared:	11/29/2006	1507		
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	111	%		62 - 127	
Toluene-d8 (Surr)	95	%		81 - 126	
4-Bromofluorobenzene (Surr)	96	%		67 - 132	
Dibromofluoromethane	117	%		77 - 119	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-7
 Lab Sample ID: 500-1992-6

Date Sampled: 11/20/2006 1530
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1024		
Prep Method: 5030B	Date Prepared:	11/30/2006	1024		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	0.99 J	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	8.8	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	6.9	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	14	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-7
 Lab Sample ID: 500-1992-6

Date Sampled: 11/20/2006 1530
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1024		
Prep Method: 5030B	Date Prepared:	11/30/2006	1024		
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	104	%		62 - 127	
Toluene-d8 (Surr)	97	%		81 - 126	
4-Bromofluorobenzene (Surr)	94	%		67 - 132	
Dibromofluoromethane	107	%		77 - 119	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-8
 Lab Sample ID: 500-1992-7

Date Sampled: 11/20/2006 1540
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006	1554		
Prep Method: 5030B	Date Prepared:	11/29/2006	1554		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0 *	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0 *	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	35	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0 *	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0 *	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	16	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	100	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-8
 Lab Sample ID: 500-1992-7

Date Sampled: 11/20/2006 1540
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006	1554		
Prep Method: 5030B	Date Prepared:	11/29/2006	1554		
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate			Acceptance Limits		
1,2-Dichloroethane-d4 (Surr)	113	%		62 - 127	
Toluene-d8 (Surr)	98	%		81 - 126	
4-Bromofluorobenzene (Surr)	96	%		67 - 132	
Dibromofluoromethane	118	%		77 - 119	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-9
 Lab Sample ID: 500-1992-8

Date Sampled: 11/20/2006 1545
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006	1642		
Prep Method: 5030B	Date Prepared:	11/29/2006	1642		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0 *	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0 *	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	1.4	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0 *	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0 *	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	2.1	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-9
 Lab Sample ID: 500-1992-8

Date Sampled: 11/20/2006 1545
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006	1642		
Prep Method: 5030B	Date Prepared:	11/29/2006	1642		
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	113	%	62 - 127
Toluene-d8 (Surr)	96	%	81 - 126
4-Bromofluorobenzene (Surr)	95	%	67 - 132
Dibromofluoromethane	117	%	77 - 119

Method: 8260B	Run Type: DL	Date Analyzed:	11/30/2006	1048	
Prep Method: 5030B		Date Prepared:	11/30/2006	1048	
Tetrachloroethene	230	ug/L	1.8	10	10

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	106	%	62 - 127
Toluene-d8 (Surr)	96	%	81 - 126
4-Bromofluorobenzene (Surr)	95	%	67 - 132
Dibromofluoromethane	111	%	77 - 119

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-9 DUP
 Lab Sample ID: 500-1992-9

Date Sampled: 11/20/2006 1545
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006	1728		
Prep Method: 5030B	Date Prepared:	11/29/2006	1728		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0 *	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0 *	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	1.4	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0 *	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0 *	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	1.9	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-9 DUP
 Lab Sample ID: 500-1992-9

Date Sampled: 11/20/2006 1545
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006	1728		
Prep Method: 5030B	Date Prepared:	11/29/2006	1728		
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	111	%	62 - 127
Toluene-d8 (Surr)	95	%	81 - 126
4-Bromofluorobenzene (Surr)	97	%	67 - 132
Dibromofluoromethane	114	%	77 - 119

Method: 8260B	Run Type: DL	Date Analyzed:	11/30/2006	1111		
Prep Method: 5030B		Date Prepared:	11/30/2006	1111		
Tetrachloroethene	220	ug/L	1.8	10	10	

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	108	%	62 - 127
Toluene-d8 (Surr)	96	%	81 - 126
4-Bromofluorobenzene (Surr)	96	%	67 - 132
Dibromofluoromethane	114	%	77 - 119

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-10
 Lab Sample ID: 500-1992-10

Date Sampled: 11/20/2006 1550
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1134		
Prep Method: 5030B	Date Prepared:	11/30/2006	1134		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	1.1	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	1.4	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	5.4	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: EW-10
 Lab Sample ID: 500-1992-10

Date Sampled: 11/20/2006 1550
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1134		
Prep Method: 5030B	Date Prepared:	11/30/2006	1134		
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		62 - 127	
Toluene-d8 (Surr)	95	%		81 - 126	
4-Bromofluorobenzene (Surr)	95	%		67 - 132	
Dibromofluoromethane	110	%		77 - 119	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: TRIP BLANK
 Lab Sample ID: 500-1992-11

Date Sampled: 11/20/2006 0700
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1157		
Prep Method: 5030B	Date Prepared:	11/30/2006	1157		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: TRIP BLANK
 Lab Sample ID: 500-1992-11

Date Sampled: 11/20/2006 0700
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1157		
Prep Method: 5030B	Date Prepared:	11/30/2006	1157		
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		62 - 127	
Toluene-d8 (Surr)	96	%		81 - 126	
4-Bromofluorobenzene (Surr)	95	%		67 - 132	
Dibromofluoromethane	113	%		77 - 119	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-1A
 Lab Sample ID: 500-1992-12

Date Sampled: 11/20/2006 0910
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1221		
Prep Method: 5030B	Date Prepared:	11/30/2006	1221		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-1A
 Lab Sample ID: 500-1992-12

Date Sampled: 11/20/2006 0910
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006 1221			
Prep Method: 5030B	Date Prepared:	11/30/2006 1221			
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	111	%		62 - 127	
Toluene-d8 (Surr)	97	%		81 - 126	
4-Bromofluorobenzene (Surr)	94	%		67 - 132	
Dibromofluoromethane	115	%		77 - 119	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-1B
 Lab Sample ID: 500-1992-13

Date Sampled: 11/21/2006 0730
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1243		
Prep Method: 5030B	Date Prepared:	11/30/2006	1243		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-1B
 Lab Sample ID: 500-1992-13

Date Sampled: 11/21/2006 0730
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1243		
Prep Method: 5030B	Date Prepared:	11/30/2006	1243		
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		62 - 127	
Toluene-d8 (Surr)	95	%		81 - 126	
4-Bromofluorobenzene (Surr)	94	%		67 - 132	
Dibromofluoromethane	115	%		77 - 119	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-2A
 Lab Sample ID: 500-1992-14

Date Sampled: 11/20/2006 0815
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006 1947			
Prep Method: 5030B	Date Prepared:	11/29/2006 1947			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0 *	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0 *	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0 *	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0 *	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	2.2	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-2A
 Lab Sample ID: 500-1992-14

Date Sampled: 11/20/2006 0815
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/29/2006 1947			
Prep Method: 5030B	Date Prepared:	11/29/2006 1947			
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	115	%		62 - 127	
Toluene-d8 (Surr)	96	%		81 - 126	
4-Bromofluorobenzene (Surr)	95	%		67 - 132	
Dibromofluoromethane	117	%		77 - 119	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-2B
 Lab Sample ID: 500-1992-15

Date Sampled: 11/20/2006 0830
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1306		
Prep Method: 5030B	Date Prepared:	11/30/2006	1306		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	1.6	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	1.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-2B
 Lab Sample ID: 500-1992-15

Date Sampled: 11/20/2006 0830
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1306		
Prep Method: 5030B	Date Prepared:	11/30/2006	1306		
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		62 - 127	
Toluene-d8 (Surr)	95	%		81 - 126	
4-Bromofluorobenzene (Surr)	94	%		67 - 132	
Dibromofluoromethane	116	%		77 - 119	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-3B
 Lab Sample ID: 500-1992-16

Date Sampled: 11/21/2006 0810
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1329		
Prep Method: 5030B	Date Prepared:	11/30/2006	1329		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	1.3	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	8.4	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	3.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-3B
 Lab Sample ID: 500-1992-16

Date Sampled: 11/21/2006 0810
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006 1329			
Prep Method: 5030B	Date Prepared:	11/30/2006 1329			
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	110	%		62 - 127	
Toluene-d8 (Surr)	96	%		81 - 126	
4-Bromofluorobenzene (Surr)	94	%		67 - 132	
Dibromofluoromethane	117	%		77 - 119	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-4A
 Lab Sample ID: 500-1992-17

Date Sampled: 11/21/2006 0810
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1353		
Prep Method: 5030B	Date Prepared:	11/30/2006	1353		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	7.2	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	1.2	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	1.2	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	36	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	33	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-4A
 Lab Sample ID: 500-1992-17

Date Sampled: 11/21/2006 0810
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1353		
Prep Method: 5030B	Date Prepared:	11/30/2006	1353		
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	112	%		62 - 127	
Toluene-d8 (Surr)	95	%		81 - 126	
4-Bromofluorobenzene (Surr)	94	%		67 - 132	
Dibromofluoromethane	117	%		77 - 119	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-4B
 Lab Sample ID: 500-1992-18

Date Sampled: 11/21/2006 0920
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1501		
Prep Method: 5030B	Date Prepared:	11/30/2006	1501		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	8.5	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	9.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	60	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-4B
 Lab Sample ID: 500-1992-18

Date Sampled: 11/21/2006 0920
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1501		
Prep Method: 5030B	Date Prepared:	11/30/2006	1501		
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	107	%		62 - 127	
Toluene-d8 (Surr)	97	%		81 - 126	
4-Bromofluorobenzene (Surr)	95	%		67 - 132	
Dibromofluoromethane	118	%		77 - 119	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-4BDUP
 Lab Sample ID: 500-1992-19

Date Sampled: 11/21/2006 0920
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	12/01/2006	1318		
Prep Method: 5030B	Date Prepared:	12/01/2006	1318		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	8.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	7.4	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	8.8	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	66	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-4BDUP
 Lab Sample ID: 500-1992-19

Date Sampled: 11/21/2006 0920
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	12/01/2006	1318		
Prep Method: 5030B	Date Prepared:	12/01/2006	1318		
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	100	%		62 - 127	
Toluene-d8 (Surr)	95	%		81 - 126	
4-Bromofluorobenzene (Surr)	97	%		67 - 132	
Dibromofluoromethane	104	%		77 - 119	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-6
 Lab Sample ID: 500-1992-20

Date Sampled: 11/21/2006 0750
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	12/01/2006 1341			
Prep Method: 5030B	Date Prepared:	12/01/2006 1341			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	4.9	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	4.1	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-6
 Lab Sample ID: 500-1992-20

Date Sampled: 11/21/2006 0750
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	12/01/2006	1341		
Prep Method: 5030B	Date Prepared:	12/01/2006	1341		
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	105	%		62 - 127	
Toluene-d8 (Surr)	96	%		81 - 126	
4-Bromofluorobenzene (Surr)	96	%		67 - 132	
Dibromofluoromethane	107	%		77 - 119	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-7
 Lab Sample ID: 500-1992-21

Date Sampled: 11/20/2006 1015
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1547		
Prep Method: 5030B	Date Prepared:	11/30/2006	1547		
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	1.7	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	3.4	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-1992-1

Client Sample ID: RFW-7
 Lab Sample ID: 500-1992-21

Date Sampled: 11/20/2006 1015
 Date Received: 11/22/2006 0930
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B	Date Analyzed:	11/30/2006	1547		
Prep Method: 5030B	Date Prepared:	11/30/2006	1547		
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	110	%		62 - 127	
Toluene-d8 (Surr)	98	%		81 - 126	
4-Bromofluorobenzene (Surr)	93	%		67 - 132	
Dibromofluoromethane	113	%		77 - 119	