

Quarterly Groundwater Monitoring Report

Prepared for

Black & Decker (U.S.) Inc.

Hampstead, Maryland

January 2010

Prepared by

WESTON SOLUTIONS, INC.

West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION	1-1
2. SITE CHARACTERISTICS	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 4th Quarter 2009	2-2
Table 2-2 Groundwater Elevation Data – 4th Quarter 2009	2-3
Table 2-3 Effluent Characteristics Summary – 4th Quarter 2009	2-4
Table 2-4 Summary of Groundwater Analytical Results - November 2009	2-5
Table 3-1 Treatment System Maintenance Activities – 4th Quarter 2009	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of October through December 2009.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of October through December 2009, the extraction wells were pumping at an average combined rate of approximately 151 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of October through December 2009 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of October through December 2009, approximately 15.9 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (84.7%) and tetrachloroethene (PCE) (15.3%). Analytical results of the groundwater collected from the air stripper for the period of October through December 2009 are included in Appendix C.

A summary of the analytical results from the third quarter (November 2009) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 4th Quarter 2009
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
October 2009	6,043,401
November 2009	6,059,578
December 2009	6,196,514

**Table 2-2
Groundwater Elevation Data - 4th Quarter 2009
Black & Decker
Hampstead, Maryland**

WELL NO.	TOC ELEV.	TOTAL DEPTH	10/21/2009		11/4/2009		12/30/2009	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NC	DRY	NC	DRY	NC
EW-2	849.21	110	72.41	776.80	73.21	776.00	74.26	774.95
EW-3	846.64	118	80.96	765.68	85.10	761.54	85.81	760.83
EW-4	858.01	97.5	PC	NC	PC	NC	PC	NC
EW-5	864.17	98	72.85	791.32	73.50	790.67	74.06	790.11
EW-6	831.98	115	102.50	729.48	102.81	729.17	103.00	728.98
EW-7	818.38	78	57.82	760.56	50.55	767.83	51.61	766.77
EW-8	811.13	98	91.79	719.34	91.75	719.38	92.05	719.08
EW-9	811.35	141	100.86	710.49	101.34	710.01	101.56	709.79
EW-10	807.74	INA	54.88	752.86	53.26	754.48	53.27	754.47
RFW-1A	864.37	78	51.03	813.34	50.61	813.76	51.11	813.26
RFW-1B	864.23	200	51.06	813.17	50.67	813.56	51.14	813.09
RFW-2A	857.41	35	15.84	841.57	13.86	843.55	15.67	841.74
RFW-2B	857.73	75	16.41	841.32	14.53	843.20	16.07	841.66
RFW-3B	839.21	153	36.16	803.05	36.26	802.95	37.02	802.19
RFW-4A	830.37	62	37.84	792.53	35.95	794.42	37.89	792.48
RFW-4B	830.37	120	37.91	792.46	35.82	794.55	38.06	792.31
RFW-5A	817.50	30	DRY	NC	DRY	NC	DRY	NC
RFW-6	785.04	120	3.67	781.37	3.23	781.81	4.41	780.63
RFW-7	805.14	29	6.99	798.15	5.24	799.90	7.40	797.74
RFW-8	860.07	56	DRY	NC	DRY	NC	DRY	NC
RFW-9	862.02	49	26.79	835.23	25.82	836.20	26.69	835.33
RFW-10	852.06	58	DRY	NC	DRY	NC	DRY	NC
RFW-11A	849.32	72	Damaged	NC	Damaged	NC	Damaged	NC
RFW-11B	849.62	116	65.96	783.66	65.79	783.83	66.10	783.52
RFW-12B	844.87	264	51.06	793.81	50.61	794.26	50.83	794.04
RFW-13	849.11	150	66.14	782.97	65.02	784.09	65.89	783.22
RFW-14B	812.39	281	48.06	764.33	49.71	762.68	47.86	764.53
RFW-16	856.14	41	DRY	NC	DRY	NC	DRY	NC
RFW-17	834.66	60.5	27.48	807.18	26.46	808.20	27.43	807.23
RFW-20	842.49	142	35.11	807.38	35.01	807.48	34.96	807.53
RFW-21	832.65	102	22.81	809.84	22.21	810.44	23.00	809.65
PH-7	805.94	89	27.43	778.51	27.50	778.44	27.61	778.33
PH-9	814.94	98	56.19	758.75	56.23	758.71	56.86	758.08
PH-11	820.68	78	50.92	769.76	50.94	769.74	50.88	769.80
PH-12	828.35	87	53.29	775.06	53.33	775.02	52.84	775.51
B-3	803.02	83	9.81	793.21	10.06	792.96	9.93	793.09
Amoco	842.29	INA	NA	NC	NA	NC	NA	NC
Hamp. Town #22	804.96	INA	29.86	775.10	19.33	785.63	27.11	777.85
Pembroke #1	INA	INA	11.77	NC	12.40	NC	12.53	NC
Pembroke #2	INA	INA	Damaged	NC	Damaged	NC	Damaged	NC
N. Houcks. Rd.	INA	INA	9.90	NC	11.79	NC	10.89	NC
E. Century St.	INA	INA	19.21	NC	23.64	NC	19.96	NC
Lwr. Beckleys. Rd.	INA	INA	55.08	NC	54.87	NC	55.21	NC

NA - Not Available/Not Accessible

NC - Not Calculable

INA - Information not available

PC - Pump Cycles

Table 2-3
Effluent Characteristics Summary - 4th Quarter 2009
Black & Decker
Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				October 2009	November 2009	December 2009	
001	FLOW	average	MGD	NA	0.220	0.166	0.223
		maximum	MGD	NA	0.770	0.468	0.837
	1,1,1-Trichloroethane		ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene		ug/l	5	< 1	< 1	< 1
	Trichloroethylene		ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	349	< 5
		quarterly average	mg/l	10	< 5	349	< 5
	pH	minimum	STD	6.0	6.20	6.30	6.10
		maximum	STD	8.5	6.90	6.80	6.30
	BOD		mg/l	15	2.0	0.0	0.0
TSS	maximum	mg/l	30	0.0	0.0	0.0	
	quarterly average	mg/l	20	0.0	0.0	0.0	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.199	0.206	0.259
		maximum	MGD	NA	0.261	0.298	0.314
	Fecal Coliform		MPN/100ml	200	1.0	1.0	1.0
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.199
		maximum	MGD	NA	NR	NR	0.245
	1,1,1-Trichloroethane		ug/l	NA	NR	NR	< 1
	Tetrachloroethylene		ug/l	NA	NR	NR	< 1
	Trichloroethylene		ug/l	NA	NR	NR	< 1

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

Note: The Non-Compliance Report Form filed to MDE for the November oil & grease result is included in Appendix B.

Table 2-4
 Summary of Groundwater Analytical Results - November 2009
 Black & Decker
 Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3.9	2.8	1 U	1 U	1 U	4.8	25	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	430	130	990	130	10	4.2	11	1.1	0.9 J	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	64	3.8	21	6.9	15	9.8	67	120	110	1.2
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

NS = Not Sampled

Table 2-4
Summary of Groundwater Analytical Results - November 2009
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	NS	2 U	2 U	NS	2 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.2	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	3.5	1 U	1 U	3.3	NS	1 U	1 U	NS	15	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	1.1	1	1.7	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.4	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	1.2	1.5	1.3	24	24	50	NS	2.4	2.7	NS	16	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	14	15	78	NS	2.8	1 U	NS	7	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicate sample
NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
J = Indicates an estimated value.

Table 2-4

Summary of Groundwater Analytical Results - November 2009

Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	RFW-20	RFW-21	Town #22	Town #23	Trip Blank
		USEPA drinking water method 524.2														
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	NS	2 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	2.6 J
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	NA	NA	NA	NA	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	2.7	1.1	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.3 J	0.5 U	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trichloroethene	ug/L	NS	11	360	4.3	NS	1 U	ABD	ABD	ABD	1 U	0.9	0.5 U	0.5 U	0.5 U	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	2.7	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	1 U	32	22	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division. Samples from all of the other wells are analyzed with USEPA Method 8260.

NS = Not sampled

U = Compound was analyzed but not detected.

ABD = Well has been abandoned

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B, EW-2 and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from wells RFW-4B and EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (October through December 2009) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 4th Quarter 2009
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Oct-09	Alarm at air stripper. High wet well, reset the system. System back online.
Oct-09	Alarm at stripper. EW-9 tripped off, replaced the control relay. System back online.
Nov-09	Alarm at air stripper. High wet well, reset the system. System back online.
Nov-09	The heater in EW-10 was replaced.
Nov-09	Alarm at air stripper. Power outage caused a temporary shut down, reset the system. System back online.
Nov-09	Alarm at stripper. EW-5 tripped off, replaced the contactor. System back online.
Nov-09	The alarm at the air stripper due to a high column blower failure . The stripper was reset all systems are okay.
Dec-09	Alarm at air stripper. High wet well, reset the system. System back online.
Dec-09	Alarm at air stripper. Power outage caused a temporary shut down, reset the system. System back online.
Dec-09	Alarm at air stripper. EW-6 tripped off due to faulty control relay, control relay was replaced. System back online.
Dec-09	Alarm at air stripper. EW-8 tripped off due to broken heater, temporary heater was placed in the well house. System back online.
Dec-09	Alarm at air stripper. EW-10 tripped off due to water in well house due to flooding from excessive snow melt and rain. The well house was swept out and water was diverted away from well house. System back online.

4. RECOMMENDATIONS

For the reporting period of October through December 2009, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(OCTOBER – DECEMBER 2009)

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility BTR Capital Group
Address 626 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrance Jones 0763, Scott Steedman 0764, Gary Dickerson 0782, Martin Whitt 0666, Gary Kesslerling 01962, David Smith 9153

Permit Number 02-DP-0022
Superintendent Earle Villarreal

Certification # 1017

Month October
Year 2009

Date	Appearance	Final Effluent outfall 001									Outfall 101						Outfall 201			Operator	
		Discharge MGD	pH su	Cl2 mg/l	1-cobaltous chloride ug/l	1-1-1 Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	1-cobaltous chloride ug/l	1-1-1-Trichloroethane ug/l	Trichloroethene ug/l		Discharge mgd
1	clear	0 16600	6 65	0 00						0 248000		0 0	10 0	10 0	5 0				0 204548	djones	
2	clear	0 16300								0 261000		0 0	10 0	10 0	5 0				0 199096	djones	
3	clear	0 15300								0 246000		0 0	10 0	10 0	5 0				0 193876	ssteedman	
4	clear	0 16300								0 239000		0 0	10 0	10 0	5 0				0 210286	ssteedman	
5	clear	0 15600								0 201000		0 0	10 0	10 0	5 0				0 199151	djones	
6	clear	0 14200	6 35	0 00						0 179000		0 0	10 0	10 0	5 0				0 181955	djones	
7	clear	0 16300			< 100	< 100	< 100	20	< 40	< 50	0 199000	< 18	0 0	10 0	10 0	5 0	< 10	< 10	< 10	0 113976	djones
8	clear	0 16200	6 40	0 00						0 197000		0 0	10 0	10 0	5 0				0 201142	djones	
9	clear	0 13500								0 172000		0 0	10 0	10 0	5 0				0 155662	djones	
10	clear	0 15500								0 194000		0 0	10 0	10 0	5 0				0 201273	djones	
11	clear	0 17200								0 209000		0 0	5 0	10 0	5 0				0 236185	djones	
12	clear	0 14900								0 183000		0 0	5 0	10 0	5 0				0 193622	ssteedman	
13	clear	0 16600	6 58	0 00						0 210000		0 0	10 0	10 0	5 0				0 215170	mwhitt	
14	clear	0 13200								0 179000	< 18	0 0	10 0	10 0	5 0				0 191050	ssteedman	
15	clear	0 17000	6 87	0 00						0 189000		0 0	10 0	10 0	5 0				0 200070	djones	
16	clear	0 12500								0 157000		0 0	10 0	10 0	5 0				0 150084	djones	
17	clear	0 36200								0 188000		0 0	10 0	10 0	5 0				0 197025	dsmith	
18	clear	0 56700								0 208000		0 0	5 0	10 0	5 0				0 242522	dsmith	
19	clear	0 14600								0 209000		0 0	10 0	10 0	5 0				0 197130	djones	
20	clear	0 17100	6 20	0 00						0 165000		0 0	10 0	10 0	5 0				0 190308	djones	
21	clear	0 16400								0 184000	< 18	0 0	15 0	10 0	5 0				0 183205	gkesslerling	
22	clear	0 15600	6 53	0 00						0 188000		0 0	15 0	10 0	5 0				0 224227	gdickerson	
23	clear	0 16200								0 240000		0 0	10 0	10 0	5 0				0 192738	djones	
24	clear	0 58100								0 226000		0 0	10 0	10 0	5 0				0 199882	mwhitt	
25	clear	0 18100								0 201000		0 0	5 0	10 0	5 0				0 200687	mwhitt	
26	clear	0 20100								0 191000		0 0	5 0	10 0	5 0				0 191963	djones	
27	clear	0 77000	6 51	0 00						0 154000		0 0	5 0	10 0	5 0				0 173335	djones	
28	clear	0 41800								0 195000	< 18	0 0	20 0	10 0	5 0				0 232750	djones	
29	clear	0 15800	6 45	0 00						0 190000		0 0	20 0	10 0	5 0				0 200265	djones	
30	clear	0 14000								0 163000		0 0	10 0	10 0	5 0				0 161400	djones	
31	clear	0 16500								0 192000		0 0	10 0	10 0	5 0				0 208818	djones	
Total		6 81400								6 157000									6 043401		
Average		0 21981	6 5	<0 10	0	0	0	2	0	0	0 198613	1	0 0	10 0	10 0	5 0	0	0	0	0 194948	
Minimum		0 12500	6 2	0 00	0	0	0	2	0	0	0 154000	1	0 0	5 0	10 0	5 0	0	0	0	0 113976	
Maximum		0 77000	6 9	<0 10	0	0	0	2	0	0	0 261000	1	0 0	20 0	10 0	5 0	0	0	0	0 242522	MOR 5-11-09

COMMENTS

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility BTR Capital Group
Address 626 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrance Jones 0763, Scott Steedman 0764, Gary Dickerson 0782, Martin Whitt, 0666, Gary Kesseling, 1962, David Smith, 9153

Permit Number 02-DP-0022

Superintendent Earle Villarreal

Certification # 1017

Month November
Year 2009

Final Effluent outfall 001											Outfall 101					Outfall 201			Operator		
Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l		Trichloroethene ug/l	Discharge mgd
1	clear	0 22400									0 217000		0 0	10 0	10 0	50				0 245419	djones
2	clear	0 13800									0 169000		0 0	10 0	10 0	50				0 197563	ssteedman
3	clear	0 14100	6 84	0 00							0 164000		0 0	10 0	10 0	50				0 171384	ssteedman
4	clear	0 15600			< 1 00	< 1 00	< 1 00	< 2 0	< 4 0	349 0	0 195000	< 1 8	0 0	10 0	10 0	50				0 230328	djones
5	clear	0 14100	6 57	0 00							0 223000		0 0	10 0	0 5	50				0 204569	djones
6	clear	0 11500									0 147000		0 0	10 0	10 0	50				0 154695	djones
7	clear	0 15700									0 183000		0 0	10 0	10 0	50				0 236525	dsmith
8	clear	0 12700									0 147000		0 0	10 0	10 0	50				0 209452	dsmith
9	clear	0 12800									0 169000		0 0	10 0	10 0	50				0 199896	djones
10	clear	0 19000	6 42	0 00							0 196000	< 1 8	0 0	10 0	10 0	4 8				0 203599	djones
11	clear	0 17500									0 169000		0 0	10 0	10 0	50				0 207152	djones
12	clear	0 18300	6 34	0 00							0 210000		0 0	10 0	10 0	50				0 195265	djones
13	clear	0 17500									0 219000		0 0	10 0	10 0	50				0 197973	djones
14	clear	0 15600									0 188000		0 0	10 0	10 0	50				0 199963	mwhitt
15	clear	0 17300									0 111000		0 0	10 0	10 0	50				0 214176	mwhitt
16	clear	0 13700									0 243000		0 0	10 0	10 0	50				0 192691	gkesseling
17	clear	0 14100	6 50	0 00							0 195000		0 0	5 0	10 0	50				0 217252	djones
18	clear	0 14600									0 183000	< 1 8	0 0	5 0	10 0	4 3				0 179048	gdickerson
19	clear	0 14600	6 35	0 00							0 226000		0 0	5 0	10 0	50				0 199065	djones
20	clear	0 13000									0 199000		0 0	5 0	10 0	50				0 160874	djones
21	clear	0 14700									0 234000		0 0	5 0	10 0	50				0 201686	djones
22	clear	0 16100									0 252000		0 0	5 0	10 0	50				0 235648	djones
23	clear	0 23800									0 225000		0 0	10 0	10 0	50				0 189501	gdickerson
24	clear	0 46800	6 38	0 00							0 254000		0 0	10 0	10 0	50				0 219741	gdickerson
25	clear	0 14900									0 247000		0 0	10 0	10 0	50				0 184229	djones
26	clear	0 16200									0 214000		0 0	5 0	10 0	50				0 175533	gdickerson
27	clear	0 19600									0 298000	< 1 8	0 0	5 0	10 0	50				0 237071	djones
28	clear	0 11700									0 227000		0 0	5 0	10 0	50				0 186477	gdickerson
29	clear	0 12800									0 237000		0 0	5 0	10 0	50				0 210944	gdickerson
30	clear	0 12600									0 245000		0 0	5 0	10 0	50				0 201859	djones
31																					
Total		4 97100									6 186000									6 059578	
Average		0 16570	6 5	<0 10	0	0	0	2	0	349	0 206200	1	0 0	8 2	10 0	50	#DIV/0!	#DIV/0!	#DIV/0!	0 201986	
Minimum		0 11500	6 3	0 00	0	0	0	2	0	349	0 111000	1	0 0	5 0	0 5	4 3	0	0	0	0 154695	
Maximum		0 46800	6 8	<0 10	0	0	0	0	0	349	0 298000	1	0 0	10 0	10 0	50	0	0	0	0 245419	MOR 5-11-09

COMMENTS:

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 626 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrance Jones 0763, Gary Dickerson 0782, Martin Whitt 0666.

Permit Number: 02-DP-0022
Superintendent: Earle Villarreal

Certification # 1017

Month: December
Year: 2009

Final Effluent outfall 001											Outfall 101						Outfall 201			Operator	
Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethane ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochloritic Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethane ug/l		Discharge mgd
1	clear	0.12000	6.20	0.00							0.241000		0.0	5.0	1.0	5.0				0.197227	djones
2	clear	0.54300			< 1.00	< 1.00	< 1.00	< 2.0	< 4.0	< 5.0	0.280000	< 1.8	0.0	10.0	1.0	5.0				0.195875	djones
3	clear	0.24000	6.17	0.00							0.278000		0.0	10.0	1.0	5.0				0.202129	djones
4	clear	0.12500									0.226000		0.0	10.0	1.0	5.0				0.152125	djones
5	clear	0.21000									0.275000		0.0	5.0	1.0	5.0				0.206634	djones
6	clear	0.14800									0.284000		0.0	5.0	1.0	5.0				0.176160	djones
7	clear	0.11300									0.258000		0.0	10.0	1.0	5.0				0.191568	gd
8	clear	0.48200	6.10	0.00							0.242000		0.0	10.0	1.0	5.0				0.186653	gd
9	clear	0.83700									0.269000	< 1.8	0.0	10.0	1.0	5.0				0.210344	djones
10	clear	0.17100	6.15	0.00							0.276000		0.0	10.0	1.0	5.0				0.221728	djones
11	clear	0.10900									0.283000		0.0	10.0	1.0	5.0				0.199664	djones
12	clear	0.10200									0.247000		0.0	5.0	1.0	5.0				0.191457	gd
13	clear	0.47200									0.261000		0.0	5.0	1.0	5.0				0.215495	gd
14	clear	0.14100									0.223000		0.0	10.0	1.0	5.0				0.196172	mwhitt
15	clear	0.13700	6.20	0.00							0.270000		0.0	5.0	1.0	5.0				0.205704	djones
16	clear	0.15500								5.8	0.243000	< 1.8	0.0	5.0	1.0	5.0				0.199189	djones
17	clear	0.17900	6.12	0.00							0.294000		0.0	10.0	1.0	5.0				0.207160	djones
18	clear	0.12600									0.223000		0.0	5.0	1.0	5.0				0.148574	djones
19	clear	0.28900									0.306000		0.0	10.0	1.0	5.0				0.222823	djones
20	clear	0.14700									0.264000		0.0	5.0	1.0	5.0				0.232744	djones
21	clear	0.11800									0.223000		0.0	10.0	1.0	5.0				0.193288	gd
22	clear	0.13200	6.14	0.00							0.263000	< 1.8	0.0	10.0	1.0	5.0				0.218920	gd
23	clear	0.10200	6.26	0.00							0.225000		0.0	5.0	1.0	5.0				0.170041	djones
24	clear	0.13100									0.256000		0.0	5.0	1.0	5.0				0.214540	gd
25	clear	0.11300									0.267000		0.0	10.0	1.0	5.0				0.229978	djones
26	clear	0.67300									0.194000		0.0	10.0	1.0	5.0				0.188326	gd
27	clear	0.20400									0.201000		0.0	5.0	1.0	5.0				0.218907	gd
28	clear	0.14200									0.270000		0.0	5.0	1.0	5.0				0.187432	djones
29	clear	0.11600	6.20	0.00							0.309000	< 1.8	0.0	5.0	1.0	5.0				0.220514	djones
30	clear	0.10300									0.279000		0.0	5.0	1.0	5.0				0.188064	djones
31	clear	0.24300	6.22	0.00							0.314000		0.0	5.0	1.0	5.0				0.207079	djones
Total		6.92300									8.044000									6.196514	
Average		0.22332	6.2	<0.10	0	0	0	2	0	3	0.259484	1	0.0	7.4	1.0	5.0	#DIV/0!	#DIV/0!	#DIV/0!	0.199888	
Minimum		0.10200	6.1	0.00	0	0	0	2	0	0	0.194000	1	0.0	5.0	1.0	5.0	0	0	0	0.148574	
Maximum		0.83700	6.3	<0.10	0	0	0	0	0	6	0.314000	1	0.0	10.0	1.0	5.0	0	0	0	0.232744	MOR 5-11-09

COMMENTS:

**APPENDIX B
DISCHARGE MONITORING REPORTS
(OCTOBER - DECEMBER 2009)**

PERMITTEE NAME ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)

State Discharge Permit

02-DP-0022

Form Approved. 12345

OMB No 2040-0004.

Approval expires 05-31-98

MD0001881

PERMIT NUMBER

001

DISCHARGE NUMBER

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	09	10	01		09	10	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

PARAMETER (32-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING (34-61)			QUANTITY OR CONCENTRATION (34-61)			NO EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE (34-35)	MAXIMUM (36-37)	UNITS (38-45)	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)				UNITS (54-61)
BOD, 5-DAY (20 DEG C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT *****	*****	*****	****	*****	*****	2	(19)	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT *****	*****	*****	****	*****	*****	15			ONE/ MONTH	GRAB
pH	SAMPLE MEASUREMENT *****	*****	*****	****	6.2	*****	6.9	(12)	0	TWO/ WEEK	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT *****	*****	*****	****	6.0	*****	8.5			TWO/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT *****	*****	*****	****	*****	0	0	(19)	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT *****	*****	*****	****	*****	20	30			ONE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT 219806	770000	(07)	****	*****	*****	*****		0	MEASURED	RECORD
	PERMIT REQUIREMENT REPORT	REPORT	GPD	****	*****	*****	*****			MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT *****	*****	****	****	*****	<0.1	<0.1	(19)	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT *****	*****	****	****	*****	0.011	0.019			ONE/ MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT *****	*****	****	****	*****	*****	0		0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT *****	*****	****	****	*****	*****	5			ONE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT *****	*****	****	****	*****	*****	0		0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT *****	*****	****	****	*****	*****	5			ONE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Jim Harkins, Director MES

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is to the best of my knowledge and belief true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

410
AREA CODE

729-8350
NUMBER

09
YEAR

11
MO

18
DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

ADDRESS **020 Hanover Pike**
Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**
 ATTN

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
09	10	01		09	10	31	
(20-21)		(22-23)		(24-25)		(26-27)	
				(28-29)		(30-31)	

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT PERMIT REQUIREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)			UNITS	NO EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	0	ug/l	0	ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	0	0	(19)	MG/L	0	ONE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE			
Jim Harkins, Director MES			410 729-8350	09	11	18	
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DAIR)

(2-16)

(17-19)

State Discharge Permit

02-DP-0022

Form Approved 12345

OMB No. 2040-0004

Approval expires 05-31-98

MD0001881

PERMIT NUMBER

101

DISCHARGE NUMBER


MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	09	10	01		09	10	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***

NOTE. Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)			UNITS	NO EX (62-63)	FREQUENCY OF ANALYSIS (64-65)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE		198613	261000	(07)	*****	*****	*****	GPD	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	****		ONE/MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	*****	1	(30)	0	ONE/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	200	MPN		ONE/WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE				
Jim Harkins, Director MES			410 729-8350	09	11	18		
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

State Discharge Permit
02-DP-0022

MD0001881
PERMIT NUMBER


001
DISCHARGE NUMBER

Form Approved. 12345
OMB No. 2040-0004.
Approval expires 05-31-98

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
09	11	01	TO	09	11	30	
(20-21)		(22-23)		(24-25)		(26-27)	
(28-29)		(30-31)					

*** NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only (46-53) (54-61))			QUANTITY OR CONCENTRATION (4 Card Only (38-45) (46-53) (54-61))			NO EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
BOD, 5-DAY (20 DEG C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15			ONE/MONTH	GRAB
pH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	6.3	*****	6.8	(12)	0	TWO/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	8.5			TWO/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	20	30			ONE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	165700	468000	(07)	*****	*****	*****		0	MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****		****	MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.01	0.09			ONE/MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5			ONE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5			ONE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
Jim Harkins, Director MES			410	729-8350	09	12	18
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here.)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

State Discharge Permit

02-DP-0022

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

MD0001881
PERMIT NUMBER

001
DISCHARGE NUMBER


MONITORING PERIOD

FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
09	11	01	09	11	30
<small>(20-21) (22-23) (24-25)</small>			<small>(26-27) (28-29) (30-31)</small>		

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only (46-53) (54-61))			QUANTITY OR CONCENTRATION (4 Card Only (38-45) (46-53) (54-61))				NO EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****		*****	*****	0		0	ONE/MONTH	GRAB
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****		*****	349	349	(19)	2	ONE/MONTH	GRAB
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Jim Harkins, Director MES	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			410	729-8350	09	12	18
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

State Discharge Permit
02-DP-0022

MD0001881
PERMIT NUMBER

101
DISCHARGE NUMBER

Form Approved. 12345
OMB No. 2040-0004.
Approval expires 05-31-98

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
09	11	01		09	11	30
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53) (54-61)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45) (46-53) (54-61)				NO EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)		
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS					
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE		206200	298000	(07)	*****	*****	*****	****	0	ONE/MONTH	GRAB		
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****			ONE/MONTH	GRAB		
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	*****	1	(30)	0	ONE/WEEK	GRAB		
	PERMIT REQUIREMENT	*****	*****		*****	*****	200	MPN		ONE/WEEK	GRAB		
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.								TELEPHONE		DATE		
Jim Harkins, Director MES									410 729-8350		09	12	18
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT								AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Maryland Environmental Service
 259 Naples Road
 Millersville, Maryland 21108

Non-Compliance
 Report Form

Date: November 04, 2008

To: MDE- Compliance and Inspection Division

From: (Name) Earle Villarreal

(Title) ESS

Subject Non-complying discharge

Facility. Black and Decker WWTP

Permit No (State) 02 -DP- 0022 (Federal) MD0001881

Non-complying Month/ Year November-09

1. A non-complying discharge of Frequency Of Analysis
 at outfall 001 occurred on 11/04/2009

2. The impact on the receiving stream was
No visible impact

3. The cause of the non-compliance was
Due to excessive precipitation totaling 4 inches in the
 previous weeks Surface runoff from the parking lot and
 impervious areas flowed into the ponds affecting monitoring
 results:

4. The non-complying discharge continued for a period of
See at right

5. The following action (is being) (was) (will be) taken to correct the problem causing the non compliance
We will continue to monitor the problem

6. The following action is being taken to prevent recurrence of a non-complying discharge of this nature
See above

7. The following analysis were performed to determine the nature and impact on the receiving stream
All other NPDES permit requirements were met daily and for the Month

8. Comments:
All other NPDES permit requirements were met daily and for the Month

Parameter	Monthly	Daily		
Limit	10 mg/l	15 mg/l		
Unit	Oil&Grease	Oil&Grease		
Date				
1				
2				
3				
4	349	349		
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
Average	349	349		

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**


LOCATION **626 Hanover Pike**

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
09	12	01	TO	09	12	31	
(20-21)		(22-23)		(24-25)		(26-27)	
				(28-29)		(30-31)	

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

ATTN:

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	0	(19)	0	ONE/MONTH GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15	MG/L		ONE/MONTH GRAB
pH	*****	*****	*****	****	6.1	*****	6.3	(12)	0	TWO/WEEK GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	8.5	SU		TWO/WEEK GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	0	0	(19)	0	ONE/MONTH GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	20	30	MG/L		ONE/MONTH GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	*****	837000	(07)	*****	*****	*****	*****	0	0	MEASURED RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		MEASURED RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONE/MONTH GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.011	0.019	MG/L		ONE/MONTH GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	0		0	ONE/MONTH GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	0		0	ONE/MONTH GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Jim Harkins, Director MES	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE	DATE		
			410 729-8350 AREA CODE NUMBER	10	01	25 YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

State Discharge Permit
02-DP-0022

MD0001881
PERMIT NUMBER

001
DISCHARGE NUMBER

Form Approved. 12345
OMB No. 2040-0004.
Approval expires 05-31-98

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
09	12	01		09	12	31
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)

*** NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (54-61)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (3 Card Only (46-53))	MAXIMUM	UNITS	MINIMUM (4 Card Only (38-45))	AVERAGE (46-53)	MAXIMUM				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****		*****	*****	0		0	ONE/MONTH	GRAB
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****		*****	3	6	(19)	0	ONE/MONTH	GRAB
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10 *****	15 *****	MG/L		ONE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Jim Harkins, Director MES	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE 410 729-8350	DATE		
			AREA CODE	NUMBER	YEAR
TYPED OR PRINTED					

COMMENT AND EXPLANATION OF ANY VIOLATIONS(Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**
 ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MD0001881
 PERMIT NUMBER


101
 DISCHARGE NUMBER

Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
09	12	01		09	12	31
(20-21)		(22-23) (24-25)		(26-27)		(28-29) (30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	259484	314000	(07)	*****	*****	*****		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	REPORT *****	REPORT *****	GPD	*****	*****	*****	****		ONE/MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		*****	*****	1	(30)	0	ONE/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200	MPN		ONE/WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Jim Harkins, Director MES	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE	DATE		
			410 729-8350 AREA CODE NUMBER	10 01 25 YEAR MO DAY		

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME **AG/GFI Hampstead, Inc**
 Facility Name/Location if different

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) **State Discharge Permit**
DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19) **02-DP-0022**

MD0001881
 PERMIT NUMBER

201
 DISCHARGE NUMBER


Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
09	10	01	TO	09	12	31	
(20-21)		(22-23)		(24-25)		(26-27)	
				(28-29)		(30-31)	

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	198908	245419	(07)	*****	*****	*****	0	MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****			
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	0	ONE/ QUARTER	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT *****	REPORT *****			
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	0	ONE/ QUARTER	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT *****	REPORT *****			
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	0	ONE/ QUARTER	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT *****	REPORT *****			
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Jim Harkins, Director MES	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE			
TYPED OR PRINTED			410 729-8350	10 01 25	AREA CODE	NUMBER	YEAR

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 Quarterly Report! Outfall 201 quarterly sample's collected on 10/07/09.

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(OCTOBER - DECEMBER 2009)



630 Churchmans Road
 Newark, Delaware 19702
 302-266-9121 • 454-8720 (FAX)
 WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
 259 Najoles Road
 Millersville, MD 21108

Order Number: A09100327
 Project Name: Black & Decker WWTP
 Receive Date: 10/7/2009
 Client Code: MES_A
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A09100327-01 **Sample Date: 10/7/2009 9:10**

Site: Black & Decker 001
 Client Sample ID:
 Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	2	mg/L	2	SM 5210 B	10/8/2009 12:00:00 PM	Ythomas
Total Suspended Solids	< 4	mg/L	4	SM 2540D	10/13/2009 2:16:00 PM	JMcGuire

Sample # A09100327-01A **Sample Date: 10/7/2009 9:12**

Site: Black & Decker 001
 Client Sample ID: A
 Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	< 5	mg/L	5	EPA 1664	10/12/2009 2:54:00 PM	HHerman

Sample # A09100327-01B **Sample Date: 10/7/2009 9:15**

Site: Black & Decker 001
 Client Sample ID: B
 Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	10/10/2009 3:05:00 AM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	10/10/2009 3:05:00 AM	JKozlowski
Trichloroethene	< 1	ug/L	1	EPA 8260B	10/10/2009 3:05:00 AM	JKozlowski

Approved: *Warren Van Arsdale*
Quality Assurance Manager

Reported: 10/21/2009 3:01:59 PM

RDL = Reporting Detection Limit N/A = Not Applicable
 Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A09110252
Project Name: Black & Decker WWTP
Receive Date: 11/4/2009
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A09110252-01 **Sample Date: 11/4/2009 9:50**

Site: Black & Decker 001 Matrix: Waste Water
Client Sample ID:
Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	< 2	mg/L	2	SM 5210 B	11/5/2009 11:35:00 AM	Skent
Total Suspended Solids	< 4	mg/L	4	SM 2540D	11/9/2009 5:51:00 PM	JMcGuire

Sample # A09110252-01A **Sample Date: 11/4/2009 9:50**

Site: Black & Decker 001 Matrix: Waste Water
Client Sample ID: A
Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	349	mg/L	5	EPA 1664	11/10/2009 12:41:00 PM	HHerman

Sample # A09110252-01B **Sample Date: 11/4/2009 9:50**


Site: Black & Decker 001 Matrix: Waste Water
Client Sample ID: E
Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	11/16/2009 7:30:00 AM	WWells
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	11/16/2009 7:30:00 AM	WWells
Trichloroethene	< 1	ug/L	1	EPA 8260B	11/16/2009 7:30:00 AM	WWells

Approved: *Warren Chen*
Quality Assurance Manager

Reported: 11/17/2009 10:35:40 AM

RDL = Reporting Detection Limit N/A = Not Applicable
Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



630 Churchmans Road
 Newark, Delaware 19702
 302-266-9121 • 454-8720 (FAX)
 WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
 259 Najoles Road
 Millersville, MD 21108

Order Number: A09120164
 Project Name: Black & Decker WWTP
 Receive Date: 12/2/2009
 Client Code: MES_A
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A09120164-01 **Sample Date: 12/2/2009 9:30**

Site: Black & Decker 001
 Client Sample ID:
 Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	< 2	mg/L	2	SM 5210 B	12/3/2009 11:30:00 AM	Skent
Total Suspended Solids	< 4	mg/L	4	SM 2540D	12/7/2009 1:05:00 PM	JMcGuire

Sample # A09120164-01A **Sample Date: 12/2/2009 9:30**

Site: Black & Decker 001
 Client Sample ID: A
 Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	< 5	mg/L	5	EPA 1664	12/2/2009 6:20:00 PM	SHess

Sample # A09120164-01B **Sample Date: 12/2/2009 9:30**

Site: Black & Decker 001
 Client Sample ID: B
 Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	12/8/2009 9:08:00 PM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	12/8/2009 9:08:00 PM	JKozlowski
Trichloroethene	< 1	ug/L	1	EPA 8260B	12/8/2009 9:08:00 PM	JKozlowski

Approved: *Warren Van Arsdale*
 Quality Assurance Manager

Reported: 12/11/2009 12:47:39 PM

RDL = Reporting Detection Limit N/A = Not Applicable
 Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A09121045
Project Name: Black & Decker WWTP
Receive Date: 12/16/2009
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A09121045-01

Sample Date: 12/16/2009 9:02

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	5.8	mg/L	5	EPA 1664	12/16/2009 4:55:00 PM	SHess

Approved: *Keith A. Handbrecht*
President

Reported: 12/24/2009 1:04:48 PM

RDL = Reporting Detection Limit N/A = Not Applicable
Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568

APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(NOVEMBER 2009)

ANALYTICAL REPORT

Job Number: 500-22332-1

Job Description: Black and Decker

For:

Weston Solutions, Inc.

1400 Weston Way

PO BOX 2653

West Chester, PA 19380

Attention: Mr. Tom Cornuet



Approved for release.
Richard C Wright
Project Manager II
11/17/2009 3:34 PM

Richard C Wright
Project Manager II
richard.wright@testamericainc.com
11/17/2009

cc: Greg Flasiniski

These test results meet all the requirements of NELAC for accredited parameters.

The Lab Certification ID# is 100201.

All questions regarding this test report should be directed to the TestAmerica Project Manager whose signature appears on this report. All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.

Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.

TestAmerica Laboratories, Inc.

TestAmerica Chicago 2417 Bond Street, University Park, IL 60484

Tel (708) 534-5200 Fax (708) 534-5211 www.testamericainc.com



Job Narrative
500-22332-1

Comments

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

GC/MS VOA

Method(s) 8260B: The following sample(s) was diluted due to the abundance of target analytes: EW-4 (500-22332-19). Elevated reporting limits (RLs) are provided.

Method(s) 8260B: The %RPD of the laboratory control sample (LCS) and laboratory control standard duplicate (LCSD) for preparation batch 75429 exceeded control limits for the following analytes: bromomethane and chloroethane.

Method(s) 8260B: The laboratory control sample (LCS) for batches 75599 and 75429 exceeded control limits for the following analytes: Hexachlorobutadiene. LCS for batch 75429 also had dichlorodifluoromethane outside the control limits.

Method(s) 8260B: The matrix spike / matrix spike duplicate (MS/MSD) for sample -21 had Dichlorodifluoromethane (RPD value) and Hexachlorobutadiene (high recovery) outside the control limits.

No other analytical or quality issues were noted.

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-22332-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-22332-3 Trichloroethene	RFW-2A	1.2	1.0	ug/L	8260B
500-22332-4 Trichloroethene	RFW-2B	1.5	1.0	ug/L	8260B
500-22332-5 cis-1,2-Dichloroethene Tetrachloroethene	RFW-3B	3.5 1.3	1.0 1.0	ug/L ug/L	8260B 8260B
500-22332-6 Chloroform Trichloroethene Tetrachloroethene	RFW-4A	1.1 24 14	1.0 1.0 1.0	ug/L ug/L ug/L	8260B 8260B 8260B
500-22332-7FD Chloroform Trichloroethene Tetrachloroethene	RFW-4A DUP	1.0 24 15	1.0 1.0 1.0	ug/L ug/L ug/L	8260B 8260B 8260B
500-22332-8 cis-1,2-Dichloroethene Chloroform Trichloroethene Tetrachloroethene	RFW-4B	3.3 1.7 50 78	1.0 1.0 1.0 1.0	ug/L ug/L ug/L ug/L	8260B 8260B 8260B 8260B
500-22332-9 Trichloroethene Tetrachloroethene	RFW-6	2.4 2.8	1.0 1.0	ug/L ug/L	8260B 8260B
500-22332-10 Trichloroethene	RFW-7	2.7	1.0	ug/L	8260B

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-22332-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-22332-11	RFW-9				
1,1-Dichloroethene		1.2	1.0	ug/L	8260B
1,1-Dichloroethane		1.0	1.0	ug/L	8260B
cis-1,2-Dichloroethene		15	1.0	ug/L	8260B
1,1,1-Trichloroethane		1.4	1.0	ug/L	8260B
Trichloroethene		16	1.0	ug/L	8260B
Tetrachloroethene		7.0	1.0	ug/L	8260B
500-22332-12	RFW-11B				
Trichloroethene		11	1.0	ug/L	8260B
500-22332-13	RFW-12B				
cis-1,2-Dichloroethene		2.7	1.0	ug/L	8260B
Trichloroethene		360	10	ug/L	8260B
Tetrachloroethene		32	1.0	ug/L	8260B
500-22332-14	RFW-13				
cis-1,2-Dichloroethene		1.1	1.0	ug/L	8260B
Trichloroethene		4.3	1.0	ug/L	8260B
Tetrachloroethene		22	1.0	ug/L	8260B
500-22332-15	RFW-17				
Benzene		2.7	1.0	ug/L	8260B
500-22332-17	EW-2				
cis-1,2-Dichloroethene		3.9	1.0	ug/L	8260B
Trichloroethene		430	10	ug/L	8260B
Tetrachloroethene		64	1.0	ug/L	8260B
500-22332-18	EW-3				
cis-1,2-Dichloroethene		2.8	1.0	ug/L	8260B
Trichloroethene		130	5.0	ug/L	8260B
Tetrachloroethene		3.8	1.0	ug/L	8260B
500-22332-19	EW-4				
Trichloroethene		990	50	ug/L	8260B
Tetrachloroethene		21	5.0	ug/L	8260B

TestAmerica Chicago

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-22332-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-22332-20	EW-5				
Trichloroethene		130	5.0	ug/L	8260B
Tetrachloroethene		6.9	1.0	ug/L	8260B
500-22332-21	EW-6				
Trichloroethene		10	1.0	ug/L	8260B
Tetrachloroethene		15	1.0	ug/L	8260B
500-22332-22	EW-7				
cis-1,2-Dichloroethene		4.8	1.0	ug/L	8260B
Trichloroethene		4.2	1.0	ug/L	8260B
Tetrachloroethene		9.8	1.0	ug/L	8260B
500-22332-23	EW-8				
cis-1,2-Dichloroethene		25	1.0	ug/L	8260B
Trichloroethene		11	1.0	ug/L	8260B
Tetrachloroethene		67	1.0	ug/L	8260B
500-22332-24	EW-9				
Trichloroethene		1.1	1.0	ug/L	8260B
Tetrachloroethene		120	5.0	ug/L	8260B
500-22332-25FD	EW-9 DUP				
Trichloroethene		0.92 J	1.0	ug/L	8260B
Tetrachloroethene		110	5.0	ug/L	8260B
500-22332-26	EW-10				
Tetrachloroethene		1.2	1.0	ug/L	8260B

METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-22332-1

Description	Lab Location	Method	Preparation Method
Matrix: Water			
VOC	TAL CHI	SW846 8260B	
Purge and Trap	TAL CHI		SW846 5030B

Lab References:

TAL CHI = TestAmerica Chicago

Method References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

METHOD / ANALYST SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-22332-1

Method	Analyst	Analyst ID
SW846 8260B	Alikpala, Elaine	EA
SW846 8260B	Drabek, Dave J	DJD

SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-22332-1

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
500-22332-1	RFW-1A	Water	11/04/2009 0900	11/06/2009 1030
500-22332-2	RFW-1B	Water	11/04/2009 1745	11/06/2009 1030
500-22332-3	RFW-2A	Water	11/04/2009 0758	11/06/2009 1030
500-22332-4	RFW-2B	Water	11/04/2009 0830	11/06/2009 1030
500-22332-5	RFW-3B	Water	11/05/2009 0715	11/06/2009 1030
500-22332-6	RFW-4A	Water	11/05/2009 0845	11/06/2009 1030
500-22332-7FD	RFW-4A DUP	Water	11/05/2009 0845	11/06/2009 1030
500-22332-8	RFW-4B	Water	11/05/2009 0915	11/06/2009 1030
500-22332-9	RFW-6	Water	11/05/2009 0700	11/06/2009 1030
500-22332-10	RFW-7	Water	11/04/2009 0950	11/06/2009 1030
500-22332-11	RFW-9	Water	11/05/2009 1230	11/06/2009 1030
500-22332-12	RFW-11B	Water	11/05/2009 1120	11/06/2009 1030
500-22332-13	RFW-12B	Water	11/05/2009 0730	11/06/2009 1030
500-22332-14	RFW-13	Water	11/04/2009 1530	11/06/2009 1030
500-22332-15	RFW-17	Water	11/04/2009 1045	11/06/2009 1030
500-22332-16TB	TRIP BLANK	Water	11/04/2009 0700	11/06/2009 1030
500-22332-17	EW-2	Water	11/04/2009 1715	11/06/2009 1030
500-22332-18	EW-3	Water	11/05/2009 1015	11/06/2009 1030
500-22332-19	EW-4	Water	11/05/2009 1045	11/06/2009 1030
500-22332-20	EW-5	Water	11/04/2009 0915	11/06/2009 1030
500-22332-21	EW-6	Water	11/04/2009 1430	11/06/2009 1030
500-22332-22	EW-7	Water	11/04/2009 1410	11/06/2009 1030
500-22332-23	EW-8	Water	11/04/2009 1345	11/06/2009 1030
500-22332-24	EW-9	Water	11/04/2009 1340	11/06/2009 1030
500-22332-25FD	EW-9 DUP	Water	11/04/2009 1340	11/06/2009 1030
500-22332-26	EW-10	Water	11/04/2009 1330	11/06/2009 1030



SAMPLE RESULTS

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-1A
 Lab Sample ID: 500-22332-1

Date Sampled: 11/04/2009 0900
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/10/2009 1430			
Prep Method: 5030B		Date Prepared: 11/10/2009 1430			
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0 *	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	<1.0	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-1A
 Lab Sample ID: 500-22332-1

Date Sampled: 11/04/2009 0900
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	96	%		72 - 135	
Toluene-d8 (Surr)	105	%		80 - 120	
4-Bromofluorobenzene (Surr)	98	%		77 - 120	
Dibromofluoromethane	101	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-1B
 Lab Sample ID: 500-22332-2

Date Sampled: 11/04/2009 1745
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	11/10/2009	1454	
Prep Method: 5030B		Date Prepared:	11/10/2009	1454	
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0 *	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	<1.0	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-1B
 Lab Sample ID: 500-22332-2

Date Sampled: 11/04/2009 1745
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	99	%		72 - 135	
Toluene-d8 (Surr)	101	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		77 - 120	
Dibromofluoromethane	102	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-2A
 Lab Sample ID: 500-22332-3

Date Sampled: 11/04/2009 0758
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/10/2009 1518			
Prep Method: 5030B		Date Prepared: 11/10/2009 1518			
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0 *	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	1.2	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-2A
 Lab Sample ID: 500-22332-3

Date Sampled: 11/04/2009 0758
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		72 - 135	
Toluene-d8 (Surr)	103	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		77 - 120	
Dibromofluoromethane	103	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-2B
 Lab Sample ID: 500-22332-4

Date Sampled: 11/04/2009 0830
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/10/2009 1542			
Prep Method: 5030B		Date Prepared: 11/10/2009 1542			
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0 *	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	1.5	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-2B
 Lab Sample ID: 500-22332-4

Date Sampled: 11/04/2009 0830
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate			Acceptance Limits		
1,2-Dichloroethane-d4 (Surr)	92	%		72 - 135	
Toluene-d8 (Surr)	99	%		80 - 120	
4-Bromofluorobenzene (Surr)	95	%		77 - 120	
Dibromofluoromethane	104	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-3B
 Lab Sample ID: 500-22332-5

Date Sampled: 11/05/2009 0715
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/10/2009 1606			
Prep Method: 5030B		Date Prepared: 11/10/2009 1606			
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0 *	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	3.5	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	<1.0	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	1.3	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-3B
 Lab Sample ID: 500-22332-5

Date Sampled: 11/05/2009 0715
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate			Acceptance Limits		
1,2-Dichloroethane-d4 (Surr)	99	%		72 - 135	
Toluene-d8 (Surr)	101	%		80 - 120	
4-Bromofluorobenzene (Surr)	97	%		77 - 120	
Dibromofluoromethane	105	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-4A
 Lab Sample ID: 500-22332-6

Date Sampled: 11/05/2009 0845
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/10/2009 1630			
Prep Method: 5030B		Date Prepared: 11/10/2009 1630			
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0 *	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	1.1	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	24	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	14	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-4A
 Lab Sample ID: 500-22332-6

Date Sampled: 11/05/2009 0845
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		72 - 135	
Toluene-d8 (Surr)	104	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		77 - 120	
Dibromofluoromethane	101	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-4A DUP
 Lab Sample ID: 500-22332-7

Date Sampled: 11/05/2009 0845
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	11/10/2009 1653		
Prep Method: 5030B		Date Prepared:	11/10/2009 1653		
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0 *	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	24	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	15	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-4A DUP
 Lab Sample ID: 500-22332-7

Date Sampled: 11/05/2009 0845
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	96	%		72 - 135	
Toluene-d8 (Surr)	102	%		80 - 120	
4-Bromofluorobenzene (Surr)	98	%		77 - 120	
Dibromofluoromethane	104	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-4B
 Lab Sample ID: 500-22332-8

Date Sampled: 11/05/2009 0915
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/10/2009 1717			
Prep Method: 5030B		Date Prepared: 11/10/2009 1717			
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0 *	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	3.3	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	1.7	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	50	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	78	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-4B
 Lab Sample ID: 500-22332-8

Date Sampled: 11/05/2009 0915
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		72 - 135	
Toluene-d8 (Surr)	103	%		80 - 120	
4-Bromofluorobenzene (Surr)	95	%		77 - 120	
Dibromofluoromethane	106	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-6
 Lab Sample ID: 500-22332-9

Date Sampled: 11/05/2009 0700
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	11/10/2009 1804	
Prep Method: 5030B			Date Prepared:	11/10/2009 1804	
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0 *	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	2.4	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	2.8	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-6
 Lab Sample ID: 500-22332-9

Date Sampled: 11/05/2009 0700
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	99	%		72 - 135	
Toluene-d8 (Surr)	100	%		80 - 120	
4-Bromofluorobenzene (Surr)	94	%		77 - 120	
Dibromofluoromethane	104	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-7
 Lab Sample ID: 500-22332-10

Date Sampled: 11/04/2009 0950
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed: 11/10/2009 1828		
Prep Method: 5030B			Date Prepared: 11/10/2009 1828		
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0 *	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	2.7	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-7
 Lab Sample ID: 500-22332-10

Date Sampled: 11/04/2009 0950
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	103	%		72 - 135	
Toluene-d8 (Surr)	100	%		80 - 120	
4-Bromofluorobenzene (Surr)	99	%		77 - 120	
Dibromofluoromethane	105	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-9
 Lab Sample ID: 500-22332-11

Date Sampled: 11/05/2009 1230
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed:	11/10/2009 1852	
Prep Method: 5030B			Date Prepared:	11/10/2009 1852	
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	1.2	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0 *	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	15	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	1.4	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	16	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	7.0	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-9
 Lab Sample ID: 500-22332-11

Date Sampled: 11/05/2009 1230
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		72 - 135	
Toluene-d8 (Surr)	100	%		80 - 120	
4-Bromofluorobenzene (Surr)	95	%		77 - 120	
Dibromofluoromethane	108	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-11B
 Lab Sample ID: 500-22332-12

Date Sampled: 11/05/2009 1120
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/10/2009 1915			
Prep Method: 5030B		Date Prepared: 11/10/2009 1915			
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0 *	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	11	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-11B
 Lab Sample ID: 500-22332-12

Date Sampled: 11/05/2009 1120
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	105	%		72 - 135	
Toluene-d8 (Surr)	108	%		80 - 120	
4-Bromofluorobenzene (Surr)	98	%		77 - 120	
Dibromofluoromethane	106	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-12B
 Lab Sample ID: 500-22332-13

Date Sampled: 11/05/2009 0730
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/10/2009 1939			
Prep Method: 5030B		Date Prepared: 11/10/2009 1939			
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0 *	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	2.7	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	32	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-12B
 Lab Sample ID: 500-22332-13

Date Sampled: 11/05/2009 0730
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	100	%	72 - 135
Toluene-d8 (Surr)	102	%	80 - 120
4-Bromofluorobenzene (Surr)	98	%	77 - 120
Dibromofluoromethane	104	%	79 - 133

Method: 8260B Run Type: DL

Date Analyzed: 11/10/2009 2003

Prep Method: 5030B

Date Prepared: 11/10/2009 2003

Trichloroethene	360	ug/L	1.6	10	10
-----------------	-----	------	-----	----	----

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	98	%	72 - 135
Toluene-d8 (Surr)	98	%	80 - 120
4-Bromofluorobenzene (Surr)	99	%	77 - 120
Dibromofluoromethane	106	%	79 - 133

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-13
 Lab Sample ID: 500-22332-14

Date Sampled: 11/04/2009 1530
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/10/2009 2027			
Prep Method: 5030B		Date Prepared: 11/10/2009 2027			
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0 *	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	1.1	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	4.3	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	22	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-13
 Lab Sample ID: 500-22332-14

Date Sampled: 11/04/2009 1530
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		72 - 135	
Toluene-d8 (Surr)	103	%		80 - 120	
4-Bromofluorobenzene (Surr)	93	%		77 - 120	
Dibromofluoromethane	109	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-17
 Lab Sample ID: 500-22332-15

Date Sampled: 11/04/2009 1045
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B			Date Analyzed: 11/10/2009 2051		
Prep Method: 5030B			Date Prepared: 11/10/2009 2051		
Benzene	2.7	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0 *	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0 *	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	<1.0	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: RFW-17
 Lab Sample ID: 500-22332-15

Date Sampled: 11/04/2009 1045
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		72 - 135	
Toluene-d8 (Surr)	101	%		80 - 120	
4-Bromofluorobenzene (Surr)	94	%		77 - 120	
Dibromofluoromethane	108	%		79 - 133.	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: TRIP BLANK
 Lab Sample ID: 500-22332-16

Date Sampled: 11/04/2009 0700
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/11/2009 1128			
Prep Method: 5030B		Date Prepared: 11/11/2009 1128			
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	<1.0	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: TRIP BLANK
 Lab Sample ID: 500-22332-16

Date Sampled: 11/04/2009 0700
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		72 - 135	
Toluene-d8 (Surr)	102	%		80 - 120	
4-Bromofluorobenzene (Surr)	92	%		77 - 120	
Dibromofluoromethane	103	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: EW-2
 Lab Sample ID: 500-22332-17

Date Sampled: 11/04/2009 1715
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/11/2009 1152			
Prep Method: 5030B		Date Prepared: 11/11/2009 1152			
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	3.9	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	64	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: EW-2
 Lab Sample ID: 500-22332-17

Date Sampled: 11/04/2009 1715
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	102	%	72 - 135
Toluene-d8 (Surr)	102	%	80 - 120
4-Bromofluorobenzene (Surr)	96	%	77 - 120
Dibromofluoromethane	104	%	79 - 133

Method: 8260B Run Type: DL

Date Analyzed: 11/11/2009 1216

Prep Method: 5030B

Date Prepared: 11/11/2009 1216

Trichloroethene	430	ug/L	1.6	10	10
-----------------	-----	------	-----	----	----

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	106	%	72 - 135
Toluene-d8 (Surr)	104	%	80 - 120
4-Bromofluorobenzene (Surr)	97	%	77 - 120
Dibromofluoromethane	104	%	79 - 133

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: EW-3
 Lab Sample ID: 500-22332-18

Date Sampled: 11/05/2009 1015
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/11/2009 1240			
Prep Method: 5030B		Date Prepared: 11/11/2009 1240			
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	2.8	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	3.8	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: EW-3
 Lab Sample ID: 500-22332-18

Date Sampled: 11/05/2009 1015
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	108	%	72 - 135
Toluene-d8 (Surr)	106	%	80 - 120
4-Bromofluorobenzene (Surr)	95	%	77 - 120
Dibromofluoromethane	101	%	79 - 133

Method: 8260B Run Type: DL

Date Analyzed: 11/11/2009 1303

Prep Method: 5030B

Date Prepared: 11/11/2009 1303

Trichloroethene	130	ug/L	0.80	5.0	5.0
-----------------	-----	------	------	-----	-----

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	104	%	72 - 135
Toluene-d8 (Surr)	103	%	80 - 120
4-Bromofluorobenzene (Surr)	97	%	77 - 120
Dibromofluoromethane	105	%	79 - 133

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: EW-4
 Lab Sample ID: 500-22332-19

Date Sampled: 11/05/2009 1045
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/12/2009 1508			
Prep Method: 5030B		Date Prepared: 11/12/2009 1508			
Benzene	<5.0	ug/L	0.75	5.0	5.0
Dichlorodifluoromethane	<5.0	ug/L	1.2	5.0	5.0
Chloromethane	<5.0	ug/L	0.70	5.0	5.0
Vinyl chloride	<5.0	ug/L	0.75	5.0	5.0
Bromomethane	<5.0	ug/L	2.2	5.0	5.0
Chloroethane	<5.0	ug/L	1.8	5.0	5.0
Trichlorofluoromethane	<5.0	ug/L	1.2	5.0	5.0
1,1-Dichloroethene	<5.0	ug/L	1.2	5.0	5.0
Carbon disulfide	<25	ug/L	3.3	25	5.0
Acetone	<25	ug/L	10	25	5.0
Methylene Chloride	<10	ug/L	2.6	10	5.0
trans-1,2-Dichloroethene	<5.0	ug/L	0.90	5.0	5.0
1,1-Dichloroethane	<5.0	ug/L	0.60	5.0	5.0
2,2-Dichloropropane	<5.0	ug/L	0.90	5.0	5.0
cis-1,2-Dichloroethene	<5.0	ug/L	0.75	5.0	5.0
Methyl Ethyl Ketone	<25	ug/L	14	25	5.0
Bromochloromethane	<5.0	ug/L	0.75	5.0	5.0
Chloroform	<5.0	ug/L	0.75	5.0	5.0
1,1,1-Trichloroethane	<5.0	ug/L	0.70	5.0	5.0
1,1-Dichloropropene	<5.0	ug/L	0.80	5.0	5.0
Carbon tetrachloride	<5.0	ug/L	1.6	5.0	5.0
1,2-Dichloroethane	<5.0	ug/L	0.70	5.0	5.0
1,2-Dichloropropane	<5.0	ug/L	0.95	5.0	5.0
Dibromomethane	<5.0	ug/L	1.2	5.0	5.0
Bromodichloromethane	<5.0	ug/L	0.65	5.0	5.0
cis-1,3-Dichloropropene	<5.0	ug/L	0.80	5.0	5.0
methyl isobutyl ketone	<25	ug/L	3.8	25	5.0
Toluene	<5.0	ug/L	0.85	5.0	5.0
trans-1,3-Dichloropropene	<5.0	ug/L	1.0	5.0	5.0
1,1,2-Trichloroethane	<5.0	ug/L	1.1	5.0	5.0
Tetrachloroethene	21	ug/L	1.0	5.0	5.0
1,3-Dichloropropane	<5.0	ug/L	1.2	5.0	5.0
2-Hexanone	<25	ug/L	3.8	25	5.0
Dibromochloromethane	<5.0	ug/L	0.85	5.0	5.0
1,2-Dibromoethane	<5.0	ug/L	0.95	5.0	5.0
Chlorobenzene	<5.0	ug/L	0.85	5.0	5.0
1,1,1,2-Tetrachloroethane	<5.0	ug/L	1.0	5.0	5.0
Ethylbenzene	<5.0	ug/L	1.1	5.0	5.0
m&p-Xylene	<10	ug/L	2.1	10	5.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: EW-4
 Lab Sample ID: 500-22332-19

Date Sampled: 11/05/2009 1045
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<5.0	ug/L	0.95	5.0	5.0
Styrene	<5.0	ug/L	0.85	5.0	5.0
Bromoform	<5.0	ug/L	1.5	5.0	5.0
Isopropylbenzene	<5.0	ug/L	1.3	5.0	5.0
Bromobenzene	<5.0	ug/L	1.3	5.0	5.0
1,1,2,2-Tetrachloroethane	<5.0	ug/L	1.4	5.0	5.0
1,2,3-Trichloropropane	<5.0	ug/L	2.4	5.0	5.0
N-Propylbenzene	<5.0	ug/L	1.3	5.0	5.0
2-Chlorotoluene	<5.0	ug/L	1.2	5.0	5.0
1,3,5-Trimethylbenzene	<5.0	ug/L	1.1	5.0	5.0
4-Chlorotoluene	<5.0	ug/L	1.3	5.0	5.0
tert-Butylbenzene	<5.0	ug/L	1.3	5.0	5.0
1,2,4-Trimethylbenzene	<5.0	ug/L	1.3	5.0	5.0
sec-Butylbenzene	<5.0	ug/L	1.2	5.0	5.0
1,3-Dichlorobenzene	<5.0	ug/L	1.3	5.0	5.0
p-Isopropyltoluene	<5.0	ug/L	1.2	5.0	5.0
1,4-Dichlorobenzene	<5.0	ug/L	1.3	5.0	5.0
n-Butylbenzene	<5.0	ug/L	1.2	5.0	5.0
1,2-Dichlorobenzene	<5.0	ug/L	1.6	5.0	5.0
1,2-Dibromo-3-Chloropropane	<10	ug/L	2.9	10	5.0
1,2,4-Trichlorobenzene	<5.0	ug/L	1.8	5.0	5.0
Hexachlorobutadiene	<5.0	ug/L	2.0	5.0	5.0
Naphthalene	<5.0	ug/L	2.2	5.0	5.0
1,2,3-Trichlorobenzene	<5.0	ug/L	2.8	5.0	5.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	106	%	72 - 135
Toluene-d8 (Surr)	106	%	80 - 120
4-Bromofluorobenzene (Surr)	98	%	77 - 120
Dibromofluoromethane	104	%	79 - 133

Method: 8260B Run Type: DL

Date Analyzed: 11/11/2009 1353

Prep Method: 5030B

Date Prepared: 11/11/2009 1353

Trichloroethene	990	ug/L	8.0	50	50
-----------------	-----	------	-----	----	----

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	101	%	72 - 135
Toluene-d8 (Surr)	104	%	80 - 120
4-Bromofluorobenzene (Surr)	93	%	77 - 120
Dibromofluoromethane	110	%	79 - 133

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: EW-5
 Lab Sample ID: 500-22332-20

Date Sampled: 11/04/2009 0915
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/12/2009 1533			
Prep Method: 5030B		Date Prepared: 11/12/2009 1533			
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	6.9	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: EW-5
 Lab Sample ID: 500-22332-20

Date Sampled: 11/04/2009 0915
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	114	%	72 - 135
Toluene-d8 (Surr)	103	%	80 - 120
4-Bromofluorobenzene (Surr)	100	%	77 - 120
Dibromofluoromethane	106	%	79 - 133

Method: 8260B Run Type: DL

Date Analyzed: 11/11/2009 1441

Prep Method: 5030B

Date Prepared: 11/11/2009 1441

Trichloroethene	130	ug/L	0.80	5.0	5.0
-----------------	-----	------	------	-----	-----

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	99	%	72 - 135
Toluene-d8 (Surr)	100	%	80 - 120
4-Bromofluorobenzene (Surr)	97	%	77 - 120
Dibromofluoromethane	110	%	79 - 133

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: EW-6
 Lab Sample ID: 500-22332-21

Date Sampled: 11/04/2009 1430
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/11/2009 1505			
Prep Method: 5030B		Date Prepared: 11/11/2009 1505			
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	10	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	15	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: EW-6
 Lab Sample ID: 500-22332-21

Date Sampled: 11/04/2009 1430
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.42	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.17	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.26	1.0	1.0
Bromobenzene	<1.0	ug/L	0.26	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.27	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.26	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.25	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.22	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.26	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.26	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.23	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.26	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.31	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.58	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.37	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.39	1.0	1.0
Naphthalene	<1.0	ug/L	0.43	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.57	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	108	%		72 - 135	
Toluene-d8 (Surr)	103	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		77 - 120	
Dibromofluoromethane	109	%		79 - 133	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-22332-1

Client Sample ID: EW-7
 Lab Sample ID: 500-22332-22

Date Sampled: 11/04/2009 1410
 Date Received: 11/06/2009 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/11/2009 1528			
Prep Method: 5030B		Date Prepared: 11/11/2009 1528			
Benzene	<1.0	ug/L	0.15	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.23	1.0	1.0
Chloromethane	<1.0	ug/L	0.14	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.15	1.0	1.0
Bromomethane	<1.0	ug/L	0.45	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.24	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.23	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.66	5.0	1.0
Acetone	<5.0	ug/L	2.1	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.52	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.12	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.18	1.0	1.0
cis-1,2-Dichloroethene	4.8	ug/L	0.15	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.8	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.15	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.32	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.14	1.0	1.0
Trichloroethene	4.2	ug/L	0.16	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.25	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.13	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.77	5.0	1.0
Toluene	<1.0	ug/L	0.17	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.21	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.22	1.0	1.0
Tetrachloroethene	9.8	ug/L	0.20	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.19	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.20	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.22	1.0	1.0