

Quarterly Groundwater Monitoring Report

Prepared for
Black & Decker (U.S.) Inc.

Hampstead, Maryland

January 2011

Prepared by

WESTON SOLUTIONS, INC.

West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION	1-1
2. SITE CHARACTERISTICS	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 4th Quarter 2010	2-2
Table 2-2 Groundwater Elevation Data – 4th Quarter 2010.....	2-3
Table 2-3 Effluent Characteristics Summary – 4th Quarter 2010.....	2-4
Table 2-4 Summary of Groundwater Analytical Results - November 2010	2-5
Table 3-1 Treatment System Maintenance Activities – 4th Quarter 2010.....	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of October through December 2010.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of October through December 2010, the extraction wells were pumping at an average combined rate of approximately 168 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of October through December 2010 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of October through December 2010, approximately 15.6 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (87.1 %) and tetrachloroethene (PCE) (12.9 %). Analytical results of the groundwater collected from the air stripper for the period of October through December 2010 are included in Appendix C.

A summary of the analytical results from the fourth quarter (November 2010) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 4th Quarter 2010
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
October 2010	6,597,998
November 2010	6,297,390
December 2010	6,990,442

Table 2-2
Groundwater Elevation Data - 4th Quarter 2010

Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV.	TOTAL DEPTH	10/14/2010		11/2/2010		12/17/2010	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NC	DRY	NC	DRY	NC
EW-2	849.21	110	92.81	756.40	56.22*	849.21	91.36	757.85
EW-3	846.64	118	85.80	760.84	89.41	757.23	82.61	764.03
EW-4	858.01	97.5	PC	NC	PC	NC	PC	NC
EW-5	864.17	98	91.33	772.84	92.01	772.16	92.10	772.07
EW-6	831.98	115	98.71	733.27	102.93	729.05	100.32	731.66
EW-7	818.38	78	53.30	765.08	48.69	769.69	52.58	765.80
EW-8	811.13	98	91.80	719.33	91.60	719.53	91.82	719.31
EW-9	811.35	141	102.00	709.35	102.00	709.35	102.50	708.85
EW-10	807.74	INA	56.43	751.31	56.29	751.45	54.48	753.26
RFW-1A	864.37	78	51.82	812.55	53.75	810.62	53.26	811.11
RFW-1B	864.23	200	51.85	812.38	53.80	810.43	53.30	810.93
RFW-2A	857.41	35	17.93	839.48	18.29	839.12	17.84	839.57
RFW-2B	857.73	75	18.57	839.16	18.92	838.81	18.11	839.62
RFW-3B	839.21	153	35.41	803.80	32.53	806.68	34.99	804.22
RFW-4A	830.37	62	37.79	792.58	38.16	792.21	38.58	791.79
RFW-4B	830.37	120	37.74	792.63	38.08	792.29	38.51	791.86
RFW-5A	817.50	30	DRY	NC	DRY	NC	DRY	NC
RFW-6	785.04	120	4.10	780.94	1.55	783.49	4.25	780.79
RFW-7	805.14	29	7.63	797.51	6.95	798.19	7.04	798.10
RFW-8	860.07	56	DRY	NC	DRY	NC	DRY	NC
RFW-9	862.02	49	28.32	833.70	28.47	833.55	27.94	834.08
RFW-10	852.06	58	DRY	NC	DRY	NC	DRY	NC
RFW-11A	849.32	72	Damaged	NC	Damaged	NC	Damaged	NC
RFW-11B	849.62	116	64.77	784.85	64.78	784.84	65.46	784.16
RFW-12B	844.87	264	53.46	791.41	56.29	788.58	54.59	790.28
RFW-13	849.11	150	60.04	789.07	61.58	787.53	58.01	791.10
RFW-14B	812.39	281	55.71	756.68	55.78	756.61	54.17	758.22
RFW-16	856.14	41	DRY	NC	DRY	NC	DRY	NC
RFW-17	834.66	60.5	27.22	807.44	27.51	807.15	25.77	808.89
RFW-20	842.49	142	34.51	807.98	35.50	806.99	35.34	807.15
RFW-21	832.65	102	21.42	811.23	22.26	810.39	22.20	810.45
PH-7	805.94	89	29.31	776.63	34.22	771.72	35.15	770.79
PH-9	814.94	98	39.73	775.21	35.51	779.43	44.40	770.54
PH-11	820.68	78	52.14	768.54	45.41	775.27	47.94	772.74
PH-12	828.35	87	53.96	774.39	46.80	781.55	48.78	779.57
B-3	803.02	83	9.98	793.04	10.09	792.93	9.83	793.19
Amoco	842.29	INA	NA	NC	NA	NC	NA	NC
Hamp. Town #22	804.96	INA	4.16	800.80	3.87	801.09	5.02	799.94
Pembroke #1	INA	INA	10.94	NC	11.04	NC	11.33	NC
Pembroke #2	INA	INA	Damaged	NC	Damaged	NC	Damaged	NC
N. Houcks. Rd.	INA	INA	9.78	NC	10.48	NC	10.41	NC
E. Century St.	INA	INA	19.31	NC	19.27	NC	19.36	NC
Lwr. Beckleys. Rd.	INA	INA	56.14	NC	56.11	NC	55.09	NC

NA - Not Available/Not Accessible

NC - Not Calculable

INA - Information not available

PC - Pump Cycles

Table 2-3
Effluent Characteristics Summary - 4th Quarter 2010
Black & Decker
Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				October 2010	November 2010	December 2010	
001	FLOW	average	MGD	NA	0.119	0.159	0.115
		maximum	MGD	NA	0.350	0.529	0.159
	1,1,1-Trichloroethane		ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene		ug/l	5	< 1	< 1	< 1
	Trichloroethylene		ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	9.0	6.0
		monthly average	mg/l	10	< 5	9.0	6.0
	pH	minimum	STD	6.0	6.4	6.2	6.1
		maximum	STD	8.5	7.9	6.7	6.7
BOD		mg/l	15	8.0	3.0	< 1	
TSS	maximum	mg/l	30	8.0	< 1	< 1	
	monthly average	mg/l	20	8.0	< 1	< 1	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.242	0.241	0.293
		maximum	MGD	NA	0.322	0.325	0.416
	Fecal Coliform		MPN/100ml	200	< 1.8	< 1.8	33.0
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.216
		maximum	MGD	NA	NR	NR	0.299
	1,1,1-Trichloroethane		ug/l	NA	NR	NR	< 1
	Tetrachloroethylene		ug/l	NA	NR	NR	< 1
	Trichloroethylene		ug/l	NA	NR	NR	< 1

DMR - Discharge Monitoring Report
NA - Not Applicable
NR - Not Reported

Table 2-4

Summary of Groundwater Analytical Results - November 2010

Black & Decker
Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2*	EW-3	EW-4	EW-4 (DUP)	EW-5	EW-6	EW-7	EW-8	EW-9	EW-10
Chloromethane	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	NS	2.3	1 U	1 U	1 U	1 U	4	25	1 U	1 U
Chloroform	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	NS	85	1400	1200	160	8.5	3.5	9.6	0.9 J	1 U
Dibromochloromethane	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	NS	2.5	27	22	4.6	17	8.1	63	130	1.3
1,1,2,2-Tetrachloroethane	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

NS = Not Sampled

*Well EW-2 down for maintenance during sampling

Table 2-4

Summary of Groundwater Analytical Results - November 2010
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	RFW-20	RFW-21	Town #22	Town #23	Trip Blank
		USEPA drinking water method 524.2														
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	NS	2 U	ABD	ABD	ABD	2 U	0.5 U	0.5 U	0.5 U	0.5 U	6.4
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	NA	NA	NA	NA	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	2.5	1	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.3 J	0.5 U	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trichloroethene	ug/L	NS	6.6	190	3.3	NS	1 U	ABD	ABD	ABD	1 U	0.7	0.5 U	0.5 U	0.5 U	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	1.4	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	1 U	14	16	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,1,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division.
Samples from all of the other wells are analyzed with USEPA Method 8260.

NS = Not sampled

U = Compound was analyzed but not detected.

ABD = Well has been abandoned

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from wells RFW-4A and EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (October through December 2010) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 4th Quarter 2010
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Oct-10	Alarm at the air stripper, EW-2 tripped off due to two bad relays, the relays were replaced. The system is back online.
Oct-10	EW-2 down due to a burned out pump motor. The pump motor was replaced and the well is back up and running.
Nov-10	Alarm at the stripper due to blower failure and high column. Reset the system, the system is back online.
Nov-10	Pulled and replaced the pump in EW-7 to increase the pumping rate in the well. The pumping rate had fallen in recent months.
Nov-10	Alarm at the stripper due to the high wet well, reset the system, the system is back online.
Nov-10	Alarm at the stripper due to a power outage. Reset the system, the system is back online.

4. RECOMMENDATIONS

For the reporting period of October through December 2010, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(OCTOBER – DECEMBER 2010)

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 626 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrance Jones 0763, Gary Dickerson 0782, David Smith 9153, Brian Musselman 2775

Permit Number: 02-DP-0022
Superintendent: Earle Villarreal

Certification # 1017

Month: October
Year: 2010

Date	Appearance	Discharge MGD	pH	Cl ₂ mg/l	Final Effluent outfall 001					Outfall 101					Outfall 201				Operator			
					Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethylene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	AJum Gpd	Hypochlorite Gpd	Post Cl ₂ mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l		Trichloroethylene ug/l	Discharge mgd	
1	Clear	0.10240										0.203000		0.0	2.0	1.5	5.0				0.241989	Djones
2	Clear	0.15300										0.229000		0.0	5.0	1.5	5.0				0.174640	Djones
3	Clear	0.11600										0.272000		0.0	5.0	1.5	5.0				0.219110	Djones
4	Clear	0.17400										0.221000		0.0	5.0	1.5	5.0				0.260823	Gdickerson
5	Clear	0.25700	7.22	0.00								0.249000	< 1.8	0.0	5.0	1.5	5.0				0.198676	Gdickerson
6	Clear	0.10400										0.251000		0.0	5.0	1.5	5.0				0.237532	Djones
7	Clear	0.09500	7.88	0.00								0.228000		0.0	5.0	1.5	5.0				0.221207	Djones
8	Clear	0.09700										0.284000		0.0	5.0	1.5	5.0				0.197396	Gdickerson
9	Clear	0.08700										0.137000		0.0	5.0	1.5	5.0				0.182875	Dsmith
10	Clear	0.09300										0.141000		0.0	5.0	1.5	5.0				0.216747	Dsmith
11	Clear	0.10400	6.38	0.00								0.200000		0.0	5.0	1.5	5.0				0.262419	Djones
12	Clear	0.08100			< 1.00	< 1.00	< 1.00	8.0	8.0	< 5.3		0.286000	< 1.8	0.0	1.0	1.5	5.0	< 1.0	< 1.0	< 1.0	0.225332	Djones
13	Clear	0.10900										0.210000		0.0	1.0	1.5	5.0				0.215028	Djones
14	Clear	0.08300	7.92	0.00								0.250000		0.0	1.0	1.5	5.0				0.214269	Djones
15	Clear	0.35000										0.265000		0.0	1.0	1.5	5.0				0.199242	Djones
16	Clear	0.11300										0.247000		0.0	1.0	1.5	5.0				0.209353	Brusselman
17	Clear	0.09100										0.247000		0.0	1.0	1.5	5.0				0.212425	Gdickerson
18	Clear	0.09100	7.75	0.00								0.213000		0.0	1.0	1.5	5.0				0.215241	Dsmith
19	Clear	0.08300	7.04	0.00								0.318000	< 1.8	0.0	1.0	1.5	5.0				0.207269	Djones
20	Clear	0.11000										0.262000		0.0	1.0	1.5	5.0				0.251609	Djones
21	Clear	0.08900	7.32	0.00								0.254000		0.0	1.0	1.5	5.0				0.213106	Djones
22	Clear	0.08600										0.243000		0.0	5.0	1.5	5.0				0.195121	Djones
23	Clear	0.08000										0.283000		0.0	5.0	1.5	5.0				0.183609	Djones
24	Clear	0.08800										0.246000		0.0	1.0	1.5	5.0				0.178244	Djones
25	Clear	0.09500										0.188000		0.0	1.0	1.5	5.0				0.241088	Gdickerson
26	Clear	0.08400	7.01	0.00								0.221000	< 1.8	0.0	1.0	1.5	5.0				0.205251	Gdickerson
27	Clear	0.19300										0.217000		0.0	1.0	1.5	5.0				0.233916	Djones
28	Clear	0.18200	6.50	0.00								0.293000		0.0	1.0	1.5	5.0				0.190123	Djones
29	Clear	0.11600										0.251000		0.0	3.0	1.5	5.0				0.231463	Djones
30	Clear	0.07700										0.282000		0.0	2.0	1.5	5.0				0.164574	Dsmith
31	Clear	0.09800										0.322000		0.0	2.0	1.5	5.0				0.198321	Dsmith
Total		3.68140										7.513000									6.597998	
Average		0.11875	7.2	<0.10	0	0	0	8	8	0		0.242355	1	0.0	2.7	1.5	5.0	0	0	0	0.212839	
Minimum		0.07700	6.4	0.00	0	0	0	8	8	0		0.137000	1	0.0	1.0	1.5	5.0	0	0	0	0.164574	
Maximum		0.35000	7.9	<0.10	0	0	0	8	8	0		0.322000	1	0.0	5.0	1.5	5.0	0	0	0	0.262419	MOR 5-11-09

COMMENTS:

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 626 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrance Jones 0763, Gary Dickerson 0782

Permit Number: 02-DP-0022
Superintendent: Earle Villarreal

Certification # 1017

Month: November
Year: 2010

Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Final Effluent outfall 001						Outfall 101						Outfall 201			Operator		
					Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Pest Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l		Discharge mgd	
1	Clear	0.10900									0.253000		0.0	5.0	1.5	5.0				0.223819	Djones	
2	Clear	0.07800	6.61	0.00	< 1.00	< 1.00	< 1.00	3.0	< 4.0	9.4	0.325000	< 1.8	0.0	3.0	1.5	5.0				0.192479	APhillips	
3	Clear	0.08500									0.312000		0.0	2.0	1.5	5.0				0.204926	Djones	
4	Clear	0.22400	6.30	0.00							0.273000		0.0	2.0	1.5	5.0				0.203390	APhillips	
5	Clear	0.52900									0.263000		0.0	1.0	1.5	5.0				0.190019	Djones	
6	Clear	0.22300									0.251000		0.0	1.0	1.5	5.0				0.195254	Gdickerson	
7	Clear	0.20000									0.268000		0.0	1.0	1.5	5.0				0.193619	Gdickerson	
8	Clear	0.20900									0.200000		0.0	1.0	1.5	5.0				0.213117	Djones	
9	Clear	0.18600	6.58	0.00							0.229000	< 1.8	0.0	4.0	1.5	5.0				0.204792	Djones	
10	Clear	0.18300	6.63	0.00							0.228000		0.0	2.0	1.5	5.0				0.210334	Djones	
11	Clear	0.16700									0.244000		0.0	2.0	1.5	5.0				0.169333	Dsmith	
12	Clear	0.18600									0.215000		0.0	1.0	1.5	5.0				0.238048	Dsmith	
13	Clear	0.12400									0.219000		0.0	1.0	1.5	5.0				0.229233	Fschmidt	
14	Clear	0.11800									0.250000		0.0	2.0	1.5	5.0				0.221719	Fschmidt	
15	Clear	0.14900									0.168000		0.0	1.0	1.5	5.0				0.273300	Djones	
16	Clear	0.12700	6.23	0.00							0.298000	< 1.8	0.0	1.0	1.5	5.0				0.229090	Djones	
17	Clear	0.14300									0.156000		0.0	2.0	0.3	5.0				0.230841	Djones	
18	Clear	0.11300	6.65	0.00							0.257000		0.0	3.0	1.0	5.0				0.210370	Djones	
19	Clear	0.13500									0.201000		0.0	5.0	1.0	5.0				0.124050	Djones	
20	Clear	0.11900									0.232000		0.0	5.0	1.0	5.0				0.123166	Djones	
21	Clear	0.13300									0.181000		0.0	2.0	0.8	5.0				0.227104	Djones	
22	Clear	0.15600									0.310000		0.0	1.0	0.8	5.0				0.273949	Bmusselman	
23	Clear	0.13200	6.51	0.00							0.258000	< 1.8	0.0	2.0	0.8	5.0				0.201274	Gdickerson	
24	Clear	0.14100	6.55	0.00							0.241000		0.0	2.0	0.8	5.0				0.259374	Djones	
25	Clear	0.12700									0.230000		0.0	2.0	0.8	5.0				0.110754	Jdowns	
26	Clear	0.13400									0.290000		0.0	1.0	0.8	5.0				0.205095	Djones	
27	Clear	0.16000									0.217000		0.0	1.0	0.8	5.0				0.269825	Gdickerson	
28	Clear	0.12200									0.252000		0.0	1.0	0.8	5.0				0.210403	Gdickerson	
29	Clear	0.13500									0.201000		0.0	1.0	0.8	5.0				0.256156	APhillips	
30	Clear	0.11800	6.67	0.00							0.212000	< 1.8	0.0	1.0	0.8	5.0				0.202557	Djones	
31																						
Total		4.76500									7.234000										6.297390	
Average		0.15883	6.5	<0.10	0	0	0	3	0	9	0.241133	1	0.0	2.0	1.2	5.0	#DIV/0!	#DIV/0!	#####	0.209913		
Minimum		0.07800	6.2	0.00	0	0	0	3	0	9	0.156000	1	0.0	1.0	0.3	5.0	0	0	0	0.110754		
Maximum		0.52900	6.7	<0.10	0	0	0	3	0	9	0.325000	1	0.0	5.0	1.5	5.0	0	0	0	0.273949	MOR 5-11-09	

COMMENTS:

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 626 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrance Jones 0763, Gary Dickerson 0782, Brian Musselman 2775, Mbrin Whitt 0666, Tony Phillips 3001, Philips Pitts 2999, Jamaal Downs 2755, David Smith 9153

Permit Number: 02-DP-0022
Superintendent: Earle Villarreal

Certification # 1017

Month: December
Year: 2010

Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Final Effluent outfall 001						Outfall 101					Outfall 201			Operator		
					Total Suspended Solids ug/l	TSS ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl ₂ mg/l	Total Suspended Solids ug/l	1,1,1-Trichloroethene ug/l		Trichloroethene ug/l	Discharge mgd
1	Clear	0.11900									0.240000		0.0	5.0	1.0	5.0				0.217643	Djones
2	Clear	0.13900	6.52	0.00							0.244000		0.0	2.0	0.8	5.0				0.233773	Djones
3	Clear	0.13200									0.226000		0.0	1.0	0.8	5.0				0.226623	Djones
4	Clear	0.11600									0.293000		0.0	1.0	0.8	5.0				0.193288	APhillips
5	Clear	0.15200									0.248000		0.0	1.0	0.8	5.0				0.272379	APhillips
6	Clear	0.12400									0.227000		0.0	1.0	0.8	5.0				0.236341	Djones
7	Clear	0.09500	6.15	0.00	< 1.00	< 1.00	< 1.00	< 2.0	< 4.0	6.1	0.348000	< 1.8	0.0	1.0	0.8	1.8				0.201558	Djones
8	Clear	0.12200									0.222000		0.0	1.0	0.8	5.0				0.299183	Djones
9	Clear	0.09500	6.20	0.00							0.282000		0.0	1.0	0.8	5.0				0.200659	Djones
10	Clear	0.11900									0.224000		0.0	1.0	0.8	5.0				0.240445	Djones
11	Clear	0.10100									0.259000		0.0	1.0	0.8	5.0				0.181152	Djones
12	Clear	0.15900									0.299000		0.0	4.0	0.8	5.0				0.225210	Djones
13	Clear	0.05100									0.255000		0.0	5.0	0.8	5.0				0.264476	Gdickerson
14	Clear	0.14200	6.67	0.00							0.307000	< 1.8	0.0	5.0	0.8	5.0				0.209436	Gdickerson
15	Clear	0.12500									0.266000		0.0	1.0	0.8	5.0				0.243108	Ppitts
16	Clear	0.10400	6.32	0.00							0.285000		0.0	1.0	0.8	5.0				0.206910	Bmusselman
17	Clear	0.11600									0.345000		0.0	1.0	0.8	5.0				0.234069	Ppitts
18	Clear	0.11200									0.237000		0.0	1.0	0.8	5.0				0.225399	Mwhitt
19	Clear	0.13100									0.332000		0.0	1.0	1.5	5.0				0.174376	Dsmith
20	Clear	0.09000									0.285000		0.0	1.0	0.8	5.0				0.267401	Djones
21	Clear	0.11300	6.10	0.00							0.348000	< 1.8	0.0	1.0	0.8	5.0				0.206666	Djones
22	Clear	0.12900									0.307000		0.0	3.0	0.8	5.0				0.241025	Djones
23	Clear	0.10200	6.45	0.00							0.368000		0.0	2.0	0.8	5.0				0.195716	Djones
24	Clear	0.12100									0.262000		0.0	3.0	1.0	5.0				0.253550	Jdowns
25	Clear	0.08500									0.416000		0.0	2.0	0.8	5.0				0.164282	Bmusselman
26	Clear	0.14300									0.288000		0.0	3.0	0.8	5.0				0.278768	APhillips
27	Clear	0.10800									0.294000		0.0	2.0	0.8	5.0				0.217072	Djones
28	Clear	0.08500	6.08	0.00							0.362000	33.0	0.0	1.0	0.8	1.9				0.208917	Djones
29	Clear	0.11000									0.335000		0.0	1.0	0.8	5.0				0.233142	Djones
30	Clear	0.10100	6.17	0.00							0.354000		0.0	1.0	0.8	5.0				0.222777	Djones
31	Clear	0.11300									0.311000		0.0	1.0	0.8	5.0				0.215098	Bmusselman
Total		3.55400									9.069000									6.990442	
Average		0.11465	6.3	<0.10	0	0	0	2	0	6	0.292548	9	0.0	1.8	0.8	4.8	#DIV/0!	#DIV/0!	#####	0.225498	
Minimum		0.05100	6.1	0.00	0	0	0	2	0	6	0.222000	1	0.0	1.0	0.8	1.8	0	0	0	0.164282	
Maximum		0.15900	6.7	<0.10	0	0	0	0	0	6	0.416000	33	0.0	5.0	1.5	5.0	0	0	0	0.299183	MOR 5-11-09

COMMENTS:

**APPENDIX B
DISCHARGE MONITORING REPORTS
(OCTOBER - DECEMBER 2010)**

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	10	01	TO	10	10	31
(20-21)		(22-23) (24-25)		(26-27)		(28-29) (30-31)

State Discharge Permit

02-DP-0022

-PARAMETER (32-37)		(3 Card Only) (46-53)			QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)		
		AVERAGE		MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS					
		PERMIT REQUIREMENT	SAMPLE MEASUREMENT	PERMIT REQUIREMENT	SAMPLE MEASUREMENT	PERMIT REQUIREMENT	SAMPLE MEASUREMENT	PERMIT REQUIREMENT	SAMPLE MEASUREMENT	PERMIT REQUIREMENT	SAMPLE MEASUREMENT	PERMIT REQUIREMENT	SAMPLE MEASUREMENT					
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	8	(19)	0	ONCE/ MONTH	GRAB	
pH	EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	6.4	*****	*****	*****	*****	7.9	(12)	0	TWICE/ WEEK	GRAB	
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	6.0 DAILY MN	*****	*****	*****	*****	8.5 DAILY MX	*****	*****	TWICE/ WEEK	GRAB	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	EFFLUENT GROSS VALUE	118,755	350,000	(07)	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	0	Measured	RECORD	
CHLORINE, TOTAL RESIDUAL 50060 1 0 0	EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	<0.1	<0.1	(19)	0	ONCE/ MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0	EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	0.011 30DA AVG	0.019 DAILY MX	*****	*****	ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0	EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	0	*****	(28)	0	ONCE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
James M. Harkins
MES Director
TYPED OR PRINTED

CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
410 729-8350
DATE
10 11 22
AREA CODE NUMBER YEAR MONTH DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments he

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc
 Address 626 Hanover Pike
Hampstead, MD 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)	(17-19)
MD0001881	001
PERMIT NUMBER	DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 10	10	01	TO	10	10	31
(20-21) (22-23) (24-25)				(26-27) (28-29) (30-31)		

State Discharge Permit
 02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	(54-61)				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB		
79141.100	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L	0	ONCE/MONTH	GRAB		
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/MONTH	GRAB		
OIL AND GREASE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L	0	ONCE/MONTH	GRAB		
TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****	****	*****	30DA AVG	DAILY/MX						
70030.100	PERMIT REQUIREMENT	*****	*****	****	*****	30DA AVG	DAILY/MX						
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.							TELEPHONE		DATE			
James M. Harkins MES Director TYPED OR PRINTED								410 729-8350		10	11	22	
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							AREA CODE	NUMBER	YEAR	MONTH	DAY	

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.
 Address 626 Hanover Pike
 Hampstead, MD 21074

Facility Black and Decker WWTP
 Location 626 Hanover Pike
 Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16) MD0001881 PERMIT NUMBER	(17-19) 101 DISCHARGE NUMBER
--------------------------------------	------------------------------------

Form Approved.
 OMB No.
 Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 10	10	01	TO 10	10	31
(20-21)		(22-23)	(24-25)	(26-27)	
(28-29)		(30-31)			

State Discharge Permit
 02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	242,355	322,000	(07)	*****	*****	*****	****	0	ONCE/MONTH	GRAB
50050 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/WEEK	GRAB
COLIFORM, FECAL GENERAL	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY-MX	MPN		ONCE/WEEK	GRAB
74055 1 0 0	SAMPLE MEASUREMENT										
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)				TELEPHONE			DATE			
James M. Harkins MES Director TYPED OR PRINTED					SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT			410	729-8350	10	11
COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)					AREA CODE	NUMBER	YEAR	MONTH	DAY		

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc
 Address 626 Hanover Pike
 Hampstead, MD 21074

Facility Black and Decker WWTP
 Location 626 Hanover Pike
 Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) MD0001881 PERMIT NUMBER
 (17-19) 001 DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
10	11	01	10	11	30
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form

State Discharge Permit
 02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM				UNITS
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	3	(19)	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/MONTH	GRAB
pH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	6.2	*****	6.7	(12)	0	TWICE/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY MN	*****	8.5 DAILY MX	SU		TWICE/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	158,833	529,000	(07)	*****	*****	*****	****	0	Measured	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L		ONCE/MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER James M. Harkins MES Director TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS 1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
		410	729-8350	10	12	20
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments he

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name AG/GFI Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address 626 Hanover Pike

MD0001881

001

Approval expires

Hampstead, MD 21074

PERMIT NUMBER

DISCHARGE NUMBER

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP

MONITORING PERIOD

Location 626 Hanover Pike

YEAR	MO	DAY	TO	YEAR	MO	DAY
10	11	01		10	11	30

Attn:

FROM

TO

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (38-45)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
79141 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE							DAILY MX				
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	****	*****	9	9	(19)	0	ONCE/ MONTH	GRAB
TOTAL RECOVERABLE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONCE/ MONTH	GRAB
70030 1 0 0						30DA AVG	DAILY MX				
EFFLUENT GROSS VALUE											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE			
James M. Harkins MES Director		SIGNATURE OF PRICIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT.	410	729-8350	10	12	20
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	10	11	01		10	11	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (38-45)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	241,133	325,000	(07)	*****	*****	*****	****	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX	MPN		ONCE/ WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)						TFL PHONE		DATE	
James M. Harkins MES Director								SIGNATURE OF PRICIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		410	729-8350
TYPED OR PRINTED		AREA CODE		NUMBER		YFAR	MONTH	DAY			

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc
Address 626 Hanover Pike
Hampstead, MD 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.
OMB No.
Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

MONITORING PERIOD


YEAR MO DAY			YEAR MO DAY				
FROM	10	12	01	TO	10	12	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit
02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM				UNITS
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15	MG/L		ONCE/ MONTH	GRAB
								DAILY MX			
pH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	6.1	*****	6.7	(12)	0	TWICE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	8.5	SU		TWICE/ WEEK	GRAB
					DAILY MN		DAILY MX				
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	20	MG/L		ONCE/ MONTH	GRAB
							30DA AVG	DAILY MX			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	114,645	159,000	(07)	*****	*****	*****	*****	0	Measured	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	*****	*****	Measured	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	<0.1	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	0.011	MG/L		ONCE/ MONTH	GRAB
							30DA AVG	DAILY MX			
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L		ONCE/ MONTH	GRAB
							DAILY MX				
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L		ONCE/ MONTH	GRAB
							DAILY MX				

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
James M. Harkins
MES Director
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 16 U.S.C. §§ 1361 AND 13 U.S.C. §§ 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)


SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TPI PPHNF		DATE		
410	729-8350	11	01	25
AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments he

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name AG/GFI Hampstead, Inc

(2-16)

(17-19)

OMB No

Address 626 Hanover Pike

MD0001881

001

Approval expires

Hampstead, MD 21074

PERMIT NUMBER

DISCHARGE NUMBER

*** NO DISCHARGE: ***

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP

MONITORING PERIOD

Location 626 Hanover Pike

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	10	12	01		10	12	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

02-DP-0022

Attn:

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	(46-53)	(54-51)			
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)		0	ONCE/ MONTH	GRAB	
79141 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L			ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	6	6	(19)		0	ONCE/ MONTH	GRAB	
OIL AND GREASE TOTAL RECOVERABLE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L			ONCE/ MONTH	GRAB	
70030 1 0 0	SAMPLE MEASUREMENT					30DA AVG	DAILY MX						
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER James M. Harkins MES Director TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 881001 AND 33 U.S.C. 881319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410	729-8350	11	01	25
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***


NOTE: Read instructions before completing this form

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
10	12	01	10	12	31
FROM (20-21) (22-23) (24-25)			TO (26-27) (28-29) (30-31)		

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		(3 Card Only) (45-53) AVERAGE	(54-61) MAXIMUM	UNITS	(4 Card Only) (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM				UNITS
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	292,548	416,000	(07)	*****	*****	*****		0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****			ONCE/ MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	33	(30)	0	ONCE/ WEEK	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX	MPN		ONCE/ WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 13 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)						TELEPHONE		DATE		
James M. Harkins MES Director	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						410	729-8350	11	01	24
TYPED OR PRINTED							AREA CODE	NUMBER	YEAR	MONTH	DAY
COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)											

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.
 Address 626 Hanover Pike
 Hampstead, MD 21074

Facility Black and Decker WWTP
 Location 626 Hanover Pike
 Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) MD0001881 (17-19) 201
 PERMIT NUMBER DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires

*** NO DISCHARGE: ***
 NOTE: Read instructions before completing this form

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 10	10	01	TO 10	12	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

State Discharge Permit
 02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (46-53)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	216,150	299,183	(07)	*****	*****	*****	****	0	Measured	Record
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	Record
EFFLUENT GROSS VALUE TETRACHLOROETHYLENE 34475 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/Quarter	Grab
EFFLUENT GROSS VALUE 1,1,1-TRICHLOROETHANE 34506 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/Quarter	Grab
EFFLUENT GROSS VALUE TRICHLOROETHENE 79141 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/Quarter	Grab
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER James M. Harkins MES Director TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 851001 AND 33 U.S.C. 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
		410	729-8350	11	01	25
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)
Quarterly Report. Monitoring was conducted on October 12, 2010.

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(OCTOBER - DECEMBER 2010)



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A10100596
Project Name: Black & Decker WWTP
Receive Date: 10/12/2010
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10100596-01

Sample Date: 10/12/2010 9:28

Site: Black & Decker 001
Client Sample ID:
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
BOD-5	8	mg/L	2	SM 5210 B	10/13/2010 7:30:00 AM	Ythomas
Total Suspended Solids	8	mg/L	4	SM 2540D	10/15/2010 9:08:00 AM	Jsantiago

Sample # A10100596-02

Sample Date: 10/12/2010 9:30

Site: Black & Decker 001
Client Sample ID:
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	< 5.3	mg/L	5.3	EPA 1664	10/18/2010 2:20:00 PM	JMcGuire

Sample # A10100596-03

Sample Date: 10/12/2010 9:32

Site: Black & Decker 001
Client Sample ID:
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	10/23/2010 12:42:00 AM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	10/23/2010 12:42:00 AM	JKozlowski
Trichloroethene	< 1	ug/L	1	EPA 8260B	10/23/2010 12:42:00 AM	JKozlowski

Approved:

Warren Van Andell
Quality Assurance Manager

Reported:

10/27/2010 12:47:05 PM

RDL = Reporting Detection Limit N/A = Not Applicable
Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A10101558
Project Name: Black & Decker WWTP
Receive Date: 10/28/2010
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10101558-01

Sample Date: 10/12/2010 9:10

Site: Black & Decker 101

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Fecal Coliform, MPN	<1.8	MPN/100 mL	N/A	SM 9221 E	10/12/2010 1:40:00 PM	ChesapeakeEnvironmentalLa

Approved:

Warren Van Antwerp
Quality Assurance Manager

Reported:

10/28/2010 3:28:35 PM

RDL = Reporting Detection Limit N/A = Not Applicable
Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



630 Churchmans Road
 Newark, Delaware - 19702
 302-266-9121 • 454-8720 (FAX)
 WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
 259 Najoles Road
 Millersville, MD 21108

Order Number A10110118
 Project Name: Black & Decker WWTP
 Receive Date: 11/2/2010
 Client Code: MES_A
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10110118-01 **Sample Date: 11/2/2010 9:40**

Site: Black & Decker 101
 Client Sample ID:
 Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	3	mg/L	2	SM 5210 B	11/3/2010 7:30:00 AM	Ythomas
Total Suspended Solids	< 4	mg/L	4	SM 2540D	11/5/2010 12:38:00 PM	Kplatt

Sample # A10110118-02 **Sample Date: 11/2/2010 9:42**

Site: Black & Decker 101
 Client Sample ID:
 Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	9.4	mg/L	5.7	EPA 1664	11/5/2010 12:30:00 PM	JMcGuire

Sample # A10110118-03 **Sample Date: 11/2/2010 9:42**

Site: Black & Decker 101
 Client Sample ID:
 Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	11/14/2010 6:37:00 AM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	11/14/2010 6:37:00 AM	JKozlowski
Trichloroethene	< 1	ug/L	1	EPA 8260B	11/14/2010 6:37:00 AM	JKozlowski

Approved: *Keith A. Hausknecht*
 President

Reported: 11/16/2010 3:53:56 PM

RDL = Reporting Detection Limit N/A = Not Applicable
 Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A10111437
Project Name: Black & Decker WWTP
Receive Date: 11/29/2010
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10111437-01

Sample Date: 11/16/2010 9:25

Site: Black & Decker 101

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Fecal Coliform, MPN	<1.8	MPN/100 mL	N/A	SM 9221 E	11/16/2010 2:10:00 PM	ChesapeakeEnvironmentalLa

Approved:

Warren Van Arsdale
Quality Assurance Manager

Reported:

12/1/2010 8:01:34 AM

RDL = Reporting Detection Limit N/A = Not Applicable
Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

Maryland Environmental Services (A)

Order Number: A10120374

Sample # A10120374-01

Sample Date: 12/7/2010 9:15

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

Test	Result	Qualifier	RL	Units	Method	Analysis Date	Analyst
BOD-5	< 1		1	mg/L	SM 5210 B	12/8/2010 7:30:00 AM	Ythomas
Total Suspended Solids	< 1		1	mg/L	SM 2540D	12/10/2010 2:35:00 PM	KPlatt

Sample # A10120374-02

Sample Date: 12/7/2010 9:17

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

Test	Result	Qualifier	RL	Units	Method	Analysis Date	Analyst
Oil and Grease (HEM)	6.1		5.3	mg/L	EPA 1664	12/16/2010 3:15:00 PM	JMcGuire

Sample # A10120374-03

Sample Date: 12/7/2010 9:19

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

Test	Result	Qualifier	RL	Units	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1		1	ug/L	EPA 8260B	12/13/2010 9:08:00 PM	JKozlowski
Tetrachloroethene	< 1		1	ug/L	EPA 8260B	12/13/2010 9:08:00 PM	JKozlowski
Trichloroethene	< 1		1	ug/L	EPA 8260B	12/13/2010 9:08:00 PM	JKozlowski

Approved:

Keith A. Hausknecht
President

Reported:

12/22/2010 7:16:30 AM



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

Maryland Environmental Services (A)

Order Number: A11010120

Sample # A11010120-01

Sample Date: 12/21/2010 9:20

Site: Black & Decker 101

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Qualifier</u>	<u>RL</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Fecal Coliform, MPN	<1.8		N/A	MPN/100 mL	SM 9221 E	12/21/2010 2:10:00 PM	ChesapeakeEnvironmentalL

Approved:

Kerth A. Handwerker
President

Reported:

1/5/2011 1:05:51 PM



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

Maryland Environmental Services (A)

Order Number: A11010445

Sample # A11010445-01

Sample Date: 12/28/2010 9:02

Site: Black & Decker 101

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Qualifier</u>	<u>RL</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Fecal Coliform, MPN	33		N/A	MPN/100 mL	SM 9221 E	12/28/2010 1:20:00 PM	ChesapeakeEnvironmentalL

Approved:

Kent D. Handkrecht

President

Reported:

1/10/2011 9:42:11 AM

Page 2 of 3



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A10100605
Project Name: Black & Decker WWTP
Receive Date: 10/12/2010
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A10100605-01

Sample Date: 10/12/2010 10:06

Site: Black & Decker 201

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	10/23/2010 1:51:00 AM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	10/23/2010 1:51:00 AM	JKozlowski
Trichloroethene	< 1	ug/L	1	EPA 8260B	10/23/2010 1:51:00 AM	JKozlowski

Approved:

Walter Van Arsdale
Quality Assurance Manager

Reported:

10/27/2010 12:47:08 PM

RDL = Reporting Detection Limit N/A = Not Applicable
Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568

APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(NOVEMBER 2010)

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

Job Number: 500-29069-1
Job Description: Black and Decker

For:
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, PA 19380
Attention: Mr. Tom Cornuet



Approved for release.
Richard C Wright
Project Manager II
11/18/2010 9:13 AM

Richard C Wright
Project Manager II
richard.wright@testamericainc.com
11/18/2010

cc: Greg Flasinski

These test results meet all the requirements of NELAC for accredited parameters.

The Lab Certification ID#:
TestAmerica Chicago 100201

All questions regarding this test report should be directed to the TestAmerica Project Manager whose signature appears on this report. All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.

Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.

TestAmerica Laboratories, Inc.
TestAmerica Chicago 2417 Bond Street, University Park, IL 60484
Tel (708) 534-5200 Fax (708) 534-5211 www.testamericainc.com



Job Narrative
500-29069-1

Comments

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

GC/MS VOA

Method(s) 8260B: The following sample(s) was diluted due to the abundance of target analytes: EW-4 (500-29069-2), EW-4 DUP (500-29069-3). Elevated reporting limits (RLs) are provided.

Method(s) 8260B: Surrogate recovery for the following sample was outside the upper control limit: EW-9 (500-29069-8), RFW-7 (500-29069-19). Sample 8 was reanalyzed at a dilution for target compounds. All surrogate recoveries were within limits in the diluted run. Both sets of surrogate data have been reported. Sample 19 had a matrix spike and matrix spike duplicate performed on it. All surrogates were within limits in the MS/MSD.

Method(s) 8260B: The laboratory control sample (LCS) for batch 100040 exceeded control limits for the following analyte: Dichlorodifluoromethane.

Method(s) 8260B: The matrix spike (MS) recovery for 1,2-Dichloropropane was outside control limits. The associated laboratory control sample (LCS) and matrix spike duplicate (MSD) recovery met acceptance criteria.

No other analytical or quality issues were noted.

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-29069-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-29069-1	EW-3				
cis-1,2-Dichloroethene		2.3	1.0	ug/L	8260B
Trichloroethene		85	1.0	ug/L	8260B
Tetrachloroethene		2.5	1.0	ug/L	8260B
500-29069-2	EW-4				
Trichloroethene		1400	50	ug/L	8260B
Tetrachloroethene		27	5.0	ug/L	8260B
500-29069-3FD	EW-4 DUP				
Trichloroethene		1200	50	ug/L	8260B
Tetrachloroethene		22	5.0	ug/L	8260B
500-29069-4	EW-5				
Trichloroethene		160	5.0	ug/L	8260B
Tetrachloroethene		4.6	1.0	ug/L	8260B
500-29069-5	EW-6				
Trichloroethene		8.5	1.0	ug/L	8260B
Tetrachloroethene		17	1.0	ug/L	8260B
500-29069-6	EW-7				
cis-1,2-Dichloroethene		4.0	1.0	ug/L	8260B
Trichloroethene		3.5	1.0	ug/L	8260B
Tetrachloroethene		8.1	1.0	ug/L	8260B
500-29069-7	EW-8				
cis-1,2-Dichloroethene		25	1.0	ug/L	8260B
Trichloroethene		9.6	1.0	ug/L	8260B
Tetrachloroethene		63	1.0	ug/L	8260B
500-29069-8	EW-9				
Trichloroethene		0.92	1.0	ug/L	8260B
Tetrachloroethene		130	10	ug/L	8260B

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-29069-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-29069-9 Tetrachloroethene	EW-10	1.3	1.0	ug/L	8260B
500-29069-12 Trichloroethene	RFW-2A	1.0	1.0	ug/L	8260B
500-29069-13 Trichloroethene	RFW-2B	1.1	1.0	ug/L	8260B
500-29069-14 cis-1,2-Dichloroethene Tetrachloroethene	RFW-3B	2.5 1.1	1.0 1.0	ug/L ug/L	8260B 8260B
500-29069-15 cis-1,2-Dichloroethene Trichloroethene Tetrachloroethene	RFW-4A	0.94 33 27	J 1.0 1.0 1.0	ug/L ug/L ug/L	8260B 8260B 8260B
500-29069-16FD Trichloroethene Tetrachloroethene	RFW-4A DUP	33 26	1.0 1.0	ug/L ug/L	8260B 8260B
500-29069-17 cis-1,2-Dichloroethene Chloroform Trichloroethene Tetrachloroethene	RFW-4B	3.9 1.7 53 85	1.0 1.0 1.0 1.0	ug/L ug/L ug/L ug/L	8260B 8260B 8260B 8260B
500-29069-18 cis-1,2-Dichloroethene Trichloroethene Tetrachloroethene	RFW-6	1.1 4.2 3.8	1.0 1.0 1.0	ug/L ug/L ug/L	8260B 8260B 8260B
500-29069-19 Trichloroethene	RFW-7	4.7	1.0	ug/L	8260B

TestAmerica Chicago

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-29069-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-29069-20	RFW-9				
1,1-Dichloroethene		1.5	1.0	ug/L	8260B
cis-1,2-Dichloroethene		9.7	1.0	ug/L	8260B
Trichloroethene		15	1.0	ug/L	8260B
Tetrachloroethene		3.6	1.0	ug/L	8260B
500-29069-21	RFW-11B				
Trichloroethene		6.6	1.0	ug/L	8260B
500-29069-22	RFW-12B				
cis-1,2-Dichloroethene		2.5	1.0	ug/L	8260B
Trichloroethene		190	10	ug/L	8260B
Tetrachloroethene		14	1.0	ug/L	8260B
500-29069-23	RFW-13				
cis-1,2-Dichloroethene		1.0	1.0	ug/L	8260B
Trichloroethene		3.3	1.0	ug/L	8260B
Tetrachloroethene		16	1.0	ug/L	8260B
500-29069-24	RFW-17				
Benzene		1.4	1.0	ug/L	8260B

METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-29069-1

Description	Lab Location	Method	Preparation Method
Matrix: Water			
VOC	TAL CHI	SW846 8260B	
Purge and Trap	TAL CHI		SW846 5030B

Lab References:

TAL CHI = TestAmerica Chicago

Method References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

METHOD / ANALYST SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-29069-1

Method	Analyst	Analyst ID
SW846 8260B	Drabek, Dave J	DJD
SW846 8260B	Swaney, Garth E	GES

SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-29069-1

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
500-29069-1	EW-3	Water	11/03/2010 1010	11/04/2010 1030
500-29069-2	EW-4	Water	11/03/2010 1220	11/04/2010 1030
500-29069-3FD	EW-4 DUP	Water	11/03/2010 1220	11/04/2010 1030
500-29069-4	EW-5	Water	11/02/2010 1000	11/04/2010 1030
500-29069-5	EW-6	Water	11/02/2010 1650	11/04/2010 1030
500-29069-6	EW-7	Water	11/02/2010 1630	11/04/2010 1030
500-29069-7	EW-8	Water	11/02/2010 1620	11/04/2010 1030
500-29069-8	EW-9	Water	11/02/2010 1610	11/04/2010 1030
500-29069-9	EW-10	Water	11/02/2010 1600	11/04/2010 1030
500-29069-10	RFW-1A	Water	11/02/2010 1015	11/04/2010 1030
500-29069-11	RFW-1B	Water	11/02/2010 1800	11/04/2010 1030
500-29069-12	RFW-2A	Water	11/02/2010 1115	11/04/2010 1030
500-29069-13	RFW-2B	Water	11/02/2010 1130	11/04/2010 1030
500-29069-14	RFW-3B	Water	11/03/2010 0715	11/04/2010 1030
500-29069-15	RFW-4A	Water	11/03/2010 0820	11/04/2010 1030
500-29069-16FD	RFW-4A DUP	Water	11/03/2010 0820	11/04/2010 1030
500-29069-17	RFW-4B	Water	11/03/2010 0945	11/04/2010 1030
500-29069-18	RFW-6	Water	11/03/2010 0700	11/04/2010 1030
500-29069-19	RFW-7	Water	11/02/2010 1350	11/04/2010 1030
500-29069-20	RFW-9	Water	11/03/2010 1225	11/04/2010 1030
500-29069-21	RFW-11B	Water	11/03/2010 1400	11/04/2010 1030
500-29069-22	RFW-12B	Water	11/03/2010 1330	11/04/2010 1030
500-29069-23	RFW-13	Water	11/02/2010 1625	11/04/2010 1030
500-29069-24	RFW-17	Water	11/02/2010 1210	11/04/2010 1030
500-29069-25TB	TRIP BLANK	Water	11/02/2010 0700	11/04/2010 1030

SAMPLE RESULTS

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-3
 Lab Sample ID: 500-29069-1

Date Sampled: 11/03/2010 1010
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/12/2010 1743			
Prep Method: 5030B		Date Prepared: 11/12/2010 1743			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	2.3	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	85	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	2.5	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-3
 Lab Sample ID: 500-29069-1

Date Sampled: 11/03/2010 1010
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	107	%		80 - 129	
Toluene-d8 (Surr)	107	%		80 - 120	
4-Bromofluorobenzene (Surr)	94	%		80 - 115	
Dibromofluoromethane	96	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-4
 Lab Sample ID: 500-29069-2

Date Sampled: 11/03/2010 1220
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/12/2010 1807			
Prep Method: 5030B		Date Prepared: 11/12/2010 1807			
Benzene	<5.0	ug/L	0.85	5.0	5.0
Dichlorodifluoromethane	<5.0	ug/L	1.6	5.0	5.0
Chloromethane	<5.0	ug/L	1.2	5.0	5.0
Vinyl chloride	<5.0	ug/L	1.0	5.0	5.0
Bromomethane	<5.0	ug/L	1.9	5.0	5.0
Chloroethane	<5.0	ug/L	1.8	5.0	5.0
Trichlorofluoromethane	<5.0	ug/L	1.0	5.0	5.0
1,1-Dichloroethene	<5.0	ug/L	0.95	5.0	5.0
Carbon disulfide	<25	ug/L	2.8	25	5.0
Acetone	<25	ug/L	8.0	25	5.0
Methylene Chloride	<10	ug/L	3.4	10	5.0
trans-1,2-Dichloroethene	<5.0	ug/L	1.6	5.0	5.0
1,1-Dichloroethane	<5.0	ug/L	1.2	5.0	5.0
2,2-Dichloropropane	<5.0	ug/L	1.2	5.0	5.0
cis-1,2-Dichloroethene	<5.0	ug/L	1.4	5.0	5.0
Methyl Ethyl Ketone	<25	ug/L	12	25	5.0
Bromochloromethane	<5.0	ug/L	1.8	5.0	5.0
Chloroform	<5.0	ug/L	0.75	5.0	5.0
1,1,1-Trichloroethane	<5.0	ug/L	0.90	5.0	5.0
1,1-Dichloropropene	<5.0	ug/L	0.80	5.0	5.0
Carbon tetrachloride	<5.0	ug/L	1.2	5.0	5.0
1,2-Dichloroethane	<5.0	ug/L	1.2	5.0	5.0
1,2-Dichloropropane	<5.0	ug/L	1.0	5.0	5.0
Dibromomethane	<5.0	ug/L	1.5	5.0	5.0
Bromodichloromethane	<5.0	ug/L	0.95	5.0	5.0
cis-1,3-Dichloropropene	<5.0	ug/L	0.85	5.0	5.0
methyl isobutyl ketone	<25	ug/L	4.2	25	5.0
Toluene	<5.0	ug/L	0.95	5.0	5.0
trans-1,3-Dichloropropene	<5.0	ug/L	1.2	5.0	5.0
1,1,2-Trichloroethane	<5.0	ug/L	1.3	5.0	5.0
Tetrachloroethene	27	ug/L	1.1	5.0	5.0
1,3-Dichloropropane	<5.0	ug/L	0.85	5.0	5.0
2-Hexanone	<25	ug/L	4.0	25	5.0
Dibromochloromethane	<5.0	ug/L	1.2	5.0	5.0
1,2-Dibromoethane	<5.0	ug/L	1.8	5.0	5.0
Chlorobenzene	<5.0	ug/L	0.85	5.0	5.0
1,1,1,2-Tetrachloroethane	<5.0	ug/L	0.95	5.0	5.0
Ethylbenzene	<5.0	ug/L	0.90	5.0	5.0
m&p-Xylene	<10	ug/L	1.6	10	5.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-4
 Lab Sample ID: 500-29069-2

Date Sampled: 11/03/2010 1220
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<5.0	ug/L	1.9	5.0	5.0
Styrene	<5.0	ug/L	0.75	5.0	5.0
Bromoform	<5.0	ug/L	2.1	5.0	5.0
Isopropylbenzene	<5.0	ug/L	1.0	5.0	5.0
Bromobenzene	<5.0	ug/L	1.0	5.0	5.0
1,1,2,2-Tetrachloroethane	<5.0	ug/L	1.4	5.0	5.0
1,2,3-Trichloropropane	<5.0	ug/L	2.4	5.0	5.0
N-Propylbenzene	<5.0	ug/L	0.95	5.0	5.0
2-Chlorotoluene	<5.0	ug/L	0.90	5.0	5.0
1,3,5-Trimethylbenzene	<5.0	ug/L	0.90	5.0	5.0
4-Chlorotoluene	<5.0	ug/L	1.0	5.0	5.0
tert-Butylbenzene	<5.0	ug/L	0.80	5.0	5.0
1,2,4-Trimethylbenzene	<5.0	ug/L	0.70	5.0	5.0
sec-Butylbenzene	<5.0	ug/L	0.80	5.0	5.0
1,3-Dichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
p-Isopropyltoluene	<5.0	ug/L	0.80	5.0	5.0
1,4-Dichlorobenzene	<5.0	ug/L	1.0	5.0	5.0
n-Butylbenzene	<5.0	ug/L	0.90	5.0	5.0
1,2-Dichlorobenzene	<5.0	ug/L	0.85	5.0	5.0
1,2-Dibromo-3-Chloropropane	<10	ug/L	4.8	10	5.0
1,2,4-Trichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
Hexachlorobutadiene	<5.0	ug/L	1.3	5.0	5.0
Naphthalene	<5.0	ug/L	2.2	5.0	5.0
1,2,3-Trichlorobenzene	<5.0	ug/L	1.2	5.0	5.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	102	%	80 - 129
Toluene-d8 (Surr)	109	%	80 - 120
4-Bromofluorobenzene (Surr)	88	%	80 - 115
Dibromofluoromethane	95	%	80 - 124

Method: 8260B Run Type: DL
 Prep Method: 5030B

Date Analyzed: 11/12/2010 1832
 Date Prepared: 11/12/2010 1832

Trichloroethene	1400	ug/L	12	50	50
-----------------	------	------	----	----	----

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	105	%	80 - 129
Toluene-d8 (Surr)	119	%	80 - 120
4-Bromofluorobenzene (Surr)	87	%	80 - 115
Dibromofluoromethane	100	%	80 - 124

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-4 DUP
 Lab Sample ID: 500-29069-3

Date Sampled: 11/03/2010 1220
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/12/2010 1857			
Prep Method: 5030B		Date Prepared: 11/12/2010 1857			
Benzene	<5.0	ug/L	0.85	5.0	5.0
Dichlorodifluoromethane	<5.0	ug/L	1.6	5.0	5.0
Chloromethane	<5.0	ug/L	1.2	5.0	5.0
Vinyl chloride	<5.0	ug/L	1.0	5.0	5.0
Bromomethane	<5.0	ug/L	1.9	5.0	5.0
Chloroethane	<5.0	ug/L	1.8	5.0	5.0
Trichlorofluoromethane	<5.0	ug/L	1.0	5.0	5.0
1,1-Dichloroethene	<5.0	ug/L	0.95	5.0	5.0
Carbon disulfide	<25	ug/L	2.8	25	5.0
Acetone	<25	ug/L	8.0	25	5.0
Methylene Chloride	<10	ug/L	3.4	10	5.0
trans-1,2-Dichloroethene	<5.0	ug/L	1.6	5.0	5.0
1,1-Dichloroethane	<5.0	ug/L	1.2	5.0	5.0
2,2-Dichloropropane	<5.0	ug/L	1.2	5.0	5.0
cis-1,2-Dichloroethene	<5.0	ug/L	1.4	5.0	5.0
Methyl Ethyl Ketone	<25	ug/L	12	25	5.0
Bromochloromethane	<5.0	ug/L	1.8	5.0	5.0
Chloroform	<5.0	ug/L	0.75	5.0	5.0
1,1,1-Trichloroethane	<5.0	ug/L	0.90	5.0	5.0
1,1-Dichloropropene	<5.0	ug/L	0.80	5.0	5.0
Carbon tetrachloride	<5.0	ug/L	1.2	5.0	5.0
1,2-Dichloroethane	<5.0	ug/L	1.2	5.0	5.0
1,2-Dichloropropane	<5.0	ug/L	1.0	5.0	5.0
Dibromomethane	<5.0	ug/L	1.5	5.0	5.0
Bromodichloromethane	<5.0	ug/L	0.95	5.0	5.0
cis-1,3-Dichloropropene	<5.0	ug/L	0.85	5.0	5.0
methyl isobutyl ketone	<25	ug/L	4.2	25	5.0
Toluene	<5.0	ug/L	0.95	5.0	5.0
trans-1,3-Dichloropropene	<5.0	ug/L	1.2	5.0	5.0
1,1,2-Trichloroethane	<5.0	ug/L	1.3	5.0	5.0
Tetrachloroethene	22	ug/L	1.1	5.0	5.0
1,3-Dichloropropane	<5.0	ug/L	0.85	5.0	5.0
2-Hexanone	<25	ug/L	4.0	25	5.0
Dibromochloromethane	<5.0	ug/L	1.2	5.0	5.0
1,2-Dibromoethane	<5.0	ug/L	1.8	5.0	5.0
Chlorobenzene	<5.0	ug/L	0.85	5.0	5.0
1,1,1,2-Tetrachloroethane	<5.0	ug/L	0.95	5.0	5.0
Ethylbenzene	<5.0	ug/L	0.90	5.0	5.0
m&p-Xylene	<10	ug/L	1.6	10	5.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-4 DUP
 Lab Sample ID: 500-29069-3

Date Sampled: 11/03/2010 1220
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<5.0	ug/L	1.9	5.0	5.0
Styrene	<5.0	ug/L	0.75	5.0	5.0
Bromoform	<5.0	ug/L	2.1	5.0	5.0
Isopropylbenzene	<5.0	ug/L	1.0	5.0	5.0
Bromobenzene	<5.0	ug/L	1.0	5.0	5.0
1,1,2,2-Tetrachloroethane	<5.0	ug/L	1.4	5.0	5.0
1,2,3-Trichloropropane	<5.0	ug/L	2.4	5.0	5.0
N-Propylbenzene	<5.0	ug/L	0.95	5.0	5.0
2-Chlorotoluene	<5.0	ug/L	0.90	5.0	5.0
1,3,5-Trimethylbenzene	<5.0	ug/L	0.90	5.0	5.0
4-Chlorotoluene	<5.0	ug/L	1.0	5.0	5.0
tert-Butylbenzene	<5.0	ug/L	0.80	5.0	5.0
1,2,4-Trimethylbenzene	<5.0	ug/L	0.70	5.0	5.0
sec-Butylbenzene	<5.0	ug/L	0.80	5.0	5.0
1,3-Dichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
p-Isopropyltoluene	<5.0	ug/L	0.80	5.0	5.0
1,4-Dichlorobenzene	<5.0	ug/L	1.0	5.0	5.0
n-Butylbenzene	<5.0	ug/L	0.90	5.0	5.0
1,2-Dichlorobenzene	<5.0	ug/L	0.85	5.0	5.0
1,2-Dibromo-3-Chloropropane	<10	ug/L	4.8	10	5.0
1,2,4-Trichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
Hexachlorobutadiene	<5.0	ug/L	1.3	5.0	5.0
Naphthalene	<5.0	ug/L	2.2	5.0	5.0
1,2,3-Trichlorobenzene	<5.0	ug/L	1.2	5.0	5.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	102	%	80 - 129
Toluene-d8 (Surr)	104	%	80 - 120
4-Bromofluorobenzene (Surr)	88	%	80 - 115
Dibromofluoromethane	93	%	80 - 124

Method: 8260B Run Type: DL
 Prep Method: 5030B

Date Analyzed: 11/12/2010 1922
 Date Prepared: 11/12/2010 1922

Trichloroethene	1200	ug/L	12	50	50
-----------------	------	------	----	----	----

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	108	%	80 - 129
Toluene-d8 (Surr)	117	%	80 - 120
4-Bromofluorobenzene (Surr)	89	%	80 - 115
Dibromofluoromethane	99	%	80 - 124

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-5
 Lab Sample ID: 500-29069-4

Date Sampled: 11/02/2010 1000
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/12/2010 1947			
Prep Method: 5030B		Date Prepared: 11/12/2010 1947			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	4.6	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-5
 Lab Sample ID: 500-29069-4

Date Sampled: 11/02/2010 1000
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	103	%		80 - 129	
Toluene-d8 (Surr)	113	%		80 - 120	
4-Bromofluorobenzene (Surr)	84	%		80 - 115	
Dibromofluoromethane	96	%		80 - 124	
Method: 8260B Run Type: DL			Date Analyzed: 11/16/2010 1532		
Prep Method: 5030B			Date Prepared: 11/16/2010 1532		
Trichloroethene	160	ug/L	1.2	5.0	5.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	97	%		80 - 129	
Toluene-d8 (Surr)	109	%		80 - 120	
4-Bromofluorobenzene (Surr)	95	%		80 - 115	
Dibromofluoromethane	97	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-6
 Lab Sample ID: 500-29069-5

Date Sampled: 11/02/2010 1650
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/12/2010 2353			
Prep Method: 5030B		Date Prepared: 11/12/2010 2353			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	8.5	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	17	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-6
 Lab Sample ID: 500-29069-5

Date Sampled: 11/02/2010 1650
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	115	%		80 - 129	
Toluene-d8 (Surr)	116	%		80 - 120	
4-Bromofluorobenzene (Surr)	101	%		80 - 115	
Dibromofluoromethane	106	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-7
 Lab Sample ID: 500-29069-6

Date Sampled: 11/02/2010 1630
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/13/2010 0018			
Prep Method: 5030B		Date Prepared: 11/13/2010 0018			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	4.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	3.5	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	8.1	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-7
 Lab Sample ID: 500-29069-6

Date Sampled: 11/02/2010 1630
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	106	%		80 - 129	
Toluene-d8 (Surr)	111	%		80 - 120	
4-Bromofluorobenzene (Surr)	91	%		80 - 115	
Dibromofluoromethane	100	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-8
 Lab Sample ID: 500-29069-7

Date Sampled: 11/02/2010 1620
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/13/2010 0043			
Prep Method: 5030B		Date Prepared: 11/13/2010 0043			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	25	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	9.6	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	63	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-8
 Lab Sample ID: 500-29069-7

Date Sampled: 11/02/2010 1620
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	107	%		80 - 129	
Toluene-d8 (Surr)	108	%		80 - 120	
4-Bromofluorobenzene (Surr)	89	%		80 - 115	
Dibromofluoromethane	98	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-9
 Lab Sample ID: 500-29069-8

Date Sampled: 11/02/2010 1610
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/13/2010 0108			
Prep Method: 5030B		Date Prepared: 11/13/2010 0108			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	0.92 J	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-9
 Lab Sample ID: 500-29069-8

Date Sampled: 11/02/2010 1610
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0

Surrogate	Result	Qualifier	Unit	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	105		%	80 - 129
Toluene-d8 (Surr)	121	X	%	80 - 120
4-Bromofluorobenzene (Surr)	87		%	80 - 115
Dibromofluoromethane	100		%	80 - 124

Method: 8260B Run Type: DL
 Prep Method: 5030B

Date Analyzed: 11/13/2010 0132
 Date Prepared: 11/13/2010 0132

Tetrachloroethene	130		ug/L	2.2	10	10
Surrogate					Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102		%		80 - 129	
Toluene-d8 (Surr)	109		%		80 - 120	
4-Bromofluorobenzene (Surr)	86		%		80 - 115	
Dibromofluoromethane	97		%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-10
 Lab Sample ID: 500-29069-9

Date Sampled: 11/02/2010 1600
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/13/2010 0157			
Prep Method: 5030B		Date Prepared: 11/13/2010 0157			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	1.3	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: EW-10
 Lab Sample ID: 500-29069-9

Date Sampled: 11/02/2010 1600
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		80 - 129	
Toluene-d8 (Surr)	112	%		80 - 120	
4-Bromofluorobenzene (Surr)	86	%		80 - 115	
Dibromofluoromethane	96	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-1A
 Lab Sample ID: 500-29069-10

Date Sampled: 11/02/2010 1015
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	11/13/2010 0222		
Prep Method: 5030B		Date Prepared:	11/13/2010 0222		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-1A
 Lab Sample ID: 500-29069-10

Date Sampled: 11/02/2010 1015
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	104	%		80 - 129	
Toluene-d8 (Surr)	107	%		80 - 120	
4-Bromofluorobenzene (Surr)	84	%		80 - 115	
Dibromofluoromethane	95	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-1B
 Lab Sample ID: 500-29069-11

Date Sampled: 11/02/2010 1800
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	11/13/2010 0246		
Prep Method: 5030B		Date Prepared:	11/13/2010 0246		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-1B
 Lab Sample ID: 500-29069-11

Date Sampled: 11/02/2010 1800
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	108	%		80 - 129	
Toluene-d8 (Surr)	106	%		80 - 120	
4-Bromofluorobenzene (Surr)	88	%		80 - 115	
Dibromofluoromethane	98	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-2A
 Lab Sample ID: 500-29069-12

Date Sampled: 11/02/2010 1115
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/13/2010 0311			
Prep Method: 5030B		Date Prepared: 11/13/2010 0311			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-2A
 Lab Sample ID: 500-29069-12

Date Sampled: 11/02/2010 1115
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	97	%		80 - 129	
Toluene-d8 (Surr)	114	%		80 - 120	
4-Bromofluorobenzene (Surr)	84	%		80 - 115	
Dibromofluoromethane	94	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-2B
 Lab Sample ID: 500-29069-13

Date Sampled: 11/02/2010 1130
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/13/2010 0336			
Prep Method: 5030B		Date Prepared: 11/13/2010 0336			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	1.1	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-2B
 Lab Sample ID: 500-29069-13

Date Sampled: 11/02/2010 1130
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	100	%		80 - 129	
Toluene-d8 (Surr)	115	%		80 - 120	
4-Bromofluorobenzene (Surr)	85	%		80 - 115	
Dibromofluoromethane	94	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-3B
 Lab Sample ID: 500-29069-14

Date Sampled: 11/03/2010 0715
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/13/2010 0401			
Prep Method: 5030B		Date Prepared: 11/13/2010 0401			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	2.5	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	1.1	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-3B
 Lab Sample ID: 500-29069-14

Date Sampled: 11/03/2010 0715
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	105	%		80 - 129	
Toluene-d8 (Surr)	112	%		80 - 120	
4-Bromofluorobenzene (Surr)	88	%		80 - 115	
Dibromofluoromethane	96	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-4A
 Lab Sample ID: 500-29069-15

Date Sampled: 11/03/2010 0820
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	11/13/2010 0425		
Prep Method: 5030B		Date Prepared:	11/13/2010 0425		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	0.94 J	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	33	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	27	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-4A
 Lab Sample ID: 500-29069-15

Date Sampled: 11/03/2010 0820
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	105	%		80 - 129	
Toluene-d8 (Surr)	107	%		80 - 120	
4-Bromofluorobenzene (Surr)	88	%		80 - 115	
Dibromofluoromethane	98	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-4A DUP
 Lab Sample ID: 500-29069-16

Date Sampled: 11/03/2010 0820
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/13/2010 0450			
Prep Method: 5030B		Date Prepared: 11/13/2010 0450			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	33	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	26	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-4A DUP
 Lab Sample ID: 500-29069-16

Date Sampled: 11/03/2010 0820
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		80 - 129	
Toluene-d8 (Surr)	112	%		80 - 120	
4-Bromofluorobenzene (Surr)	87	%		80 - 115	
Dibromofluoromethane	94	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-4B
 Lab Sample ID: 500-29069-17

Date Sampled: 11/03/2010 0945
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	11/13/2010 0515		
Prep Method: 5030B		Date Prepared:	11/13/2010 0515		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	3.9	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	1.7	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	53	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	85	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-4B
 Lab Sample ID: 500-29069-17

Date Sampled: 11/03/2010 0945
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		80 - 129	
Toluene-d8 (Surr)	113	%		80 - 120	
4-Bromofluorobenzene (Surr)	83	%		80 - 115	
Dibromofluoromethane	95	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-6
 Lab Sample ID: 500-29069-18

Date Sampled: 11/03/2010 0700
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/13/2010 0540			
Prep Method: 5030B		Date Prepared: 11/13/2010 0540			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	1.1	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	4.2	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	3.8	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-6
 Lab Sample ID: 500-29069-18

Date Sampled: 11/03/2010 0700
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		80 - 129	
Toluene-d8 (Surr)	116	%		80 - 120	
4-Bromofluorobenzene (Surr)	86	%		80 - 115	
Dibromofluoromethane	100	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-7
 Lab Sample ID: 500-29069-19

Date Sampled: 11/02/2010 1350
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	11/13/2010 0605		
Prep Method: 5030B		Date Prepared:	11/13/2010 0605		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	4.7	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-7
 Lab Sample ID: 500-29069-19

Date Sampled: 11/02/2010 1350
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	105	%		80 - 129	
Toluene-d8 (Surr)	121	X %		80 - 120	
4-Bromofluorobenzene (Surr)	86	%		80 - 115	
Dibromofluoromethane	101	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-9
 Lab Sample ID: 500-29069-20

Date Sampled: 11/03/2010 1225
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	11/16/2010	1553	
Prep Method: 5030B		Date Prepared:	11/16/2010	1553	
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	1.5	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	9.7	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	15	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	3.6	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-9
 Lab Sample ID: 500-29069-20

Date Sampled: 11/03/2010 1225
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	103	%		80 - 129	
Toluene-d8 (Surr)	112	%		80 - 120	
4-Bromofluorobenzene (Surr)	100	%		80 - 115	
Dibromofluoromethane	104	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-11B
 Lab Sample ID: 500-29069-21

Date Sampled: 11/03/2010 1400
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/16/2010 1616			
Prep Method: 5030B		Date Prepared: 11/16/2010 1616			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	6.6	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-11B
 Lab Sample ID: 500-29069-21

Date Sampled: 11/03/2010 1400
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	103	%		80 - 129	
Toluene-d8 (Surr)	110	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		80 - 115	
Dibromofluoromethane	99	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-12B
 Lab Sample ID: 500-29069-22

Date Sampled: 11/03/2010 1330
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	11/16/2010	1638	
Prep Method: 5030B		Date Prepared:	11/16/2010	1638	
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	2.5	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	14	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-12B
 Lab Sample ID: 500-29069-22

Date Sampled: 11/03/2010 1330
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	99	%	80 - 129
Toluene-d8 (Surr)	108	%	80 - 120
4-Bromofluorobenzene (Surr)	95	%	80 - 115
Dibromofluoromethane	94	%	80 - 124

Method: 8260B Run Type: DL

Date Analyzed: 11/16/2010 1659

Prep Method: 5030B

Date Prepared: 11/16/2010 1659

Trichloroethene	190	ug/L	2.4	10	10
-----------------	-----	------	-----	----	----

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	96	%	80 - 129
Toluene-d8 (Surr)	104	%	80 - 120
4-Bromofluorobenzene (Surr)	95	%	80 - 115
Dibromofluoromethane	97	%	80 - 124

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-13
 Lab Sample ID: 500-29069-23

Date Sampled: 11/02/2010 1625
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/16/2010 1721			
Prep Method: 5030B		Date Prepared: 11/16/2010 1721			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	3.3	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	16	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-13
 Lab Sample ID: 500-29069-23

Date Sampled: 11/02/2010 1625
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	103	%		80 - 129	
Toluene-d8 (Surr)	107	%		80 - 120	
4-Bromofluorobenzene (Surr)	104	%		80 - 115	
Dibromofluoromethane	99	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-17
 Lab Sample ID: 500-29069-24

Date Sampled: 11/02/2010 1210
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed:	11/16/2010	1742	
Prep Method: 5030B		Date Prepared:	11/16/2010	1742	
Benzene	1.4	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: RFW-17
 Lab Sample ID: 500-29069-24

Date Sampled: 11/02/2010 1210
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		80 - 129	
Toluene-d8 (Surr)	108	%		80 - 120	
4-Bromofluorobenzene (Surr)	100	%		80 - 115	
Dibromofluoromethane	101	%		80 - 124	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: TRIP BLANK
 Lab Sample ID: 500-29069-25

Date Sampled: 11/02/2010 0700
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 11/16/2010 1805			
Prep Method: 5030B		Date Prepared: 11/16/2010 1805			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0 *	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-29069-1

Client Sample ID: TRIP BLANK
 Lab Sample ID: 500-29069-25

Date Sampled: 11/02/2010 0700
 Date Received: 11/04/2010 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		80 - 129	
Toluene-d8 (Surr)	106	%		80 - 120	
4-Bromofluorobenzene (Surr)	98	%		80 - 115	
Dibromofluoromethane	99	%		80 - 124	

DATA REPORTING QUALIFIERS

Client: Weston Solutions, Inc.

Job Number: 500-29069-1

<u>Lab Section</u>	<u>Qualifier</u>	<u>Description</u>
GC/MS VOA	*	LCS or LCSD exceeds the control limits
	F	MS or MSD exceeds the control limits
	J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
	X	Surrogate is outside control limits



QUALITY CONTROL RESULTS

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-29069-1

QC Association Summary

Lab Sample ID	Client Sample ID	Report Basis	Client Matrix	Method	Prep Batch
GC/MS VOA					
Analysis Batch:500-99699					
LCS 500-99699/5	Lab Control Sample	T	Water	8260B	
MB 500-99699/4	Method Blank	T	Water	8260B	
500-29069-1	EW-3	T	Water	8260B	
500-29069-2	EW-4	T	Water	8260B	
500-29069-2DL	EW-4	T	Water	8260B	
500-29069-3FD	EW-4 DUP	T	Water	8260B	
500-29069-3FDDL	EW-4 DUP	T	Water	8260B	
500-29069-4	EW-5	T	Water	8260B	
Analysis Batch:500-99737					
LCS 500-99737/8	Lab Control Sample	T	Water	8260B	
MB 500-99737/7	Method Blank	T	Water	8260B	
500-29069-5	EW-6	T	Water	8260B	
500-29069-6	EW-7	T	Water	8260B	
500-29069-7	EW-8	T	Water	8260B	
500-29069-8	EW-9	T	Water	8260B	
500-29069-8DL	EW-9	T	Water	8260B	
500-29069-9	EW-10	T	Water	8260B	
500-29069-10	RFW-1A	T	Water	8260B	
500-29069-11	RFW-1B	T	Water	8260B	
500-29069-12	RFW-2A	T	Water	8260B	
500-29069-13	RFW-2B	T	Water	8260B	
500-29069-14	RFW-3B	T	Water	8260B	
500-29069-15	RFW-4A	T	Water	8260B	
500-29069-16FD	RFW-4A DUP	T	Water	8260B	
500-29069-17	RFW-4B	T	Water	8260B	
500-29069-18	RFW-6	T	Water	8260B	
500-29069-19	RFW-7	T	Water	8260B	
500-29069-19MS	Matrix Spike	T	Water	8260B	
500-29069-19MSD	Matrix Spike Duplicate	T	Water	8260B	
Analysis Batch:500-100040					
LCS 500-100040/25	Lab Control Sample	T	Water	8260B	
MB 500-100040/5	Method Blank	T	Water	8260B	
500-29069-4DL	EW-5	T	Water	8260B	
500-29069-20	RFW-9	T	Water	8260B	
500-29069-21	RFW-11B	T	Water	8260B	
500-29069-22	RFW-12B	T	Water	8260B	
500-29069-22DL	RFW-12B	T	Water	8260B	
500-29069-23	RFW-13	T	Water	8260B	
500-29069-24	RFW-17	T	Water	8260B	
500-29069-25TB	TRIP BLANK	T	Water	8260B	

TestAmerica Chicago

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-29069-1

QC Association Summary

Lab Sample ID	Client Sample ID	Report Basis	Client Matrix	Method	Prep Batch
---------------	------------------	--------------	---------------	--------	------------

Report Basis
T = Total