

Quarterly Groundwater Monitoring Report

Prepared for

Stanley Black & Decker Inc.

Hampstead, Maryland

January 2013

Prepared by

WESTON SOLUTIONS, INC.

West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 4th Quarter 2012.....	2-2
Table 2-2 Groundwater Elevation Data – 4th Quarter 2012.....	2-3
Table 2-3 Effluent Characteristics Summary – 4th Quarter 2012.....	2-4
Table 2-4 Summary of Groundwater Analytical Results - November 2012	2-5
Table 3-1 Treatment System Maintenance Activities – 4th Quarter 2012	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of October through December 2012.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of October through December 2012, the extraction wells were pumping at an average combined rate of approximately 173 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of October through December 2012 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of October through December 2012, approximately 12.7 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (83.1 %) and tetrachloroethene (PCE) (16.9 %). Analytical results of the groundwater collected from the air stripper for the period of October through December 2012 are included in Appendix C.

A summary of the analytical results from the fourth quarter (November 2012) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 4th Quarter 2012
Stanley Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
October 2012	7,327,763
November 2012	7,047,445
December 2012	7,216,348

Table 2-2
Groundwater Elevation Data - 4th Quarter 2012
Stanley Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV.	TOTAL DEPTH	10/10/2012		11/1/2012		12/28/2012	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NC	DRY	NC	DRY	NC
EW-2	849.21	110	93.14	756.07	93.01	756.20	92.88	756.33
EW-3	846.64	118	83.60	763.04	85.95	760.69	85.06	761.58
EW-4	858.01	97.5	PC	NC	PC	NC	PC	NC
EW-5	864.17	98	90.19	773.98	90.22	773.95	89.77	774.40
EW-6	831.98	115	103.00	728.98	103.00	728.98	103.00	728.98
EW-7	818.38	78	73.00	745.38	73.00	745.38	73.00	745.38
EW-8	811.13	98	96.00	715.13	96.00	715.13	96.00	715.13
EW-9	811.35	141	103.50	707.85	103.00	708.35	103.00	708.35
EW-10	807.74	INA	56.11	751.63	55.88	751.86	55.14	752.60
RFW-1A	864.37	78	50.51	813.86	51.51	812.86	51.43	812.94
RFW-1B	864.23	200	50.55	813.68	51.62	812.61	51.44	812.79
RFW-2A	857.41	35	15.12	842.29	13.33	844.08	14.71	842.70
RFW-2B	857.73	75	15.49	842.24	13.45	844.28	15.02	842.71
RFW-3B	839.21	153	31.13	808.08	30.17	809.04	32.41	806.80
RFW-4A	830.37	62	37.44	792.93	37.01	793.36	37.12	793.25
RFW-4B	830.37	120	37.30	793.07	36.81	793.56	36.84	793.53
RFW-5A	817.50	30	DRY	NC	DRY	NC	DRY	NC
RFW-6	785.04	120	2.87	782.17	2.94	782.10	3.67	781.37
RFW-7	805.14	29	6.90	798.24	4.63	800.51	7.55	797.59
RFW-8	860.07	56	DRY	NC	DRY	NC	DRY	NC
RFW-9	862.02	49	26.17	835.85	25.85	836.17	27.11	834.91
RFW-10	852.06	58	DRY	NC	DRY	NC	DRY	NC
RFW-11A	849.32	72	Damaged	NC	Damaged	NC	Damaged	NC
RFW-11B	849.62	116	63.28	786.34	63.41	786.21	63.06	786.56
RFW-12B	844.87	264	50.04	794.83	50.46	794.41	50.14	794.73
RFW-13	849.11	150	61.44	787.67	62.98	786.13	60.86	788.25
RFW-14B	812.39	281	52.03	760.36	52.09	760.30	51.89	760.50
RFW-16	856.14	41	DRY	NC	DRY	NC	DRY	NC
RFW-17	834.66	60.5	25.83	808.83	27.13	807.53	26.20	808.46
RFW-20	842.49	142	34.46	808.03	35.57	806.92	34.13	808.36
RFW-21	832.65	102	20.94	811.71	21.61	811.04	21.41	811.24
PH-7	805.94	89	32.40	773.54	29.53	776.41	29.41	776.53
PH-9	814.94	98	52.26	762.68	51.94	763.00	51.87	763.07
PH-11	820.68	78	49.53	771.15	48.26	772.42	48.73	771.95
PH-12	828.35	87	52.75	775.60	50.98	777.37	51.60	776.75
B-3	803.02	83	10.40	792.62	10.47	792.55	10.83	792.19
Amoco	842.29	INA	NA	NC	NA	NC	NA	NC
Hamp. Town #22	804.96	INA	1.58	803.38	2.19	802.77	0.79	804.17
Pembroke #1	INA	INA	11.43	NC	11.33	NC	11.12	NC
Pembroke #2	INA	INA	Damaged	NC	Damaged	NC	Damaged	NC
N. Houcks. Rd.	INA	INA	9.89	NC	9.53	NC	9.74	NC
E. Century St.	INA	INA	19.22	NC	19.19	NC	19.21	NC
Lwr. Beckleys. Rd.	INA	INA	56.44	NC	55.49	NC	55.77	NC

NA - Not Available/Not Accessible
NC - Not Calculable
INA - Information not available
PC - Pump Cycles

Table 2-3
Effluent Characteristics Summary - 4th Quarter 2012
Black & Decker
Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				October 2012	November 2012	December 2012	
001	FLOW	average	MGD	NA	0.265	0.243	0.222
		maximum	MGD	NA	1.155	0.980	1.128
	1,1,1-Trichloroethane		ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene		ug/l	5	< 1	< 1	< 1
	Trichloroethylene		ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		monthly average	mg/l	10	< 5	< 5	< 5
	pH	minimum	STD	6.0	6.7	7.0	6.7
		maximum	STD	8.5	7.5	7.8	7.9
	BOD		mg/l	15	5.0	0.0	5.0
TSS	maximum	mg/l	30	5.0	4.0	< 1	
	monthly average	mg/l	20	5.0	4.0	< 1	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.220	0.219	0.199
		maximum	MGD	NA	0.265	0.271	0.277
	Fecal Coliform		MPN/100ml	200	5.0	5.0	1.0
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.235
		maximum	MGD	NA	NR	NR	0.284
	1,1,1-Trichloroethane		ug/l	NA	NR	NR	< 1
	Tetrachloroethylene		ug/l	NA	NR	NR	< 1
	Trichloroethylene		ug/l	NA	NR	NR	< 1

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

Table 2-4

Summary of Groundwater Analytical Results - November 2012

Stanley Black & Decker

Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-8 (DUP)	EW-9	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	0.5 J	0.8 J	0.8 J	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3.5	1.7	1 U	1 U	1 U	5.4	24	24	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	200	48	930	110	6.4	3.8	8	8.2	0.6	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	45	1.5	19	3.4	12	8.8	66	67	110	0.6 J
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

NS = Not Sampled

Table 2-4

Summary of Groundwater Analytical Results - November 2012
Stanley Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	NS	2 U	2 U	NS	2 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	0.7 J	0.8 J	0.8 J	4.1	NS	0.8 J	1 U	NS	7.1	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	0.7 J	0.8 J	1.1	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	0.7	0.6	1 U	29	29	34	NS	2	0.5	NS	5.5	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	0.2 J	1 U	1 U	1 U	1 U	NS	1 U	0.2 J	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	0.5 J	20	20	64	NS	2.3	1 U	NS	2.7	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicate sample
NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
J = Indicates an estimated value.

Table 2-4

Summary of Groundwater Analytical Results - November 2012
Stanley Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	USEPA drinking water method 524.2				
												RFW-20	RFW-21	Town #22	Town #23	Trip Blank
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	NS	2 U	ABD	ABD	ABD	2 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	NA	NA	NA	NA	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	1.8	1 J	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trichloroethene	ug/L	NS	2.8	73	2.7	NS	1 U	ABD	ABD	ABD	1 U	0.5	0.5 U	0.5 U	0.5 U	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	1.1	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	1 U	5	17	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.34 J	0.5 U	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	0.1 J	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division.
Samples from all of the other wells are analyzed with USEPA Method 8260.

NS = Not sampled

U = Compound was analyzed but not detected.

ABD = Well has been abandoned

analytical data package is included in Appendix D.

As found in earlier sampling events at the Stanley Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from wells RFW-4B and EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (October through December 2012) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 4th Quarter 2012
Stanley Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Nov-12	Alarm at EW-7. Found that the heating elements were bad. Replaced heating elements, the well is back online.
Dec-12	New wet well probes were installed, system back online.
Dec-12	EW-6 tripped off. It was found that the pump motor was locked up.
Dec-12	EW-6 pump motor was replaced the pump is back online. The pump was off for less than 24 hours.

4. RECOMMENDATIONS

For the reporting period of October through December 2012, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(OCTOBER – DECEMBER 2012)

Superintendent: Earle Villarreal Certification # 1017

Black & Decker WTP

PWSID # 106 0004

County: Carroll

Month: October

Operated by

Address: BTR CAPITAL GROUP, Hampstead, MD 21073

Maryland Environmental Service

625 Hanover Pike, Hampstead, Carroll County, Maryland

Year: 2012

GENERAL			(DOMESTIC WATER)				CHEMICAL					MONITORING		DISTRIBUTION			RAW WATER		Comments	
Date	Day	Weather	Flow meter reading 0	MGD Total FQIR	pH P.O.E	Free Cl2	Na2CO3 Level	Na2CO3 (gpd)	NaOCl Level	NaOCl (gpd)	VOC'S (ppb)	Bacti Pos/Neg	pH su	TRC mg/l	DISTRIBUTION LOCATION	Operator Initials	pH su	TOTAL RAW WATER WELL (mgd)		
1	Mon	Clear	0	0.0025	7.6	1.42	33.00	1.00	53.00	0.00			7.24	1.23	Admin 1st FI	GD		0.250941		
2	Tue	Rain	0	0.0049	7.7	1.43	31.00	2.00	53.00	0.00						GD		0.225202		
3	Wed	Cloudy	0	0.0078	8.2	1.45	28.00	3.00	53.00	0.00			8.17	1.31	Loading Dock	DJ		0.260285		
4	Thur	Cloudy	0	0.0028	7.6	1.26	27.00	1.00	53.00	0.00						DJ	5.08	0.236611		
5	Fri	Clear	0	0.0051	8.0	1.15	25.00	2.00	53.00	0.00			7.7	1.01	Admin 2nd FI	GD		0.222772		
6	Sat	Cloudy	0	0.0025	7.4	1.20	25.00	1.00	53.00	0.00						AP		0.243717		
7	Sun	Rain	0	0.0028	7.3	1.10	24.00	1.00	53.00	0.00						AP		0.230763		
8	Mon	Cloudy	0	0.0027	7.6	1.12	22.00	2.00	53.00	0.00			7.4	1.05	Loading Dock	PP		0.251608		
9	Tue	Clear	0	0.0035	7.2	1.03	51.00	1.00	53.00	0.00						GD		0.225750		
10	Wed	Clear	0	0.0052	7.2	1.10	50.00	1.00	53.00	0.00			7.4	0.85	Loading Dock	JE		0.225961		
11	Thur	Clear	0	0.0057	7.3	1.19	48.00	2.00	53.00	0.00						PP		0.260892		
12	Fri	Clear	0	0.0034	7.6	1.12	47.00	1.00	53.00	0.00			7.5	1.08	Loading Dock	JE	6.56	0.214155		
13	Sat	Clear	0	0.0029	8.7	1.03	46.00	1.00	53.00	0.00						MW		0.253574		
14	Sun	Cloudy	0	0.0023	7.4	1.01	45.00	1.00	53.00	0.00						MW		0.222175		
15	Mon	Rain	0	0.0024	7.4	0.62	42.00	3.00	53.00	0.00						DJ		0.250698		
16	Tue	Clear	0	0.0059	8.8	1.81	39.00	3.00	53.00	0.00			8.3	1.22	Admin 1st FI	DJ		0.238241		
17	Wed	Clear	0	0.0050	8.0	1.28	37.00	2.00	53.00	0.00			8.1	1.26	Admin 2nd FI	DJ		0.230007		
18	Thur	Clear	0	0.0029	7.4	1.16	36.00	1.00	53.00	0.00						DJ	5.74	0.219760	Nitrate 4.20	
19	Fri	Cloudy	0	0.0055	8.0	1.33	34.00	2.00	53.00	0.00			7.9	1.06	Loading Dock	DJ		0.252101		
20	Sat	Clear	0	0.0026	8.1	1.23	33.00	1.00	53.00	0.00						DJ		0.231024		
21	Sun	Clear	0	0.0027	8.0	1.12	32.00	1.00	53.00	0.00						DJ		0.224256		
22	Mon	Clear	0	0.0025	7.6	1.01	31.00	1.00	53.00	0.00			7.3	0.96	Admin 1st FI	GD		0.235220		
23	Tue	Rain	0	0.0036	8.2	0.90	30.00	1.00	53.00	0.00						GD		0.218469		
24	Wed	Cloudy	0	0.0049	7.4	1.02	28.00	2.00	53.00	0.00						AP		0.243304		
25	Thur	Fog	0	0.0045	7.6	0.93	27.00	1.00	53.00	0.00			7.4	0.75	Loading Dock	DJ	5.72	0.234995		
26	Fri	Cloudy	0	0.0079	7.9	1.56	24.00	3.00	53.00	0.00			7.8	1.23	Admin 2nd FI	DJ		0.255816		
27	Sat	Cloudy	0	0.0025	7.6	1.34	23.00	1.00	53.00	0.00						AP		0.236780		
28	Sun	Cloudy	0	0.0023	7.2	1.22	22.00	1.00	53.00	0.00						AP		0.221526		
29	Mon	Rain	0	0.0019	8.7	1.28	21.00	1.00	53.00	0.00			7.1	1.14	Admin 1st FI	PP		0.217817		
30	Tue	Rain	0	0.0008	7.3	1.17	20.00	1.00	53.00	0.00						DJ		0.239216		
31	Wed	Rain	0	0.0053	7.6	1.53	37.00	3.00	53.00	0.00			7.4	1.17	Loading Dock	DJ	5.26	0.254127		
Total				0.1173	239.3	37.12	1018.0	48.00	1643.0	0.00	0.0	0.0	107	15					7.327763	
Average				0.0038	7.72	1.20	32.84	1.55	53.00	0.00	0.0	0.0	7.62	1.09					0.236379	
Minimum				0.0008	7.16	0.62	20.00	1.00	53.00	0.00	0.0	0.0	7.14	0.75					0.214155	Central MOR
Maximum				0.0079	8.76	1.81	51.00	3.00	53.00	0.00	0.0	0.0	8.27	1.31					0.260892	02/02/12

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 626 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrance Jones 0763, Gary Dickerson 0782

Permit Number: 02-DP-0022
Superintendent: Earle Villarreal

Certification # 1017

Month: November
Year: 2012

Date	Appearance	Final Effluent outfall 001										Outfall 101					Outfall 201				Operator
		Discharge MGD	pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	Discharge mgd	
1	Clear	0.30800	7.10	0.00							0.206000		0.0	1.0	1.0	5.0				0.237123	Djones
2	Clear	0.18900									0.250000	< 1.8	0.0	1.0	1.0	5.0	< 0.4	< 0.2	< 0.3	0.187384	Djones
3	Clear	0.19600									0.208000		0.0	1.0	1.0	5.0				0.284412	Mwhitt
4	Clear	0.15200									0.199000		0.0	1.0	1.0	5.0				0.229958	Mwhitt
5	Clear	0.16100									0.211000		0.0	1.0	1.0	5.0				0.245468	Djones
6	Clear	0.12800	6.97	0.00	< 0.31	< 0.26	< 0.34	< 2.0	4.0	< 5.0	0.216000	< 1.8	0.0	1.0	1.0	5.0				0.221525	Djones
7	Clear	0.12300									0.202000		0.0	1.0	1.0	5.0				0.251772	Djones
8	Clear	0.12400	7.15	0.00							0.220000		0.0	1.0	1.0	5.0				0.215510	Djones
9	Clear	0.10400									0.225000		0.0	1.0	1.0	5.0				0.253116	Djones
10	Clear	0.12000									0.202000		0.0	1.0	1.0	5.0				0.230258	Djones
11	Clear	0.11200									0.205000		0.0	1.0	1.0	5.0				0.228747	Djones
12	Clear	0.12100									0.202000		0.0	1.0	1.0	5.0				0.232649	Jelliott
13	Clear	0.46400	7.21	0.00							0.184000		0.0	1.0	1.0	5.0				0.229450	Jelliott
14	Clear	0.29100									0.226000	< 1.8	0.0	1.0	1.0	5.0				0.254852	Djones
15	Clear	0.14800	6.95	0.00							0.216000		0.0	1.0	1.0	5.0				0.233099	Djones
16	Clear	0.12700									0.216000		0.0	1.0	1.0	5.0				0.234966	Djones
17	Clear	0.12300									0.202000		0.0	1.0	1.0	5.0				0.226444	Aphillips
18	Clear	0.91000									0.190000		0.0	1.0	1.0	5.0				0.229848	Aphillips
19	Clear	0.11000									0.200000		0.0	1.0	1.0	5.0				0.249417	Djones
20	Clear	0.95000	7.10	0.00							0.266000	< 1.8	0.0	1.0	1.0	5.0				0.240668	Djones
21	Clear	0.14700	7.45	0.00							0.205000		0.0	1.0	1.0	5.0				0.228200	Djones
22	Clear	0.13700									0.263000		0.0	1.0	1.0	5.0				0.189039	Jelliott
23	Clear	0.13400									0.271000		0.0	1.0	1.0	5.0				0.254671	Jelliott
24	Clear	0.15300									0.227000		0.0	1.0	1.0	5.0				0.257712	Mwhitt
25	Clear	0.10700									0.227000		0.0	1.0	1.0	5.0				0.218615	Mwhitt
26	Clear	0.98000	7.20	0.00							0.213000		0.0	1.0	1.0	5.0				0.253601	Djones
27	Clear	0.11700									0.239000	4.5	0.0	1.0	1.0	5.0				0.215160	Djones
28	Clear	0.18900									0.202000		0.0	1.0	1.0	5.0				0.250543	Djones
29	Clear	0.17800									0.230000		0.0	1.0	1.0	5.0				0.212002	Djones
30	Clear	0.18800	7.83	0.00							0.250000		0.0	1.0	1.0	5.0				0.251236	Djones
31																					
Total		7.29100									6.573000									7.047445	
Average		0.24303	7.2	<0.10	0	0	0	2	4	0	0.219100	2	0.0	1.0	1.0	5.0	0	0	0	0.234915	
Minimum		0.10400	7.0	0.00	0	0	0	2	4	0	0.184000	1	0.0	1.0	1.0	5.0	0	0	0	0.187384	
Maximum		0.98000	7.8	<0.10	0	0	0	0	4	0	0.271000	5	0.0	1.0	1.0	5.0	0	0	0	0.284412	MOR 5-11-09

COMMENTS:

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:

Facility: BTR Capital Group

Permit Number: 02-DP-0022

Month: December

Maryland Environmental Service

Address: 626 Hanover Pike, Hampstead Maryland

Superintendent: Earle Villarreal

Certification # 1017

Year: 2012

259 Najoles Road, Millersville MD

Additional Op's & cert # - Dorrance Jones 0763, Gary Dickerson 0782, Anthony Phillips 3001, James Elliott 3738, Martin Whitt 0666

Date	Appearance	Final Effluent outfall 001									Outfall 101					Outfall 201			Operator		
		Discharge MGD	pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l		Trichloroethene ug/l	Discharge mgd
1	Clear	0.18800								0.219000		0.0	1.0	1.0	5.0				0.227024	Djones	
2	Clear	0.16300								0.234000		0.0	1.0	1.0	5.0				0.225559	Djones	
3	Clear	0.09700								0.224000		0.0	1.0	1.0	5.0				0.235698	Jelliott	
4	Clear	0.05300	7.91	0.00						0.235000	< 1.8	0.0	1.0	1.0	5.0				0.227945	Jelliott	
5	Clear	0.07700								0.200000		0.0	1.0	1.0	5.0				0.216163	Djones	
6	Clear	0.07100	7.30	0.00						0.245000		0.0	1.0	1.0	5.0				0.206937	Djones	
7	Clear	0.10300								0.249000		0.0	1.0	1.0	5.0				0.247664	Djones	
8	Clear	0.18200								0.229000		0.0	1.0	1.0	5.0				0.237983	APhillips	
9	Clear	0.20300								0.219000		0.0	1.0	1.0	5.0				0.237301	APhillips	
10	Clear	0.29100	7.70	0.00						0.203000		0.0	1.0	1.0	5.0				0.249088	Djones	
11	Clear	0.17700			< 1.00	< 1.00	< 1.00	5.0	< 4.0	< 5.0	0.257000	< 1.8	0.0	1.0	1.0	5.0			0.234651	Djones	
12	Clear	0.14200	7.47	0.00						0.237000		0.0	1.0	1.0	5.0				0.232960	Djones	
13	Clear	0.14000								0.251000		0.0	1.0	1.0	5.0				0.217379	Djones	
14	Clear	0.12300								0.277000		0.0	1.0	1.0	5.0				0.246248	Djones	
15	Clear	0.13600								0.236000		0.0	1.0	1.0	5.0				0.238465	Mwhitt	
16	Clear	0.12700								0.220000		0.0	1.0	1.0	5.0				0.224579	Mwhitt	
17	Clear	0.13800								0.229000		0.0	1.0	1.0	5.0				0.240409	Djones	
18	Clear	0.17700	7.20	0.00						0.274000	< 1.8	0.0	1.0	1.0	5.0				0.238276	Djones	
19	Clear	0.11500								0.260000		0.0	1.0	1.0	5.0				0.205794	Djones	
20	Clear	0.12300	6.95	0.00						0.273000		0.0	1.0	1.0	5.0				0.240581	Djones	
21	Clear	0.84000								0.277000		0.0	1.0	1.0	5.0				0.251868	Djones	
22	Clear	0.28200								0.253000		0.0	1.0	1.0	5.0				0.229096	Djones	
23	Clear	0.15600								0.263000		0.0	1.0	1.0	5.0				0.226153	Djones	
24	Clear	0.17800	6.97	0.00						0.214000		0.0	1.0	1.0	5.0				0.238933	Jelliott	
25	Clear	0.21300								0.175000		0.0	1.0	1.0	5.0				0.190946	Jelliott	
26	Clear	0.14100								0.009000		0.0	1.0	1.0	5.0				0.263114	Gdickerson	
27	Clear	1.27800	6.92	0.00						0.000000	< 1.8	0.0	1.0	1.0	5.0				0.241160	Gdickerson	
28	Clear	0.28700								0.003200		0.0	1.0	1.0	5.0				0.235903	Gdickerson	
29	Clear	0.19700								0.000000		0.0	1.0	1.0	5.0				0.234110	APhillips	
30	Clear	0.31400								0.191000		0.0	1.0	1.0	5.0				0.225910	APhillips	
31	Clear	0.17800	6.65	0.00						0.000000		0.0	1.0	1.0	5.0				0.248451	Djones	
Total		6.89000								6.156200									7.216348		
Average		0.22226	7.2	<0.10	0	0	0	5	0	0	0.198587	1	0.0	1.0	1.0	5.0	#DIV/0!	#DIV/0!	#####	0.232785	
Minimum		0.05300	6.7	0.00	0	0	0	5	0	0	0.000000	1	0.0	1.0	1.0	5.0	0	0	0	0.190946	
Maximum		1.27800	7.9	<0.10	0	0	0	5	0	0	0.277000	1	0.0	1.0	1.0	5.0	0	0	0	0.263114	MOR 5-11-09

COMMENTS:

**APPENDIX B
DISCHARGE MONITORING REPORTS
(OCTOBER - DECEMBER 2012)**

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc
 Address 626 Hanover Pike
 Hampstead, MD 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
12	10	01	12	10	31
FROM (20-21) (22-23) (24-25)			TO (26-27) (28-29) (30-31)		

State Discharge Permit

02-DP-0022

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS				
BOD, 5-DAY (20 DEG. C)	MEASUREMENT	*****	*****	****	*****	*****	5	(19)	0	ONCE/MONTH	GRAB	
00310 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/MONTH	GRAB	
EFFLUENT GROSS VALUE	MEASUREMENT	*****	*****	****	6.7	*****	7.5	(12)	0	TWICE/WEEK	GRAB	
pH	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY MN	*****	8.5 DAILY MX	SU		TWICE/WEEK	GRAB	
00400 1 0 0	MEASUREMENT	*****	*****	****	*****	5	5	(19)	0	ONCE/MONTH	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA AVG.	30 DAILY MX	MG/L		ONCE/MONTH	GRAB	
SOLIDS, TOTAL SUSPENDED	MEASUREMENT	265,000	1,155,000	(07)	*****	*****	*****	****	0	Measured	RECORD	
00530 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	RECORD	
EFFLUENT GROSS VALUE	MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/MONTH	GRAB	
CHLORINE, TOTAL RESIDUAL	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG.	0.019 DAILY MX	MG/L		ONCE/MONTH	GRAB	
00660 1 0 0	MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB	
TETRACHLOROETHYLENE	MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB	
34475 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB	
EFFLUENT GROSS VALUE	MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB	
1,1,1-TRICHLOROETHANE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB	
34506 1 0 0	MEASUREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB	
EFFLUENT GROSS VALUE	NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE NUMBER		DATE		
		James M. Harkins MES Director						410 729-8350	12	11	27	
		TYPED OR PRINTED						AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE [] ***


NOTE: Read instructions before completing this form

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	12	10	01		12	10	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53)			QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB					
79141 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L	0	ONCE/ MONTH	GRAB					
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(19)	0	ONCE/ MONTH	GRAB					
OIL AND GREASE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	10	MG/L	0	ONCE/ MONTH	GRAB					
TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	15	30DA AVG.	0	ONCE/ MONTH	GRAB					
70030 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	DAILY MX			ONCE/ MONTH	GRAB					
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)										TOLL PHONE		DATE			
James M. Harkins MES Director	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT										410	729-8350	12	11	27	
TYPED OR PRINTED											AREA CODE	NUMBER	YEAR	MONTH	DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
12	10	01	12	10	31
FROM				TO	
(20-21)		(22-23) (24-25)		(26-27) (28-29) (30-31)	

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	219,803	265,000	(07)	*****	*****	*****	****	0	ONCE/MONTH	GRAB	
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/MONTH	GRAB	
EFFLUENT GROSS VALUE COLIFORM, FECAL GENERAL 74055 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	5	(30)	0	ONCE/WEEK	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX	MPN		ONCE/WEEK	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 551001 AND 33 U.S.C. 55 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)							TFFPHONE		DATE		
James M. Harkins MES Director TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							410	729-8350	12	11	19
								AREA CODE	NUMBER	YFAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	12	11	01		12	11	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY/MX	MG/L		ONCE/ MONTH	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	****	7.0	*****	7.8	(12)	0	TWICE/ WEEK	GRAB
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY-MN	*****	8.5 DAILY/MX	SU		TWICE/ WEEK	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	4	4	(19)	0	ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	243,033	980,000	(07)	*****	*****	*****	****	0	Measured	RECORD
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	RECORD
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/ MONTH	GRAB
CHLORINE, TOTAL RESIDUAL 50060 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE											

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

James M. Harkins

MES Director

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

410

729-8350

12

12

17

AREA CODE

NUMBER

YEAR

MONTH

DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name AG/GFI Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address 626 Hanover Pike

MD0001881

001

Approval expires

Hampstead, MD 21074

PERMIT NUMBER

DISCHARGE NUMBER

*** NO DISCHARGE ***

Facility Black and Decker WWTP

NOTE: Read instructions before completing this form

Location 626 Hanover Pike


State Discharge Permit

Attn:

02-DP-0022

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
12	11	01	12	11	30
(20-21)		(22-23)		(24-25)	
		(26-27)		(28-29)	
				(30-31)	

PARAMETER (32-37)		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
79141 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE							DAILY:MX				
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/ MONTH	GRAB
TOTAL RECOVERABLE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONCE/ MONTH	GRAB
70030 1 0 0						30DA:AVG	DAILY:MX				
EFFLUENT GROSS VALUE											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
		410	729-8350	12	12	17
James M. Harkins MES Director		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				
TYPED OR PRINTED		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD

YEAR			MO			DAY		
12	11	01	12	11	30			
(20-21) (22-23) (24-25)			(26-27) (28-29) (30-31)					

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53) QUANTITY OR LOADING			(4 Card Only) (38-45) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	219,100	271,000	(07)	*****	*****	*****	****	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	5	(30)	0	ONCE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY-MX	MPN		ONCE/ WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
James M. Harkins
MES Director
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TPI PHONE		DATE		
410	729-8350	12	12	17
AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
12	12	01	12	12	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

FROM

TO

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM				
		UNITS	UNITS		UNITS						
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	5	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX			ONCE/ MONTH	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	****	6.7	*****	7.9	(12)	0	TWICE/ WEEK	GRAB
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY MIN	*****	8.5 DAILY MX			TWICE/ WEEK	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA AVG	30 DAILY MX			ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	222,258	1,278,000	(07)	*****	*****	*****		0	Measured	RECORD
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****			Measured	RECORD
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/ MONTH	GRAB
CHLORINE, TOTAL RESIDUAL 50060 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX			ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT			TELEPHONE		DATE		
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	James M. Harkins MES Director			410 729-8350			13	01	18		
TYPED OR PRINTED				AREA CODE NUMBER			YEAR	MONTH	DAY		

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name AG/GFI Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address 626 Hanover Pike

MD0001881

001

Approval expires

Hampstead, MD 21074

PERMIT NUMBER

DISCHARGE NUMBER

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	12	12	01		12	12	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form


State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS					
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB		
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB		
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/ MONTH	GRAB		
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10 30DA AVG	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB		
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
James M. Harkins
MES Director
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 551001 AND 33 U.S.C. 55 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)


SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TFI PHONE		DATE		
410	729-8350	13	01	18
AREA CODE	NUMBER	YFAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP

Location 626 Hanover Pike


Attn:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
12	12	01	12	12	31
(20-21)		(22-23)	(24-25)	(26-27)	(28-29) (30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	198,587	277,000	(07)	*****	*****	*****	****	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE COLIFORM, FECAL GENERAL 74055 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX	MPN		ONCE/ WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
		James M. Harkins MES Director TYPED OR PRINTED		410	729-8350	13
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.
 Address 626 Hanover Pike
Hampstead, MD 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)

MD0001881
PERMIT NUMBER

201
DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP
 Location 626 Hanover Pike
 Attn: _____

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	12	10	01		12	12	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	234,691	284,412	(07)	*****	*****	*****	****	0	Measured	Record
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	Record
TETRACHLOROETHYLENE 34475 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
1,1,1-TRICHLOROETHANE 34506 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
TRICHLOROETHENE 79141 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
James M. Harkins MES Director TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	410	729-8350	13	01
		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(OCTOBER - DECEMBER 2012)

Account No:AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample Number Sample Description
L4319250-1 FINAL 001 GRAB
Received Date/Time/Temp 10/09/12 05:10pm 6.3 C Iced (Y/N): Y
Samp. Date/Time/Temp Sampled by
10/09/12 08:30am NA C Customer

Parameter	Method	Result	RLs	Test Date, Time, Analyst
-----------	--------	--------	-----	--------------------------

GENERAL CHEMISTRY

BIOCHEMICAL OXYGEN DEMAND (DELAWARE)	SM 5210B	5.00 mg/l	2.00 mg/l	10/10/12 10:30AM SKJ
TOTAL SUSPENDED SOLIDS (DELAWARE)	SM 2540D	5.40 mg/l	4.00 mg/l	10/11/12 12:00AM MS3
HEXANE EXTR.-HEM (OIL+GREASE)	1664A HEM	ND mg/l	5.00 mg/l	10/19/12 12:45PM RHB

GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES

1,1,1-TRICHLOROETHANE	EPA 624	ND ug/l	1.00 ug/l*	10/18/12 01:17AM EEW
TRICHLOROETHENE	EPA 624	ND ug/l	1.00 ug/l*	10/18/12 01:17AM EEW
TETRACHLOROETHENE	EPA 624	ND ug/l	1.00 ug/l*	10/18/12 01:17AM EEW
DIBROMOFLUOROMETHANE	EPA 624	100 %		10/18/12 01:17AM EEW
TOLUENE-D8 (SURR)	EPA 624	99 %		10/18/12 01:17AM EEW
4-BROMOFLUOROBENZENE	EPA 624	102 %		10/18/12 01:17AM EEW

Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.

Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive

MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.

The test results meet all requirements of NELAC unless otherwise specified.

The report shall not be reproduced except in full without the written consent of the laboratory.

Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.

The reported results relate only to the samples.

All samples are collected as "grab" samples unless otherwise identified.

A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.

The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), Kim Billington (Dairy & Food Microbiology), QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223

State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # : 2515238

E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.

* - The "RLs" represents a reporting/quantitation limit. When an "*" is present in the column identified as the "RLs", it is being reported as a Method Detection Limit (MDL).



Account No:AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample Number Sample Description
L4371563-1 BLACK & DECKER 101
Received Date/Time 11/02/12 11:45am

Samp. Date/Time/Temp Sampled by
10/16/12 09:10am NA C Customer

Parameter	Method	Result	RLs	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY				
FECAL COLIFORM-MPN CEL(DELAWARE)	SM 9221E	4.5 MPN/100ml	MPN/100ml	10/16/12 01:55PM SUB

L4371563-1 :

Fecal coliform was analyzed by Chesapeake Environmental Lab, Inc. in Stevensville, MD.

Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.
Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive
MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.
The test results meet all requirements of NELAC unless otherwise specified.
The report shall not be reproduced except in full without the written consent of the laboratory.
Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.
The reported results relate only to the samples.
All samples are collected as "grab" samples unless otherwise identified.
A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.
The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), Kim Billington (Dairy & Food Microbiology);
QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223
State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # :2515238
E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.



Account No:AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample Number Sample Description Smp. Date/Time/Temp Sampled by
L4358770-1 FINAL 001 GRAB 11/06/12 09:07am NA C Customer
Received Date/Time/Temp 11/06/12 05:00pm 2.2 C Iced (Y/N): Y

Parameter Method Result RLs Test Date, Time, Analyst

GENERAL CHEMISTRY

BIOCHEMICAL OXYGEN DEMAND (DELAWARE)	SM 5210B	ND mg/l	2.00 mg/l	11/07/12 09:10AM	SKJ
TOTAL SUSPENDED SOLIDS (DELAWARE)	SM 2540D	4.00 mg/l	4.00 mg/l	11/07/12 12:00AM	MS3
HEXANE EXTR.-HEM (OIL+GREASE)	1664A HEM	ND mg/l	5.00 mg/l	11/14/12 08:30AM	RHB

GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES

1,1,1-TRICHLOROETHANE	EPA 624	ND ug/l	0.260 ug/l*	11/17/12 04:36PM	DSV
TRICHLOROETHENE	EPA 624	ND ug/l	0.340 ug/l*	11/17/12 04:36PM	DSV
TETRACHLOROETHENE	EPA 624	ND ug/l	0.310 ug/l*	11/17/12 04:36PM	DSV
DIBROMOFLUOROMETHANE	EPA 624	120 %		11/17/12 04:36PM	DSV
TOLUENE-D8 (SURR)	EPA 624	103 %		11/17/12 04:36PM	DSV
4-BROMOFLUOROBENZENE	EPA 624	109 %		11/17/12 04:36PM	DSV

L4358770-1 :

For the BOD 5 test on this day, the nutrient blank was 0.45 mg/l, over the limit of <0.40 mg/l. The nutrient blank was acceptable at 0.90 mg/ml DO depletion and all GGA's were acceptable at 175 mg/l, 178 mg/l, 173 mg/l and 185 mg/l.

Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.
Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive
MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.
The test results meet all requirements of NELAC unless otherwise specified.
The report shall not be reproduced except in full without the written consent of the laboratory.
Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.
The reported results relate only to the samples.
All samples are collected as "grab" samples unless otherwise identified.
A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.
The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), Kim Billington (Dairy & Food Microbiology),
QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223
State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # : 2515238
E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.
* - The "RLs" represents a reporting/quantitation limit. When an "" is present in the column identified as the "RLs", it is being reported as a Method Detection Limit (MDL).



Account No:AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample Number Sample Description Samp. Date/Time/Temp Sampled by
L4419487-1 BLACK & DECKER 101 11/27/12 09:05am NA C Customer
Received Date/Time 12/11/12 11:15am

Parameter	Method	Result	RLs	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY				
FECAL COLIFORM-MPN CEL(DELAWARE)	SM 9221E	4.5 MPN/100ml	MPN/100ml	11/27/12 02:02PM SUB

L4419487-1 :

Fecal coliform was analyzed by Chesapeake Environmental Lab, Inc. in Stevensville, MD.

Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.

Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive

MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.

The test results meet all requirements of NELAC unless otherwise specified.

The report shall not be reproduced except in full without the written consent of the laboratory.

Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.

The reported results relate only to the samples.

All samples are collected as "grab" samples unless otherwise identified.

A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.

The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki

Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), Kim Billington (Dairy & Food Microbiology),

QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223

State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # : 2515238

E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.



Account No:AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample Number Sample Description
L4388616-1 FINAL 001 GRAB
Received Date/Time/Temp 12/11/12 05:15pm 2.4 C Iced (Y/N): Y
Samp. Date/Time/Temp Sampled by
12/11/12 09:08am NA C Customer

Parameter Method Result RLS Test Date, Time, Analyst

GENERAL CHEMISTRY

BIOCHEMICAL OXYGEN DEMAND (DELAWARE)	SM 5210B	5.00 mg/l	2.00 mg/l	12/12/12 07:55AM	SKJ
TOTAL SUSPENDED SOLIDS (DELAWARE)	SM 2540D	ND mg/l	4.00 mg/l	12/12/12 12:00AM	MS3
HEXANE EXTR.-HEM (OIL+GREASE)	1664A HEM	ND mg/l	5.00 mg/l	12/24/12 01:10PM	RHB

GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES

1,1,1-TRICHLOROETHANE	EPA 624	ND ug/l	1.00 ug/l	12/19/12 11:48PM	DSV
TRICHLOROETHENE	EPA 624	ND ug/l	1.00 ug/l	12/19/12 11:48PM	DSV
TETRACHLOROETHENE	EPA 624	ND ug/l	1.00 ug/l	12/19/12 11:48PM	DSV
DIBROMOFUOROMETHANE	EPA 624	95 %		12/19/12 11:48PM	DSV
TOLUENE-D8 (SURR)	EPA 624	100 %		12/19/12 11:48PM	DSV
4-BROMOFUOROBENZENE	EPA 624	99 %		12/19/12 11:48PM	DSV

Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLS.

Definitions: NEG=negative; POS=positive; COL=colonies; RLS=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive

MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.

The test results meet all requirements of NELAC unless otherwise specified.

The report shall not be reproduced except in full without the written consent of the laboratory.

Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.

The reported results relate only to the samples.

All samples are collected as "grab" samples unless otherwise identified.

A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.

The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), Kim Billington (Dairy & Food Microbiology),

QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223

State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. #: 2515238

E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.



Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample Number Sample Description Smp. Date/Time/Temp Sampled by
L4371643-1 BLACK & DECKER FINAL 201 11/02/12 09:07am NA C Customer
Received Date/Time/Temp 11/02/12 04:30pm 4.1 C Iced (Y/N): Y

Parameter Method Result RLs Test Date, Time, Analyst

GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES

1,1,1-TRICHLOROETHANE	EPA 8260B	ND ug/l	0.210 ug/l*	11/12/12 04:08PM JSH
TRICHLOROETHENE	EPA 8260B	ND ug/l	0.250 ug/l*	11/12/12 04:08PM JSH
TETRACHLOROETHENE	EPA 8260B	ND ug/l	0.370 ug/l*	11/12/12 04:08PM JSH
DIBROMOFLUOROMETHANE	EPA 8260B	98 %		11/12/12 04:08PM JSH
TOLUENE-D8 (SURR)	EPA 8260B	103 %		11/12/12 04:08PM JSH
4-BROMOFLUOROBENZENE	EPA 8260B	101 %		11/12/12 04:08PM JSH

Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.

Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive

MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.

The test results meet all requirements of NELAC unless otherwise specified.

The report shall not be reproduced except in full without the written consent of the laboratory.

Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.

The reported results relate only to the samples.

All samples are collected as "grab" samples unless otherwise identified.

A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.

The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki

Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), Kim Billington (Dairy & Food Microbiology),

@QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223

State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. #: 2515238

E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.

* - The "RLs" represents a reporting/quantitation limit. When an "" is present in the column identified as the "RLs", it is being reported as a Method Detection Limit (MDL).



Account No:AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample Number Sample Description Samp. Date/Time/Temp Sampled by
L4435559-1 BLACK & DECKER 101 12/18/12 09:01am NA C Customer
Received Date/Time 12/27/12 10:00am

Parameter	Method	Result	RLs	Test Date, Time, Analyst
-----------	--------	--------	-----	--------------------------

ENVIRONMENTAL MICROBIOLOGY

FECAL COLIFORM-MPN CEL(DELAWARE)	SM 9221E	<1.8 MPN/100ml	MPN/100ml	12/18/12 02:25PM SUB
-------------------------------------	----------	----------------	-----------	----------------------

L4435559-1 :

Fecal coliform was analyzed by Chesapeake Environmental Lab, Inc. in Stevensville, MD.

Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.
Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive
MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.
The test results meet all requirements of NELAC unless otherwise specified.
The report shall not be reproduced except in full without the written consent of the laboratory.
Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.
The reported results relate only to the samples.
All samples are collected as "grab" samples unless otherwise identified.
A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.
The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), Kim Billington (Dairy & Food Microbiology),
QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131; NJ PA166, NY 11223
State ID's: CT.PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # : 2515238
E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.



**APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(NOVEMBER 2012)**

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING


ANALYTICAL REPORT

TestAmerica Laboratories, Inc.
TestAmerica Chicago
2417 Bond Street
University Park, IL 60484
Tel: (708)534-5200

TestAmerica Job ID: 500-52022-1
Client Project/Site: Black and Decker

For:
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, Pennsylvania 19380

Attn: Mr. Tom Cornuet



Authorized for release by:
11/19/2012 9:33:02 AM

Richard Wright
Project Manager II
richard.wright@testamericainc.com

LINKS

Review your project
results through
Total Access

Have a Question?

Ask
The
Expert

Visit us at:
www.testamericainc.com

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

1

2

4

5

6

7

8

9

10

12

13

14

Table of Contents

Cover Page	1
Table of Contents	2
Case Narrative	3
Detection Summary	4
Method Summary	8
Sample Summary	9
Client Sample Results	10
Definitions	62
QC Association	63
Surrogate Summary	64
QC Sample Results	65
Chronicle	78
Certification Summary	83
Chain of Custody	84
Receipt Checklists	87



Case Narrative

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Job ID: 500-52022-1

Laboratory: TestAmerica Chicago

Narrative

Job Narrative
500-52022-1

Comments

No additional comments.

Receipt

The samples were received on 11/3/2012 11:20 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 2.7° C.

GC/MS VOA

Method(s) 8260B: The following analyte(s) recovered outside control limits for the LCS associated with batch 169122: 2-Chlorotoluene and 4-Chlorotoluene. These analytes are not indicative of a systematic problem and were within the Marginal Exceedance Limits; therefore, the results have been reported and qualified.

No other analytical or quality issues were noted.



Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-52022-1

No Detections

Client Sample ID: RFW-1B

Lab Sample ID: 500-52022-2

No Detections

Client Sample ID: RFW-2A

Lab Sample ID: 500-52022-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.65		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-2B

Lab Sample ID: 500-52022-4

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Benzene	0.16	J	0.50	0.074	ug/L	1		8260B	Total/NA
Trichloroethene	0.61		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-7

Lab Sample ID: 500-52022-5

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Benzene	0.23	J	0.50	0.074	ug/L	1		8260B	Total/NA
Trichloroethene	0.50		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-6

Lab Sample ID: 500-52022-6

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.81	J	1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	2.0		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	2.3		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-17

Lab Sample ID: 500-52022-7

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Benzene	1.1		0.50	0.074	ug/L	1		8260B	Total/NA
o-Xylene	0.14	J	0.50	0.068	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-13

Lab Sample ID: 500-52022-8

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.95	J	1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	2.7		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	17		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-3B

Lab Sample ID: 500-52022-9

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.69	J	1.0	0.12	ug/L	1		8260B	Total/NA
Tetrachloroethene	0.54	J	1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-9

Lab Sample ID: 500-52022-10

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	7.1		1.0	0.12	ug/L	1		8260B	Total/NA

TestAmerica Chicago

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-9 (Continued)

Lab Sample ID: 500-52022-10

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	5.5		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	2.7		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: TRIP BLANK

Lab Sample ID: 500-52022-11

No Detections

Client Sample ID: RFW-4A

Lab Sample ID: 500-52022-12

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.77	J	1.0	0.12	ug/L	1		8260B	Total/NA
Chloroform	0.66	J	1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	29		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	20		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-4A DUP

Lab Sample ID: 500-52022-13

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.84	J	1.0	0.12	ug/L	1		8260B	Total/NA
Chloroform	0.76	J	1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	29		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	20		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-4B

Lab Sample ID: 500-52022-14

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	4.1		1.0	0.12	ug/L	1		8260B	Total/NA
Chloroform	1.1		1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	34		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	64		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-11B

Lab Sample ID: 500-52022-15

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	2.8		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-12B

Lab Sample ID: 500-52022-16

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	1.8		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	73		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	5.0		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-2

Lab Sample ID: 500-52022-17

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	3.5		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	200		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	45		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-3

Lab Sample ID: 500-52022-18

TestAmerica Chicago

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-3 (Continued)

Lab Sample ID: 500-52022-18

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	1.7		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	48		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	1.5		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-4

Lab Sample ID: 500-52022-19

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Tetrachloroethene	19		1.0	0.17	ug/L	1		8260B	Total/NA
Trichloroethene - DL	930		2.5	0.95	ug/L	5		8260B	Total/NA

Client Sample ID: EW-5

Lab Sample ID: 500-52022-20

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	110		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	3.4		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-6

Lab Sample ID: 500-52022-21

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	6.4		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	12		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-7

Lab Sample ID: 500-52022-22

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethane	0.47	J	1.0	0.19	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	5.4		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	3.8		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	8.8		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-8

Lab Sample ID: 500-52022-23

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethane	0.78	J	1.0	0.19	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	24		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	8.0		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	66		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-8 DUP

Lab Sample ID: 500-52022-24

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethane	0.75	J	1.0	0.19	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	24		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	8.2		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	67		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-9

Lab Sample ID: 500-52022-25

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.56		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	110		1.0	0.17	ug/L	1		8260B	Total/NA

TestAmerica Chicago

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-10

Lab Sample ID: 500-52022-26

Analyte	Result	Qualifier	RL	MDL	Unit	Dil	Fac	D	Method	Prep Type
Tetrachloroethene	0.58	J	1.0	0.17	ug/L	1			8260B	Total/NA



TestAmerica Chicago

Method Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Method	Method Description	Protocol	Laboratory
8260B	VOC	SW846	TAL CHI

Protocol References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200



TestAmerica Chicago

Sample Summary

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
500-52022-1	RFW-1A	Water	11/01/12 09:10	11/03/12 11:20
500-52022-2	RFW-1B	Water	11/01/12 16:00	11/03/12 11:20
500-52022-3	RFW-2A	Water	11/01/12 10:05	11/03/12 11:20
500-52022-4	RFW-2B	Water	11/01/12 10:15	11/03/12 11:20
500-52022-5	RFW-7	Water	11/01/12 10:55	11/03/12 11:20
500-52022-6	RFW-6	Water	11/01/12 12:10	11/03/12 11:20
500-52022-7	RFW-17	Water	11/01/12 12:50	11/03/12 11:20
500-52022-8	RFW-13	Water	11/01/12 14:35	11/03/12 11:20
500-52022-9	RFW-3B	Water	11/01/12 16:05	11/03/12 11:20
500-52022-10	RFW-9	Water	11/01/12 16:45	11/03/12 11:20
500-52022-11	TRIP BLANK	Water	11/01/12 07:00	11/03/12 11:20
500-52022-12	RFW-4A	Water	11/02/12 08:30	11/03/12 11:20
500-52022-13	RFW-4A DUP	Water	11/02/12 08:30	11/03/12 11:20
500-52022-14	RFW-4B	Water	11/02/12 09:00	11/03/12 11:20
500-52022-15	RFW-11B	Water	11/02/12 11:30	11/03/12 11:20
500-52022-16	RFW-12B	Water	11/02/12 12:30	11/03/12 11:20
500-52022-17	EW-2	Water	11/02/12 12:10	11/03/12 11:20
500-52022-18	EW-3	Water	11/02/12 10:00	11/03/12 11:20
500-52022-19	EW-4	Water	11/02/12 10:35	11/03/12 11:20
500-52022-20	EW-5	Water	11/01/12 09:05	11/03/12 11:20
500-52022-21	EW-6	Water	11/01/12 11:40	11/03/12 11:20
500-52022-22	EW-7	Water	11/01/12 11:35	11/03/12 11:20
500-52022-23	EW-8	Water	11/01/12 11:25	11/03/12 11:20
500-52022-24	EW-8 DUP	Water	11/01/12 11:25	11/03/12 11:20
500-52022-25	EW-9	Water	11/01/12 11:15	11/03/12 11:20
500-52022-26	EW-10	Water	11/01/12 10:45	11/03/12 11:20



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-52022-1

Date Collected: 11/01/12 09:10

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 02:47	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 02:47	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 02:47	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 02:47	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 02:47	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 02:47	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 02:47	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 02:47	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 02:47	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 02:47	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 02:47	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 02:47	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 02:47	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 02:47	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 02:47	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 02:47	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 02:47	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 02:47	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 02:47	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 02:47	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 02:47	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 02:47	1
Trichloroethene	<0.50		0.50	0.19	ug/L			11/09/12 02:47	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 02:47	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 02:47	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 02:47	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 02:47	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 02:47	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 02:47	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 02:47	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 02:47	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 02:47	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 02:47	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 02:47	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 02:47	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 02:47	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 02:47	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 02:47	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 02:47	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 02:47	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 02:47	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 02:47	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 02:47	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 02:47	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 02:47	1
1,1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 02:47	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 02:47	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 02:47	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 02:47	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-52022-1

Date Collected: 11/01/12 09:10

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 02:47	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 02:47	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 02:47	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 02:47	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 02:47	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 02:47	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 02:47	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 02:47	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 02:47	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 02:47	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 02:47	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 02:47	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 02:47	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 02:47	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 02:47	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	99		75 - 131					11/09/12 02:47	1
Toluene-d8 (Surr)	93		80 - 120					11/09/12 02:47	1
4-Bromofluorobenzene (Surr)	91		79 - 120					11/09/12 02:47	1
Dibromofluoromethane	96		74 - 123					11/09/12 02:47	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-52022-2

Date Collected: 11/01/12 16:00

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 03:13	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 03:13	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 03:13	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 03:13	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 03:13	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 03:13	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 03:13	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 03:13	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 03:13	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 03:13	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 03:13	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 03:13	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 03:13	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 03:13	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 03:13	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 03:13	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 03:13	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 03:13	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 03:13	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 03:13	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 03:13	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 03:13	1
Trichloroethene	<0.50		0.50	0.19	ug/L			11/09/12 03:13	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 03:13	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 03:13	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 03:13	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 03:13	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 03:13	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 03:13	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 03:13	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 03:13	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 03:13	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 03:13	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 03:13	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 03:13	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 03:13	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:13	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 03:13	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 03:13	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 03:13	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 03:13	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 03:13	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 03:13	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:13	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 03:13	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 03:13	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 03:13	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 03:13	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 03:13	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-52022-2

Date Collected: 11/01/12 16:00

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 03:13	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 03:13	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:13	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:13	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 03:13	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 03:13	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 03:13	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 03:13	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 03:13	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 03:13	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 03:13	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 03:13	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 03:13	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 03:13	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 03:13	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	98		75 - 131					11/09/12 03:13	1
Toluene-d8 (Surr)	95		80 - 120					11/09/12 03:13	1
4-Bromofluorobenzene (Surr)	89		79 - 120					11/09/12 03:13	1
Dibromofluoromethane	97		74 - 123					11/09/12 03:13	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-52022-3

Date Collected: 11/01/12 10:05

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 03:39	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 03:39	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 03:39	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 03:39	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 03:39	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 03:39	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 03:39	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 03:39	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 03:39	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 03:39	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 03:39	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 03:39	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 03:39	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 03:39	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 03:39	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 03:39	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 03:39	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 03:39	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 03:39	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 03:39	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 03:39	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 03:39	1
Trichloroethene	0.65		0.50	0.19	ug/L			11/09/12 03:39	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 03:39	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 03:39	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 03:39	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 03:39	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 03:39	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 03:39	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 03:39	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 03:39	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 03:39	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 03:39	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 03:39	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 03:39	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 03:39	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:39	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 03:39	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 03:39	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 03:39	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 03:39	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 03:39	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 03:39	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:39	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 03:39	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 03:39	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 03:39	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 03:39	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 03:39	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-52022-3

Date Collected: 11/01/12 10:05

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 03:39	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 03:39	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:39	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:39	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 03:39	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 03:39	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 03:39	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 03:39	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 03:39	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 03:39	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 03:39	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 03:39	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 03:39	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 03:39	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 03:39	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	97		75 - 131					11/09/12 03:39	1
Toluene-d8 (Surr)	92		80 - 120					11/09/12 03:39	1
4-Bromofluorobenzene (Surr)	92		79 - 120					11/09/12 03:39	1
Dibromofluoromethane	95		74 - 123					11/09/12 03:39	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-52022-4

Date Collected: 11/01/12 10:15

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	0.16	J	0.50	0.074	ug/L			11/09/12 04:05	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 04:05	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 04:05	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 04:05	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 04:05	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 04:05	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 04:05	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 04:05	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 04:05	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 04:05	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 04:05	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 04:05	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 04:05	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 04:05	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 04:05	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 04:05	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 04:05	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 04:05	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 04:05	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 04:05	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 04:05	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 04:05	1
Trichloroethene	0.61		0.50	0.19	ug/L			11/09/12 04:05	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 04:05	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 04:05	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 04:05	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 04:05	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 04:05	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 04:05	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 04:05	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 04:05	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 04:05	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 04:05	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 04:05	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 04:05	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 04:05	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:05	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 04:05	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 04:05	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 04:05	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 04:05	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 04:05	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 04:05	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:05	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 04:05	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 04:05	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 04:05	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 04:05	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 04:05	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-52022-4

Date Collected: 11/01/12 10:15

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 04:05	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 04:05	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:05	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:05	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:05	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:05	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 04:05	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:05	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 04:05	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 04:05	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 04:05	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 04:05	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 04:05	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 04:05	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 04:05	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		75 - 131					11/09/12 04:05	1
Toluene-d8 (Surr)	97		80 - 120					11/09/12 04:05	1
4-Bromofluorobenzene (Surr)	92		79 - 120					11/09/12 04:05	1
Dibromofluoromethane	109		74 - 123					11/09/12 04:05	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-7

Lab Sample ID: 500-52022-5

Date Collected: 11/01/12 10:55

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	0.23	J	0.50	0.074	ug/L			11/09/12 04:30	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 04:30	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 04:30	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 04:30	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 04:30	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 04:30	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 04:30	1
1,1-Dichloroethane	<1.0		1.0	0.31	ug/L			11/09/12 04:30	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 04:30	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 04:30	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 04:30	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 04:30	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 04:30	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 04:30	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 04:30	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 04:30	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 04:30	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 04:30	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 04:30	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 04:30	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 04:30	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 04:30	1
Trichloroethene	0.50		0.50	0.19	ug/L			11/09/12 04:30	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 04:30	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 04:30	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 04:30	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 04:30	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 04:30	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 04:30	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 04:30	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 04:30	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 04:30	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 04:30	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 04:30	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 04:30	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 04:30	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:30	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 04:30	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 04:30	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 04:30	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 04:30	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 04:30	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 04:30	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:30	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 04:30	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 04:30	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 04:30	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 04:30	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 04:30	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-7

Lab Sample ID: 500-52022-5

Date Collected: 11/01/12 10:55

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 04:30	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 04:30	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:30	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:30	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:30	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:30	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 04:30	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:30	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 04:30	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 04:30	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 04:30	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 04:30	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 04:30	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 04:30	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 04:30	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		75 - 131					11/09/12 04:30	1
Toluene-d8 (Surr)	99		80 - 120					11/09/12 04:30	1
4-Bromofluorobenzene (Surr)	95		79 - 120					11/09/12 04:30	1
Dibromofluoromethane	106		74 - 123					11/09/12 04:30	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-6

Lab Sample ID: 500-52022-6

Date Collected: 11/01/12 12:10

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 04:56	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 04:56	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 04:56	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 04:56	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 04:56	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 04:56	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 04:56	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 04:56	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 04:56	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 04:56	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 04:56	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 04:56	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 04:56	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 04:56	1
cis-1,2-Dichloroethene	0.81	J	1.0	0.12	ug/L			11/09/12 04:56	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 04:56	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 04:56	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 04:56	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 04:56	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 04:56	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 04:56	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 04:56	1
Trichloroethene	2.0		0.50	0.19	ug/L			11/09/12 04:56	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 04:56	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 04:56	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 04:56	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 04:56	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 04:56	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 04:56	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 04:56	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 04:56	1
Tetrachloroethene	2.3		1.0	0.17	ug/L			11/09/12 04:56	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 04:56	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 04:56	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 04:56	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 04:56	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:56	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 04:56	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 04:56	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 04:56	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 04:56	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 04:56	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 04:56	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:56	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 04:56	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 04:56	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 04:56	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 04:56	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 04:56	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-6

Lab Sample ID: 500-52022-6

Date Collected: 11/01/12 12:10

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 04:56	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 04:56	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:56	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:56	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:56	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:56	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 04:56	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:56	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 04:56	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 04:56	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 04:56	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 04:56	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 04:56	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 04:56	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 04:56	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	96		75 - 131					11/09/12 04:56	1
Toluene-d8 (Surr)	93		80 - 120					11/09/12 04:56	1
4-Bromofluorobenzene (Surr)	89		79 - 120					11/09/12 04:56	1
Dibromofluoromethane	95		74 - 123					11/09/12 04:56	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-17

Lab Sample ID: 500-52022-7

Date Collected: 11/01/12 12:50

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	1.1		0.50	0.074	ug/L			11/09/12 05:22	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 05:22	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 05:22	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 05:22	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 05:22	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 05:22	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 05:22	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 05:22	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 05:22	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 05:22	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 05:22	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 05:22	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 05:22	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 05:22	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 05:22	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 05:22	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 05:22	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 05:22	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 05:22	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 05:22	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 05:22	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 05:22	1
Trichloroethene	<0.50		0.50	0.19	ug/L			11/09/12 05:22	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 05:22	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 05:22	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 05:22	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 05:22	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 05:22	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 05:22	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 05:22	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 05:22	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 05:22	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 05:22	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 05:22	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 05:22	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 05:22	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:22	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 05:22	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 05:22	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 05:22	1
o-Xylene	0.14	J	0.50	0.068	ug/L			11/09/12 05:22	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 05:22	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 05:22	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:22	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 05:22	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 05:22	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 05:22	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 05:22	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 05:22	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-17

Lab Sample ID: 500-52022-7

Date Collected: 11/01/12 12:50

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 05:22	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 05:22	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:22	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:22	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 05:22	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 05:22	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 05:22	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 05:22	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 05:22	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 05:22	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 05:22	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 05:22	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 05:22	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 05:22	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 05:22	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	100		75 - 131		11/09/12 05:22	1
Toluene-d8 (Surr)	95		80 - 120		11/09/12 05:22	1
4-Bromofluorobenzene (Surr)	94		79 - 120		11/09/12 05:22	1
Dibromofluoromethane	99		74 - 123		11/09/12 05:22	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-13

Lab Sample ID: 500-52022-8

Date Collected: 11/01/12 14:35

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 05:48	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 05:48	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 05:48	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 05:48	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 05:48	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 05:48	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 05:48	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 05:48	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 05:48	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 05:48	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 05:48	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 05:48	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 05:48	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 05:48	1
cis-1,2-Dichloroethene	0.95	J	1.0	0.12	ug/L			11/09/12 05:48	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 05:48	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 05:48	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 05:48	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 05:48	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 05:48	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 05:48	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 05:48	1
Trichloroethene	2.7		0.50	0.19	ug/L			11/09/12 05:48	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 05:48	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 05:48	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 05:48	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 05:48	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 05:48	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 05:48	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 05:48	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 05:48	1
Tetrachloroethene	17		1.0	0.17	ug/L			11/09/12 05:48	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 05:48	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 05:48	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 05:48	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 05:48	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:48	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 05:48	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 05:48	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 05:48	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 05:48	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 05:48	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 05:48	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:48	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 05:48	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 05:48	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 05:48	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 05:48	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 05:48	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-13

Lab Sample ID: 500-52022-8

Date Collected: 11/01/12 14:35

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 05:48	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 05:48	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:48	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:48	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 05:48	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 05:48	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 05:48	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 05:48	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 05:48	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 05:48	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 05:48	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 05:48	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 05:48	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 05:48	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 05:48	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	109		75 - 131		11/09/12 05:48	1
Toluene-d8 (Surr)	103		80 - 120		11/09/12 05:48	1
4-Bromofluorobenzene (Surr)	100		79 - 120		11/09/12 05:48	1
Dibromofluoromethane	106		74 - 123		11/09/12 05:48	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-52022-9

Date Collected: 11/01/12 16:05

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 06:14	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 06:14	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 06:14	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 06:14	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 06:14	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 06:14	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 06:14	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 06:14	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 06:14	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 06:14	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 06:14	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 06:14	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 06:14	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 06:14	1
cis-1,2-Dichloroethene	0.69	J	1.0	0.12	ug/L			11/09/12 06:14	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 06:14	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 06:14	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 06:14	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 06:14	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 06:14	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 06:14	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 06:14	1
Trichloroethene	<0.50		0.50	0.19	ug/L			11/09/12 06:14	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 06:14	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 06:14	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 06:14	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 06:14	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 06:14	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 06:14	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 06:14	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 06:14	1
Tetrachloroethene	0.54	J	1.0	0.17	ug/L			11/09/12 06:14	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 06:14	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 06:14	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 06:14	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 06:14	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:14	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 06:14	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 06:14	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 06:14	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 06:14	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 06:14	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 06:14	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:14	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 06:14	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 06:14	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 06:14	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 06:14	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 06:14	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-52022-9

Date Collected: 11/01/12 16:05

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 06:14	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 06:14	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:14	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:14	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 06:14	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 06:14	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 06:14	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 06:14	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 06:14	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 06:14	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 06:14	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 06:14	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 06:14	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 06:14	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 06:14	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	99		75 - 131					11/09/12 06:14	1
Toluene-d8 (Surr)	96		80 - 120					11/09/12 06:14	1
4-Bromofluorobenzene (Surr)	95		79 - 120					11/09/12 06:14	1
Dibromofluoromethane	101		74 - 123					11/09/12 06:14	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-9

Lab Sample ID: 500-52022-10

Date Collected: 11/01/12 16:45

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 06:40	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 06:40	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 06:40	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 06:40	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 06:40	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 06:40	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 06:40	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 06:40	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 06:40	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 06:40	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 06:40	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 06:40	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 06:40	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 06:40	1
cis-1,2-Dichloroethene	7.1		1.0	0.12	ug/L			11/09/12 06:40	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 06:40	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 06:40	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 06:40	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 06:40	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 06:40	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 06:40	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 06:40	1
Trichloroethene	5.5		0.50	0.19	ug/L			11/09/12 06:40	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 06:40	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 06:40	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 06:40	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 06:40	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 06:40	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 06:40	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 06:40	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 06:40	1
Tetrachloroethene	2.7		1.0	0.17	ug/L			11/09/12 06:40	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 06:40	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 06:40	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 06:40	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 06:40	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:40	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 06:40	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 06:40	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 06:40	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 06:40	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 06:40	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 06:40	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:40	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 06:40	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 06:40	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 06:40	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 06:40	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 06:40	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-9

Lab Sample ID: 500-52022-10

Date Collected: 11/01/12 16:45

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 06:40	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 06:40	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:40	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:40	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 06:40	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 06:40	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 06:40	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 06:40	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 06:40	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 06:40	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 06:40	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 06:40	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 06:40	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 06:40	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 06:40	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	100		75 - 131					11/09/12 06:40	1
Toluene-d8 (Surr)	96		80 - 120					11/09/12 06:40	1
4-Bromofluorobenzene (Surr)	91		79 - 120					11/09/12 06:40	1
Dibromofluoromethane	99		74 - 123					11/09/12 06:40	1

TestAmerica Chicago