

**QUARTERLY GROUNDWATER
MONITORING REPORT**

Prepared for
BLACK & DECKER (U.S.) INC.
Hampstead, Maryland

April 2004

Prepared by
WESTON SOLUTIONS, INC
1400 Weston Way
West Chester, Pennsylvania 19380

W.O. No. 02501.004.004.0200

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 1 st Quarter 2004.....	2-2
Table 2-2 Groundwater Elevation Data – 1 st Quarter 2004	2-3
Table 2-3 Effluent Characteristics Summary – 1 st Quarter 2004	2-4
Table 2-4 Summary of Groundwater Analytical Results - February 2004.....	2-6
Table 3-1 Treatment System Maintenance Activities - 1 st Quarter 2004	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order. Each of these documents is to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site which is maintained at the Hampstead Public Library.

2. SITE CHARACTERIZATION

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of January through March 2004.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. At the time the water level measurements were collected, the extraction wells were pumping at an average combined rate of approximately 167 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of January through March 2004 are included in Appendix B

2.3 GROUNDWATER QUALITY DATA

For the reporting period of January through March 2004, approximately 65 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (85 %) and tetrachlorethene (PCE) (15 %). Analytical results of the groundwater collected at the inlet to the air stripper for the period of January through March 2004 are included in Appendix C.

Table 2-1
Treatment System Pumping Records - 1st Quarter 2004
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
January 2004	6,566,259
February 2004	6,081,242
March 2004	6,863,229

**Table 2-2
Groundwater Elevation Data - 1st Quarter 2004
Black & Decker
Hampstead, Maryland**

WELL NO.	TOC ELEV.	TOTAL DEPTH	1/21/04		2/18/04		3/22/04	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NA	DRY	NA	DRY	NA
EW-2	849.21	110	61.57	787.64	61.62	787.59	62.30	786.91
EW-3	846.64	118	71.68	774.96	72.33	774.31	74.08	772.56
EW-4	858.01	97.5	NA	NA	NA	NA	NA	NA
EW-5	864.17	98	72.04	792.13	70.73	793.44	71.43	792.74
EW-6	831.98	115	63.46	768.52	61.73	770.25	62.43	769.55
EW-7	818.38	78	36.16	782.22	37.62	780.76	35.26	783.12
EW-8	811.13	98	44.62	766.51	42.25	768.88	42.12	769.01
EW-9	811.35	141	56.24	755.11	42.50	768.85	42.03	769.32
EW-10	807.74	NA	NA	NA	19.32	788.42	15.39	792.35
RFW-1A	864.37	78	44.30	820.07	44.86	819.51	44.57	819.80
RFW-1B	864.23	200	44.12	820.11	45.03	819.20	44.86	819.37
RFW-2A	857.41	35	11.51	845.90	12.56	844.85	12.38	845.03
RFW-2B	857.73	75	11.94	845.79	12.96	844.77	12.74	844.99
RFW-3B	839.21	153	24.12	815.09	24.41	814.80	23.86	815.35
RFW-4A	830.37	62	33.74	796.63	34.83	795.54	35.31	795.06
RFW-4B	830.37	120	33.98	796.39	34.74	795.63	35.26	795.11
RFW-5A	817.50	30	DRY	NA	DRY	NA	DRY	NA
RFW-6	785.04	120	2.12	782.92	2.43	782.61	4.14	780.90
RFW-7	805.14	29	NA	NA	4.86	800.28	5.91	799.23
RFW-8	860.07	56	DRY	NA	DRY	NA	52.82	807.25
RFW-9	862.02	49	23.32	838.70	23.29	838.73	23.97	838.05
RFW-10	852.06	58	DRY	NA	DRY	NA	51.87	800.19
RFW-11A	849.32	72	NA	NA	NA	NA	NA	NA
RFW-11B	849.62	116	62.26	787.36	63.41	786.21	63.74	785.88
RFW-12B	844.87	264	NA	NA	46.62	798.25	45.89	798.98
RFW-13	849.11	150	53.92	795.19	54.82	794.29	52.74	796.37
RFW-14B	812.39	281	28.82	783.57	27.23	785.16	25.98	786.41
RFW-16	856.14	41	DRY	NA	DRY	NA	DRY	NA
RFW-17	834.66	60.5	22.88	811.78	23.92	810.74	23.81	810.85
RFW-20	842.49	142	30.86	811.63	31.81	810.68	32.02	810.47
RFW-21	832.65	102	19.89	812.76	20.07	812.58	20.21	812.44
PH-7	805.94	89	9.82	796.12	7.52	798.42	6.50	799.44
PH-9	814.94	98	NA	NA	28.23	786.71	27.04	787.90
PH-11	820.68	78	36.40	784.28	38.77	781.91	38.97	781.71
PH-12	828.35	87	38.87	789.48	40.09	788.26	39.64	788.71
B-3	803.02	83	NA	NA	NA	NA	NA	NA
Amoco	842.29	NA	NA	NA	NA	NA	NA	NA
Hamp. Town #22	804.96	NA	6.43	798.53	19.62	785.34	43.53	761.43
Pembroke #1	NA	NA	NA	NA	NA	NA	NA	NA
Pembroke #2	NA	NA	NA	NA	NA	NA	NA	NA
N. Houcks. Rd.	NA	NA	NA	NA	NA	NA	NA	NA
E. Century St.	NA	NA	NA	NA	NA	NA	NA	NA
Lwr. Beckleys. Rd.	NA	NA	NA	NA	NA	NA	NA	NA

NA - Not Available/Not Accessible

Table 2-3
Effluent Characteristics Summary - 1st Quarter 2004
Black & Decker
Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				January 2004	February 2004	March 2004	
001	FLOW	average	MGD	NA	0.138	0.303	0.227
		maximum	MGD	NA	0.167	0.482	0.352
	1,1,1-Trichloroethane	ug/l	5	< 5	< 5	< 5	
	Tetrachloroethylene	ug/l	5	< 5	< 5	< 5	
	Trichloroethylene	ug/l	5	< 5	< 5	< 5	
	Total Residual Chlorine	mg/l	<0.1	<0.1	<0.1	<0.1	
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		quarterly average	mg/l	10	NR	NR	< 5
	pH	minimum	STD	6.0	6.74	6.17	6.27
		maximum	STD	8.5	7.09	7.41	7.08
	BOD		mg/l	15	5.6	3.9	6.0
TSS	maximum	mg/l	30	3.5	4.5	9.0	
	quarterly average	mg/l	20	NR	NR	5.7	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.280	0.282	0.254
		maximum	MGD	NA	0.392	0.308	0.269
	Fecal Coliform	MPN/100ml	200	< 2	< 2	< 2	
201 (Monitoring Point)	FLOW	average	MGD	NA	0.212	0.210	0.221
		maximum	MGD	NA	0.250	0.230	0.242
	1,1,1-Trichloroethane	ug/l	NA	< 5	< 5	< 5	
	Tetrachloroethylene	ug/l	NA	< 5	< 5	< 5	
	Trichloroethylene	ug/l	NA	< 5	< 5	< 5	

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

A summary of the analytical results from the first quarter (February 2004) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete analytical data package is included in Appendix D. As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B, EW-2 and EW-4. The highest concentration of PCE was detected in the groundwater sample collected from extraction well EW-9. Lower concentrations of 1,2-dichloroethene were also detected. The remainder of VOCs present were detected at levels well below the federal Maximum Contaminant Levels (MCL).

Table 2-4
Summary of Groundwater Analytical Results - February 2004
Black & Decker
Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9	EW-10	RFW-1A	RFW-1B
			(10)	(5)	(25)	(10)					(DUP)			
Chloromethane	ug/L	NS	100 U	50 U	250 U	100 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Bromomethane	ug/L	NS	100 U	50 U	250 U	100 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Vinyl Chloride	ug/L	NS	100 U	50 U	250 U	100 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Chloroethane	ug/L	NS	100 U	50 U	250 U	100 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Methylene Chloride	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Acetone	ug/L	NS	100 U	50 U	250 U	25 J	10 U	10 U	10 U	10 U	10 U	10 U	10 U	5 J
Carbon Disulfide	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethane	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloroethene (total)	ug/L	NS	50 U	25 U	120 U	50 U	5 U	3 J	16	1 J	5 U	5 U	5 U	5 U
Chloroform	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloroethane	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Butanone	ug/L	NS	100 U	50 U	250 U	100 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Tetrachloride	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Bromodichloromethane	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloropropane	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
cis-1,3-Dichloropropene	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Trichloroethene	ug/L	NS	1100	350	3800	590	11	4 J	10	2 J	2 J	5 U	5 U	5 U
Dibromochloromethane	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,2-Trichloroethane	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Benzene	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Trans-1,3-Dichloropropene	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Bromoform	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
4-Methyl-2-pentanone	ug/L	NS	100 U	50 U	250 U	100 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	100 U	50 U	250 U	100 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	65	8 J	89 J	46 J	30	11	75	210	200	9	5 U	5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Toluene	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Chlorobenzene	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Ethylbenzene	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Styrene	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Xylene (total)	ug/L	NS	50 U	25 U	120 U	50 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U

Notes: U = Compound was analyzed for but not detected.
Value shown is the method detection limit for quantification.
J = Indicates an estimated value.

DUP = Duplicate sample
NS = Not sampled
(5) = Dilution factor.

Table 2-4
 Summary of Groundwater Analytical Results - February 2004
 Black & Decker
 Hampstead, Maryland

PARAMETER	Units	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10	RFW-11A	RFW-11B
Chloromethane	ug/L	10 U	10 U	10 U	10 U	10 U	10 U	NS	10 U	10 U	NS	10 U	NS	NS	10 U
Bromomethane	ug/L	10 U	10 U	10 U	10 U	10 U	10 U	NS	10 U	10 U	NS	10 U	NS	NS	10 U
Vinyl Chloride	ug/L	10 U	10 U	10 U	10 U	10 U	10 U	NS	10 U	10 U	NS	10 U	NS	NS	10 U
Chloroethanane	ug/L	10 U	10 U	10 U	10 U	10 U	10 U	NS	10 U	10 U	NS	10 U	NS	NS	10 U
Methylene Chloride	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
Acetone	ug/L	10 U	10 U	10 U	10 U	10 U	3 J	NS	3 J	10 U	NS	10 U	NS	NS	10 U
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
1,1-Dichloroethene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
1,1-Dichloroethane	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	4 J	NS	NS	5 U
1,2-Dichloroethene (total)	ug/L	5 U	5 U	14	2 J	2 J	5 J	NS	5 U	5 U	NS	24	NS	NS	5 U
Chloroform	ug/L	5 U	5 U	5 U	1 J	1 J	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
1,2-Dichloroethane	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
2-Butanone	ug/L	10 U	10 U	10 U	10 U	10 U	2 J	NS	10 U	10 U	NS	10 U	NS	NS	10 U
1,1,1-Trichloroethane	ug/L	5 U	5 U	3 J	5 U	5 U	5 U	NS	5 U	5 U	NS	3 J	NS	NS	5 U
Carbon Tetrachloride	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
Bromodichloromethane	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
1,2-Dichloropropane	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
cis-1,3-Dichloropropene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
Trichloroethene	ug/L	5 U	2 J	13	84	78	10	NS	8	5 J	NS	23	NS	NS	62
Dibromochloromethane	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
1,1,2-Trichloroethane	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
Benzene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
Trans-1,3-Dichloropropene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
Bromoform	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
4-Methyl-2-pentanone	ug/L	10 U	10 U	10 U	10 U	10 U	10 U	NS	10 U	10 U	NS	10 U	NS	NS	10 U
2-Hexanone	ug/L	10 U	10 U	10 U	10 U	10 U	10 U	NS	10 U	10 U	NS	10 U	NS	NS	10 U
Tetrachloroethene	ug/L	5 U	5 U	11	83	81	48	NS	7	5 U	NS	14	NS	NS	1 J
1,1,2,2-Tetrachloroethane	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
Toluene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
Chlorobenzene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
Ethylbenzene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
Styrene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U
Xylene (total)	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	NS	5 U

Notes: U = Compound was analyzed for but not detected.
 Value shown is the method detection limit for quantification.
 J = Indicates an estimated value.

DUP = Duplicate sample
 NS = Not sampled
 (5) = Dilution factor.

Table 2-4
 Summary of Groundwater Analytical Results - February 2004
 Black & Decker
 Hampstead, Maryland

PARAMETER	Units	RFW-12B (5)	RFW-13	RFW-16	RFW-17	RFW-20	RFW-21	Town #22	Town #23	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank
Chloromethane	ug/L	50 U	10 U	NS	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Bromomethane	ug/L	50 U	10 U	NS	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Vinyl Chloride	ug/L	50 U	10 U	NS	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Chloroethane	ug/L	50 U	10 U	NS	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Methylene Chloride	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Acetone	ug/L	50 U	10 U	NS	10 U	5 J	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethane	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloroethene (total)	ug/L	8 J	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Chloroform	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloroethane	ug/L	25 U	10 U	NS	10 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Butanone	ug/L	50 U	10 U	NS	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Tetrachloride	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Bromodichloromethane	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloropropane	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
cis-1,3-Dichloropropene	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Trichloroethene	ug/L	710	5 J	NS	5 U	2 J	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Dibromochloromethane	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,2-Trichloroethane	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Benzene	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Trans-1,3-Dichloropropene	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Bromoform	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
4-Methyl-2-pentanone	ug/L	50 U	10 U	NS	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	50 U	10 U	NS	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	39	29	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,2,2-Tetrachloroethane	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Toluene	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Chlorobenzene	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Ethylbenzene	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Styrene	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Xylene (total)	ug/L	25 U	5 U	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U

Notes: U = Compound was analyzed for but not detected.
 Value shown is the method detection limit for quantification.
 J = Indicates an estimated value.

DUP = Duplicate sample
 NS = Not sampled
 (5) = Dilution factor.

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities that were undertaken with the extraction and treatment system during the reporting period (January through March 2004) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts, as appropriate, or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 1st Quarter 2004
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Jan-04	EW-1 through 5 were taken out of service for 3 days to replace the power feed and control wire. The wells are back in service.
Jan-04	EW- 4 & 5 had cracked fittings repaired. The wells are back in service.
Feb-04	A new water meter was installed in EW-9 and new thermostats were installed in EW- 3 & 4.
Feb-04	EW-10 was automatically shut off by the moisture probe alarm due to melted ice and snow water moisture on the floor. The well was restarted three days later. A new check valve was also installed at this time.

4. RECOMMENDATIONS

For the reporting period of January through March 2004, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(JANUARY - MARCH 2004)

MONTH / YEAR

Jan. 2004

BLACK DECKER
AIR STRIPPER # 2
OPERATING RECORD

PAST MONTH READING

638808

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	T	1300	88 1148	181 090	19345	19380
2	F	0915	1062239	↑	19345	19399
3						
4				698187		
5	M	1300	1760425	194447	19345	19476
6	T	1010	1954872	250199	19366	19476
7	W	1330	2205071	197361	19393	19476
8	T	1100	2402432	231608	19415	19476
9	F	1200	2633440	↑	19440	19476
10						
11				654891		
12	M	1110	3288331	219612	19511	19476
13	T	1100	3507943	234504	19511	19499
14	W	1225	3742447	220855	19511	19525
15	T	1220	3963302	195207	19511	19549
16	F	0940	4158509	↑	19511	19570
17						
18				674071		
19	M	1050	4832580	230415	19511	19643
20	T	1155	5062995	200608	19536	19643
21	W	0950	5263603	211439	19558	19643
22	T	0945	5475042	232898	19581	19643
23	F	1020	5707940	↑	19606	19643
24						
25				665105		
26	M	1050	6373045	218465	19679	19643
27	T	1035	6691510	215743	19703	19643
28	W	1045	6807253	216371	19703	19668
29	T	1025	7017624	216007	19703	19691
30	F	1030	7233631	↑	19703	19715
31				429783		
Total				6566259		
Average				211815		

NEXT MONTH READING 7663414

DATE 02-01-04

MONTH / YEAR

Feb. 04

**BLACK DECKER
AIR STRIPPER # 2
OPERATING RECORD**

PAST MONTH READING

1233631

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	S	1045	7663414	209451	19703	19763
2	M	1005	7872865	218230	19703	19787
3	T	1035	8091095	179846	19727	19787
4	W	0945	8270941	195842	19750	19787
5	T	0920	8476787	230065	19773	19787
6	F	1120	8706848	↑	19800	19787
7						
8				515154		
9	M	0815	9322004	214566	19869	19787
10	T	0810	9436570	220830	19869	19811
11	W	0840	9657400	215196	19869	19835
12	T	0840	9872596	213635	19869	19859
13	F	0825	10086231	↑	19869	19883
14						
15				653899		
16	M	0900	10740130	225419	19869	19956
17	T	1005	10965549	215469	19894	19956
18	W	1005	11181018	204579	19918	19956
19	T	0850	11385597	203957	19940	19956
20	F	0730	11589554	↑	19963	19956
21						
22				662153		
23	M	0910	12251707	221911	20037	19956
24	T	0950	12473618	211687	20037	19980
25	W	0930	12685305	230117	20037	20004
26	T	1110	12915422	196199	20037	20030
27	F	0905	13111621	↑	20037	20052
28	S					
29	S			644035		
30						
31						
Total				6081242		
Average				209698		

NEXT MONTH READING 13755656

DATE 3-1-04

**BLACK DECKER
AIR STRIPPER # 2
OPERATING RECORD**

MONTH / YEAR

Mar. 2004

PAST MONTH READING

13111621

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	M	0910	13755656	239552	20037	20124
2	T	1150	13995208	242403	20064	20124
3	W	1500	14237611	186671	20091	20124
4	T	1155	14424282	210140	20112	20124
5	F	1125	14634422	↑	20135	20124
6						
7				634369		
8	M	1025	15268791	202657	20206	20124
9	T	0905	15471448	237326	20206	20146
10	W	1145	15708774	186445	20206	20173
11	T	0840	15895219	225176	20206	20194
12	F	1000	16120395	↑	20206	20219
13						
14				633491		
15	M	0915	16753886	204627	20206	20291
16	T	0825	16958513	220567	20229	20291
17	W	0915	17179080	214013	20254	20291
18	T	0925	17393093	205289	20278	20291
19	F	0845	17595382	↑	20307	20291
20						
21				660050		
22	M	1105	18258432	223500	20376	20291
23	T	0945	18481932	242389	20376	20313
24	W	1030	18724321	238677	20376	20338
25	T	1025	18962398	233937	20376	20362
26	F	0955	19196335	↑	20376	20385
27						
28				716100		
29	M	1015	19912435	230187	20376	20458
30	T	0935	20142622	238098	20399	20458
31	W	0945	20380720	238165	20423	20458
Total				6863229		
Average				221394		

NEXT MONTH READING 20618885

DATE 4-1-04

**APPENDIX B
DISCHARGE MONITORING REPORTS
(JANUARY - MARCH 2004)**

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)
NAME: AG/GFI Hampstead, Inc.
ADDRESS: 133 Pearl Street
Suite 400
Boston, MA 02110
FACILITY: Hampstead, Maryland 21074
LOCATION: CARROLL COUNTY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
PERMIT NUMBER

001
DISCHARGE NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2004	01	01	04	01	31

FROM

TO

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	QUANTITY OR LOADING (4 Card Only)			QUALITY OR CONCENTRATION (4 Card Only)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.138	0.167	MGD					0	Measured/Recorded	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Measured/Recorded	
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						5			1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						5			1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						5			1/MONTH	GRAB
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT						<0.1	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						0.011	0.010		1/MONTH	GRAB
OIL & GREASE	SAMPLE MEASUREMENT						<5	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						10	<5		1/MONTH	GRAB
pH	SAMPLE MEASUREMENT				6.74		7.09	STD	0	2WEEK	GRAB
	PERMIT REQUIREMENT				6.00		8.00			2WEEK	GRAB

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Henry C Suominen, Jr.
AG/GFI Manger
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 16 U.S.C. § 1301 AND 33 U.S.C. § 1311. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 3 years.)

Earl Wedde
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
 410-374-9025
 AREA CODE-NUMBER
 DATE
 04 | 02 | 03
 YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

NAME: **AG/GFI Hampstead, Inc.**
 ADDRESS: **133 Pearl Street**
Suite 400
Boston, MA 02110

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER (2-16)

001
 DISCHARGE NUMBER (17-18)

FACILITY: **Hampstead, Maryland, 21074**

LOCATION: **CARROLL COUNTY**

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
2004	01	01	04	01	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)				NO EX (62-67)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
BOD	SAMPLE MEASUREMENT							5.6	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT							15			1/MONTH	GRAB
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT							3.5	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT							20 30			1/MONTH	GRAB
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREON; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 22 U.S.C. § 1315. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	<i>Earl Wedder</i> SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
Henry C Suominen, Jr. AG/GFI Manger			410-374-9025	04 02 03
TYPED OR PRINTED			AREA CODE-NUMBER	YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **AG/GFI Hampstead, Inc.**
 ADDRESS: **133 Pearl Street**
 Suite 400
 Boston, MA 02110
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER

101
 DISCHARGE NUMBER

MONITORING PERIOD					
FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
2004	01	01	04	01	31

FORM APPROVED
 OMB No 2040-0004

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (46-53)				NO EX (62-65)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
FLOW	SAMPLE MEASUREMENT	0.280	0.392	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record	
FECAL COLIFORM	SAMPLE MEASUREMENT					<2	MPN/ 100ml		0	1/WEEK GRAB	
	PERMIT REQUIREMENT					200				1/WEEK GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER									TELEPHONE	DATE	
Henry C Suominen, Jr. AG/GFI Manger									410-374-9025	04 02 03	
TYPED OR PRINTED									AREA CODE-NUMBER	YEAR MO DAY	

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1318. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Weddler
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **AG/GFI Hampstead, Inc.**
 ADDRESS: **133 Pearl Street**
Suite 400
Boston, MA 02110
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No. 2040-0004

MD0001881
 PERMIT NUMBER (2-19)

201
 DISCHARGE NUMBER (17-19)

MONITORING PERIOD					
FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
2004	01	01	04	01	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-67)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.212	0.250	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record	
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER Henry C Suominen, Jr. AG/GFI Manger TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1312. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 3 years.)	<i>Earl Wedder</i> SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
			410-374-9025 AREA CODE-NUMBER	04 02 03 YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **AG/GFI Hampstead, Inc.**
 ADDRESS: **133 Pearl Street**
Suite 400
Boston, MA 02110

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881 **001**
 PERMIT NUMBER DISCHARGE NUMBER

(2-18) (17-18)

MONITORING PERIOD

FROM YEAR 2004 MO 02 DAY 01 TO YEAR 04 MO 02 DAY 29

(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUALITY OR CONCENTRATION (4 Card Only)			NO. EX. ANALYSIS (62-65)	FREQUENCY OF ANALYSIS (64-66)	SAMPLE TYPE (68-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW	SAMPLE MEASUREMENT	0.303	0.482	MGD				0	Measured/Recorded	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT						Measured/Recorded	
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	0	1/MONTH GRAB	
	PERMIT REQUIREMENT						5		1/MONTH GRAB	
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	0	1/MONTH GRAB	
	PERMIT REQUIREMENT						5		1/MONTH GRAB	
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	0	1/MONTH GRAB	
	PERMIT REQUIREMENT						5		1/MONTH GRAB	
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT						<0.1	0	1/MONTH GRAB	
	PERMIT REQUIREMENT					0.011	0.010		1/MONTH GRAB	
OIL & GREASE	SAMPLE MEASUREMENT						<5	0	1/MONTH GRAB	
	PERMIT REQUIREMENT					10	<5		1/MONTH GRAB	
pH	SAMPLE MEASUREMENT				6.17		7.41	0	2/WEEK GRAB	
	PERMIT REQUIREMENT				6.00		8.00		2/WEEK GRAB	

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Henry C Suominen, Jr.
AG/GFI Manger
 TYPED OR PRINTED

Earl Weddler
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: 410-374-9025
 DATE: 04 | 03 | 05
 AREA CODE-NUMBER: YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.
 EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **AG/GFI Hampstead, Inc.**
 ADDRESS: **133 Pearl Street**
Suite 400
Boston, MA 02110

FACILITY: **Hampstead, Maryland, 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No. 2040-0004

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

(2-16)			(17-19)		
MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2004	02	01	04	02	29

FROM

TO

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
BOD	SAMPLE MEASUREMENT								0	1/MONTH	GRAB
	PERMIT REQUIREMENT									1/MONTH	GRAB
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT					4.5			0	1/MONTH	GRAB
	PERMIT REQUIREMENT					20	30	mg/l		1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER

Henry C Suominen, Jr.
AG/GFI Manger

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1315. (Penalties under these statutes may include: fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Weddler
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

410-374-9025

AREA CODE-NUMBER

DATE

04 | 03 | 05

YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **AG/GFI Hampstead, Inc.**
 ADDRESS: **133 Pearl Street**
Suite 400
Boston, MA 02110

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No. 2040-0004

MD0001881	101
PERMIT NUMBER	DISCHARGE NUMBER
(2-16)	(17-18)

MONITORING PERIOD					
FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
2004	02	01	04	02	29
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW	SAMPLE MEASUREMENT	0.282	0.308	MGD				0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record
FECAL COLIFORM	SAMPLE MEASUREMENT					<2	MPN/ 100ml	0	1/WEEK	GRAB
	PERMIT REQUIREMENT					200			1/WEEK	GRAB
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Henry C Suominen, Jr.
AG/GFI Manger
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREON, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 35 U.S.C. § 1315. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Weddell
 SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE
 410-374-9025
 AREA CODE-NUMBER

DATE
 04 | 03 | 05
 YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: AG/GFI Hampstead, Inc.
 ADDRESS: 133 Pearl Street
Suite 400
Boston, MA 02110
 FACILITY: Hampstead, Maryland 21074
 LOCATION: CARROLL COUNTY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No. 2040-0004

MD0001881
 PERMIT NUMBER

201
 DISCHARGE NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2004	02	01	04	02	29

FROM

TO

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION				NO EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.210	0.230	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT					<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT					N/A					
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT					<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT					N/A					
TRICHLOROETHYLENE	SAMPLE MEASUREMENT					<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT					N/A					
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						TELEPHONE		DATE	
Henry C Suominen, Jr. AG/GFI Manger								410-374-9025		04 03 05	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						AREA CODE-NUMBER		YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **AG/GFI Hampstead, Inc.**

ADDRESS: **133 Pearl Street**

Suite 400

Boston, MA 02110

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881

PERMIT NUMBER

(2-10)

001

DISCHARGE NUMBER

(17-18)


FORM APPROVED

OMB No. 2040-0004

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	2004	03	01		04	03	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
FLOW	SAMPLE MEASUREMENT	0.227	0.352	MGD				0	Measured/Recorded		
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT						Measured/Recorded		
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	0	1/MONTH GRAB		
	PERMIT REQUIREMENT						5	ppb	1/MONTH GRAB		
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	0	1/MONTH GRAB		
	PERMIT REQUIREMENT						5	ppb	1/MONTH GRAB		
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	0	1/MONTH GRAB		
	PERMIT REQUIREMENT						5	ppb	1/MONTH GRAB		
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT						<0.1	0	1/MONTH GRAB		
	PERMIT REQUIREMENT						<0.1	mg/l	1/MONTH GRAB		
OIL & GREASE	SAMPLE MEASUREMENT						<5	0	1/MONTH GRAB		
	PERMIT REQUIREMENT						10	15	mg/l	1/MONTH GRAB	
pH	SAMPLE MEASUREMENT				6.27		7.08	0	2/WEEK GRAB		
	PERMIT REQUIREMENT				6.00		8.50	STD	2/WEEK GRAB		
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREON; AND BASED ON MY INQUIRY OF THESE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 16 U.S.C. § 1361 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						TELEPHONE		DATE	
Henry C Suominen, Jr. AG/GFI Manger								410-374-9025		04 04 02	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						AREA CODE/NUMBER		YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PAGE 1 OF 2

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **AG/GFI Hampstead, Inc.**
 ADDRESS: **133 Pearl Street**
Suite 400
Boston, MA 02110
 FACILITY: **Hampstead, Maryland, 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No. 2040-0004

MD001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

(2-16)

(17-19)

MONITORING PERIOD

FROM

YEAR	MO	DAY
2004	03	01

 TO

YEAR	MO	DAY
04	03	31

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
BOD	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT							0	1/MONTH	GRAB	
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT					5.7	9.0				
	PERMIT REQUIREMENT					20	30	0	1/MONTH	GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						TELEPHONE		DATE	
Henry C Suominen, Jr. AG/GFI Manger								410-374-9025		04 04 02	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						AREA CODE-NUMBER		YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **AG/GFI Hampstead, Inc.**
 ADDRESS: **133 Pearl Street**
Suite 400
Boston, MA 02110
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No. 2040-0004

MD0001881 **101**
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD
 FROM YEAR MO DAY TO YEAR MO DAY
2004 03 01 04 03 31
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (46-53)				NO EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.264	0.269	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record	
FECAL COLIFORM	SAMPLE MEASUREMENT					<2	MPN/ 100ml	0	1/WEEK	GRAB	
	PERMIT REQUIREMENT					200			1/WEEK	GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Henry C Suominen, Jr.
AG/GFI Manger
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 22 U.S.C. § 1519. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Weddle
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **410-374-9025**
 DATE **04 | 04 | 02**
 AREA CODE-NUMBER YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **AG/GFI Hampstead, Inc.**
 ADDRESS: **133 Pearl Street**
Suite 400
Boston, MA 02110
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)


DISCHARGE MONITORING REPORT (DMR)

MD0001881 **201**
 PERMIT NUMBER DISCHARGE NUMBER
 (2-16) (17-19)

FORM APPROVED
 OMB No. 2040-0004

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2004	03	01	04	03	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.221	0.242	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record	
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 18 U.S.C. § 1519. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)							TELEPHONE	DATE	
Henry C Suominen, Jr. AG/GFI Manger TYPED OR PRINTED									 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	410-374-9025	04 04 02
COMMENT AND EXPLANATION OF ANY VIOLATIONS									AREA CODE-NUMBER	YEAR MO DAY	

(Reference all attachments here)

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(JANUARY - MARCH 2004)



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800
 Fax: 410-633-6553
 www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 4

Client: AG/GFI Hampstead Client Sample ID: Air Stripper 2 (Pre)
 Report No: 0401102 Lab ID: 0401102-002
 Project: Hampstead-Monthly Collection Date: 1/7/2004 10:09
 Matrix: WASTEWATER

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
VOLATILE ORGANIC COMPOUNDS (EPA 624)				Analyst: THP
Prep. Method: <u>NA</u>	Prep. Date: <u>NA</u>	Prep Analyst	<u>NA</u>	
Chloromethane	< 10	10	µg/L	1/14/2004 17:46
Vinyl chloride	< 10	10	µg/L	1/14/2004 17:46
Bromomethane	< 10	10	µg/L	1/14/2004 17:46
Chloroethane	< 10	10	µg/L	1/14/2004 17:46
Acrolein	< 100	100	µg/L	1/14/2004 17:46
1,1-Dichloroethene	< 5.0	5.0	µg/L	1/14/2004 17:46
Methylene chloride	< 5.0	5.0	µg/L	1/14/2004 17:46
Acrylonitrile	< 100	100	µg/L	1/14/2004 17:46
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	1/14/2004 17:46
1,1-Dichloroethane	< 5.0	5.0	µg/L	1/14/2004 17:46
Chloroform	< 5.0	5.0	µg/L	1/14/2004 17:46
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	1/14/2004 17:46
Carbon tetrachloride	< 5.0	5.0	µg/L	1/14/2004 17:46
Benzene	< 5.0	5.0	µg/L	1/14/2004 17:46
1,2-Dichloroethane	< 5.0	5.0	µg/L	1/14/2004 17:46
Trichloroethene	280	25	µg/L	1/14/2004 17:14
1,2-Dichloropropane	< 5.0	5.0	µg/L	1/14/2004 17:46
Bromodichloromethane	< 5.0	5.0	µg/L	1/14/2004 17:46
2-Chloroethyl vinyl ether	< 10	10	µg/L	1/14/2004 17:46
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	1/14/2004 17:46
Toluene	< 5.0	5.0	µg/L	1/14/2004 17:46
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	1/14/2004 17:46
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	1/14/2004 17:46
Tetrachloroethene	55	5.0	µg/L	1/14/2004 17:46
Dibromochloromethane	< 5.0	5.0	µg/L	1/14/2004 17:46
Chlorobenzene	< 5.0	5.0	µg/L	1/14/2004 17:46
Ethylbenzene	< 5.0	5.0	µg/L	1/14/2004 17:46
Bromoform	< 5.0	5.0	µg/L	1/14/2004 17:46



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 5

Client: AG/GFI Hampstead

Client Sample ID: Air Stripper 2 (Pre)

Report No: 0401102

Lab ID: 0401102-002

Project: Hampstead-Monthly

Collection Date: 1/7/2004 10:09

Matrix: WASTEWATER

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	1/14/2004 17:46
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	1/14/2004 17:46
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	1/14/2004 17:46
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	1/14/2004 17:46



Microbac

www.microbac.com

Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 6

Client: AG/GFI Hampstead

Client Sample ID: Outfall 201 (Post)

Report No: 0401102

Lab ID: 0401102-003

Project: Hampstead-Monthly

Collection Date: 1/7/2004 10:08

Matrix: WASTEWATER

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: THP

Prep. Method: NA

Prep. Date: NA

Prep Analyst: NA

Chloromethane	< 10	10	µg/L	1/14/2004 18:17
Vinyl chloride	< 10	10	µg/L	1/14/2004 18:17
Bromomethane	< 10	10	µg/L	1/14/2004 18:17
Chloroethane	< 10	10	µg/L	1/14/2004 18:17
Acrolein	< 100	100	µg/L	1/14/2004 18:17
1,1-Dichloroethene	< 5.0	5.0	µg/L	1/14/2004 18:17
Methylene chloride	< 5.0	5.0	µg/L	1/14/2004 18:17
Acrylonitrile	< 100	100	µg/L	1/14/2004 18:17
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	1/14/2004 18:17
1,1-Dichloroethane	< 5.0	5.0	µg/L	1/14/2004 18:17
Chloroform	< 5.0	5.0	µg/L	1/14/2004 18:17
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	1/14/2004 18:17
Carbon tetrachloride	< 5.0	5.0	µg/L	1/14/2004 18:17
Benzene	< 5.0	5.0	µg/L	1/14/2004 18:17
1,2-Dichloroethane	< 5.0	5.0	µg/L	1/14/2004 18:17
Trichloroethene	< 5.0	5.0	µg/L	1/14/2004 18:17
1,2-Dichloropropane	< 5.0	5.0	µg/L	1/14/2004 18:17
Bromodichloromethane	< 5.0	5.0	µg/L	1/14/2004 18:17
2-Chloroethyl vinyl ether	< 10	10	µg/L	1/14/2004 18:17
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	1/14/2004 18:17
Toluene	< 5.0	5.0	µg/L	1/14/2004 18:17
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	1/14/2004 18:17
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	1/14/2004 18:17
Tetrachloroethene	< 5.0	5.0	µg/L	1/14/2004 18:17
Dibromochloromethane	< 5.0	5.0	µg/L	1/14/2004 18:17
Chlorobenzene	< 5.0	5.0	µg/L	1/14/2004 18:17
Ethylbenzene	< 5.0	5.0	µg/L	1/14/2004 18:17
Bromoform	< 5.0	5.0	µg/L	1/14/2004 18:17



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 7

Client: AG/GFI Hampstead

Client Sample ID: Outfall 201 (Post)

Report No: 0401102

Lab ID: 0401102-003

Project: Hampstead-Monthly

Collection Date: 1/7/2004 10:08

Matrix: WASTEWATER

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	1/14/2004 18:17
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	1/14/2004 18:17
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	1/14/2004 18:17
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	1/14/2004 18:17



Microbac

www.microbac.com

Microbac Laboratories, Inc. Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 5

Client: AG/GFI Hampstead
Report No: 0402080
Project: Hampstead-Annually
Matrix: WASTEWATER

Client Sample ID: Air Stripper (2 Pre)
Lab ID: 0402080-002
Collection Date: 2/4/2004 11:33

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
VOLATILE ORGANIC COMPOUNDS (EPA 624)				
Prep. Method: <u>NA</u>	Prep. Date: <u>NA</u>		Prep Analyst <u>NA</u>	Analyst: THP
Chloromethane	< 10	10	µg/L	2/8/2004 18:23
Vinyl chloride	< 10	10	µg/L	2/8/2004 18:23
Bromomethane	< 10	10	µg/L	2/8/2004 18:23
Chloroethane	< 10	10	µg/L	2/8/2004 18:23
Acrolein	< 100	100	µg/L	2/8/2004 18:23
1,1-Dichloroethene	< 5.0	5.0	µg/L	2/8/2004 18:23
Methylene chloride	< 5.0	5.0	µg/L	2/8/2004 18:23
Acrylonitrile	< 100	100	µg/L	2/8/2004 18:23
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	2/8/2004 18:23
1,1-Dichloroethane	< 5.0	5.0	µg/L	2/8/2004 18:23
Chloroform	< 5.0	5.0	µg/L	2/8/2004 18:23
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	2/8/2004 18:23
Carbon tetrachloride	< 5.0	5.0	µg/L	2/8/2004 18:23
Benzene	< 5.0	5.0	µg/L	2/8/2004 18:23
1,2-Dichloroethane	< 5.0	5.0	µg/L	2/8/2004 18:23
Trichloroethene	280	25	µg/L	2/8/2004 17:48
1,2-Dichloropropane	< 5.0	5.0	µg/L	2/8/2004 18:23
Bromodichloromethane	< 5.0	5.0	µg/L	2/8/2004 18:23
2-Chloroethyl vinyl ether	< 10	10	µg/L	2/8/2004 18:23
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	2/8/2004 18:23
Toluene	< 5.0	5.0	µg/L	2/8/2004 18:23
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	2/8/2004 18:23
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	2/8/2004 18:23
Tetrachloroethene	64	5.0	µg/L	2/8/2004 18:23
Dibromochloromethane	< 5.0	5.0	µg/L	2/8/2004 18:23
Chlorobenzene	< 5.0	5.0	µg/L	2/8/2004 18:23
Ethylbenzene	< 5.0	5.0	µg/L	2/8/2004 18:23
Bromoform	< 5.0	5.0	µg/L	2/8/2004 18:23



Microbac

www.microbac.com

Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 6

Client:	AG/GFI Hampstead	Client Sample ID:	Air Stripper (2 Pre)
Report No:	0402080	Lab ID:	0402080-002
Project:	Hampstead-Annually	Collection Date:	2/4/2004 11:33
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed	
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	2/8/2004	18:23
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	2/8/2004	18:23
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	2/8/2004	18:23
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	2/8/2004	18:23



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 7

Client:	AG/GFI Hampstead	Client Sample ID:	Outfall 201 (Post)
Report No:	0402080	Lab ID:	0402080-003
Project:	Hampstead-Annually	Collection Date:	2/4/2004 11:34
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: THP

Prep. Method: NA

Prep. Date: NA

Prep Analyst NA

Chloromethane	< 10	10	µg/L	2/8/2004 18:56
Vinyl chloride	< 10	10	µg/L	2/8/2004 18:56
Bromomethane	< 10	10	µg/L	2/8/2004 18:56
Chloroethane	< 10	10	µg/L	2/8/2004 18:56
Acrolein	< 100	100	µg/L	2/8/2004 18:56
1,1-Dichloroethene	< 5.0	5.0	µg/L	2/8/2004 18:56
Methylene chloride	< 5.0	5.0	µg/L	2/8/2004 18:56
Acrylonitrile	< 100	100	µg/L	2/8/2004 18:56
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	2/8/2004 18:56
1,1-Dichloroethane	< 5.0	5.0	µg/L	2/8/2004 18:56
Chloroform	< 5.0	5.0	µg/L	2/8/2004 18:56
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	2/8/2004 18:56
Carbon tetrachloride	< 5.0	5.0	µg/L	2/8/2004 18:56
Benzene	< 5.0	5.0	µg/L	2/8/2004 18:56
1,2-Dichloroethane	< 5.0	5.0	µg/L	2/8/2004 18:56
Trichloroethene	< 5.0	5.0	µg/L	2/8/2004 18:56
1,2-Dichloropropane	< 5.0	5.0	µg/L	2/8/2004 18:56
Bromodichloromethane	< 5.0	5.0	µg/L	2/8/2004 18:56
2-Chloroethyl vinyl ether	< 10	10	µg/L	2/8/2004 18:56
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	2/8/2004 18:56
Toluene	< 5.0	5.0	µg/L	2/8/2004 18:56
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	2/8/2004 18:56
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	2/8/2004 18:56
Tetrachloroethene	< 5.0	5.0	µg/L	2/8/2004 18:56
Dibromochloromethane	< 5.0	5.0	µg/L	2/8/2004 18:56
Chlorobenzene	< 5.0	5.0	µg/L	2/8/2004 18:56
Ethylbenzene	< 5.0	5.0	µg/L	2/8/2004 18:56
Bromoform	< 5.0	5.0	µg/L	2/8/2004 18:56



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 8

Client: AG/GFI Hampstead **Client Sample ID:** Outfall 201 (Post)
Report No: 0402080 **Lab ID:** 0402080-003
Project: Hampstead-Annually **Collection Date:** 2/4/2004 11:34
Matrix: WASTEWATER

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	2/6/2004 18:56
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	2/6/2004 18:56
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	2/6/2004 18:56
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	2/6/2004 18:56



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 4

Client:	AG/GFI Hampstead	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0403097	Lab ID:	0403097-002
Project:	Hampstead-Monthly	Collection Date:	3/3/2004 13:30
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: THP

Prep. Method: NA

Prep. Date: NA

Prep Analyst NA

Chloromethane	< 10	10	µg/L	3/9/2004	3:59
Vinyl chloride	< 10	10	µg/L	3/9/2004	3:59
Bromomethane	< 10	10	µg/L	3/9/2004	3:59
Chloroethane	< 10	10	µg/L	3/9/2004	3:59
Acrolein	< 100	100	µg/L	3/9/2004	3:59
1,1-Dichloroethene	< 5.0	5.0	µg/L	3/9/2004	3:59
Methylene chloride	< 5.0	5.0	µg/L	3/9/2004	3:59
Acrylonitrile	< 100	100	µg/L	3/9/2004	3:59
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	3/9/2004	3:59
1,1-Dichloroethane	< 5.0	5.0	µg/L	3/9/2004	3:59
Chloroform	< 5.0	5.0	µg/L	3/9/2004	3:59
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	3/9/2004	3:59
Carbon tetrachloride	< 5.0	5.0	µg/L	3/9/2004	3:59
Benzene	< 5.0	5.0	µg/L	3/9/2004	3:59
1,2-Dichloroethane	< 5.0	5.0	µg/L	3/9/2004	3:59
Trichloroethene	460	25	µg/L	3/9/2004	3:27
1,2-Dichloropropane	< 5.0	5.0	µg/L	3/9/2004	3:59
Bromodichloromethane	< 5.0	5.0	µg/L	3/9/2004	3:59
2-Chloroethyl vinyl ether	< 10	10	µg/L	3/9/2004	3:59
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	3/9/2004	3:59
Toluene	< 5.0	5.0	µg/L	3/9/2004	3:59
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	3/9/2004	3:59
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	3/9/2004	3:59
Tetrachloroethene	56	5.0	µg/L	3/9/2004	3:59
Dibromochloromethane	< 5.0	5.0	µg/L	3/9/2004	3:59
Chlorobenzene	< 5.0	5.0	µg/L	3/9/2004	3:59
Ethylbenzene	< 5.0	5.0	µg/L	3/9/2004	3:59
Bromoform	< 5.0	5.0	µg/L	3/9/2004	3:59



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 5

Client: AG/GFI Hampstead **Client Sample ID:** Air Stripper 2 (Pre)
Report No: 0403097 **Lab ID:** 0403097-002
Project: Hampstead-Monthly **Collection Date:** 3/3/2004 13:30
Matrix: WASTEWATER

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed	
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	3/9/2004	3:59
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	3/9/2004	3:59
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	3/9/2004	3:59
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	3/9/2004	3:59



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 6

Client: AG/GFI Hampstead	Client Sample ID: Outfall 201 (Post)
Report No: 0403097	
Project: Hampstead-Monthly	Lab ID: 0403097-003
Matrix: WASTEWATER	Collection Date: 3/3/2004 13:29

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
VOLATILE ORGANIC COMPOUNDS (EPA 624)				
Prep. Method: <u>NA</u>	Prep. Date: <u>NA</u>		Prep Analyst <u>NA</u>	Analyst: THP
Chloromethane	< 10	10	µg/L	3/9/2004 4:34
Vinyl chloride	< 10	10	µg/L	3/9/2004 4:34
Bromomethane	< 10	10	µg/L	3/9/2004 4:34
Chloroethane	< 10	10	µg/L	3/9/2004 4:34
Acrolein	< 100	100	µg/L	3/9/2004 4:34
1,1-Dichloroethene	< 5.0	5.0	µg/L	3/9/2004 4:34
Methylene chloride	< 5.0	5.0	µg/L	3/9/2004 4:34
Acrylonitrile	< 100	100	µg/L	3/9/2004 4:34
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	3/9/2004 4:34
1,1-Dichloroethane	< 5.0	5.0	µg/L	3/9/2004 4:34
Chloroform	< 5.0	5.0	µg/L	3/9/2004 4:34
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	3/9/2004 4:34
Carbon tetrachloride	< 5.0	5.0	µg/L	3/9/2004 4:34
Benzene	< 5.0	5.0	µg/L	3/9/2004 4:34
1,2-Dichloroethane	< 5.0	5.0	µg/L	3/9/2004 4:34
Trichloroethene	< 5.0	5.0	µg/L	3/9/2004 4:34
1,2-Dichloropropane	< 5.0	5.0	µg/L	3/9/2004 4:34
Bromodichloromethane	< 5.0	5.0	µg/L	3/9/2004 4:34
2-Chloroethyl vinyl ether	< 10	10	µg/L	3/9/2004 4:34
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	3/9/2004 4:34
Toluene	< 5.0	5.0	µg/L	3/9/2004 4:34
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	3/9/2004 4:34
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	3/9/2004 4:34
Tetrachloroethene	< 5.0	5.0	µg/L	3/9/2004 4:34
Dibromochloromethane	< 5.0	5.0	µg/L	3/9/2004 4:34
Chlorobenzene	< 5.0	5.0	µg/L	3/9/2004 4:34
Ethylbenzene	< 5.0	5.0	µg/L	3/9/2004 4:34
Bromoform	< 5.0	5.0	µg/L	3/9/2004 4:34



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 7

Client: AG/GFI Hampstead **Client Sample ID:** Outfall 201 (Post)
Report No: 0403097 **Lab ID:** 0403097-003
Project: Hampstead-Monthly **Collection Date:** 3/3/2004 13:29
Matrix: WASTEWATER

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	3/9/2004 4:34
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	3/9/2004 4:34
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	3/9/2004 4:34
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	3/9/2004 4:34

APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(FEBRUARY 2004)



Client: BLACK & DECKER
LVL #: 0402L870

W.O. #: 02501-004-002-0200-00
Date Received: 02-20-2004


GC/MS VOLATILE

Thirty-three (33) water samples were collected on 02-18,19-2004.

The samples and their associated QC samples were analyzed according to criteria set forth in Lionville Laboratory SOPs based on SW 846 Method 8260A for TCL Volatile target compounds on 02-27,28-2004 and 03-01-2004.

The following is a summary of the QC results accompanying the sample results and a description of any problems encountered during their analyses:

1. All results presented in this report are derived from samples that met LVL's sample acceptance policy.
2. The required holding time for analysis was met.
3. A non-target compound was detected in sample RFW-17.
4. Several samples required 2 to 25-fold dilution due to high levels of target compounds.
5. Four (4) of one hundred fifty (150) surrogate recoveries were outside EPA QC limits. The analysis of associated matrix spike duplicate fulfills the reanalysis requirement of sample RFW-4A MS. Sample EW-9 was diluted, analyzed on 03-01-2004 and reported. Sample RFW-3B was reanalyzed on 03-01-2004 and reported.
6. All matrix spike recoveries were within EPA QC limits.
7. All blank spike recoveries were within EPA QC limits.
8. Internal standard area criteria were not met for several samples. The analysis of associated matrix spike samples fulfills the reanalysis requirement of sample RFW-4A. Sample EW-9 DUP was diluted, analyzed on 03-01-2004 and reported. All other out of criteria samples were reanalyzed on 03-01-2004 and reported.
9. Manual integrations are performed according to SOP QA-125 to produce quality data with the utmost integrity. All manual integrations are required to be technically valid and properly documented. Appropriate technical flags are defined in the Glossary ("Technical Flags For Manual Integration").


J. Michael Taylor
President
Lionville Laboratory Incorporated

3/19/04
Date

som\group\data\bna\black-decker\0402-870.doc

The results presented in this report relate only to the analytical testing and conditions of the samples at receipt and during storage. All pages of this report are integral parts of the analytical data. Therefore, this report should only be reproduced in its entirety of 7 2 pages.

GLOSSARY

DATA QUALIFIERS

- U** = Compound was analyzed for but not detected. The associated numerical value is the estimated sample quantitation limit which is included and corrected for dilution and percent moisture.
- J** = Indicates an estimated value. This flag is used under the following circumstances: 1) when estimating a concentration for tentatively identified compounds (TICs) where a 1:1 response is assumed; or 2) when the mass spectral data indicate the presence of a compound that meets the identification criteria but the result is less than the specified detection limit but greater than zero. For example, if the limit of detection is 10 ug/L and a concentration of 3 ug/L is calculated, it is reported as 3J.
- B** = This flag is used when the analyte is found in the associated blank as well as in the sample. It indicates possible/probable blank contamination. This flag is also used for a TIC as well as for a positively identified TCL compound.
- E** = Indicates that the compound was detected beyond the calibration range and was subsequently analyzed at a dilution.
- D** = Identifies all compounds identified in an analysis at a secondary dilution factor.
- I** = Interference.
- NQ** = Result qualitatively confirmed but not able to quantify.
- N** = Indicates presumptive evidence of a compound. This flag is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It is applied to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the N code is not used.
- X** = This flag is used for a TIC compound which is quantified relative to a response factor generated from a daily calibration standard (rather than quantified relative to the closest internal standard).
- Y** = Additional qualifiers used as required are explained in the case narrative.

sb\10-03\gloss.doc



GLOSSARY

ABBREVIATIONS

- BS** = Indicates blank spike in which reagent grade water is spiked with the CLP matrix spike solutions and carried through all the steps in the method. Spike recoveries are reported.
- BSD** = Indicates blank spike duplicate.
- MS** = Indicates matrix spike.
- MSD** = Indicates matrix spike duplicate.
- DL** = Suffix added to sample number to indicate that results are from a diluted analysis.
- NA** = Not Applicable.
- DF** = Dilution Factor.
- NR** = Not Required.
- SP, Z** = Indicates Spiked Compound.

sb\10-03\gloss.doc



TECHNICAL FLAGS FOR MANUAL INTEGRATION

Manual quan modifications or integrations are performed routinely to improve the data quality for a variety of technical reasons. Documentation of these modifications should be clear and concise. The following 'flags' are used to indicate the technical reasons for quan modifications:

- MP - **Missed Peak:** Manually added peak not found by automatic quan program.
- PA - **Peak Assignment:** Quan report was changed to reflect correct peak assignment.
- RJ - **Routine Integration:** Routine integrations are performed for some analytes that are consistently integrated improperly by the automatic integration programs. Examples are the Dichlorobenzene isomers on the VOA packed column and Benzo (b) fluoranthene /Benzo (k) fluoranthene which are poorly resolve on the BNA column.
- SP - **Split Peak:** The automatic integration improperly split the peak; a manual integration was performed to get the correct area.
- CB - **Co-elution/ Background:** Peak was manually integrated to eliminate contribution from co-eluting compounds, background signal, or other interference.
- PI - **Proper Integration:** A peak with poor or inconsistent integration (i.e., excessive tail) was properly integrated manually.

LVL-21-21-035/A-08/93



Lionville Laboratory, Inc.

Volatiles by GC/MS, HSL List

Report Date: 03/18/04 11:31

RFW Batch Number: 0402L870

Client: BLACK & DECKER

Work Order: 02501004002 Page: 1a

	Cust ID:	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7
Sample Information	RFW#:	001	002	003	004	005	006
	Matrix:	WATER	WATER	WATER	WATER	WATER	WATER
	D.F.:	10.0	5.00	25.0	10.0	1.00	1.00
	Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L
Surrogate	Toluene-d8	95 %	97 %	103 %	100 %	101 %	94 %
Recovery	Bromofluorobenzene	98 %	103 %	105 %	106 %	114 %	102 %
	1,2-Dichloroethane-d4	107 %	111 %	119 %	118 %	120 %	113 %
=====fl=====fl=====fl=====fl=====fl=====fl=====fl=====							
Chloromethane		100 U	50 U	250 U	100 U	10 U	10 U
Bromomethane		100 U	50 U	250 U	100 U	10 U	10 U
Vinyl Chloride		100 U	50 U	250 U	100 U	10 U	10 U
Chloroethane		100 U	50 U	250 U	100 U	10 U	10 U
Methylene Chloride		50 U	25 U	120 U	50 U	5 U	5 U
Acetone		100 U	50 U	250 U	25 J	10 U	10 U
Carbon Disulfide		50 U	25 U	120 U	50 U	5 U	5 U
1,1-Dichloroethene		50 U	25 U	120 U	50 U	5 U	5 U
1,1-Dichloroethane		50 U	25 U	120 U	50 U	5 U	5 U
1,2-Dichloroethene (total)		50 U	25 U	120 U	50 U	5 U	3 J
Chloroform		50 U	25 U	120 U	50 U	5 U	5 U
1,2-Dichloroethane		50 U	25 U	120 U	50 U	5 U	5 U
2-Butanone		100 U	50 U	250 U	100 U	10 U	10 U
1,1,1-Trichloroethane		50 U	25 U	120 U	50 U	5 U	5 U
Carbon Tetrachloride		50 U	25 U	120 U	50 U	5 U	5 U
Vinyl Acetate		100 U	50 U	250 U	100 U	10 U	10 U
Bromodichloromethane		50 U	25 U	120 U	50 U	5 U	5 U
1,2-Dichloropropane		50 U	25 U	120 U	50 U	5 U	5 U
cis-1,3-Dichloropropene		50 U	25 U	120 U	50 U	5 U	5 U
Trichloroethene		1100	350	3800	590	11	4 J
Dibromochloromethane		50 U	25 U	120 U	50 U	5 U	5 U
1,1,2-Trichloroethane		50 U	25 U	120 U	50 U	5 U	5 U
Benzene		50 U	25 U	120 U	50 U	5 U	5 U
Trans-1,3-Dichloropropene		50 U	25 U	120 U	50 U	5 U	5 U
Bromoform		50 U	25 U	120 U	50 U	5 U	5 U
4-Methyl-2-pentanone		100 U	50 U	250 U	100 U	10 U	10 U
2-Hexanone		100 U	50 U	250 U	100 U	10 U	10 U
Tetrachloroethene		65	8 J	89 J	46 J	30	11
1,1,2,2-Tetrachloroethane		50 U	25 U	120 U	50 U	5 U	5 U

*= Outside of EPA CLP QC limits.

Cust ID:	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7
RFW#:	001	002	003	004	005	006

Toluene	50 U	25 U	120 U	50 U	5 U	5 U
Chlorobenzene	50 U	25 U	120 U	50 U	5 U	5 U
Ethylbenzene	50 U	25 U	120 U	50 U	5 U	5 U
Styrene	50 U	25 U	120 U	50 U	5 U	5 U
Xylene (total)	50 U	25 U	120 U	50 U	5 U	5 U

*= Outside of EPA CLP QC limits.

Lionville Laboratory, Inc.

Volatiles by GC/MS, HSL List

Report Date: 03/18/04 11:31

RFW Batch Number: 0402L870

Client: BLACK & DECKER

Work Order: 02501004002 Page: 2a

Sample Information	Cust ID:	EW-8	EW-9	EW-9	EW-9 DUP	EW-9 DUP	EW-10
	RFW#:	007	008	008 DL	009	009 DL	010
	Matrix:	WATER	WATER	WATER	WATER	WATER	WATER
	D.F.:	1.00	1.00	2.00	1.00	2.00	1.00
	Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L
Toluene-d8		87 %	84 * %	100 %	85 %	91 %	97 %
Surrogate Bromofluorobenzene		98 %	99 %	107 %	100 %	93 %	96 %
Recovery 1,2-Dichloroethane-d4		121 %	118 %	119 %	119 %	106 %	118 %
=====fl=====fl=====fl=====fl=====fl=====fl=====fl=====							
Chloromethane		10 U	10 U	20 U	10 U	20 U	10 U
Bromomethane		10 U	10 U	20 U	10 U	20 U	10 U
Vinyl Chloride		10 U	10 U	20 U	10 U	20 U	10 U
Chloroethane		10 U	10 U	20 U	10 U	20 U	10 U
Methylene Chloride		5 U	5 U	10 U	5 U	10 U	5 U
Acetone		10 U	10 U	20 U	10 U	20 U	10 U
Carbon Disulfide		5 U	5 U	10 U	5 U	10 U	5 U
1,1-Dichloroethene		5 U	5 U	10 U	5 U	2 JD	5 U
1,1-Dichloroethane		5 U	5 U	10 U	5 U	10 U	5 U
1,2-Dichloroethene (total)		16	1 J	10 U	5 U	10 U	5 U
Chloroform		5 U	5 U	10 U	5 U	10 U	5 U
1,2-Dichloroethane		5 U	5 U	10 U	5 U	10 U	5 U
2-Butanone		10 U	10 U	20 U	10 U	20 U	10 U
1,1,1-Trichloroethane		5 U	5 U	10 U	5 U	10 U	5 U
Carbon Tetrachloride		5 U	5 U	10 U	5 U	10 U	5 U
Vinyl Acetate		10 U	10 U	20 U	10 U	20 U	10 U
Bromodichloromethane		5 U	5 U	10 U	5 U	10 U	5 U
1,2-Dichloropropane		5 U	5 U	10 U	5 U	10 U	5 U
cis-1,3-Dichloropropene		5 U	5 U	10 U	5 U	10 U	5 U
Trichloroethene		10	2 J	10 U	2 J	5 JD	5 U
Dibromochloromethane		5 U	5 U	10 U	5 U	10 U	5 U
1,1,2-Trichloroethane		5 U	5 U	10 U	5 U	10 U	5 U
Benzene		5 U	5 U	10 U	5 U	10 U	5 U
Trans-1,3-Dichloropropene		5 U	5 U	10 U	5 U	10 U	5 U
Bromoform		5 U	5 U	10 U	5 U	10 U	5 U
4-Methyl-2-pentanone		10 U	10 U	20 U	10 U	20 U	10 U
2-Hexanone		10 U	10 U	20 U	10 U	20 U	10 U
Tetrachloroethene		75	230 E	210 D	230 E	200 D	9
1,1,2,2-Tetrachloroethane		5 U	5 U	10 U	5 U	10 U	5 U

*= Outside of EPA CLP QC limits.

Cust ID: EW-8 EW-9 EW-9 EW-9 DUP EW-9 DUP EW-10

RFW#: 007 008 008 DL 009 009 DL 010

	EW-8	EW-9	EW-9	EW-9 DUP	EW-9 DUP	EW-10
	007	008	008 DL	009	009 DL	010
Toluene	5 U	5 U	10 U	5 U	10 U	5 U
Chlorobenzene	5 U	5 U	10 U	5 U	10 U	5 U
Ethylbenzene	5 U	5 U	10 U	5 U	10 U	5 U
Styrene	5 U	5 U	10 U	5 U	10 U	5 U
Xylene (total)	5 U	5 U	10 U	5 U	10 U	5 U

*= Outside of EPA CLP QC limits.

Lionville Laboratory, Inc.

Volatiles by GC/MS, HSL List

Report Date: 03/18/04 11:31

RFW Batch Number: 0402L870

Client: BLACK & DECKER

Work Order: 02501004002 Page: 3a

Sample Information	RFW#:	010 MS	010 MSD	011	011	012	012
	Matrix:	WATER	WATER	WATER	WATER	WATER	WATER
	D.F.:	1.00	1.00	1.00	1.00	1.00	1.00
	Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L
					REPREP		REPREP
Toluene-d8		94 %	95 %	91 %	94 %	92 %	91 %
Surrogate Bromofluorobenzene		100 %	104 %	104 %	99 %	103 %	97 %
Recovery 1,2-Dichloroethane-d4		118 %	116 %	125 %	122 %	125 %	118 %
=====fl=====fl=====fl=====fl=====fl=====fl=====fl=====							
Chloromethane		10 U	10 U	10 U	10 U	10 U	10 U
Bromomethane		10 U	10 U	10 U	10 U	10 U	10 U
Vinyl Chloride		10 U	10 U	10 U	10 U	10 U	10 U
Chloroethane		10 U	10 U	10 U	10 U	10 U	10 U
Methylene Chloride		5 U	5 U	5 U	5 U	5 U	5 U
Acetone		10 U	10 U	10 U	10 U	5 J	5 J
Carbon Disulfide		5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene		106 %	105 %	5 U	5 U	5 U	5 U
1,1-Dichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloroethene (total)		5 U	5 U	5 U	5 U	5 U	5 U
Chloroform		5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
2-Butanone		10 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
Carbon Tetrachloride		5 U	5 U	5 U	5 U	5 U	5 U
Vinyl Acetate		10 U	10 U	10 U	10 U	10 U	10 U
Bromodichloromethane		5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloropropane		5 U	5 U	5 U	5 U	5 U	5 U
cis-1,3-Dichloropropene		5 U	5 U	5 U	5 U	5 U	5 U
Trichloroethene		95 %	99 %	5 U	5 U	5 U	5 U
Dibromochloromethane		5 U	5 U	5 U	5 U	5 U	5 U
1,1,2-Trichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
Benzene		113 %	117 %	5 U	5 U	5 U	5 U
Trans-1,3-Dichloropropene		5 U	5 U	5 U	5 U	5 U	5 U
Bromoform		5 U	5 U	5 U	5 U	5 U	5 U
4-Methyl-2-pentanone		10 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone		10 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene		8	8	5 U	5 U	5 U	5 U
1,1,2,2-Tetrachloroethane		5 U	5 U	5 U	5 U	5 U	5 U

*= Outside of EPA CLP QC limits.

Cust ID: EW-10 EW-10 RFW-1A RFW-1A RFW-1B RFW-1B

10

RFW#:	010 MS	010 MSD	011	011 REPREP	012	012 REPREP
Toluene	112 %	117 %	5 U	5 U	5 U	5 U
Chlorobenzene	103 %	107 %	5 U	5 U	5 U	5 U
Ethylbenzene	5 U	5 U	5 U	5 U	5 U	5 U
Styrene	5 U	5 U	5 U	5 U	5 U	5 U
Xylene (total)	5 U	5 U	5 U	5 U	5 U	5 U

*= Outside of EPA CLP QC limits.

Lionville Laboratory, Inc.

Volatiles by GC/MS, HSL List

Report Date: 03/18/04 11:31

RFW Batch Number: 0402L870

Client: BLACK & DECKER

Work Order: 02501004002 Page: 4a

Sample Information	Cust ID:	RFW-2A	RFW-2A	RFW-2B	RFW-2B	RFW-3B	RFW-3B
	RFW#:	013	013	014	014	015	015
	Matrix:	WATER	WATER	WATER	WATER	WATER	WATER
	D.F.:	1.00	1.00	1.00	1.00	1.00	1.00
	Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L
			REPREP		REPREP		REPREP
Surrogate	Toluene-d8	90 %	91 %	91 %	92 %	89 %	98 %
Recovery	Bromofluorobenzene	108 %	93 %	102 %	94 %	104 %	106 %
	1,2-Dichloroethane-d4	122 %	118 %	124 %	119 %	127 * %	131 * %
		-----fl	-----fl	-----fl	-----fl	-----fl	-----fl
	Chloromethane	10 U	10 U	10 U	10 U	10 U	10 U
	Bromomethane	10 U	10 U	10 U	10 U	10 U	10 U
	Vinyl Chloride	10 U	10 U	10 U	10 U	10 U	10 U
	Chloroethane	10 U	10 U	10 U	10 U	10 U	10 U
	Methylene Chloride	5 U	5 U	5 U	5 U	5 U	5 U
	Acetone	10 U	10 U	10 U	10 U	10 U	4 J
	Carbon Disulfide	5 U	5 U	5 U	5 U	5 U	5 U
	1,1-Dichloroethene	5 U	5 U	5 U	5 U	5 U	5 U
	1,1-Dichloroethane	5 U	5 U	5 U	5 U	5 U	5 U
	1,2-Dichloroethene (total)	5 U	5 U	5 U	5 U	14	13
	Chloroform	5 U	5 U	5 U	5 U	5 U	5 U
	1,2-Dichloroethane	5 U	5 U	5 U	5 U	5 U	5 U
	2-Butanone	10 U	10 U	10 U	10 U	10 U	10 U
	1,1,1-Trichloroethane	5 U	5 U	5 U	5 U	3 J	3 J
	Carbon Tetrachloride	5 U	5 U	5 U	5 U	5 U	5 U
	Vinyl Acetate	10 U	10 U	10 U	10 U	10 U	10 U
	Bromodichloromethane	5 U	5 U	5 U	5 U	5 U	5 U
	1,2-Dichloropropane	5 U	5 U	5 U	5 U	5 U	5 U
	cis-1,3-Dichloropropene	5 U	5 U	5 U	5 U	5 U	5 U
	Trichloroethene	5 U	5 U	2 J	2 J	13	12
	Dibromochloromethane	5 U	5 U	5 U	5 U	5 U	5 U
	1,1,2-Trichloroethane	5 U	5 U	5 U	5 U	5 U	5 U
	Benzene	5 U	5 U	5 U	5 U	5 U	5 U
	Trans-1,3-Dichloropropene	5 U	5 U	5 U	5 U	5 U	5 U
	Bromoform	5 U	5 U	5 U	5 U	5 U	5 U
	4-Methyl-2-pentanone	10 U	10 U	10 U	10 U	10 U	10 U
	2-Hexanone	10 U	10 U	10 U	10 U	10 U	10 U
	Tetrachloroethene	5 U	5 U	5 U	5 U	11	10
	1,1,2,2-Tetrachloroethane	5 U	5 U	5 U	5 U	5 U	5 U

*= Outside of EPA CLP QC limits.

Cust ID:	RFW-2A	RFW-2A	RFW-2B	RFW-2B	RFW-3B	RFW-3B
RFW#:	013	013	014	014	015	015
		REPREP		REPREP		REPREP
Toluene	5 U	5 U	5 U	5 U	5 U	5 U
Chlorobenzene	5 U	5 U	5 U	5 U	5 U	5 U
Ethylbenzene	5 U	5 U	5 U	5 U	5 U	5 U
Styrene	5 U	5 U	5 U	5 U	5 U	5 U
Xylene (total)	5 U	5 U	5 U	5 U	5 U	5 U

*= Outside of EPA CLP QC limits.

Lionville Laboratory, Inc.

Volatiles by GC/MS, HSL List

Report Date: 03/18/04 11:31

RFW Batch Number: 0402L870

Client: BLACK & DECKER

Work Order: Q2501004002 Page: 5a

Sample Information	Cust ID:	RFW-4A	RFW-4A	RFW-4A	RFW-4A DUP	RFW-4B	RFW-6
	RFW#:	016	016 MS	016 MSD	017	018	019
	Matrix:	WATER	WATER	WATER	WATER	WATER	WATER
	D.F.:	1.00	1.00	1.00	1.00	1.00	1.00
	Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L
Toluene-d8		92 %	95 %	92 %	104 %	105 %	96 %
Surrogate Bromofluorobenzene		106 %	105 %	103 %	110 %	112 %	104 %
Recovery 1,2-Dichloroethane-d4		125 %	126 * %	124 %	117 %	121 %	102 %
=====fl=====fl=====fl=====fl=====fl=====fl=====fl=====							
Chloromethane		10 U	10 U	10 U	10 U	10 U	10 U
Bromomethane		10 U	10 U	10 U	10 U	10 U	10 U
Vinyl Chloride		10 U	10 U	10 U	10 U	10 U	10 U
Chloroethane		10 U	10 U	10 U	10 U	10 U	10 U
Methylene Chloride		5 U	5 U	5 U	5 U	5 U	5 U
Acetone		10 U	10 U	10 U	10 U	3 J	3 J
Carbon Disulfide		5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene		5 U	117 %	113 %	5 U	5 U	5 U
1,1-Dichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloroethene (total)		2 J	1 J	1 J	2 J	5 J	5 U
Chloroform		1 J	1 J	1 J	1 J	5 U	5 U
1,2-Dichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
2-Butanone		10 U	10 U	10 U	10 U	2 J	10 U
1,1,1-Trichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
Carbon Tetrachloride		5 U	5 U	5 U	5 U	5 U	5 U
Vinyl Acetate		10 U	10 U	10 U	10 U	10 U	10 U
Bromodichloromethane		5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloropropane		5 U	5 U	5 U	5 U	5 U	5 U
cis-1,3-Dichloropropene		5 U	5 U	5 U	5 U	5 U	5 U
Trichloroethene		84	104 %	94 %	78	10	8
Dibromochloromethane		5 U	5 U	5 U	5 U	5 U	5 U
1,1,2-Trichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
Benzene		5 U	124 %	124 %	5 U	5 U	5 U
Trans-1,3-Dichloropropene		5 U	5 U	5 U	5 U	5 U	5 U
Bromoform		5 U	5 U	5 U	5 U	5 U	5 U
4-Methyl-2-pentanone		10 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone		10 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene		83	75	72	81	48	7
1,1,2,2-Tetrachloroethane		5 U	5 U	5 U	5 U	5 U	5 U

*= Outside of EPA CLP QC limits.

Cust ID:	RFW-4A	RFW-4A	RFW-4A	RFW-4A DUP	RFW-4B	RFW-6
RFW#:	016	016 MS	016 MSD	017	018	019

Toluene	5 U	122 %	119 %	5 U	5 U	5 U
Chlorobenzene	5 U	113 %	111 %	5 U	5 U	5 U
Ethylbenzene	5 U	5 U	5 U	5 U	5 U	5 U
Styrene	5 U	5 U	5 U	5 U	5 U	5 U
Xylene (total)	5 U	5 U	5 U	5 U	5 U	5 U

*= Outside of EPA CLP QC limits.

Lionville Laboratory, Inc.

Volatiles by GC/MS, HSL List

Report Date: 03/18/04 11:31

RFW Batch Number: 0402L870

Client: BLACK & DECKER

Work Order: 02501004002 Page: 6a

	Cust ID:	RFW-7	RFW-9	RFW-11B	RFW-12B	RFW-13	RFW-17
Sample Information	RFW#:	020	021	022	023	024	025
	Matrix:	WATER	WATER	WATER	WATER	WATER	WATER
	D.F.:	1.00	1.00	1.00	5.00	1.00	1.00
	Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L
	Toluene-d8	95 %	98 %	101 %	98 %	97 %	98 %
Surrogate	Bromofluorobenzene	99 %	106 %	107 %	104 %	109 %	110 %
Recovery	1,2-Dichloroethane-d4	109 %	110 %	113 %	111 %	111 %	111 %
=====fl=====fl=====fl=====fl=====fl=====fl=====fl=====							
Chloromethane		10 U	10 U	10 U	50 U	10 U	10 U
Bromomethane		10 U	10 U	10 U	50 U	10 U	10 U
Vinyl Chloride		10 U	10 U	10 U	50 U	10 U	10 U
Chloroethane		10 U	10 U	10 U	50 U	10 U	10 U
Methylene Chloride		5 U	5 U	5 U	25 U	5 U	5 U
Acetone		10 U	10 U	10 U	50 U	10 U	10 U
Carbon Disulfide		5 U	5 U	5 U	25 U	5 U	5 U
1,1-Dichloroethene		5 U	5 U	5 U	25 U	5 U	5 U
1,1-Dichloroethane		5 U	4 J	5 U	25 U	5 U	5 U
1,2-Dichloroethene (total)		5 U	24	5 U	8 J	5 U	5 U
Chloroform		5 U	5 U	5 U	25 U	5 U	5 U
1,2-Dichloroethane		5 U	5 U	5 U	25 U	5 U	5 U
2-Butanone		10 U	10 U	10 U	50 U	10 U	10 U
1,1,1-Trichloroethane		5 U	3 J	5 U	25 U	5 U	5 U
Carbon Tetrachloride		5 U	5 U	5 U	25 U	5 U	5 U
Vinyl Acetate		10 U	10 U	10 U	50 U	10 U	10 U
Bromodichloromethane		5 U	5 U	5 U	25 U	5 U	5 U
1,2-Dichloropropane		5 U	5 U	5 U	25 U	5 U	5 U
cis-1,3-Dichloropropene		5 U	5 U	5 U	25 U	5 U	5 U
Trichloroethene		5 J	23	62	710	5 J	5 U
Dibromochloromethane		5 U	5 U	5 U	25 U	5 U	5 U
1,1,2-Trichloroethane		5 U	5 U	5 U	25 U	5 U	5 U
Benzene		5 U	5 U	5 U	25 U	5 U	5 U
Trans-1,3-Dichloropropene		5 U	5 U	5 U	25 U	5 U	5 U
Bromoform		5 U	5 U	5 U	25 U	5 U	5 U
4-Methyl-2-pentanone		10 U	10 U	10 U	50 U	10 U	10 U
2-Hexanone		10 U	10 U	10 U	50 U	10 U	10 U
Tetrachloroethene		5 U	14	1 J	39	29	5 U
1,1,2,2-Tetrachloroethane		5 U	5 U	5 U	25 U	5 U	5 U

*= Outside of EPA CLP QC limits.

Cust ID:	RFW-7	RFW-9	RFW-11B	RFW-12B	RFW-13	RFW-17
RFW#:	020	021	022	023	024	025

Toluene	5 U	5 U	5 U	25 U	5 U	5 U
Chlorobenzene	5 U	5 U	5 U	25 U	5 U	5 U
Ethylbenzene	5 U	5 U	5 U	25 U	5 U	5 U
Styrene	5 U	5 U	5 U	25 U	5 U	5 U
Xylene (total)	5 U	5 U	5 U	25 U	5 U	5 U

*= Outside of EPA CLP QC limits.

Lionville Laboratory, Inc.

Volatiles by GC/MS, HSL List

Report Date: 03/18/04 11:31

RFW Batch Number: 0402L870

Client: BLACK & DECKER

Work Order: 02501004002 Page: 7a

Sample Information	Cust ID:	RFW-20	RFW-21	LEISTER-1	LEISTER-2	LEISTER-DAIR Y	TOWN #22
	RFW#:	026	027	028	029	030	031
	Matrix:	WATER	WATER	WATER	WATER	WATER	WATER
	D.F.:	1.00	1.00	1.00	1.00	1.00	1.00
	Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L
Surrogate	Toluene-d8	101 %	98 %	97 %	100 %	97 %	95 %
Recovery	Bromofluorobenzene	108 %	107 %	107 %	114 %	106 %	105 %
	1,2-Dichloroethane-d4	114 %	114 %	111 %	122 %	116 %	119 %
=====fl=====fl=====fl=====fl=====fl=====fl=====fl=====							
Chloromethane		10 U	10 U	10 U	10 U	10 U	10 U
Bromomethane		10 U	10 U	10 U	10 U	10 U	10 U
Vinyl Chloride		10 U	10 U	10 U	10 U	10 U	10 U
Chloroethane		10 U	10 U	10 U	10 U	10 U	10 U
Methylene Chloride		5 U	5 U	5 U	5 U	5 U	5 U
Acetone		5 J	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide		5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene		5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloroethene (total)		5 U	5 U	5 U	5 U	5 U	5 U
Chloroform		5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
2-Butanone		10 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
Carbon Tetrachloride		5 U	5 U	5 U	5 U	5 U	5 U
Vinyl Acetate		10 U	10 U	10 U	10 U	10 U	10 U
Bromodichloromethane		5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloropropane		5 U	5 U	5 U	5 U	5 U	5 U
cis-1,3-Dichloropropene		5 U	5 U	5 U	5 U	5 U	5 U
Trichloroethene		2 J	5 U	5 U	5 U	5 U	5 U
Dibromochloromethane		5 U	5 U	5 U	5 U	5 U	5 U
1,1,2-Trichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
Benzene		5 U	5 U	5 U	5 U	5 U	5 U
Trans-1,3-Dichloropropene		5 U	5 U	5 U	5 U	5 U	5 U
Bromoform		5 U	5 U	5 U	5 U	5 U	5 U
4-Methyl-2-pentanone		10 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone		10 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene		5 U	5 U	5 U	5 U	5 U	5 U
1,1,2,2-Tetrachloroethane		5 U	5 U	5 U	5 U	5 U	5 U

*= Outside of EPA CLP QC limits.

Cust ID:	RFW-20	RFW-21	LEISTER-1	LEISTER-2	LEISTER-DAIR	TOWN #22
RFW#:	026	027	028	029	Y 030	031
Toluene	5 U	5 U	5 U	5 U	5 U	5 U
Chlorobenzene	5 U	5 U	5 U	5 U	5 U	5 U
Ethylbenzene	5 U	5 U	5 U	5 U	5 U	5 U
Styrene	5 U	5 U	5 U	5 U	5 U	5 U
Xylene (total)	5 U	5 U	5 U	5 U	5 U	5 U

*= Outside of EPA CLP QC limits.

Lionville Laboratory, Inc.

Volatiles by GC/MS, HSL List

Report Date: 03/18/04 11:30

RFW Batch Number: 0402L870

Client: BLACK & DECKER

Work Order: 02501004002 Page: 8a

Sample Information	Cust ID:	TOWN #23	TRIP BLANK	VBLKXH	VBLKXH BS	VBLKYX	VBLKYX BS
RFW#:	032	033	04LVG057-MB1	04LVG057-MB1	04LVG059-MB1	04LVG059-MB1	
Matrix:	WATER	WATER	WATER	WATER	WATER	WATER	WATER
D.F.:	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L
Toluene-d8	99 %	97 %	96 %	93 %	98 %	97 %	
Surrogate Bromofluorobenzene	100 %	99 %	102 %	98 %	102 %	104 %	
Recovery 1,2-Dichloroethane-d4	109 %	111 %	114 %	105 %	111 %	109 %	
Chloromethane	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Bromomethane	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Vinyl Chloride	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Chloroethane	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Methylene Chloride	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Acetone	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	5 U	5 U	5 U	119 %	5 U	111 %	
1,1-Dichloroethane	5 U	5 U	5 U	5 U	5 U	5 U	
1,2-Dichloroethene (total)	5 U	5 U	5 U	5 U	5 U	5 U	
Chloroform	5 U	5 U	5 U	5 U	5 U	5 U	
1,2-Dichloroethane	5 U	5 U	5 U	5 U	5 U	5 U	
2-Butanone	10 U	10 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Tetrachloride	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Vinyl Acetate	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Bromodichloromethane	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloropropane	5 U	5 U	5 U	5 U	5 U	5 U	5 U
cis-1,3-Dichloropropene	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Trichloroethene	5 U	5 U	5 U	107 %	5 U	99 %	
Dibromochloromethane	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,2-Trichloroethane	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Benzene	5 U	5 U	5 U	125 %	5 U	115 %	
Trans-1,3-Dichloropropene	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Bromoform	5 U	5 U	5 U	5 U	5 U	5 U	5 U
4-Methyl-2-pentanone	10 U	10 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,2,2-Tetrachloroethane	5 U	5 U	5 U	5 U	5 U	5 U	5 U

*= Outside of EPA CLP QC limits.

Cust ID:	TOWN #23	TRIP BLANK	VBLKXH	VBLKXH BS	VBLKYX	VBLKYX BS
RFW#:	032	033	04LVG057-MB1	04LVG057-MB1	04LVG059-MB1	04LVG059-MB1

Toluene	5 U	5 U	5 U	122 %	5 U	114 %
Chlorobenzene	5 U	5 U	5 U	112 %	5 U	105 %
Ethylbenzene	5 U	5 U	5 U	5 U	5 U	5 U
Styrene	5 U	5 U	5 U	5 U	5 U	5 U
Xylene (total)	5 U	5 U	5 U	5 U	5 U	5 U

*= Outside of EPA CLP QC limits.

Lionville Laboratory, Inc.

Volatiles by GC/MS, HSL List

Report Date: 03/18/04 11:31

RFW Batch Number: 0402L870

Client: BLACK & DECKER

Work Order: 02501004002 Page: 9a

Cust ID: VBLKYV VBLKYV BS

Sample	RFW#:	04LVG058-MB1	04LVG058-MB1
Information	Matrix:	WATER	WATER
	D.F.:	1.00	1.00
	Units:	UG/L	UG/L

	Toluene-d8	96 %	94 %
Surrogate Bromofluorobenzene	107 %		105 %
Recovery 1,2-Dichloroethane-d4	107 %		104 %
-----fl-----fl-----fl-----fl-----fl-----fl-----			
Chloromethane	10 U		10 U
Bromomethane	10 U		10 U
Vinyl Chloride	10 U		10 U
Chloroethane	10 U		10 U
Methylene Chloride	5 U		5 U
Acetone	10 U		10 U
Carbon Disulfide	5 U		5 U
1,1-Dichloroethene	5 U	118 %	
1,1-Dichloroethane	5 U		5 U
1,2-Dichloroethene (total)	5 U		5 U
Chloroform	5 U		5 U
1,2-Dichloroethane	5 U		5 U
2-Butanone	10 U		10 U
1,1,1-Trichloroethane	5 U		5 U
Carbon Tetrachloride	5 U		5 U
Vinyl Acetate	10 U		10 U
Bromodichloromethane	5 U		5 U
1,2-Dichloropropane	5 U		5 U
cis-1,3-Dichloropropene	5 U		5 U
Trichloroethene	5 U	100 %	
Dibromochloromethane	5 U		5 U
1,1,2-Trichloroethane	5 U		5 U
Benzene	5 U	119 %	
Trans-1,3-Dichloropropene	5 U		5 U
Bromoform	5 U		5 U
4-Methyl-2-pentanone	10 U		10 U
2-Hexanone	10 U		10 U
Tetrachloroethene	5 U		5 U
1,1,2,2-Tetrachloroethane	5 U		5 U

*= Outside of EPA CLP QC limits.

RFW#: 04LVG058-MB1 04LVG058-MB1

Toluene	5	U	113	%
Chlorobenzene	5	U	104	%
Ethylbenzene	5	U	5	U
Styrene	5	U	5	U
Xylene (total)	5	U	5	U

*= Outside of EPA CLP QC limits.

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

EW-2

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-001

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q022706

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/27/04

Column: (pack/cap) CAP

Dilution Factor: 10.0

Number TICs found: 0

CONCENTRATION UNITS:

(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
 VOLATILE ORGANICS ANALYSIS SHEET
 TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

EW-3

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-002

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q022707

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/27/04

Column: (pack/cap) CAP

Dilution Factor: 5.00

Number TICs found: 0

CONCENTRATION UNITS:

(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

EW-4

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-003

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q022708

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/27/04

Column: (pack/cap) CAP

Dilution Factor: 25.0

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

EW-5

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-004

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q022709

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/27/04

Column: (pack/cap) CAP

Dilution Factor: 10.0

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

EW-6

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-005

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: g022710

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/27/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

EW-7

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-006

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q022711

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/27/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:

(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

EW-8

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____ SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER Lab Sample ID: 0402L870-007

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: g022712

Level: (low/med) LOW Date Received: 02/20/04

% Moisture: not dec. _____ Date Analyzed: 02/27/04

Column: (pack/cap) CAP Dilution Factor: 1.00

Number TICs found: 0 CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
 VOLATILE ORGANICS ANALYSIS SHEET
 TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

EW-9

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____ SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER Lab Sample ID: 0402L870-008

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: q022713

Level: (low/med) LOW Date Received: 02/20/04

% Moisture: not dec. _____ Date Analyzed: 02/27/04

Column: (pack/cap) CAP Dilution Factor: 1.00

Number TICs found: 0 CONCENTRATION UNITS:
 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

EW-9DL

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-008 DL

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q030109

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 03/01/04

Column: (pack/cap) CAP

Dilution Factor: 2.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

EW-9 DUP

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-009

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: g022714

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/27/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:

(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

EW-9 DUPDL

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-009 DL

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q030110

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 03/01/04

Column: (pack/cap) CAP

Dilution Factor: 2.00

Number TICs found: 0

CONCENTRATION UNITS:

(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

EW-10

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____ SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER Lab Sample ID: 0402L870-010

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: g030111

Level: (low/med) LOW Date Received: 02/20/04

% Moisture: not dec. _____ Date Analyzed: 03/01/04

Column: (pack/cap) CAP Dilution Factor: 1.00

Number TICs found: 0 CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-1A

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-011

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: g022716

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/27/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-1ARE

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____ SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER Lab Sample ID: 0402L870-011

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: q030114

Level: (low/med) LOW Date Received: 02/20/04

% Moisture: not dec. _____ Date Analyzed: 03/01/04

Column: (pack/cap) CAP Dilution Factor: 1.00

Number TICs found: 0 CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-1B

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-012

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: g022717

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/27/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-1BRE

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____ SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER Lab Sample ID: 0402L870-012

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: q030115

Level: (low/med) LOW Date Received: 02/20/04

% Moisture: not dec. _____ Date Analyzed: 03/01/04

Column: (pack/cap) CAP Dilution Factor: 1.00

Number TICs found: 0 CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-2A

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-013

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q022718

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/27/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-2ARE

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____ SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER Lab Sample ID: 0402L870-013

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: q030116

Level: (low/med) LOW Date Received: 02/20/04

% Moisture: not dec. _____ Date Analyzed: 03/01/04

Column: (pack/cap) CAP Dilution Factor: 1.00

Number TICs found: 0 CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-2B

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-014

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: 022719

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/27/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-2BRE

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-014

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q030117

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 03/01/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:

(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-3B

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-015

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q022720

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/27/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:

(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
 VOLATILE ORGANICS ANALYSIS SHEET
 TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-3BRE

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____ SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER Lab Sample ID: 0402L870-015

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: g030118

Level: (low/med) LOW Date Received: 02/20/04

% Moisture: not dec. _____ Date Analyzed: 03/01/04

Column: (pack/cap) CAP Dilution Factor: 1.00

Number TICs found: 0 CONCENTRATION UNITS:
 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-4A

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-016

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q030119

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 03/01/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-4A DUP

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-017

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: g022806

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/28/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:

(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-4B

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-018

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: g022807

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/28/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-6

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-019

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: g022808

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/28/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:

(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-7

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-020

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q022809

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/28/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-9

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-021

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: g022810

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/28/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-11B

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-022

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q022811

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/28/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:

(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
 VOLATILE ORGANICS ANALYSIS SHEET
 TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-12B

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____ SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER Lab Sample ID: 0402L870-023

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: g022812

Level: (low/med) LOW Date Received: 02/20/04

% Moisture: not dec. _____ Date Analyzed: 02/28/04

Column: (pack/cap) CAP Dilution Factor: 5.00

Number TICs found: 0 CONCENTRATION UNITS:
 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-13

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-024

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q022813

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/28/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-17

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-025

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: g022814

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/28/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 1

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1. 1634044	PROPANE, 2-METHOXY-2-METHYL-	8.399	50	NJ

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-20

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-026

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: g022815

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/28/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

RFW-21

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-027

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: g022816

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/28/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

LEISTER-1

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-028

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q022817

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/28/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

LEISTER-2

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____ SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER Lab Sample ID: 0402L870-029

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: q022818

Level: (low/med) LOW Date Received: 02/20/04

% Moisture: not dec. _____ Date Analyzed: 02/28/04

Column: (pack/cap) CAP Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

LEISTER-DAIRY

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-030

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q022819

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/28/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

TOWN #22

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-031

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q022820

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 02/28/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

TOWN #23

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-032

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: g030107

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 03/01/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:

(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

TRIP BLANK

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 0402L870-033

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: q030108

Level: (low/med) LOW

Date Received: 02/20/04

% Moisture: not dec. _____

Date Analyzed: 03/01/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
 VOLATILE ORGANICS ANALYSIS SHEET
 TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

VBLKXH

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 04LVG057-MB1

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: g022704

Level: (low/med) LOW

Date Received: 02/27/04

% Moisture: not dec. _____

Date Analyzed: 02/27/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
 VOLATILE ORGANICS ANALYSIS SHEET
 TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

VBLKYX

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____ SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER Lab Sample ID: 04LVG059-MB1

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: 030106

Level: (low/med) LOW Date Received: 03/01/04

% Moisture: not dec. _____ Date Analyzed: 03/01/04

Column: (pack/cap) CAP Dilution Factor: 1.00

Number TICs found: 0 CONCENTRATION UNITS:
 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

EPA SAMPLE NO.

VBLKYV

Lab Name: Lionville Labs, Inc. Contract: 02501004002

Lab Code: Lionvi Case No.: _____

SAS No.: _____ SDG No.: _____

Matrix: (soil/water) WATER

Lab Sample ID: 04LVG058-MB1

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: 0022805

Level: (low/med) LOW

Date Received: 02/28/04

% Moisture: not dec. _____

Date Analyzed: 02/28/04

Column: (pack/cap) CAP

Dilution Factor: 1.00

Number TICs found: 0

CONCENTRATION UNITS:
(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

Lionville Laboratory, Inc.
 VOA ANALYTICAL DATA PACKAGE FOR
 BLACK & DECKER

DATE RECEIVED: 02/20/04

LVL LOT # :0402L870

CLIENT ID	LVL #	MTX	PREP #	COLLECTION	EXTR/PREP	ANALYSIS
EW-2	001	W	04LVG057	02/19/04	N/A	02/27/04
EW-3	002	W	04LVG057	02/19/04	N/A	02/27/04
EW-4	003	W	04LVG057	02/19/04	N/A	02/27/04
EW-5	004	W	04LVG057	02/19/04	N/A	02/27/04
EW-6	005	W	04LVG057	02/19/04	N/A	02/27/04
EW-7	006	W	04LVG057	02/19/04	N/A	02/27/04
EW-8	007	W	04LVG057	02/19/04	N/A	02/27/04
EW-9	008	W	04LVG057	02/19/04	N/A	02/27/04
EW-9	008	D1	W 04LVG059	02/19/04	N/A	03/01/04
EW-9 DUP	009	W	04LVG057	02/19/04	N/A	02/27/04
EW-9 DUP	009	D1	W 04LVG059	02/19/04	N/A	03/01/04
EW-10	010	W	04LVG059	02/19/04	N/A	03/01/04
EW-10	010	MS	W 04LVG059	02/19/04	N/A	03/01/04
EW-10	010	MSD	W 04LVG059	02/19/04	N/A	03/01/04
RFW-1A	011	W	04LVG057	02/18/04	N/A	02/27/04
RFW-1A	011	R1	W 04LVG059	02/18/04	N/A	03/01/04
RFW-1B	012	W	04LVG057	02/19/04	N/A	02/27/04
RFW-1B	012	R1	W 04LVG059	02/19/04	N/A	03/01/04
RFW-2A	013	W	04LVG057	02/18/04	N/A	02/27/04
RFW-2A	013	R1	W 04LVG059	02/18/04	N/A	03/01/04
RFW-2B	014	W	04LVG057	02/18/04	N/A	02/27/04
RFW-2B	014	R1	W 04LVG059	02/18/04	N/A	03/01/04
RFW-3B	015	W	04LVG057	02/19/04	N/A	02/27/04
RFW-3B	015	R1	W 04LVG059	02/19/04	N/A	03/01/04
RFW-4A	016	W	04LVG059	02/19/04	N/A	03/01/04
RFW-4A	016	MS	W 04LVG059	02/19/04	N/A	03/01/04
RFW-4A	016	MSD	W 04LVG059	02/19/04	N/A	03/01/04
RFW-4A DUP	017	W	04LVG058	02/19/04	N/A	02/28/04
RFW-4B	018	W	04LVG058	02/19/04	N/A	02/28/04
RFW-6	019	W	04LVG058	02/19/04	N/A	02/28/04
RFW-7	020	W	04LVG058	02/18/04	N/A	02/28/04
RFW-9	021	W	04LVG058	02/19/04	N/A	02/28/04
RFW-11B	022	W	04LVG058	02/19/04	N/A	02/28/04
RFW-12B	023	W	04LVG058	02/19/04	N/A	02/28/04
RFW-13	024	W	04LVG058	02/18/04	N/A	02/28/04
RFW-17	025	W	04LVG058	02/18/04	N/A	02/28/04
RFW-20	026	W	04LVG058	02/19/04	N/A	02/28/04
RFW-21	027	W	04LVG058	02/18/04	N/A	02/28/04

Lionville Laboratory, Inc.
VOA ANALYTICAL DATA PACKAGE FOR
BLACK & DECKER

DATE RECEIVED: 02/20/04

LVL LOT # :0402L870

CLIENT ID	LVL #	MTX	PREP #	COLLECTION	EXTR/PREP	ANALYSIS
LEISTER-1	028	W	04LVG058	02/18/04	N/A	02/28/04
LEISTER-2	029	W	04LVG058	02/18/04	N/A	02/28/04
LEISTER-DAIRY	030	W	04LVG058	02/18/04	N/A	02/28/04
TOWN #22	031	W	04LVG058	02/19/04	N/A	02/28/04
TOWN #23	032	W	04LVG059	02/19/04	N/A	03/01/04
TRIP BLANK	033	W	04LVG059	02/18/04	N/A	03/01/04

LAB QC:

VBLKXH	MB1	W	04LVG057	N/A	N/A	02/27/04
VBLKXH	MB1 BS	W	04LVG057	N/A	N/A	02/27/04
VBLKYX	MB1	W	04LVG059	N/A	N/A	03/01/04
VBLKYX	MB1 BS	W	04LVG059	N/A	N/A	03/01/04
VBLKYV	MB1	W	04LVG058	N/A	N/A	02/28/04
VBLKYV	MB1 BS	W	04LVG058	N/A	N/A	02/28/04



0402L870

FIELD PERSONNEL: COMPLETE ONLY SHADED AREAS

AB

Client <u>Black + Decker</u>	Refrigerator # <u>1</u>
Est. Final Proj. Sampling Date <u>02501-004-002-0200-00</u>	#/Type Container Liquid <u>2</u> Solid
Project # <u>02501.004.004.0200</u>	Volume Liquid <u>40ml</u> Solid
Project Contact/Phone # <u>Greg Flaszinski 610-701-7293</u>	Preservatives <u>HCl</u>
Lionville Laboratory Project Manager <u>Mark H.</u>	ANALYSES REQUESTED →
QC <u>SW846</u> Del <u>Std</u> TAT <u>28 Days</u>	
Date Rec'd <u>2/20/04</u> Date Due <u>3/19/04</u>	ORGANIC VOA BNA Pes/PCB Herb INORG Metal CN

MATRIX CODES: S - Soil SE - Sediment SO - Solid SL - Sludge W - Water O - Oil A - Air DS - Drum Solids DL - Drum Liquids L - EP/TCLP Leachate WI - Wipe X - Other F - Fish	Lab ID	Client ID/Description	Matrix QC Chosen (✓)		Matrix	Date Collected	Time Collected	06024H	Lionville Laboratory Use Only											
			MS	MSD																
	001	EW-2			W	2-18-04	810	✓												
	002	EW-3					1040	✓												
	003	EW-4					1050	✓												
	004	EW-5					1115	✓												
	005	EW-6					1340	✓												
	006	EW-7					1320	✓												
	007	EW-8					1310	✓												
	008	EW-9					1300	✓												
	009	EW-9 Dup					1300	✓												
	010	EW-10					1240	✓												

Special Instructions:	DATE/REVISIONS:	Lionville Laboratory Use Only	
	1. _____	Samples were:	Tamper Resistant Seal was:
	2. _____	1) Shipped _____ or	1) Present on Outer Package Y or N
	3. _____	Hand Delivered _____	2) Unbroken on Outer Package Y or N
	4. _____	Airbill # _____	3) Present on Sample Y or N
	5. _____	2) Ambient or Chilled	4) Unbroken on Sample Y or N
6. _____	3) Received in Good Condition Y or N	5) Received Within Holding Times Y or N	
		4) Samples Properly Preserved Y or N	COC Record Present Upon Sample Rec't Y or N
			Cooler Temp. _____ °C

Relinquished by	Received by	Date	Time	Relinquished by	Received by	Date	Time
<i>[Signature]</i>	<i>[Signature]</i>	12/20/04	1215				

Discrepancies Between Samples Labels and COC Record? Y or N
NOTES:



0402L870

FIELD PERSONNEL: COMPLETE ONLY SHADED AREAS

AB

Client <u>Black + Decker</u>	Refrigerator # <u>1</u>														
Est. Final Proj. Sampling Date _____	#/Type Container Liquid <u>2</u> Solid _____														
Project # <u>See Page 1</u>	Volume Liquid <u>40ml</u> Solid _____														
Project Contact/Phone # _____	Preservatives <u>HCl</u>														
Lionville Laboratory Project Manager _____	ANALYSES REQUESTED														
QC _____ Del _____ TAT _____	<table border="1"> <tr> <td colspan="5">ORGANIC</td> <td colspan="2">INORG</td> </tr> <tr> <td>VOA</td> <td>BNA</td> <td>Pes/ PCB</td> <td>Herb</td> <td>Metal</td> <td>CN</td> <td></td> </tr> </table>	ORGANIC					INORG		VOA	BNA	Pes/ PCB	Herb	Metal	CN	
ORGANIC					INORG										
VOA	BNA	Pes/ PCB	Herb	Metal	CN										

Date Rec'd _____ Date Due _____

MATRIX CODES: S - Soil SE - Sediment SO - Solid SL - Sludge W - Water O - Oil A - Air DS - Drum Solids DL - Drum Liquids L - EP/TCLP Leachate WI - Wipe X - Other F - Fish	Lab ID	Client ID/Description	Matrix QC Chosen (✓)		Matrix	Date Collected	Time Collected	Lionville Laboratory Use Only													
			MS	MSD																	
	011	RFW-1A			W	2/18/04	1100	06244													
	012	RFW-1B				2/19/04															
	013	RFW-2A				2/18/04	1126														
	014	RFW-2B				2/18/04	1158														
	015	RFW-3B				2/19/04	1300														
	016	RFW-4A					905														
	017	RFW-4A Dup					905														
	018	RFW-4B					943														
	019	RFW-6					1400														
	020	RFW-7				2/18/04	945														

DATE/REVISIONS:

- _____
- _____
- _____
- _____
- _____
- _____

Special Instructions:

Lionville Laboratory Use Only

Samples were:
 1) Shipped _____ or Hand Delivered _____
 Airbill # _____
 2) Ambient or Chilled _____
 3) Received in Good Condition Y or N _____
 4) Samples Properly Preserved Y or N _____
 5) Received Within Holding Times Y or N _____

Tamper Resistant Seal was:
 1) Present on Outer Package Y or N _____
 2) Unbroken on Outer Package Y or N _____
 3) Present on Sample Y or N _____
 4) Unbroken on Sample Y or N _____
 COC Record Present Upon Sample Rec't Y or N _____
 Cooler Temp. _____ °C

Relinquished by	Received by	Date	Time	Relinquished by	Received by	Date	Time
<i>[Signature]</i>	<i>[Signature]</i>	2/20/04	1215				

Discrepancies Between Samples Labels and COC Record? Y or N _____

NOTES:



0402L870

FIELD PERSONNEL: COMPLETE ONLY SHADED AREAS

AB

Client <u>Black + Decker</u>	Refrigerator # <u>1</u>
Est. Final Proj. Sampling Date _____	#/Type Container
Project # <u>See Page 1</u>	Liquid <u>2</u>
Project Contact/Phone # _____	Solid _____
Lionville Laboratory Project Manager _____	Volume
QC _____ Del _____ TAT _____	Liquid <u>4gal</u>
	Solid _____
	Preservatives <u>HCl</u>
Date Rec'd <u>2/20/04</u> Date Due <u>3/19/04</u>	ANALYSES REQUESTED
	ORGANIC
	INORG
	VOA BNA Pest/PCB Herb Metal CN

MATRIX CODES: S - Soil SE - Sediment SO - Solid SL - Sludge W - Water O - Oil A - Air DS - Drum DL - Drum L - EP/TCLP Leachate WI - Wipe X - Other F - Fish	Lab ID	Client ID/Description	Matrix QC Chosen (✓)		Matrix	Date Collected	Time Collected	Lionville Laboratory Use Only												
			MS	MSD				06244												
			021	RFW-9						W	2-19-04	1236	✓							
022	RFW-11B					1130	✓													
X 023	RFW-12B					1430	✓													
024	RFW-13				2-18-04	1653	✓													
025	RFW-17				2-18-04	1230	✓													
026	RFW-20				2-19-04	1005	✓													
027	RFW-21				2-18-04	1338	✓													
028	Leister-1				2-18-04		✓													
029	Leister-2				2-18-04	1820	✓													
030	Leister-Dairy				2-18-04		✓													

Special Instructions:	DATE/REVISIONS:	Lionville Laboratory Use Only
	1. _____	Samples were: _____
	2. _____	1) Shipped _____ or _____
	3. _____	Hand Delivered _____
	4. _____	Airbill # _____
	5. _____	2) Ambient or Chilled _____
	6. _____	3) Received in Good Condition Y or N
		4) Samples Properly Preserved Y or N
		5) Received Within Holding Times Y or N
		Tamper Resistant Seal was: _____
		1) Present on Outer Package Y or N
		2) Unbroken on Outer Package Y or N
		3) Present on Sample Y or N
		4) Unbroken on Sample Y or N
		COC Record Present Upon Sample Rec't Y or N
		Cooler Temp. _____ °C

Relinquished by	Received by	Date	Time	Relinquished by	Received by	Date	Time
<i>[Signature]</i>	<i>[Signature]</i>	2/20/04	1215				

Discrepancies Between Samples Labels and COC Record? Y or N _____

NOTES:

Lionville Laboratory Use Only

Custody Transfer Record/Lab Work Request Page 4 of 4

0402L870

FIELD PERSONNEL: COMPLETE ONLY SHADED AREAS

Client <u>Black + Decker</u>		Refrigerator #	<u>1</u>																	
Est. Final Proj. Sampling Date		#/Type Container	Liquid	<u>2</u>																
Project # <u>See Page 1</u>			Solid																	
Project Contact/Phone #		Volume	Liquid	<u>40ml</u>																
Lionville Laboratory Project Manager			Solid																	
QC _____ Del _____ TAT _____		Preservatives	<u>ACI</u>																	
Date Rec'd <u>3/2/20/04</u> Date Due <u>3/19/04</u>		ANALYSES REQUESTED →	ORGANIC				INORG													
			VOA	BNA	Pest/PCB	Herb	Metal	CN												
MATRIX CODES: S - Soil SE - Sediment SO - Solid SL - Sludge W - Water O - Oil A - Air DS - Drum Solids DL - Drum Liquids L - EP/TCLP Leachate WI - Wipe X - Other F - Fish	Lab ID	Client ID/Description	Matrix QC Chosen (✓)	Matrix	Date Collected	Time Collected	Lionville Laboratory Use Only													
			MS	MSD																
		<u>031</u>	<u>Town #22</u>			<u>W</u>	<u>2/19/04</u>	<u>1020</u>	<u>03/24/04</u>											
		<u>032</u>	<u>Town #23</u>			<u>I</u>	<u>2/19/04</u>	<u>1015</u>	<u>03/24/04</u>											
	<u>033</u>	<u>Trip Blank</u>			<u>I</u>	<u>2/18/04</u>	<u>800</u>	<u>03/24/04</u>												

Special Instructions:

DATE/REVISIONS:

- _____
- _____
- _____
- _____
- _____
- _____

Lionville Laboratory Use Only

- Samples were:
1) Shipped _____ or Hand Delivered _____
Airbill # _____
2) Ambient or Chilled
3) Received in Good Condition Y or N
4) Samples Properly Preserved Y or N
5) Received Within Holding Times Y or N

- Tamper Resistant Seal was:
1) Present on Outer Package Y or N
2) Unbroken on Outer Package Y or N
3) Present on Sample or N
4) Unbroken on Sample Y or N
COC Record Present Upon Sample Rec't Y or N
Cooler _____ °C
Temp. _____ °C

Relinquished by	Received by	Date	Time
<u>[Signature]</u>	<u>[Signature]</u>	<u>2/20/04</u>	<u>1215</u>

Relinquished by	Received by	Date	Time

Discrepancies Between Samples Labels and COC Record? Y or N
NOTES: