

Quarterly Groundwater Monitoring Report

Prepared for
Black & Decker (U.S.) Inc.

Hampstead, Maryland

April 2006

Prepared by

WESTON SOLUTIONS, INC.
West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 1st Quarter 2006	2-2
Table 2-2 Groundwater Elevation Data – 1st Quarter 2006	2-3
Table 2-3 Effluent Characteristics Summary – 1st Quarter 2006	2-4
Table 2-4 Summary of Groundwater Analytical Results - February 2006.....	2-5
Table 3-1 Treatment System Maintenance Activities – 1st Quarter 2006.....	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of January through March 2006.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of January through March 2006, the extraction wells were pumping at an average combined rate of approximately 182 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of January through March 2006 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of January through March 2006, approximately 37 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (62 %) and tetrachloroethene (PCE) (38 %). Analytical results of the groundwater collected at the inlet to the air stripper for the period of January through March 2006 are included in Appendix C.

A summary of the analytical results from the first quarter (February 2006) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 1st Quarter 2006
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
January 2006	6,686,728
February 2006	6,248,297
March 2006	6,852,072

Table 2-2
Groundwater Elevation Data - 1st Quarter 2006
Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV.	TOTAL DEPTH	1/19/2006		2/27/2006		3/17/2006	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NA	DRY	NA	DRY	NA
EW-2	849.21	110	89.74	759.47	95.10	754.11	94.26	754.95
EW-3	846.64	118	94.61	752.03	97.31	749.33	96.86	749.78
EW-4	858.01	97.5	NA	NA	NA	NA	NA	NA
EW-5	864.17	98	84.40	779.77	84.88	779.29	85.10	779.07
EW-6	831.98	115	87.96	744.02	88.47	743.51	89.70	742.28
EW-7	818.38	78	44.97	773.41	47.31	771.07	47.83	770.55
EW-8	811.13	98	48.03	763.10	49.11	762.02	49.96	761.17
EW-9	811.35	141	101.40	709.95	100.05	711.30	101.30	710.05
EW-10	807.74	NA	44.03	763.71	45.87	761.87	45.69	762.05
RFW-1A	864.37	78	51.43	812.94	50.16	814.21	51.41	812.96
RFW-1B	864.23	200	51.46	812.77	50.24	813.99	50.46	813.77
RFW-2A	857.41	35	16.01	841.40	12.64	844.77	12.70	844.71
RFW-2B	857.73	75	16.43	841.30	13.28	844.45	13.21	844.52
RFW-3B	839.21	153	32.27	806.94	29.33	809.88	27.67	811.54
RFW-4A	830.37	62	37.33	793.04	36.28	794.09	36.29	794.08
RFW-4B	830.37	120	37.21	793.16	36.11	794.26	36.13	794.24
RFW-5A	817.50	30	DRY	NA	DRY	NA	DRY	NA
RFW-6	785.04	120	3.48	781.56	3.74	781.30	4.12	780.92
RFW-7	805.14	29	7.71	797.43	5.68	799.46	6.34	798.80
RFW-8	860.07	56	DRY	NA	DRY	NA	DRY	NA
RFW-9	862.02	49	25.64	836.38	24.76	837.26	25.03	836.99
RFW-10	852.06	58	DRY	NA	DRY	NA	DRY	NA
RFW-11A	849.32	72	NA	NA	NA	NA	NA	NA
RFW-11B	849.62	116	71.47	778.15	69.54	780.08	70.17	779.45
RFW-12B	844.87	264	54.30	790.57	53.86	791.01	53.61	791.26
RFW-13	849.11	150	61.40	787.71	62.60	786.51	62.47	786.64
RFW-14B	812.39	281	35.86	776.53	34.71	777.68	35.13	777.26
RFW-16	856.14	41	DRY	NA	DRY	NA	DRY	NA
RFW-17	834.66	60.5	27.60	807.06	25.83	808.83	25.92	808.74
RFW-20	842.49	142	31.99	810.50	33.71	808.78	33.37	809.12
RFW-21	832.65	102	22.50	810.15	21.20	811.45	21.03	811.62
PH-7	805.94	89	23.08	782.86	23.78	782.16	24.06	781.88
PH-9	814.94	98	37.46	777.48	38.11	776.83	38.30	776.64
PH-11	820.68	78	43.01	777.67	42.88	777.80	43.19	777.49
PH-12	828.35	87	43.29	785.06	43.35	785.00	43.43	784.92
B-3	803.02	83	NA	NA	NA	NA	NA	NA
Amoco	842.29	NA	NA	NA	NA	NA	NA	NA
Hamp. Town #22	804.96	NA	31.40	773.56	27.63	777.33	27.13	777.83
Pembroke #1	NA	NA	10.94	NA	NA	NA	10.98	NA
Pembroke #2	NA	NA	NA	NA	NA	NA	NA	NA
N. Houcks. Rd.	NA	NA	9.87	NA	NA	NA	10.73	NA
E. Century St.	NA	NA	27.40	NA	NA	NA	23.84	NA
Lwr. Beckleys. Rd.	NA	NA	55.49	NA	NA	NA	53.31	NA

NA - Not Available/Not Accessible

Table 2-3
 Effluent Characteristics Summary - 1st Quarter 2006
 Black & Decker
 Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				January 2006	February 2006	March 2006	
001	FLOW	average	MGD	NA	0.246	0.250	0.181
		maximum	MGD	NA	0.487	0.630	0.247
	1,1,1-Trichloroethane		ug/l	5	< 5	< 5	< 5
	Tetrachloroethylene		ug/l	5	< 5	< 5	< 5
	Trichloroethylene		ug/l	5	< 5	< 5	< 5
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		quarterly average	mg/l	10	NR	NR	< 5
	pH	minimum	STD	6.0	6.10	6.10	6.10
		maximum	STD	8.5	6.70	6.70	7.20
	BOD		mg/l	15	< 2	< 2	< 2
TSS	maximum	mg/l	30	< 2.5	3.5	2.8	
	quarterly average	mg/l	20	NR	NR	2.5	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.217	0.251	0.251
		maximum	MGD	NA	0.256	0.275	0.275
	Fecal Coliform		MPN/100ml	200	< 2	< 2	< 2
201 (Monitoring Point)	FLOW	average	MGD	NA	0.216	0.215	0.221
		maximum	MGD	NA	0.248	0.239	0.247
	1,1,1-Trichloroethane		ug/l	NA	< 5	< 5	< 5
	Tetrachloroethylene		ug/l	NA	< 5	< 5	< 5
	Trichloroethylene		ug/l	NA	< 5	< 5	< 5

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

Table 2-4
 Summary of Groundwater Analytical Results - February 2006
 Black & Decker
 Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 DUP	EW-10
					(5)							
Chloromethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Acetone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3.6	1.7	5 U	1 U	1 U	8	23	1.5	1.3	1 U
Chloroform	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	5 U	1.2	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	520	170	1200	260	11	7.2	12	2.2	2.2	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	63	5	26	7.8	19	13	73	310	310	9.1
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

DUP = Duplicate sample
 NS = Not sampled
 (2.5) = Dilution factor.

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
 J = Indicates an estimated value.
 B = Indicates that the analyte was found in the associated blank as well as in the sample.

Table 2-4
Summary of Groundwater Analytical Results - February 2006
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4B	RFW-4B (DUP)	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	5 U	1 U	NS	1 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	1 U	5 U	NS	1 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	1 U	5 U	NS	1 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.5	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.3	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	9.3	1.2	4.5	4.4	NS	1.4	1 U	NS	14	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	1 U	5 U	NS	1 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	2.1	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	5 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	5 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	1.3	2	1.2	41	13	13	NS	8.8	4.3	NS	22	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	1 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	1 U	NS
Tetrachloroethene	ug/L	1.2	1 U	1 U	1 U	4.7	40	37	36	NS	6.9	1 U	NS	6.9	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

DUP = Duplicate sample
 NS = Not sampled
 (2.5) = Dilution factor.

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
 J = Indicates an estimated value.
 B = Indicates that the analyte was found in the associated blank as well as in the sample.

Table 2-4
 Summary of Groundwater Analytical Results - February 2006
 Black & Decker
 Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	RFW-20	RFW-21	Town #22	Town #23	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U
Methylene Chloride	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	10 U	10 U	10 U	10 U	5 U	5 U	5 U	NS	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	NA	NA	NA	NA	5 U	5 U	5 U	NS	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	6	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	10 U	10 U	10 U	10 U	5 U	5 U	5 U	NS	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Trichloroethene	ug/L	NS	27	630	16	NS	1.1	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	10 U	10 U	10 U	10 U	5 U	5 U	5 U	NS	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	10 U	10 U	10 U	10 U	5 U	5 U	5 U	NS	5 U
Tetrachloroethene	ug/L	NS	1 U	48	41	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U

DUP = Duplicate sample
 NS = Not sampled
 (2.5) = Dilution factor.

Note: Samples from wells RFW-20&21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division. Samples from all of the other wells are analyzed with USEPA Method U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from well EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (January through March 2006) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 1st Quarter 2006
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
March 2006	The pump motor on EW - 5 shorted out. A new pump and motor were installed. The well was down for 6 days. The well is back online.

4. RECOMMENDATIONS

For the reporting period of January through March 2006, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(JANUARY - MARCH 2006)

MONTH / YEAR

JAN. 2006

BLACK & DECKER
AIR STRIPPER # 2
OPERATING RECORD

PAST MONTH READING

79636248

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	S	1241	790 19024	↑	28083	281785
2	M			377850		
3	T	1240	79396878	261529	28083	28225
4	W	1235	79598407	204980	28107	28225
5	T	1235	79803387	184939	28131	28225
6	F	1050	79988326	↑	28153	28225
7	S					
8				598238		
9	M	1325	80586564	198429	28227	28225
10	T	1300	80784993	224230	28227	28249
11	W	1340	81009223	225454	28227	28274
12	T	1405	81234677	195841	28227	28298
13	F	1115	81430518	↑	28227	28319
14						
15				282892		
16	M	1255	82113410	242055	28227	28393
17	T	1610	82355465	201116	28253	28393
18	W	1250	82556581	239118	28275	28393
19	T	1440	82795699	↑	28301	28393
20	F					
21						
22				880854		
23	M	1340	83676553	222615	28346	28393
24	T	1340	83849168	208218	28396	28417
25	W	1205	84109386	243241	28396	28439
26	T	1420	84350627	171021	28396	28465
27	F	0845	84521648	↑	28396	28484
28						
29				705483		
30	M	1240	85227131	230269	28396	28560
31	T	1325	85457400	248356	28421	28560
Total				6686728		
Average				215701		

NEXT MONTH READING 85705754

DATE 2-1-06

Month / Year

Feb. 2006

Black & Decker
Air Stripper # 2
Operating Record

Past Month Reading

85457400

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	W	1410	85705756	188059	28447	28560
2	T	1320	85893915	221887	28468	28560
3	F	1210	86115702	↑	28492	28560
4						
5						
6	M	1140	86782459	6666756 222833	28563	28560
7	T	1130	87005291	235867	28563	28584
8	W	1245	87241158	238400	28563	28609
9	T	1420	87479558	197484	28563	28635
10	F	1330	87677042	↑	28563	28656
11						
12						
13	M	1325	88368470	691428 230463	28563	28730
14	T	1405	88598933	207019	28588	28730
15	W	1215	88805952	235611	28610	28730
16	T	1330	89041563	217376	28635	28730
17	F	1245	89258939	↑	28658	28730
18						
19						
20	M	1230	89430652	671713 221039	28730	28730
21	T	1205	90151691	234918	28730	28753
22	W	1310	90386609	217825	28730	28778
23	T	1225	90604434	228846	28730	28801
24	F	1250	90833280	↑	28730	28826
25						
26						
27	M	1210	91503384	670109 238982	28730	28897
28	T	1340	91742371	211682	28756	28847
29						
30						
31						
Total				6248297		
Average				215459		

Next Month Reading 91954053

Date 3-1-06

Month / Year

Mar. 2006

**Black & Decker
Air Stripper # 2
Operating Record**

Past Month Reading

91742371

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	W	1215	91954053	239852	28778	28897
2	T	1345	92193905	216084	28804	28897
3	F	1345	92409989	↑	28827	28897
4						
5				667634		
6	M	1155	93077623	231267	28898	28897
7	T	1230	93308890	211730	28898	28922
8	W	1105	93520620	220789	28898	28944
9	T	1035	93741409	247305	28898	28968
10	F	1250	93988714	↑	28898	28994
11						
12				696995		
13	M	1510	94685609	187309	28898	29069
14	T	1105	94872998	244795	28918	29069
15	W	1310	95117793	211653	28944	29069
16	T	1145	95329446	225937	28966	29069
17	F	1145	9555383	↑	28990	29069
18						
19				669172		
20	M	1055	96224555	237552	29062	29069
21	T	1220	96462107	244277	29062	29094
22	W	1415	96706384	210422	29062	29120
23	T	1240	96916806	215584	29062	29142
24	F	1235	97132390	↑	29062	29165
25						
26				613530		
27	M	1055	97745920	218067	29062	29236
28	T	1320	97963987	177584	29088	29236
29	W	1050	98141571	212090	29110	29236
30	T	1235	98353667	226563	29135	29236
31	F	1430	98580230	225875		
Total				6852072		
Average						

3-27 = #5 well off at panel. Pump Motor burnt up Sat. 25th

Next Month Reading 99257856

Date 4/3/06

**APPENDIX B
DISCHARGE MONITORING REPORTS
(JANUARY- MARCH 2006)**

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**


NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881	001
PERMIT NUMBER	DISCHARGE NUMBER
(2-16)	(17-19)
MONITORING PERIOD	
YEAR MO DAY	YEAR MO DAY
FROM 2006 01 01	TO 06 01 31
(20-21) (22-23) (24-25)	(26-27) (28-29) (30-31)

FORM APPROVED
OMB No. 2040-0004

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW	SAMPLE MEASUREMENT	0.246	0.487	MGD				0	Measured/Recorded	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT						Measured/Recorded	
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT					<5		0	1/MONTH GRAB	
	PERMIT REQUIREMENT					5	ppb		1/MONTH GRAB	
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT					<5		0	1/MONTH GRAB	
	PERMIT REQUIREMENT					5	ppb		1/MONTH GRAB	
TRICHLOROETHYLENE	SAMPLE MEASUREMENT					<5		0	1/MONTH GRAB	
	PERMIT REQUIREMENT					5	ppb		1/MONTH GRAB	
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT					<0.1		0	1/MONTH GRAB	
	PERMIT REQUIREMENT					0.011	0.019	mg/l	1/MONTH GRAB	
OIL & GREASE	SAMPLE MEASUREMENT					<5		0	1/MONTH GRAB	
	PERMIT REQUIREMENT					10	<5	mg/l	1/MONTH GRAB	
pH	SAMPLE MEASUREMENT				6.10	6.70		0	2/WEEK GRAB	
	PERMIT REQUIREMENT				6.00	8.50		STD	2/WEEK GRAB	
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)							TELEPHONE	DATE	
Michael A. Clark Principal								410-374-9025	06 02 02	
TYPED OR PRINTED								SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**

ADDRESS: **555 13th Street., NW**

Suite 420E

Washington, DC 20004

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED

OMB No.2040-0004

MD0001881
PERMIT NUMBER

(2-16)

001
DISCHARGE NUMBER

(17-19)

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	2006	01	01		06	01	31

(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
BOD	SAMPLE MEASUREMENT							3.6		0	1/MONTH	GRAB
	PERMIT REQUIREMENT							15	mg/l		1/MONTH	GRAB
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT							<2.5		0	1/MONTH	GRAB
	PERMIT REQUIREMENT							20	30	mg/l	1/MONTH	GRAB
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
Principal
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Reddick
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: 410-374-9025
DATE: 06 | 02 | 02
AREA CODE-NUMBER: YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PAGE 2 OF 2

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881 **101**
 PERMIT NUMBER DISCHARGE NUMBER

(2-16) (17-19)

MONITORING PERIOD

FROM

YEAR	MO	DAY
2006	01	01

 TO

YEAR	MO	DAY
06	01	31

(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	QUANTITY OR LOADING (3 Card Only) (46-53)			QUALITY OR CONCENTRATION (4 Card Only) (38-45)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
FLOW	SAMPLE MEASUREMENT	0.217	0.256	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record	
FECAL COLIFORM	SAMPLE MEASUREMENT					<2	MPN/100ml	0	1/WEEK	GRAB	
	PERMIT REQUIREMENT					200			1/WEEK	GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER

Michael A. Clark
Principal

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN. AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Meddler

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

410-374-9025

AREA CODE-NUMBER

DATE

06 | 02 | 02

YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No.2040-0004

MD0001881	201
PERMIT NUMBER	DISCHARGE NUMBER
(2-16)	(17-19)

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	2006	01	01		06	01	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUALITY OR CONCENTRATION (4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.216	0.248	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record	
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH GRAB	
	PERMIT REQUIREMENT						N/A			1/MONTH GRAB	
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH GRAB	
	PERMIT REQUIREMENT						N/A			1/MONTH GRAB	
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH GRAB	
	PERMIT REQUIREMENT						N/A			1/MONTH GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN. AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	TELEPHONE	DATE
Michael A. Clark Principal TYPED OR PRINTED		<i>Earl Weddler</i> SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	410-374-9025 AREA CODE-NUMBER

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER
 (2-16)

001
 DISCHARGE NUMBER
 (17-19)

MONITORING PERIOD
 FROM: YEAR **2006** MO **02** DAY **01**
 TO: YEAR **06** MO **02** DAY **28**

FORM APPROVED
 OMB No.2040-0004

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) (46-53) QUANTITY OR LOADING (54-61)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.250	0.630	MGD					0	Measured/Recorded	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								Measured/Recorded
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						5			1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						5			1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						5			1/MONTH	GRAB
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT						<0.1	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					0.011	0.019			1/MONTH	GRAB
OIL & GREASE	SAMPLE MEASUREMENT						<5	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					10	<5			1/MONTH	GRAB
pH	SAMPLE MEASUREMENT				6.10		6.70	STD	0	2WEEK	GRAB
	PERMIT REQUIREMENT				6.00		8.50			2WEEK	GRAB

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
 Principal
 TYPED OR PRINTED

CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Weddell
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: 410-374-9025
 DATE: 06 | 03 | 01
 AREA CODE-NUMBER: 410-374-9025
 YEAR | MO | DAY: 06 | 03 | 01

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

FORM APPROVED
OMB No.2040-0004

NAME: **BTR CAPITAL GROUP**
ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004

MD0001881
PERMIT NUMBER
(2-16)

001
DISCHARGE NUMBER
(17-19)


FACILITY: **Hampstead, Maryland 21074**

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
2006	02	01	06	02	28
(20-21)			(26-27)		
(22-23)			(28-29)		
(24-25)			(30-31)		

LOCATION: **CARROLL COUNTY**

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
BOD	SAMPLE MEASUREMENT							<2	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT							15			1/MONTH	GRAB
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT							3.5	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					20	30				1/MONTH	GRAB
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER									TELEPHONE	DATE		
Michael A. Clark Principal TYPED OR PRINTED									410-374-9025	06 03 01		
CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)									Signature of Principal Executive Officer or Authorized Agent 		AREA CODE-NUMBER	YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PAGE 2 OF 2

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: BTR CAPITAL GROUP

ADDRESS: 555 13th Street., NW

Suite 420E

Washington, DC 20004

FACILITY: Hampstead, Maryland 21074

LOCATION: CARROLL COUNTY

MD0001881
PERMIT NUMBER
(2-16)

101
DISCHARGE NUMBER
(17-18)

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2006	02	01	06	02	28
(20-21)	(22-23)	(24-25)	(26-27)	(28-28)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) (46-53) QUANTITY OR LOADING (54-61)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.251	0.275	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record	
FECAL COLIFORM	SAMPLE MEASUREMENT						<2	MPN/100ml	0	1/WEEK GRAB	
	PERMIT REQUIREMENT						200			1/WEEK GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
Principal
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Weddell

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: 410-374-9025
DATE: 06 | 03 | 01
AREA CODE-NUMBER: 410-374-9025
YEAR | MO | DAY: 06 | 03 | 01

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER
 (2-18)

201
 DISCHARGE NUMBER
 (17-18)

MONITORING PERIOD					
FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
2006	02	01	06	02	28
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

FORM APPROVED
 OMB No.2040-0004

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.215	0.239	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1919. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						TELEPHONE		DATE	
Michael A. Clark Principal TYPED OR PRINTED								Signature of <i>Emil Weddler</i> SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		410-374-9025	
COMMENT AND EXPLANATION OF ANY VIOLATIONS								AREA CODE-NUMBER		YEAR MO DAY	

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881 **001**
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD
 FROM 2006 03 01 TO 06 03 31

FORM APPROVED
 OMB No.2040-0004

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (46-53) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
FLOW	SAMPLE MEASUREMENT	0.181	0.247	MGD					0	Measured/Recorded		
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT									
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT						5			1/MONTH	GRAB	
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT						5			1/MONTH	GRAB	
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT						5			1/MONTH	GRAB	
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT						<0.1	mg/l	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT						0.011		0.019		1/MONTH	GRAB
OIL & GREASE	SAMPLE MEASUREMENT						<5	mg/l	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT						10		<5		1/MONTH	GRAB
pH	SAMPLE MEASUREMENT				6.10		7.20	STD	0	2/WEEK	GRAB	
	PERMIT REQUIREMENT				6.00		8.50			2/WEEK	GRAB	
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)							TELEPHONE		DATE	
Michael A. Clark Principal									410-374-9025		06 04 04	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							AREA CODE-NUMBER		YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

(2-16)

(17-19)

MONITORING PERIOD

FROM YEAR 2006 MO 03 DAY 01 TO YEAR 06 MO 03 DAY 31

(20-21)

(22-23)

(24-25)

(26-27)

(28-29)

(30-31)

NOTE: Read instructions before completing this form.

FORM APPROVED
 OMB No.2040-0004

PARAMETER (32-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (48-53)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
BOD	SAMPLE MEASUREMENT							mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						<2				
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT					2.8	2.5	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					20	30				
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Weddle
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: 410-374-9025
 DATE: 06 | 04 | 04
 AREA CODE-NUMBER: YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.
 EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)
 NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No. 2040-0004

MD0001881
 PERMIT NUMBER
101
 DISCHARGE NUMBER

MONITORING PERIOD
 FROM YEAR **2006** MO **03** DAY **01** TO YEAR **06** MO **03** DAY **31**

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (48-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
FLOW	SAMPLE MEASUREMENT	0.251	0.275	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record	
FECAL COLIFORM	SAMPLE MEASUREMENT					<2	MPN/ 100ml	0	1/WEEK	GRAB	
	PERMIT REQUIREMENT					200			1/WEEK	GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
 Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Weddell
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
410-374-9025
 AREA CODE-NUMBER
 DATE
06 | 04 | 04
 YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER
201
 DISCHARGE NUMBER

FORM APPROVED
 OMB No.2040-0004

MONITORING PERIOD
 FROM YEAR **2006** MO **03** DAY **01** TO YEAR **06** MO **03** DAY **31**

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.221	0.247	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT					<5		ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					N/A				1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT					<5		ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					N/A				1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT					<5		ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					N/A				1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREON, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Weddell
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: **410-374-9025**
 DATE: **06 | 04 | 04**

COMMENT AND EXPLANATION OF ANY VIOLATIONS
 (Reference all attachments here)

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(JANUARY - MARCH 2006)



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 2

Client:	BTR Hampstead, Inc.	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0601078	Lab ID:	0601078-002
Project:	Hampstead-Monthly	Collection Date:	1/4/2006 11:27
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst NA

Chloromethane	< 10	10	µg/L	1/6/2006 14:19
Vinyl chloride	< 10	10	µg/L	1/6/2006 14:19
Bromomethane	< 10	10	µg/L	1/6/2006 14:19
Chloroethane	< 10	10	µg/L	1/6/2006 14:19
Acrolein	< 100	100	µg/L	1/6/2006 14:19
1,1-Dichloroethene	< 5.0	5.0	µg/L	1/6/2006 14:19
Methylene chloride	< 5.0	5.0	µg/L	1/6/2006 14:19
Acrylonitrile	< 100	100	µg/L	1/6/2006 14:19
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	1/6/2006 14:19
1,1-Dichloroethane	< 5.0	5.0	µg/L	1/6/2006 14:19
Chloroform	< 5.0	5.0	µg/L	1/6/2006 14:19
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	1/6/2006 14:19
Carbon tetrachloride	< 5.0	5.0	µg/L	1/6/2006 14:19
Benzene	< 5.0	5.0	µg/L	1/6/2006 14:19
1,2-Dichloroethane	< 5.0	5.0	µg/L	1/6/2006 14:19
Trichloroethene	160	5.0	µg/L	1/6/2006 14:19
1,2-Dichloropropane	< 5.0	5.0	µg/L	1/6/2006 14:19
Bromodichloromethane	< 5.0	5.0	µg/L	1/6/2006 14:19
2-Chloroethyl vinyl ether	< 10	10	µg/L	1/6/2006 14:19
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	1/6/2006 14:19
Toluene	< 5.0	5.0	µg/L	1/6/2006 14:19
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	1/6/2006 14:19
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	1/6/2006 14:19
Tetrachloroethene	99	5.0	µg/L	1/6/2006 14:19
Dibromochloromethane	< 5.0	5.0	µg/L	1/6/2006 14:19
Chlorobenzene	< 5.0	5.0	µg/L	1/6/2006 14:19
Ethylbenzene	< 5.0	5.0	µg/L	1/6/2006 14:19
Bromoform	< 5.0	5.0	µg/L	1/6/2006 14:19
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	1/6/2006 14:19
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	1/6/2006 14:19
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	1/6/2006 14:19



Microbac

www.microbac.com

Microbac Laboratories, Inc. Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 3

Client:	BTR Hampstead, Inc.	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0601078	Lab ID:	0601078-002
Project:	Hampstead-Monthly	Collection Date:	1/4/2006 11:27
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	1/6/2006 14:19



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 4

Client:	BTR Hampstead, Inc.	Client Sample ID:	Outfall 201 (Post)
Report No:	0601078		
Project:	Hampstead-Monthly	Lab ID:	0601078-003
Matrix:	WASTEWATER	Collection Date:	1/4/2006 11:26

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
VOLATILE ORGANIC COMPOUNDS (EPA 624)				Analyst: MLS
Prep. Method: <u>NA</u>	Prep. Date: <u>NA</u>	Prep Analyst <u>NA</u>		
<i>note: Result for 2-Chloroethyl vinyl ether estimated due to matrix spike recovery out of acceptance limits.</i>				
Chloromethane	< 10	10	µg/L	1/6/2006 14:53
Vinyl chloride	< 10	10	µg/L	1/6/2006 14:53
Bromomethane	< 10	10	µg/L	1/6/2006 14:53
Chloroethane	< 10	10	µg/L	1/6/2006 14:53
Acrolein	< 100	100	µg/L	1/6/2006 14:53
1,1-Dichloroethene	< 5.0	5.0	µg/L	1/6/2006 14:53
Methylene chloride	< 5.0	5.0	µg/L	1/6/2006 14:53
Acrylonitrile	< 100	100	µg/L	1/6/2006 14:53
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	1/6/2006 14:53
1,1-Dichloroethane	< 5.0	5.0	µg/L	1/6/2006 14:53
Chloroform	< 5.0	5.0	µg/L	1/6/2006 14:53
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	1/6/2006 14:53
Carbon tetrachloride	< 5.0	5.0	µg/L	1/6/2006 14:53
Benzene	< 5.0	5.0	µg/L	1/6/2006 14:53
1,2-Dichloroethane	< 5.0	5.0	µg/L	1/6/2006 14:53
Trichloroethene	< 5.0	5.0	µg/L	1/6/2006 14:53
1,2-Dichloropropane	< 5.0	5.0	µg/L	1/6/2006 14:53
Bromodichloromethane	< 5.0	5.0	µg/L	1/6/2006 14:53
2-Chloroethyl vinyl ether	< 10	10	µg/L	1/6/2006 14:53
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	1/6/2006 14:53
Toluene	< 5.0	5.0	µg/L	1/6/2006 14:53
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	1/6/2006 14:53
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	1/6/2006 14:53
Tetrachloroethene	< 5.0	5.0	µg/L	1/6/2006 14:53
Dibromochloromethane	< 5.0	5.0	µg/L	1/6/2006 14:53
Chlorobenzene	< 5.0	5.0	µg/L	1/6/2006 14:53
Ethylbenzene	< 5.0	5.0	µg/L	1/6/2006 14:53
Bromoform	< 5.0	5.0	µg/L	1/6/2006 14:53
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	1/6/2006 14:53
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	1/6/2006 14:53
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	1/6/2006 14:53



Microbac

www.microbac.com

Microbac Laboratories, Inc. Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 5

Client:	BTR Hampstead, Inc.	Client Sample ID:	Outfall 201 (Post)
Report No:	0601078	Lab ID:	0601078-003
Project:	Hampstead-Monthly	Collection Date:	1/4/2006 11:26
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	1/6/2006 14:53



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 2

Client: BTR Hampstead, Inc. Client Sample ID: Air Stripper 2 (Pre)
 Report No: 0602011
 Project: Hampstead-Quarterly Lab ID: 0602011-002
 Matrix: WASTEWATER Collection Date: 2/1/2006 9:05

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst: NA

note: Result for 2-Chloroethyl vinyl ether estimated due to matrix spike recovery out of acceptance limits.

Chloromethane	< 10	10	µg/L	2/6/2006	13:54
Vinyl chloride	< 10	10	µg/L	2/6/2006	13:54
Bromomethane	< 10	10	µg/L	2/6/2006	13:54
Chloroethane	< 10	10	µg/L	2/6/2006	13:54
Acrolein	< 100	100	µg/L	2/6/2006	13:54
1,1-Dichloroethene	< 5.0	5.0	µg/L	2/6/2006	13:54
Methylene chloride	< 5.0	5.0	µg/L	2/6/2006	13:54
Acrylonitrile	< 100	100	µg/L	2/6/2006	13:54
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	2/6/2006	13:54
1,1-Dichloroethane	< 5.0	5.0	µg/L	2/6/2006	13:54
Chloroform	< 5.0	5.0	µg/L	2/6/2006	13:54
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	2/6/2006	13:54
Carbon tetrachloride	< 5.0	5.0	µg/L	2/6/2006	13:54
Benzene	< 5.0	5.0	µg/L	2/6/2006	13:54
1,2-Dichloroethane	< 5.0	5.0	µg/L	2/6/2006	13:54
Trichloroethene	120	5.0	µg/L	2/6/2006	13:54
1,2-Dichloropropane	< 5.0	5.0	µg/L	2/6/2006	13:54
Bromodichloromethane	< 5.0	5.0	µg/L	2/6/2006	13:54
2-Chloroethyl vinyl ether	< 10	10	µg/L	2/6/2006	13:54
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	2/6/2006	13:54
Toluene	< 5.0	5.0	µg/L	2/6/2006	13:54
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	2/6/2006	13:54
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	2/6/2006	13:54
Tetrachloroethene	79	5.0	µg/L	2/6/2006	13:54
Dibromochloromethane	< 5.0	5.0	µg/L	2/6/2006	13:54
Chlorobenzene	< 5.0	5.0	µg/L	2/6/2006	13:54
Ethylbenzene	< 5.0	5.0	µg/L	2/6/2006	13:54
Bromoform	< 5.0	5.0	µg/L	2/6/2006	13:54
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	2/6/2006	13:54
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	2/6/2006	13:54
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	2/6/2006	13:54



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

Test Results

Page 3

Client:	BTR Hampstead, Inc.	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0602011		
Project:	Hampstead-Quarterly	Lab ID:	0602011-002
Matrix:	WASTEWATER	Collection Date:	2/1/2006 9:05

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	2/6/2006 13:54



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 4

Client: BTR Hampstead, Inc. Client Sample ID: Outfall 201 (Post)
 Report No: 0602011
 Project: Hampstead-Quarterly Lab ID: 0602011-003
 Matrix: WASTEWATER Collection Date: 2/1/2006 9:06

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst NA

Chloromethane	< 10	10	µg/L	2/3/2006	22:52
Vinyl chloride	< 10	10	µg/L	2/3/2006	22:52
Bromomethane	< 10	10	µg/L	2/3/2006	22:52
Chloroethane	< 10	10	µg/L	2/3/2006	22:52
Acrolein	< 100	100	µg/L	2/3/2006	22:52
1,1-Dichloroethene	< 5.0	5.0	µg/L	2/3/2006	22:52
Methylene chloride	< 5.0	5.0	µg/L	2/3/2006	22:52
Acrylonitrile	< 100	100	µg/L	2/3/2006	22:52
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	2/3/2006	22:52
1,1-Dichloroethane	< 5.0	5.0	µg/L	2/3/2006	22:52
Chloroform	< 5.0	5.0	µg/L	2/3/2006	22:52
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	2/3/2006	22:52
Carbon tetrachloride	< 5.0	5.0	µg/L	2/3/2006	22:52
Benzene	< 5.0	5.0	µg/L	2/3/2006	22:52
1,2-Dichloroethane	< 5.0	5.0	µg/L	2/3/2006	22:52
Trichloroethene	< 5.0	5.0	µg/L	2/3/2006	22:52
1,2-Dichloropropane	< 5.0	5.0	µg/L	2/3/2006	22:52
Bromodichloromethane	< 5.0	5.0	µg/L	2/3/2006	22:52
2-Chloroethyl vinyl ether	< 10	10	µg/L	2/3/2006	22:52
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	2/3/2006	22:52
Toluene	< 5.0	5.0	µg/L	2/3/2006	22:52
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	2/3/2006	22:52
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	2/3/2006	22:52
Tetrachloroethene	< 5.0	5.0	µg/L	2/3/2006	22:52
Dibromochloromethane	< 5.0	5.0	µg/L	2/3/2006	22:52
Chlorobenzene	< 5.0	5.0	µg/L	2/3/2006	22:52
Ethylbenzene	< 5.0	5.0	µg/L	2/3/2006	22:52
Bromoform	< 5.0	5.0	µg/L	2/3/2006	22:52
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	2/3/2006	22:52
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	2/3/2006	22:52
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	2/3/2006	22:52



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

Test Results

Page 5

Client:	BTR Hampstead, Inc.	Client Sample ID:	Outfall 201 (Post)
Report No:	0602011		
Project:	Hampstead-Quarterly	Lab ID:	0602011-003
Matrix:	WASTEWATER	Collection Date:	2/1/2006 9:06

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	2/3/2006 22:52



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 4

Client:	BTR Hampstead, Inc.	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0603018		
Project:	Hampstead-Monthly	Lab ID:	0603018-002
Matrix:	WASTEWATER	Collection Date:	3/1/2006 10:19

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
VOLATILE ORGANIC COMPOUNDS (EPA 624)				Analyst: MLS
Prep. Method: <u>NA</u>	Prep. Date: <u>NA</u>	Prep Analyst: <u>NA</u>		
<i>note: Large SO2 peak detected in sample may interfere with chloromethane.</i>				
Chloromethane	< 10	10	µg/L	3/6/2006 22:35
Vinyl chloride	< 10	10	µg/L	3/6/2006 22:35
Bromomethane	< 10	10	µg/L	3/6/2006 22:35
Chloroethane	< 10	10	µg/L	3/6/2006 22:35
Acrolein	< 100	100	µg/L	3/6/2006 22:35
1,1-Dichloroethene	< 5.0	5.0	µg/L	3/6/2006 22:35
Methylene chloride	< 5.0	5.0	µg/L	3/6/2006 22:35
Acrylonitrile	< 100	100	µg/L	3/6/2006 22:35
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	3/6/2006 22:35
1,1-Dichloroethane	< 5.0	5.0	µg/L	3/6/2006 22:35
Chloroform	< 5.0	5.0	µg/L	3/6/2006 22:35
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	3/6/2006 22:35
Carbon tetrachloride	< 5.0	5.0	µg/L	3/6/2006 22:35
Benzene	< 5.0	5.0	µg/L	3/6/2006 22:35
1,2-Dichloroethane	< 5.0	5.0	µg/L	3/6/2006 22:35
Trichloroethene	130	5.0	µg/L	3/6/2006 22:35
1,2-Dichloropropane	< 5.0	5.0	µg/L	3/6/2006 22:35
Bromodichloromethane	< 5.0	5.0	µg/L	3/6/2006 22:35
2-Chloroethyl vinyl ether	< 10	10	µg/L	3/6/2006 22:35
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	3/6/2006 22:35
Toluene	< 5.0	5.0	µg/L	3/6/2006 22:35
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	3/6/2006 22:35
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	3/6/2006 22:35
Tetrachloroethene	77	5.0	µg/L	3/6/2006 22:35
Dibromochloromethane	< 5.0	5.0	µg/L	3/6/2006 22:35
Chlorobenzene	< 5.0	5.0	µg/L	3/6/2006 22:35
Ethylbenzene	< 5.0	5.0	µg/L	3/6/2006 22:35
Bromoform	< 5.0	5.0	µg/L	3/6/2006 22:35
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	3/6/2006 22:35
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	3/6/2006 22:35
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	3/6/2006 22:35



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800
Fax: 410-633-6553
www.microbac.com

Test Results

Page 5

Client:	BTR Hampstead, Inc.	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0603018	Lab ID:	0603018-002
Project:	Hampstead-Monthly	Collection Date:	3/1/2006 10:19
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	3/6/2006 22:35



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 6

Client:	BTR Hampstead, Inc.	Client Sample ID:	Outfall 201 (Post)
Report No:	0603018		
Project:	Hampstead-Monthly	Lab ID:	0603018-003
Matrix:	WASTEWATER	Collection Date:	3/1/2006 10:18

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst NA

Chloromethane	< 10	10	µg/L	3/6/2006 23:10
Vinyl chloride	< 10	10	µg/L	3/6/2006 23:10
Bromomethane	< 10	10	µg/L	3/6/2006 23:10
Chloroethane	< 10	10	µg/L	3/6/2006 23:10
Acrolein	< 100	100	µg/L	3/6/2006 23:10
1,1-Dichloroethene	< 5.0	5.0	µg/L	3/6/2006 23:10
Methylene chloride	< 5.0	5.0	µg/L	3/6/2006 23:10
Acrylonitrile	< 100	100	µg/L	3/6/2006 23:10
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	3/6/2006 23:10
1,1-Dichloroethane	< 5.0	5.0	µg/L	3/6/2006 23:10
Chloroform	< 5.0	5.0	µg/L	3/6/2006 23:10
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	3/6/2006 23:10
Carbon tetrachloride	< 5.0	5.0	µg/L	3/6/2006 23:10
Benzene	< 5.0	5.0	µg/L	3/6/2006 23:10
1,2-Dichloroethane	< 5.0	5.0	µg/L	3/6/2006 23:10
Trichloroethene	< 5.0	5.0	µg/L	3/6/2006 23:10
1,2-Dichloropropane	< 5.0	5.0	µg/L	3/6/2006 23:10
Bromodichloromethane	< 5.0	5.0	µg/L	3/6/2006 23:10
2-Chloroethyl vinyl ether	< 10	10	µg/L	3/6/2006 23:10
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	3/6/2006 23:10
Toluene	< 5.0	5.0	µg/L	3/6/2006 23:10
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	3/6/2006 23:10
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	3/6/2006 23:10
Tetrachloroethene	< 5.0	5.0	µg/L	3/6/2006 23:10
Dibromochloromethane	< 5.0	5.0	µg/L	3/6/2006 23:10
Chlorobenzene	< 5.0	5.0	µg/L	3/6/2006 23:10
Ethylbenzene	< 5.0	5.0	µg/L	3/6/2006 23:10
Bromoform	< 5.0	5.0	µg/L	3/6/2006 23:10
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	3/6/2006 23:10
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	3/6/2006 23:10
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	3/6/2006 23:10



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

Test Results

Page 7

Client:	BTR Hampstead, Inc.	Client Sample ID:	Outfall 201 (Post)
Report No:	0603018	Lab ID:	0603018-003
Project:	Hampstead-Monthly	Collection Date:	3/1/2006 10:18
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	3/6/2006 23:10

APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(FEBRUARY 2006)

STL Chicago
2417 Bond Street
University Park, IL 60466

Tel: 708 534 5200 Fax: 708 534 5211
www.stl-inc.com

SEVERN TRENT LABORATORIES
ANALYTICAL REPORT

JOB NUMBER: 244715

Prepared For:

Weston Solutions, Inc.
Building 5-2
1400 Weston Way
West Chester, PA 19380-1499

Project: Black & Decker - MD

Attention: Tom Cornuet

Date: 03/15/2006

Signature

Name: Richard C. Wright

Title: Project Manager

E-Mail: rwright@stl-inc.com

Date

3/15/06

STL Chicago
2417 Bond Street
University Park, IL 60466


PHONE: (708) 534-5200
FAX...: (708) 534-5211

This Report Contains (110) Pages

Severn Trent Laboratories Chicago
GC/MS Case Narrative

Weston Solutions
Black and Decker
JOB Number: 244715
VOA DATA:

1. All of the samples were analyzed within the 14-day hold time from the date of collection.
2. All Method Blank target compounds were below reporting limits.
3. The LCS (Laboratory Control Samples) had all five-controlled spike recoveries within the in-house generated QC limits.
4. Matrix Spike/Matrix Spike Duplicate analyses were not performed on this sample set.
5. The volatile samples had all surrogate recoveries within the in-house generated QC limits.
6. The water samples were prepared using Method 5030 and analyzed following SW846 Method 8260B and 8000B. All calibration criteria are met per method or SOP (for minimum R values for certain compounds). The low point in the initial calibration verifies the base reporting limits. The target compounds were quantitated using the initial calibration.
7. The volatile samples had all internal standard areas and retention times within the SOP acceptance limits as compared to the corresponding calibration verification standard.
8. The water samples were analyzed using a 10-mL purge volume. An initial dilution was required on sample 3 due to sample matrix. Secondary dilutions for target compounds were required on samples 1, 2, 3, 4, 8, 9, and 23. The results and reporting limits were adjusted to account for the dilution performed.



John Nagel
GC/MS Dept.

3-13-06
Date

STL Chicago is part of Severn Trent Laboratories, Inc.

SAMPLE INFORMATION
Date: 03/15/2006

Job Number.: 244715
Customer...: Weston Solutions, Inc.
Attn.....: Tom Cornuet

Project Number.....: 20005711
Customer Project ID.....: BLACK AND DECKER
Project Description.....: Black & Decker - MD

Laboratory Sample ID	Customer Sample ID	Sample Matrix	Date Sampled	Time Sampled	Date Received	Time Received
244715-1	EW-2	Water	02/28/2006	09:45	03/02/2006	10:10
244715-2	EW-3	Water	02/28/2006	10:00	03/02/2006	10:10
244715-3	EW-4	Water	02/28/2006	12:10	03/02/2006	10:10
244715-4	EW-5	Water	02/28/2006	11:15	03/02/2006	10:10
244715-5	EW-6	Water	02/27/2006	13:35	03/02/2006	10:10
244715-6	EW-7	Water	02/27/2006	13:40	03/02/2006	10:10
244715-7	EW-8	Water	02/27/2006	13:45	03/02/2006	10:10
244715-8	EW-9	Water	02/27/2006	13:55	03/02/2006	10:10
244715-9	EW-9 DUP	Water	02/27/2006	13:55	03/02/2006	10:10
244715-10	EW-10	Water	02/27/2006	14:05	03/02/2006	10:10
244715-11	RFW-1A	Water	02/27/2006	09:00	03/02/2006	10:10
244715-12	RFW-1B	Water	02/28/2006	08:30	03/02/2006	10:10
244715-13	RFW-2A	Water	02/27/2006	08:00	03/02/2006	10:10
244715-14	RFW-2B	Water	02/27/2006	08:20	03/02/2006	10:10
244715-15	RFW-3B	Water	02/28/2006	08:15	03/02/2006	10:10
244715-16	RFW-4A	Water	02/28/2006	07:30	03/02/2006	10:10
244715-17	RFW-4B	Water	02/28/2006	08:00	03/02/2006	10:10
244715-18	RFW-4B DUP	Water	02/28/2006	08:00	03/02/2006	10:10
244715-19	RFW-6	Water	02/28/2006	07:45	03/02/2006	10:10
244715-20	RFW-7	Water	02/27/2006	09:50	03/02/2006	10:10
244715-21	RFW-9	Water	02/28/2006	12:00	03/02/2006	10:10
244715-22	RFW-11B	Water	02/28/2006	12:30	03/02/2006	10:10
244715-23	RFW-12B	Water	02/28/2006	08:50	03/02/2006	10:10
244715-24	RFW-13	Water	02/27/2006	14:25	03/02/2006	10:10
244715-25	RFW-17	Water	02/27/2006	10:45	03/02/2006	10:10
244715-26	TRIP BLANK	Water	02/27/2006	08:00	03/02/2006	10:10

STL Chicago is part of Severn Trent Laboratories, Inc.

SAMPLE INFORMATION
Date:

Job Number.: 244715

Customer...: Weston Solutions, Inc.

Attn.....: Tom Cornuet

Project Number.....: 20005711

Customer Project ID....: BLACK AND DECKER

Project Description....: Black & Decker - MD

Laboratory Sample ID	Customer Sample ID	Sample Matrix	Date Sampled	Time Sampled	Date Received	Time Received
244715-27	LEISTER-1	Water	02/27/2006	17:15	03/02/2006	10:10
244715-28	LEISTER-DAIRY	Water	02/27/2006	17:20	03/02/2006	10:10

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-2
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 09:45
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-1
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	cis-1,2-Dichloroethene	3.6	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Trichloroethene	520	U		1.3	10	10.00000	ug/L	175148	D1	03/07/06 1609	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175148		03/07/06 1544	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-2
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 09:45
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-1
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Tetrachloroethene	63			0.18	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175148		03/07/06 1544	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1544	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715 Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc. PROJECT: BLACK AND DECKER ATTN: Tom Cornuet

Customer Sample ID: EW-2
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 09:45
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-1
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1544	jd n
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1544	jd n
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175148		03/07/06 1544	jd n
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1544	jd n
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1544	jd n
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175148		03/07/06 1544	jd n
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175148		03/07/06 1544	jd n

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-3
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 10:00
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-2
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	cis-1,2-Dichloroethene	1.7	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Trichloroethene	170	U		1.3	10	10.0000	ug/L	175148	01	03/07/06 1658	jd
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175148		03/07/06 1634	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS												
Job Number: 244715								Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: EW-3 Date Sampled.....: 02/28/2006 Time Sampled.....: 10:00 Sample Matrix.....: Water						Laboratory Sample ID: 244715-2 Date Received.....: 03/02/2006 Time Received.....: 10:10						
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Tetrachloroethane	5.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175148		03/07/06 1634	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1634	jd

* In Description = Dry Wgt.

LABORATORY TEST RESULTS												
Job Number: 244715								Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: EW-3 Date Sampled.....: 02/28/2006 Time Sampled.....: 10:00 Sample Matrix.....: Water						Laboratory Sample ID: 244715-2 Date Received.....: 03/02/2006 Time Received.....: 10:10						
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-4
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 12:10
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-3
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	5.0	U		0.60	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Chloromethane	5.0	U		1.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Vinyl chloride	5.0	U		0.80	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Bromomethane	5.0	U		3.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Chloroethane	5.0	U		1.6	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Trichlorofluoromethane	5.0	U		0.70	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,1-Dichloroethene	5.0	U		1.2	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Carbon disulfide	25	U		0.75	25	5.00000	ug/L	175148		03/07/06 1723	jdj
	Acetone	25	U		7.0	25	5.00000	ug/L	175148		03/07/06 1723	jdj
	Methylene chloride	5.0	U		1.2	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	trans-1,2-Dichloroethene	5.0	U		1.4	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,1-Dichloroethane	5.0	U		0.75	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	2,2-Dichloropropane	5.0	U		0.85	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	cis-1,2-Dichloroethene	5.0	U		1.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	2-Butanone (MEK)	25	U		5.0	25	5.00000	ug/L	175148		03/07/06 1723	jdj
	Bromochloromethane	5.0	U		1.4	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Chloroform	5.0	U		0.70	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,1,1-Trichloroethane	5.0	U		0.85	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,1-Dichloropropene	5.0	U		1.9	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Carbon tetrachloride	5.0	U		1.7	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Benzene	5.0	U		1.2	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2-Dichloroethane	5.0	U		1.2	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Trichloroethene	1200	U		6.5	50	50.00000	ug/L	175148	D1	03/07/06 1748	jdj
	1,2-Dichloropropane	5.0	U		0.95	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Dibromomethane	5.0	U		1.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Bromodichloromethane	5.0	U		1.1	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	cis-1,3-Dichloropropene	5.0	U		0.75	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	4-Methyl-2-pentanone (MIBK)	25	U		4.6	25	5.00000	ug/L	175148		03/07/06 1723	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-4
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 12:10
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-3
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	5.0	U		0.90	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	trans-1,3-Dichloropropene	5.0	U		0.80	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,1,2-Trichloroethane	5.0	U		1.2	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Tetrachloroethane	26			0.90	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,3-Dichloropropane	5.0	U		1.1	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	2-Hexanone	25	U		5.0	25	5.00000	ug/L	175148		03/07/06 1723	jdj
	Dibromochloromethane	5.0	U		1.1	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2-Dibromoethane (EDB)	5.0	U		1.6	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Chlorobenzene	5.0	U		0.75	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,1,1,2-Tetrachloroethane	5.0	U		1.6	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Ethylbenzene	5.0	U		1.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	m&p-Xylenes	10	U		1.8	10	5.00000	ug/L	175148		03/07/06 1723	jdj
	o-Xylene	5.0	U		0.95	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Styrene	5.0	U		0.90	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Bromoform	5.0	U		1.6	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Isopropylbenzene	5.0	U		1.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Bromobenzene	5.0	U		1.1	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,1,2,2-Tetrachloroethane	5.0	U		1.7	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2,3-Trichloropropane	5.0	U		1.8	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	n-Propylbenzene	5.0	U		0.80	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	2-Chlorotoluene	5.0	U		0.80	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,3,5-Trimethylbenzene	5.0	U		0.90	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	4-Chlorotoluene	5.0	U		0.90	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	tert-Butylbenzene	5.0	U		0.80	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2,4-Trimethylbenzene	5.0	U		1.3	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	sec-Butylbenzene	5.0	U		0.95	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,3-Dichlorobenzene	5.0	U		1.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	p-Isopropyltoluene	5.0	U		1.4	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,4-Dichlorobenzene	5.0	U		1.2	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS						Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-4 Date Sampled.....: 02/28/2006 Time Sampled.....: 12:10 Sample Matrix.....: Water			Laboratory Sample ID: 244715-3 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	5.0	U		1.8	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2-Dichlorobenzene	5.0	U		1.4	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2-Dibromo-3-chloropropane	5.0	U		2.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2,4-Trichlorobenzene	5.0	U		1.8	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Hexachlorobutadiene	5.0	U		1.8	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Naphthalene	5.0	U		1.8	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2,3-Trichlorobenzene	5.0	U		2.2	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-5
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 11:15
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-4
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,1-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	trans-1,2-Dichloroethane	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	cis-1,2-Dichloroethane	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,1,1-Trichloroethane	1.2	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Trichloroethane	260	U		1.3	10	10.0000	ug/L	175148	D1	03/07/06 1837	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175148		03/07/06 1812	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-5
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 11:15
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-4
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Tetrachloroethene	7.8	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS												
Job Number: 244715								Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: EW-5 Date Sampled.....: 02/28/2006 Time Sampled.....: 11:15 Sample Matrix.....: Water						Laboratory Sample ID: 244715-4 Date Received.....: 03/02/2006 Time Received.....: 10:10						
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-6
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 13:35
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-5
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Trichloroethene	11	U		0.13	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175148		03/07/06 1903	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-6
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 13:35
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-5
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	Tetrachloroethane	19			0.18	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1903	jd n

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS						Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-6 Date Sampled.....: 02/27/2006 Time Sampled.....: 13:35 Sample Matrix.....: Water			Laboratory Sample ID: 244715-5 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-7
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 13:40
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-6
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	cis-1,2-Dichloroethene	8.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Trichloroethene	7.2	U		0.13	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175148		03/07/06 1928	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-7
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 13:40
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-6
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Tetrachloroethane	13			0.18	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS							Date: 03/15/2006			
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: EW-7 Date Sampled.....: 02/27/2006 Time Sampled.....: 13:40 Sample Matrix.....: Water				Laboratory Sample ID: 244715-6 Date Received.....: 03/02/2006 Time Received.....: 10:10								
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-8
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 13:45
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-7
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	cis-1,2-Dichloroethene	23	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Trichloroethene	12	U		0.13	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175148		03/07/06 1952	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-8
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 13:45
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-7
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Tetrachloroethane	73			0.18	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS						Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-8 Date Sampled.....: 02/27/2006 Time Sampled.....: 13:45 Sample Matrix.....: Water			Laboratory Sample ID: 244715-7 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj

* In Description = Dry Wgt.