

**Quarterly Groundwater Monitoring Report**

Prepared for  
**Black & Decker (U.S.) Inc.**

Hampstead, Maryland

April 2010

Prepared by

**WESTON SOLUTIONS, INC.**

**West Chester, Pennsylvania 19380-1499**

---

## TABLE OF CONTENTS

---

Section	Page
1. INTRODUCTION .....	1-1
2. SITE CHARACTERISTICS .....	2-1
2.1 HYDRAULIC PROPERTIES .....	2-1
2.2 EFFLUENT CHARACTERISTICS .....	2-1
2.3 GROUNDWATER QUALITY DATA .....	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS .....	4-1

---

## LIST OF APPENDICES

---

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

---

## LIST OF TABLES

---

<b>Table</b>	<b>Page</b>
Table 2-1 Treatment System Pumping Records – 1st Quarter 2010.....	2-2
Table 2-2 Groundwater Elevation Data – 1st Quarter 2010 .....	2-3
Table 2-3 Effluent Characteristics Summary – 1st Quarter 2010 .....	2-4
Table 2-4 Summary of Groundwater Analytical Results - February 2010.....	2-5
Table 3-1 Treatment System Maintenance Activities – 1st Quarter 2010.....	3-2

## 1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

## **2. SITE CHARACTERISTICS**

### **2.1 HYDRAULIC PROPERTIES**

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of January through March 2010.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of January through March 2010, the extraction wells were pumping at an average combined rate of approximately 167 gallons per minute (gpm).

### **2.2 EFFLUENT CHARACTERISTICS**

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of January through March 2010 are included in Appendix B.

### **2.3 GROUNDWATER QUALITY DATA**

For the reporting period of January through March 2010, approximately 18.6 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (86.1%) and tetrachloroethene (PCE) (13.9%). Analytical results of the groundwater collected from the air stripper for the period of January through March 2010 are included in Appendix C.

A summary of the analytical results from the third quarter (February 2010) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

**Table 2-1**  
**Treatment System Pumping Records - 1st Quarter 2010**  
**Black & Decker**  
**Hampstead, Maryland**

<b>Date</b>	<b>Water Pumped (gallons)</b>
January 2010	6,627,345
February 2010	6,213,673
March 2010	7,395,042

**Table 2-2**  
**Groundwater Elevation Data - 1st Quarter 2010**  
**Black & Decker**  
**Hampstead, Maryland**

WELL NO.	TOC ELEV.	TOTAL DEPTH	1/15/2010		2/18/2010*		3/11/2010	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NC	DRY	NC	DRY	NC
EW-2	849.21	110	66.58	782.63	88.17	761.04	92.47	756.74
EW-3	846.64	118	82.50	764.14	79.40	767.24	79.81	766.83
EW-4	858.01	97.5	PC	NC	PC	NC	PC	NC
EW-5	864.17	98	78.40	785.77	86.72	777.45	89.32	774.85
EW-6	831.98	115	102.87	729.11	102.90	729.08	99.28	732.70
EW-7	818.38	78	50.94	767.44	45.41	772.97	40.68	777.70
EW-8	811.13	98	91.72	719.41	92.05	719.08	89.31	721.82
EW-9	811.35	141	101.90	709.45	102.61	708.74	101.61	709.74
EW-10	807.74	INA	47.85	759.89	52.17	755.57	47.72	760.02
RFW-1A	864.37	78	50.90	813.47	47.16	817.21	47.40	816.97
RFW-1B	864.23	200	50.91	813.32	47.22	817.01	47.46	816.77
RFW-2A	857.41	35	14.41	843.00	12.36	845.05	11.96	845.45
RFW-2B	857.73	75	15.06	842.67	12.98	844.75	12.34	845.39
RFW-3B	839.21	153	33.94	805.27	NA	NC	33.29	805.92
RFW-4A	830.37	62	34.56	795.81	35.00	795.37	33.91	796.46
RFW-4B	830.37	120	35.03	795.34	34.92	795.45	33.80	796.57
RFW-5A	817.50	30	DRY	NC	DRY	NC	DRY	NC
RFW-6	785.04	120	3.18	781.86	3.24	781.80	2.86	782.18
RFW-7	805.14	29	6.94	798.20	NA	NC	6.40	798.74
RFW-8	860.07	56	DRY	NC	DRY	NC	DRY	NC
RFW-9	862.02	49	24.22	837.80	24.36	837.66	23.78	838.24
RFW-10	852.06	58	DRY	NC	DRY	NC	DRY	NC
RFW-11A	849.32	72	Damaged	NC	Damaged	NC	Damaged	NC
RFW-11B	849.62	116	65.71	783.91	64.83	784.79	66.84	782.78
RFW-12B	844.87	264	50.48	794.39	48.83	796.04	48.86	796.01
RFW-13	849.11	150	59.89	789.22	NA	NC	65.67	783.44
RFW-14B	812.39	281	46.94	765.45	46.81	765.58	47.53	764.86
RFW-16	856.14	41	DRY	NC	DRY	NC	DRY	NC
RFW-17	834.66	60.5	27.37	807.29	24.56	810.10	24.61	810.05
RFW-20	842.49	142	34.17	808.32	31.82	810.67	31.62	810.87
RFW-21	832.65	102	22.16	810.49	20.08	812.57	19.83	812.82
PH-7	805.94	89	26.02	779.92	25.91	780.03	22.69	783.25
PH-9	814.94	98	54.16	760.78	55.94	759.00	54.47	760.47
PH-11	820.68	78	45.06	775.62	NA	NC	51.01	769.67
PH-12	828.35	87	47.78	780.57	NA	NC	52.78	775.57
B-3	803.02	83	8.67	794.35	NA	NC	9.63	793.39
Amoco	842.29	INA	NA	NC	NA	NC	NA	NC
Hamp. Town #22	804.96	INA	17.49	787.47	NA	NC	20.46	784.50
Pembroke #1	INA	INA	12.31	NC	NA	NC	11.31	NC
Pembroke #2	INA	INA	Damaged	NC	Damaged	NC	Damaged	NC
N. Houcks. Rd.	INA	INA	10.68	NC	NA	NC	9.85	NC
E. Century St.	INA	INA	19.39	NC	NA	NC	19.08	NC
Lwr. Beckleys. Rd.	INA	INA	55.08	NC	NA	NC	54.26	NC

NA - Not Available/Not Accessible

NC - Not Calculable

INA - Information not available

PC - Pump Cycles

\* - Due to heavy snow many wells were inaccessible

**Table 2-3**  
**Effluent Characteristics Summary - 1st Quarter 2010**  
**Black & Decker**  
**Hampstead, Maryland**

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				January 2010	February 2010	March 2010	
001	FLOW	average	MGD	NA	0.191	0.232	0.279
		maximum	MGD	NA	0.846	0.389	0.655
	1,1,1-Trichloroethane		ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene		ug/l	5	< 1	< 1	< 1
	Trichloroethylene		ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	< 5	13.0
		quarterly average	mg/l	10	< 5	< 5	7.0
	pH	minimum	STD	6.0	6.00	6.20	6.30
		maximum	STD	8.5	6.20	7.20	6.60
	BOD		mg/l	15	0.0	0.0	0.0
TSS	maximum	mg/l	30	0.0	0.0	0.0	
	quarterly average	mg/l	20	0.0	0.0	0.0	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.297	0.283	0.280
		maximum	MGD	NA	0.377	0.431	0.362
	Fecal Coliform		MPN/100ml	200	1.0	1.0	1.0
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.225
		maximum	MGD	NA	NR	NR	0.299
	1,1,1-Trichloroethane		ug/l	NA	NR	NR	< 1
	Tetrachloroethylene		ug/l	NA	NR	NR	< 1
	Trichloroethylene		ug/l	NA	NR	NR	< 1

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported



Table 2-4

Summary of Groundwater Analytical Results - February 2010  
 Black & Decker  
 Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3.5	2.8	1 U	1 U	1 U	4.4	24	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	410	130	1100	150	10	4	10	1.1	1 J	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1.5
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	62	3.4	22	5.9	17	9.6	63	110	100	1 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

NS = Not Sampled

Table 2-4  
**Summary of Groundwater Analytical Results - February 2010**  
**Black & Decker**  
**Hampstead, Maryland**

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10	
Chloromethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
Bromomethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
Chloroethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
Methylene Chloride	ug/L	2 U	2 U	2 U	2 U	NS	2 U	2 U	2 U	NS	2 U	NS	NS	2 U	NS	
Acetone	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	NS	NS	5 U	NS	
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	NS	NS	5 U	NS	
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1.3	NS	
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1.6	1	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	3.7	NS	1 U	NS	NS	25	NS	
Chloroform	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
2-Butanone	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	NS	NS	5 U	NS	
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1.6	NS	
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
Trichloroethene	ug/L	1 U	1 U	1 U	1 U	NS	30	28	50	NS	1 U	NS	NS	15	NS	
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
Benzene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
Bromoform	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	NS	5 U	5 U	5 U	NS	5 U	NS	NS	5 U	NS	
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	NS	NS	5 U	NS	
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	NS	17	16	69	NS	1.4	NS	NS	8.5	NS	
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
Toluene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
Styrene	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	NS	NS	1 U	NS	

Notes: DUP = Duplicate sample  
NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.  
J = Indicates an estimated value.

Table 2-4

Summary of Groundwater Analytical Results - February 2010  
 Black & Decker  
 Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	RFW-20	RFW-21	Town #22	Town #23	Trip Blank
		USEPA drinking water method 524.2														
Chloromethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	NS	NS	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	NS	NS	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	NS	NS	2 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Acetone	ug/L	NS	5 U	5 U	NS	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	NS	NS	5 U	ABD	ABD	ABD	5 U	NA	NA	NS	NS	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	3	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Chloroform	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	9.8	0.5 U	0.5 U	NS	NS	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	NS	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	6.8	0.5 U	0.5 U	NS	NS	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Trichloroethene	ug/L	NS	7.9	280	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	2.8	0.5 U	0.5 U	NS	NS	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Benzene	ug/L	NS	1 U	1 U	NS	NS	1.5	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Bromoform	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1.7	0.5 U	0.5 U	NS	NS	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	NS	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
2-Hexanone	ug/L	NS	5 U	5 U	NS	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
Tetrachloroethene	ug/L	NS	1 U	25	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Toluene	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Styrene	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	NS	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division. Samples from all of the other wells are analyzed with USEPA Method 8260.

NS = Not sampled

U = Compound was analyzed but not detected.

ABD = Well has been abandoned

analytical data package is included in Appendix D. Wells RFW-3B, RFW-7 and RFW-13 were not accessible due to heavy snow falls.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from wells RFW-4B and EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

### 3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (January through March 2010) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

**Table 3-1**  
**Treatment System Maintenance Activities - 1st Quarter 2010**  
**Black & Decker**  
**Hampstead, Maryland**

<b>Date</b>	<b>Event/Corrective Action</b>
<b>Jan-10</b>	Alarm at the stripper due to a power outage. Reset the system everything back online.
<b>Jan-10</b>	Alarm at the stripper due to wet well supply failure due to a frozen supply pipe. The pipe was thawed and the system is back online.
<b>Jan-10</b>	Alarm at stripper due to a high wet well. Reset the system and everything is back online.
<b>Jan-10</b>	Replace the heater in EW-5
<b>Feb-10</b>	Alarm at stripper. EW-5 tripped off. Heating elements in EW-5 heater are bad. The well is reset, a temporary heater is used until the heating elements are replaced. in the heater.
<b>Mar-10</b>	Alarm at stripper due to a power outage. Reset the system everything back online.
<b>Mar-10</b>	Alarm at the stripper due to a high column blower failure. The system was reset everything is okay.
<b>Mar-10</b>	EW-8 tripped off due to a bad control relay. Replaced the relay and the well is back online.

#### 4. RECOMMENDATIONS

For the reporting period of January through March 2010, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

---

**APPENDIX A**  
**GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS**  
**(JANUARY – MARCH 2010)**

---



MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:  
Maryland Environmental Service  
259 Najoles Road, Millersville MD

Facility: BTR Capital Group  
Address: 626 Hanover Pike, Hampstead Maryland  
Additional Op's & cert # - Dorrance Jones 0763, Gary Dickerson 0782

Permit Number: 02-DP-0022  
Superintendent: Earle Villarreal

Certification # 1017

Month: January  
Year: 2010

Final Effluent outfall 001											Outfall 101					Outfall 201			Operator		
Date	Appearance	Discharge MGD	pH	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD <sub>5</sub> mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin inches	Alum Gpd	Hypochlorite Gpd	Post Cl <sub>2</sub> mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l		Trichloroethene ug/l	Discharge mgd
1	Clear	0.16000									0.267000		0.0	5.0	1.0	5.0				0.183305	gdickerson
2	Clear	0.13500									0.312000		0.0	5.0	1.0	5.0				0.211153	djones
3	Clear	0.11000									0.317000		0.0	5.0	1.0	5.0				0.227532	djones
4	Clear	0.09600									0.275000		0.0	5.0	1.0	5.0				0.221972	gdickerson
5	Clear	0.11300	6.15	0.00							0.289000		0.0	5.0	1.0	5.0				0.209149	gdickerson
6	Clear	0.14600			< 1.00	< 1.00	< 1.00	< 2.0	< 4.0	< 5.0	0.303000	< 1.8	0.0	10.0	1.0	5.0				0.219937	djones
7	Clear	0.13300	6.23	0.00							0.298000		0.0	10.0	1.0	5.0				0.220453	djones
8	Clear	0.14700									0.308000		0.0	10.0	1.0	5.0				0.216629	gdickerson
9	Clear	0.11900									0.270000		0.0	10.0	1.0	5.0				0.199657	gdickerson
10	Clear	0.12300									0.265000		0.0	5.0	1.0	5.0				0.220021	gdickerson
11	Clear	0.14000									0.303000		0.0	5.0	1.0	5.0				0.226791	djones
12	Clear	0.13700	6.11	0.00							0.296000		0.0	5.0	1.0	5.0				0.212351	djones
13	Clear	0.11500									0.313000	< 1.8	0.0	5.0	1.0	5.0				0.219525	djones
14	Clear	0.08700	6.07	0.00							0.280000		0.0	5.0	1.0	5.0				0.213232	djones
15	Clear	0.07200									0.222000		0.0	5.0	1.0	5.0				0.168193	djones
16	Clear	0.09300									0.279000		0.0	5.0	1.0	5.0				0.223326	djones
17	Clear	0.62900									0.323000		0.0	5.0	1.0	5.0				0.227788	djones
18	Clear	0.20700									0.289000		0.0	5.0	1.0	5.0				0.218506	gdickerson
19	Clear	0.17300	6.03	0.00							0.313000		0.0	5.0	1.0	5.0				0.207249	gdickerson
20	Clear	0.16600									0.299000		0.0	10.0	1.0	5.0	< 1.0	< 1.0	< 1.0	0.220468	djones
21	Clear	0.17900	6.10	0.00							0.377000	< 1.8	0.0	5.0	1.0	5.0				0.227615	djones
22	Clear	0.15100									0.308000		0.0	5.0	1.0	5.0				0.179822	djones
23	Clear	0.17500									0.354000		0.0	5.0	1.0	5.0				0.232339	djones
24	Clear	0.84600									0.328000		0.0	5.0	1.0	5.0				0.236200	gdickerson
25	Clear	0.45200									0.245000		0.0	5.0	1.0	5.0				0.196617	djones
26	Clear	0.20100	6.17	0.00							0.297000		0.0	5.0	1.0	5.0				0.231992	djones
27	Clear	0.14300									0.276000	< 1.8	0.0	10.0	1.0	5.0				0.208329	djones
28	Clear	0.16400	6.22	0.00							0.316000		0.0	5.0	1.0	5.0				0.213679	djones
29	Clear	0.16300									0.319000		0.0	5.0	1.0	5.0				0.223944	djones
30	Clear	0.16100									0.231000		0.0	5.0	1.0	5.0				0.169468	djones
31	Clear	0.18400									0.327000		0.0	5.0	1.0	5.0				0.240103	djones
Total		5.92000									9.199000									6.627345	
Average		0.19097	6.1	<0.10	0	0	0	0	0	0	0.296742	1	0.0	6.0	1.0	5.0	0	0	0	0.213785	
Minimum		0.07200	6.0	0.00	0	0	0	0	0	0	0.222000	1	0.0	5.0	1.0	5.0	0	0	0	0.168193	
Maximum		0.84600	6.2	<0.10	0	0	0	0	0	0	0.377000	1	0.0	10.0	1.0	5.0	0	0	0	0.240103	MOR 5-11-09

COMMENTS:

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:

Facility: BTR Capital Group

Permit Number: 02-DP-0022

Month: February

Maryland Environmental Service  
259 Najoles Road, Millersville MD

Address: 626 Hanover Pike, Hampstead Maryland

Superintendent: Earle Villarreal

Certification # 1017

Year: 2010

Additional Op's & cert # - Dorrance Jones 0763, Martin Whitt 0666, David Smith 9153, Gary Kesselring 1962, Dave Coale 1662

Date	Appearance	Final Effluent outfall 001									Outfall 101						Outfall 201			Operator
		Discharge MGD	pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD <sub>5</sub> mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	
1	Clear	0.15900								0.258000		0.0	5.0	1.0	5.0				0.210292	mwhitt
2	Clear	0.21300	7.21	0.00						0.264000		0.0	5.0	1.0	5.0				0.233163	mwhitt
3	Clear	0.18900								0.245000	< 1.8	0.0	5.0	1.0	5.0				0.116581	djones
4	Clear	0.17200	6.20	0.00						0.272000		0.0	2.0	1.0	5.0				0.232914	djones
5	Clear	0.27700								0.277000		0.0	1.0	1.0	5.0				0.103769	djones
6	Clear	0.28800								0.277000		0.0	1.0	1.0	5.0				0.283393	djones
7	Clear	0.32700								0.277000		0.0	2.0	1.0	5.0				0.283393	dcoale
8	Clear	0.28400								0.296000		0.0	3.0	1.0	5.0				0.251250	djones
9	Clear	0.38900								0.166000		0.0	5.0	1.0	5.0				0.120787	djones
10	Clear	0.28000								0.431000		0.0	5.0	1.0	5.0				0.227734	dcoale
11	Clear	0.19800								0.244000		0.0	5.0	1.0	5.0				0.227734	dcoale
12	Clear	0.15000	6.21	0.00						0.295000	< 1.8	0.0	2.0	1.0	5.0				0.175734	djones
13	Clear	0.18500								0.280000		0.0	3.0	1.0	5.0				0.226511	djones
14	Clear	0.21500	6.36	0.00						0.343000		0.0	5.0	1.0	5.0				0.260778	djones
15	Clear	0.21800								0.290000		0.0	5.0	1.0	5.0				0.245778	mwhitt
16	Clear	0.21900								0.249000		0.0	5.0	1.0	5.0				0.210997	dsmith
17	Clear	0.10000	6.68	0.00	< 1.00	< 1.00	< 1.00	< 2.0	< 4.0	< 5.3	0.271000	< 1.8	0.0	5.0	1.0	5.0			0.245350	mwhitt
18	Clear	0.16100	6.45	0.00						0.222000		0.0	5.0	1.0	5.0				0.203107	gkesselring
19	Clear	0.20400	6.43	0.00						0.341000		0.0	2.0	1.0	5.0				0.253125	mwhitt
20	Clear	0.19100								0.293000		0.0	3.0	1.0	5.0				0.239462	mwhitt
21	Clear	0.17200								0.261000		0.0	5.0	1.0	5.0				0.246802	mwhitt
22	Clear	0.33800								0.289000		0.0	5.0	1.0	5.0				0.216984	djones
23	Clear	0.33600	6.20	0.00						0.298000		0.0	5.0	1.0	2.2				0.233255	djones
24	Clear	0.35400								0.276000	< 1.8	0.0	5.0	1.0	5.0				0.217297	djones
25	Clear	0.25100	6.49	0.00						0.313000		0.0	5.0	1.0	5.0				0.235062	djones
26	Clear	0.17600								0.272000		0.0	5.0	1.0	5.0				0.209296	djones
27	Clear	0.19200								0.290000		0.0	5.0	1.0	5.0				0.232837	djones
28	Clear	0.24800								0.347000		0.0	5.0	1.0	5.0				0.270288	djones
29																				
30																				
31																				
Total		6.48600								7.937000									6.213673	
Average		0.23164	6.5	<0.10	0	0	0	2	0	0	0.283464	1	0.0	4.1	1.0	4.9	#DIV/0!	#DIV/0!	#DIV/0!	0.221917
Minimum		0.10000	6.2	0.00	0	0	0	2	0	0	0.166000	1	0.0	1.0	1.0	2.2	0	0	0	0.103769
Maximum		0.38900	7.2	<0.10	0	0	0	0	0	0	0.431000	1	0.0	5.0	1.0	5.0	0	0	0	0.283393

COMMENTS:

MOR 5:11-09

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:

Facility: BTR Capital Group

Permit Number: 02-DP-0022

Month: March

Maryland Environmental Service  
259 Najoles Road, Millersville MD

Address: 626 Hanover Pike, Hampstead Maryland

Superintendent: Earle Villarreal

Certification # 1017

Year: 2010

Additional Op's & cert # - Dorrance Jones 0763, Martin Whitt 0666, Dave Smith 9153, Francis Schmidt 2757, Jammal Downs 2755, Gary Kesselring 1962

Final Effluent outfall 001											Outfall 101					Outfall 201			Operator		
Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD <sub>5</sub> mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l		Trichloroethene ug/l	Discharge mgd
1	Clear	0.22400									0.261000		0.0	5.0	1.0	5.0				0.202124	mwhitt
2	Clear	0.23000	6.59	0.00							0.265000		0.0	5.0	1.0	5.0				0.258908	mwhitt
3	Clear	0.25100			< 1.00	< 1.00	< 1.00	< 2.0	< 4.0	< 5.0	0.312000	< 1.8	0.0	2.0	1.0	5.0				0.231198	djones
4	Clear	0.21800	6.55	0.00							0.308000		0.0	1.0	1.0	5.0				0.254265	djones
5	Clear	0.17300									0.260000		0.0	2.0	1.0	5.0				0.189388	djones
6	Clear	0.20900									0.342000		0.0	2.0	1.0	5.0				0.267736	djones
7	Clear	0.19000									0.292000		0.0	3.0	1.0	5.0				0.251571	mwhitt
8	Clear	0.16900									0.260000		0.0	5.0	1.0	4.2				0.217330	fschmidt
9	Clear	0.17800	6.30	0.00							0.303000		0.0	5.0	1.0	5.0				0.248715	fschmidt
10	Clear	0.16200									0.270000	< 1.8	0.0	5.0	1.0	5.0				0.208329	djones
11	Clear	0.45500	6.46	0.00							0.324000		0.0	2.0	1.0	5.0				0.267902	gkesselring
12	Clear	0.65500									0.258000		0.0	3.0	1.0	5.0				0.191235	fschmidt
13	Clear	0.10990									0.258000		0.0	5.0	1.0	5.0				0.227942	djones
14	Clear	0.46400									0.324000		0.0	5.0	1.0	5.0				0.272855	djones
15	Clear	0.24500	6.50	0.00							0.277000		0.0	2.0	1.0	5.0				0.252626	dsmith
16	Clear	0.14300									0.256000		0.0	3.0	1.0	5.0				0.215863	fschmidt
17	Clear	0.28500									0.298000	< 1.8	0.0	2.0	1.0	5.0				0.246169	fschmidt
18	Clear	0.29700	6.41	0.00							0.320000		0.0	3.0	1.0	5.0				0.258910	djones
19	Clear	0.24700									0.250000		0.0	5.0	1.0	5.0				0.192054	fschmidt
20	Clear	0.29400									0.302000		0.0	5.0	1.0	5.0				0.235293	djones
21	Clear	0.34500									0.362000		0.0	5.0	1.0	5.0				0.299051	dsmith
22	Clear	0.28400									0.292000		0.0	2.0	1.0	5.0				0.215678	djones
23	Clear	0.25600	6.33	0.00							0.242000		0.0	2.0	1.0	5.0				0.240537	djones
24	Clear	0.28000								13.0	0.265000	< 1.8	0.0	2.0	1.0	5.0				0.261461	djones
25	Clear	0.26000	6.56	0.00							0.256000		0.0	2.0	1.0	5.0				0.250298	jdowns
26	Clear	0.25400									0.201000		0.0	2.0	1.0	5.0				0.187809	jdowns
27	Clear	0.30700									0.257000		0.0	5.0	1.0	5.0				0.242722	djones
28	Clear	0.37200									0.296000		0.0	5.0	1.0	5.0				0.275588	djones
29	Clear	0.33600	6.41	0.00							0.261000		0.0	5.0	1.0	5.0				0.238233	dsmith
30	Clear	0.38600									0.266000		0.0	5.0	1.0	5.0				0.257027	dsmith
31	Clear	0.37700									0.257000	< 1.8	0.0	5.0	1.0	5.0				0.236225	djones
Total		8.65590									8.695000									7.395042	
Average		0.27922	6.5	<0.10	0	0	0	2	0	7	0.280484	1	0.0	3.5	1.0	5.0	#DIV/0!	#DIV/0!	#DIV/0!	0.238550	
Minimum		0.10990	6.3	0.00	0	0	0	2	0	0	0.201000	1	0.0	1.0	1.0	4.2	0	0	0	0.187809	
Maximum		0.65500	6.6	<0.10	0	0	0	0	0	13	0.362000	1	0.0	5.0	1.0	5.0	0	0	0	0.299051	MOR 5-11-09

COMMENTS:

---

**APPENDIX B  
DISCHARGE MONITORING REPORTS  
(JANUARY – MARCH 2010)**

---

PERMITTEE NAME/... (Include Facility Name/Location if different)  
 NAME **AGIGFI Hampstead, Inc**  
 ADDRESS **626 Hanover Pike**  
**Hampstead, MD 21074**  
 FACILITY **Black and Decker WWTP**  
 LOCATION **626 Hanover Pike**  
 ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
**DISCHARGE MONITORING REPORT (DMR)**  
 (2-16) (17-19)

State Discharge Permit  
**02-DP-0022**

Form Approved. 12345  
 OMB No. 2040-0004.  
 Approval expires 05-31-98

**MD0001881**  
 PERMIT NUMBER

**001**  
 DISCHARGE NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
10	01	01	10	01	31
(20-21)		(22-23)		(24-25)	
		(26-27)		(28-29)	
				(30-31)	

\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUANTITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	0	( 19)	0	ONE/MONTH GRAB
pH	*****	*****	*****	****	6.0	*****	6.2	( 12)	0	TWO/WEEK GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	0	0	( 19)	0	ONE/MONTH GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	190968	846000	( 07)	****	*****	*****	*****	0	MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	<0.1	<0.1	( 19)	0	ONE/MONTH GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	0	0	ONE/MONTH GRAB	
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	0	0	ONE/MONTH GRAB	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER <b>Jim Harkins, Director MES</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE		
TYPED OR PRINTED			410 729-8350	10 02 23		

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)  
 NAME **AG/GFI Hampstead, Inc**  
 ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
**DISCHARGE MONITORING REPORT (DMR)**  
 (2-16) (17-19)

**State Discharge Permit**  
**02-DP-0022**

Form Approved. 12345  
 OMB No. 2040-0004.  
 Approval expires 05-31-98

**MD0001881**  
 PERMIT NUMBER

**001**  
 DISCHARGE NUMBER

**Hampstead, MD 21074**  
 FACILITY **Black and Decker WWTP**  
 LOCATION **626 Hanover Pike**  
 ATTN:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
10	01	01	TO	10	01	31	
(20-21)		(22-23)		(24-25)		(26-27)	
				(28-29)		(30-31)	

\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
TRICHLOROETHENE	*****	*****	*****	****	*****	*****	0	ug/l	0	ONE/MONTH	GRAB
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5			ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE	*****	*****	*****	****	*****	0	0	( 19)	0	ONE/MONTH	GRAB
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
**Jim Harkins, Director MES**  
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: **410 729-8350**  
 DATE: **10 02 23**  
 AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ **AG/GFI Hampstead, Inc**  
 Facility Name/Location (if different)  
 NAME **AG/GFI Hampstead, Inc**  
 ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
**DISCHARGE MONITORING REPORT (DMR)**  
 (2-16) (17-19)

State Discharge Permit  
**02-DP-0022**

Form Approved. 12345  
 OMB No. 2040-0004.  
 Approval expires 05-31-98

**MD0001881**  
 PERMIT NUMBER


**101**  
 DISCHARGE NUMBER

**Hampstead, MD 21074**  
 FACILITY **Black and Decker WWTP**  
 LOCATION **626 Hanover Pike**  
 ATTN:

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
10	01	01	TO	10	01	31	
(20-21)		(22-23)		(24-25)		(26-27)	
				(28-29)		(30-31)	

\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE		296742	377000	( '07)	*****	*****	*****	*****	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	*****	****	ONE/ MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	*****	1	( 30)	0	ONE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200	MPN		ONE/ WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE			
<b>Jim Harkins, Director MES</b>			410 729-8350	10	02	23	
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)  
 NAME **AG/GFI Hampstead, Inc**  
 ADDRESS **626 Hanover Pike**  
**Hampstead, MD 21074**  
 FACILITY **Black and Decker WWTP**  
 LOCATION **626 Hanover Pike**  
 ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
**DISCHARGE MONITORING REPORT (DMR)**  
 (2-16) (17-19)

State Discharge Permit  
**02-DP-0022**

Form Approved. 12345  
 OMB No. 2040-0004.  
 Approval expires 05-31-98

**MD0001881**  
 PERMIT NUMBER

**001**  
 DISCHARGE NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM <b>10</b>	<b>02</b>	<b>01</b>	TO <b>10</b>	<b>02</b>	<b>28</b>
(20-21)		(22-23)	(24-25)	(26-27)	(28-29) (30-31)

\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (46-53)			QUANTITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	0	( 19)	0	ONE/MONTH GRAB
pH	*****	*****	*****	*****	6.2	*****	7.2	( 12)	0	TWO/WEEK GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	0	0	( 19)	0	ONE/MONTH GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	231643	389000	( 07)	*****	*****	*****	*****	0	MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	<0.1	<0.1	<0.1	( 19)	0	ONE/MONTH GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	0	0	ONE/MONTH GRAB	
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	0	0	ONE/MONTH GRAB	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
**Jim Harkins, Director MES**  
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE  
**410 729-8350**  
 AREA CODE NUMBER

DATE  
**10 03 23**  
 YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)



PERMITTEE NAME AND ADDRESS (Include Facility Name/Location if different)  
 NAME **AG/GFI Hampstead, Inc**  
 ADDRESS **626 Hanover Pike**  
**Hampstead, MD 21074**  
 FACILITY **Black and Decker WWTP**  
 LOCATION **626 Hanover Pike**  
 ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
**DISCHARGE MONITORING REPORT**  
 (2-16) (DMR) (17-19)

State Discharge Permit  
**02-DP-0022**

Form Approved. 12345  
 OMB No. 2040-0004.  
 Approval expires 05-31-98

**MD0001881**  
 PERMIT NUMBER

**001**  
 DISCHARGE NUMBER

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	10	02	01		10	02	28
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (46-53)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (3 Card Only) (46-53)	MAXIMUM	UNITS	MINIMUM (4 Card Only) (38-45)	AVERAGE	MAXIMUM				
TRICHLOROETHENE		*****	*****		*****	*****	0	ug/l	0	ONE/MONTH	GRAB
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5			ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE		*****	*****		*****	0	0	( 19)	0	ONE/MONTH	GRAB
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
**Jim Harkins, Director MES**  
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: **410 729-8350**  
 AREA CODE NUMBER

DATE: **10 03 23**  
 YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)  
 NAME **AG/GFI Hampstead, Inc**  
 ADDRESS **626 Hanover Pike**  
**Hampstead, MD 21074**  
 FACILITY **Black and Decker WWTP**  
 LOCATION **626 Hanover Pike**  
 ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
 DISCHARGE MONITORING REPORT (DMR)  
 (2-16) (17-19)

State Discharge Permit  
 02-DP-0022

Form Approved. 12345  
 OMB No. 2040-0004.  
 Approval expires 05-31-98

MD0001881  
 PERMIT NUMBER

101  
 DISCHARGE NUMBER

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	02	01		10	02	28
(20-21)		(22-23)		(24-25)		(26-27)
				(28-29)		(30-31)


\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	283464	431000	( 07 )	*****	*****	*****		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONE/MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	( 30 )	0	ONE/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200	MPN		ONE/WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
**Jim Harkins, Director MES**  
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT



TELEPHONE		DATE		
410	729-8350	10	03	23
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE ADDRESS (Include Facility Name/Location if different)  
 NAME **AG/GFI Hampstead, Inc**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
 DISCHARGE MONITORING REPORT (DMR)  
 (2-16) (17-19)

State Discharge Permit  
 02-DP-0022

Form Approved. 12345  
 OMB No. 2040-0004.  
 Approval expires 05-31-98

ADDRESS **626 Hanover Pike**

**MD0001881**  
 PERMIT NUMBER

**001**  
 DISCHARGE NUMBER

**Hampstead, MD 21074**

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	03	01	TO	10	03	31
(20-21) (22-25) (24-25)				(26-27) (28-29) (30-31)		

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	( 19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15	MG/L		ONE/MONTH	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	****	6.3	*****	6.6	( 12)	0	TWO/WEEK	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	8.5	SU		TWO/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	( 19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	20	30	MG/L		ONE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 00050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	279223	655000	( 07)	*****	*****	*****		0	MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	( 19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.011	0.019	MG/L		ONE/MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
<b>Jim Harkins, Director MES</b>		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	410	729-8350	10	04
TYPED OR PRINTED	AREA CODE		NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)  
 NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

**Hampstead, MD 21074**

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
 DISCHARGE MONITORING REPORT (DMR)  
 (2-16) (17-19)

State Discharge Permit  
 02-DP-0022

**MD0001881**  
 PERMIT NUMBER

**001**  
 DISCHARGE NUMBER

Form Approved. 12345


OMB No. 2040-0004.

Approval expires 05-31-98

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	10	03	01		10	03	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (46-53)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (46-53)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	ug/l	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5			ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	7	13	( 19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER <b>Jim Harkins, Director MES</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE		DATE		
			410	729-8350	10	04	23
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

**Hampstead, MD 21074**

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

State Discharge Permit  
02-DP-0022

MD0001881

PERMIT NUMBER

101

DISCHARGE NUMBER

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	10	03	01		10	03	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

\*\*\* NO DISCHARGE  \*\*\*  
NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS (38-43)	MINIMUM (46-53)	AVERAGE (54-61)	MAXIMUM (54-61)			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	REPORT *****	280484	362000	( 07) GPD	*****	*****	*****	0	ONE/ MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	1	0	ONE/ WEEK	GRAB
							200		MPN	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
**Jim Harkins, Director MES**  
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE	DATE	
410 729-8350	10 04 23	
AREA CODE NUMBER	YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)  
 NAME **AG/GFI Hampstead, Inc**  
 ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
**DISCHARGE MONITORING REPORT (DMR)**  
 (2-16) (17-19)

State Discharge Permit  
**02-DP-0022**

**MD0001881**  
 PERMIT NUMBER

**201**  
 DISCHARGE NUMBER

Form Approved. 12345  
 OMB No. 2040-0004.  
 Approval expires 05-31-98

**Hampstead, MD 21074**

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	01	01		10	03	31
(20-21)		(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (54-61)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	224845	299051	( 07)	*****	*****	*****		0	MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		MEASURED	RECORD
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0		0	ONE/ QUARTER	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT *****	REPORT *****	ug/l		ONE/ QUARTER	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0		0	ONE/ QUARTER	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT *****	REPORT *****	ug/l		ONE/ QUARTER	GRAB
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0		0	ONE/ QUARTER	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT *****	REPORT *****	ug/l		ONE/ QUARTER	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
**Jim Harkins, Director MES**  
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE  
**410 729-8350**  
 AREA CODE NUMBER  
 DATE  
**10 04 27**  
 YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
 Quarterly Report! Outfall 201 quarterly sample's collected on 01/06/10.

---

**APPENDIX C**  
**GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS**  
**(JANUARY – MARCH 2010)**

---

**REPORT OF ANALYSIS**

Maryland Environmental Services (A)  
 259 Najoles Road  
 Millersville, MD 21108

Order Number: A10010246  
 Project Name: Black & Decker WWTP  
 Receive Date: 1/6/2010  
 Client Code: MES\_A  
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A10010246-01** **Sample Date: 1/6/2010 10:05**

Site: Black & Decker 001 Matrix: Waste Water  
 Client Sample ID:  
 Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	<2	mg/L	2	SM 5210 B	1/7/2010 11:30:00 AM	Skent
Total Suspended Solids	<4	mg/L	4	SM 2540D	1/12/2010 1:44:00 PM	KPlatt

**Sample # A10010246-01A** **Sample Date: 1/6/2010 10:05**

Site: Black & Decker 001 Matrix: Waste Water  
 Client Sample ID: A  
 Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	<5	mg/L	5	EPA 1664	1/7/2010 2:00:00 PM	SHess

**Sample # A10010246-01B** **Sample Date: 1/6/2010 10:05**

Site: Black & Decker 001 Matrix: Waste Water  
 Client Sample ID: B  
 Sample Comments: None


Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	1/13/2010 4:48:00 AM	JKozlowski
Tetrachloroethene	<1	ug/L	1	EPA 8260B	1/13/2010 4:48:00 AM	JKozlowski
Trichloroethene	<1	ug/L	1	EPA 8260B	1/13/2010 4:48:00 AM	JKozlowski

Approved: *Wanda Van Arsdale*  
 Quality Assurance Manager

Reported: 1/15/2010 3:23:34 PM

RDL = Reporting Detection Limit    N/A = Not Applicable  
 Laboratory Certification Numbers: Delaware - DE00011    Maryland - #138    Pennsylvania - 68-335    New Jersey - DE568





630 Churchmans Road  
 Newark, Delaware 19702  
 302-266-9121 • 454-8720 (FAX)  
 WWW.ATLANTICCOASTLABS.COM

**REPORT OF ANALYSIS**

Maryland Environmental Services (A)  
 259 Najoles Road  
 Millersville, MD 21108

Order Number: A10020789  
 Project Name: Black & Decker WWTP  
 Receive Date: 2/17/2010  
 Client Code: MES\_A  
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A10020789-01** **Sample Date: 2/17/2010 8:30**

Site: Black & Decker 001 Matrix: Waste Water  
 Client Sample ID:  
 Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	< 2	mg/L	2	SM 5210 B	2/18/2010 11:35:00 AM	Skent
Total Suspended Solids	< 4	mg/L	4	SM 2540D	2/22/2010 1:13:00 PM	KPlatt

**Sample # A10020789-02** **Sample Date: 2/17/2010 8:30**

Site: Black & Decker 001 Matrix: Waste Water  
 Client Sample ID:  
 Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	< 5.3	mg/L	5.3	EPA 1664	2/25/2010 1:10:00 PM	JMcGuire

**Sample # A10020789-03** **Sample Date: 2/17/2010 8:30**

Site: Black & Decker 001 Matrix: Waste Water  
 Client Sample ID:  
 Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	2/18/2010 10:02:00 PM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	2/18/2010 10:02:00 PM	JKozlowski
Trichloroethene	< 1	ug/L	1	EPA 8260B	2/18/2010 10:02:00 PM	JKozlowski

Approved: *Warren Van Arsdale*  
 Quality Assurance Manager

Reported: 3/2/2010 12:49:23 PM

RDL = Reporting Detection Limit    N/A = Not Applicable  
 Laboratory Certification Numbers: Delaware - DE00011    Maryland - #138    Pennsylvania - 68-335    New Jersey - DE568

**REPORT OF ANALYSIS**

Maryland Environmental Services (A)  
259 Najoles Road  
Millersville, MD 21108

Order Number: A10030274  
Project Name: Black & Decker WWTP  
Receive Date: 3/3/2010  
Client Code: MES\_A  
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A10030274-01** **Sample Date: 3/3/2010 9:50**

Site: Black & Decker 101 Matrix: Waste Water  
Client Sample ID:  
Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	< 2	mg/L	2	SM 5210 B	3/4/2010 10:50:00 AM	Skent
Total Suspended Solids	< 4	mg/L	4	SM 2540D	3/9/2010 1:45:00 PM	KPlatt

**Sample # A10030274-02** **Sample Date: 3/3/2010 9:50**

Site: Black & Decker 101 Matrix: Waste Water  
Client Sample ID:  
Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	< 5	mg/L	5	EPA 1664	3/8/2010 1:45:00 PM	JMcGuire

**Sample # A10030274-03** **Sample Date: 3/3/2010 9:50**


Site: Black & Decker 101 Matrix: Waste Water  
Client Sample ID:  
Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	3/9/2010 3:42:00 AM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	3/9/2010 3:42:00 AM	JKozlowski
Trichloroethene	< 1	ug/L	1	EPA 8260B	3/9/2010 3:42:00 AM	JKozlowski

Approved: *Wesley Van Andell*  
Quality Assurance Manager

Reported: 3/15/2010 1:22:39 PM

RDL = Reporting Detection Limit    N/A = Not Applicable  
Laboratory Certification Numbers: Delaware - DE00011    Maryland - #138    Pennsylvania - 68-335    New Jersey - DE568



630 Churchmans Road  
 Newark, Delaware 19702  
 302-266-9121 • 454-8720 (FAX)  
 WWW.ATLANTICCOASTLABS.COM

**REPORT OF ANALYSIS**

Maryland Environmental Services (A)  
 259 Najoles Road  
 Millersville, MD 21108

Order Number: A10031517  
 Project Name: Black & Decker WWTP  
 Receive Date: 3/24/2010  
 Client Code: MES\_A  
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A10031517-01**

**Sample Date: 3/24/2010 9:15**

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	13.0	mg/L	5.4	EPA 1664	4/2/2010 2:00:00 PM	JMcGuire

Approved:

*Keith A. Hausknecht*

President

Reported:

4/7/2010 8:41:10 AM

RDL = Reporting Detection Limit N/A = Not Applicable

Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568

---

**APPENDIX D  
GROUNDWATER ANALYTICAL DATA PACKAGE  
(FEBRUARY 2010)**

---

## ANALYTICAL REPORT

Job Number: 500-24183-1

Job Description: Black and Decker

For:

Weston Solutions, Inc.

1400 Weston Way

PO BOX 2653

West Chester, PA 19380

Attention: Mr. Tom Cornuet



Approved for release.  
Richard C Wright  
Project Manager II  
3/4/2010 12:41 PM

---

Richard C Wright  
Project Manager II  
richard.wright@testamericainc.com  
03/04/2010

cc: Greg Flasinski

These test results meet all the requirements of NELAC for accredited parameters.

The Lab Certification ID# is 100201.

All questions regarding this test report should be directed to the TestAmerica Project Manager whose signature appears on this report. All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.

Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.

TestAmerica Laboratories, Inc.

TestAmerica Chicago 2417 Bond Street, University Park, IL 60484

Tel (708) 534-5200 Fax (708) 534-5211 [www.testamericainc.com](http://www.testamericainc.com)



**Job Narrative**  
**500-24183-1**

**Comments**

No additional comments.

**Receipt**

All samples were received in good condition within temperature requirements.

**GC/MS VOA**

Method(s) 8260B: The laboratory control sample (LCS) for preparation batch 81056 exceeded control limits for the following analytes: 2-Hexanone. These analytes were biased high in the LCS and were not detected in the associated samples; therefore, the data have been reported.

Method(s) 8260B: The laboratory control sample (LCS) for preparation batch 81296 exceeded control limits for the following analytes: Bromomethane. These analytes were biased high in the LCS and were not detected in the associated samples; therefore, the data have been reported.

Method(s) 8260B: The trip blank associated with these samples contained a detection above the reporting limit (RL) for the following analytes: Chloroform, Bromodichloromethane, Dibromochloromethane, and Bromoform. The sample was re-analyzed with duplicate results.

Method(s) 8260B: The following sample(s) was diluted due to the abundance of target analytes: EW-4 (500-24183-3). Elevated reporting limits (RLs) are provided.

Method(s) 8260B: The continuing calibration verification 6C0302A (CCV) for Bromomethane recovered above the upper control limit. The samples associated with this CCV were non-detects for the affected analytes; therefore, the data have been reported.

No other analytical or quality issues were noted.

## EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
<b>500-24183-1</b>	<b>EW-2</b>				
cis-1,2-Dichloroethene		3.5	1.0	ug/L	8260B
Trichloroethene		410	10	ug/L	8260B
Tetrachloroethene		62	1.0	ug/L	8260B
<b>500-24183-2</b>	<b>EW-3</b>				
cis-1,2-Dichloroethene		2.8	1.0	ug/L	8260B
Trichloroethene		130	5.0	ug/L	8260B
Tetrachloroethene		3.4	1.0	ug/L	8260B
<b>500-24183-3</b>	<b>EW-4</b>				
Trichloroethene		1100	50	ug/L	8260B
Tetrachloroethene		22	5.0	ug/L	8260B
<b>500-24183-4</b>	<b>EW-5</b>				
Trichloroethene		150	5.0	ug/L	8260B
Tetrachloroethene		5.9	1.0	ug/L	8260B
<b>500-24183-5</b>	<b>EW-6</b>				
Trichloroethene		10	1.0	ug/L	8260B
Tetrachloroethene		17	1.0	ug/L	8260B
<b>500-24183-6</b>	<b>EW-7</b>				
cis-1,2-Dichloroethene		4.4	1.0	ug/L	8260B
Trichloroethene		4.0	1.0	ug/L	8260B
Tetrachloroethene		9.6	1.0	ug/L	8260B
<b>500-24183-7</b>	<b>EW-8</b>				
cis-1,2-Dichloroethene		24	1.0	ug/L	8260B
Trichloroethene		10	1.0	ug/L	8260B
Tetrachloroethene		63	1.0	ug/L	8260B
<b>500-24183-8</b>	<b>EW-9</b>				
Trichloroethene		1.1	1.0	ug/L	8260B
Tetrachloroethene		110	2.0	ug/L	8260B

TestAmerica Chicago

## EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
<b>500-24183-9FD</b>	<b>EW-9 DUP</b>				
Trichloroethene		0.95 J	1.0	ug/L	8260B
Tetrachloroethene		100	2.0	ug/L	8260B
<b>500-24183-11</b>	<b>RFW-17</b>				
Benzene		1.5	1.0	ug/L	8260B
<b>500-24183-16</b>	<b>RFW-6</b>				
Tetrachloroethene		1.4	1.0	ug/L	8260B
<b>500-24183-17</b>	<b>RFW-12B</b>				
cis-1,2-Dichloroethene		3.0	1.0	ug/L	8260B
Trichloroethene		280	5.0	ug/L	8260B
Tetrachloroethene		25	1.0	ug/L	8260B
<b>500-24183-18</b>	<b>RFW-4A</b>				
Trichloroethene		30	1.0	ug/L	8260B
Tetrachloroethene		17	1.0	ug/L	8260B
<b>500-24183-19FD</b>	<b>RFW-4A DUP</b>				
Trichloroethene		28	1.0	ug/L	8260B
Tetrachloroethene		16	1.0	ug/L	8260B
<b>500-24183-20</b>	<b>RFW-4B</b>				
cis-1,2-Dichloroethene		3.7	1.0	ug/L	8260B
Trichloroethene		50	1.0	ug/L	8260B
Tetrachloroethene		69	1.0	ug/L	8260B
<b>500-24183-21</b>	<b>RFW-9</b>				
1,1-Dichloroethene		1.3	1.0	ug/L	8260B
1,1-Dichloroethane		1.6	1.0	ug/L	8260B
cis-1,2-Dichloroethene		25	1.0	ug/L	8260B
1,1,1-Trichloroethane		1.6	1.0	ug/L	8260B
Trichloroethene		15	1.0	ug/L	8260B
Tetrachloroethene		8.5	1.0	ug/L	8260B



## EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-24183-22 Trichloroethene	RFW-11B	7.9	1.0	ug/L	8260B
500-24183-23TB Chloroform	TRIP BLANK	9.8	1.0	ug/L	8260B
Bromodichloromethane		6.8	1.0	ug/L	8260B
Dibromochloromethane		2.8	1.0	ug/L	8260B
Bromoform		1.7	1.0	ug/L	8260B

## METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

Description	Lab Location	Method	Preparation Method
<b>Matrix: Water</b>			
VOC	TAL CHI	SW846 8260B	
Purge and Trap	TAL CHI		SW846 5030B

### Lab References:

TAL CHI = TestAmerica Chicago

### Method References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

## METHOD / ANALYST SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

<u>Method</u>	<u>Analyst</u>	<u>Analyst ID</u>
SW846 8260B	Alikpala, Elaine	EA
SW846 8260B	Manzano, Louis	LM
SW846 8260B	Swaney, Garth E	GES

## SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-24183-1

<u>Lab Sample ID</u>	<u>Client Sample ID</u>	<u>Client Matrix</u>	<u>Date/Time Sampled</u>	<u>Date/Time Received</u>
500-24183-1	EW-2	Water	02/18/2010 1730	02/23/2010 0950
500-24183-2	EW-3	Water	02/19/2010 0945	02/23/2010 0950
500-24183-3	EW-4	Water	02/19/2010 1200	02/23/2010 0950
500-24183-4	EW-5	Water	02/18/2010 1130	02/23/2010 0950
500-24183-5	EW-6	Water	02/18/2010 1440	02/23/2010 0950
500-24183-6	EW-7	Water	02/18/2010 1415	02/23/2010 0950
500-24183-7	EW-8	Water	02/18/2010 1400	02/23/2010 0950
500-24183-8	EW-9	Water	02/18/2010 1340	02/23/2010 0950
500-24183-9FD	EW-9 DUP	Water	02/18/2010 1340	02/23/2010 0950
500-24183-10	EW-10	Water	02/18/2010 1330	02/23/2010 0950
500-24183-11	RFW-17	Water	02/18/2010 1140	02/23/2010 0950
500-24183-12	RFW-1A	Water	02/18/2010 1240	02/23/2010 0950
500-24183-13	RFW-1B	Water	02/18/2010 1800	02/23/2010 0950
500-24183-14	RFW-2A	Water	02/18/2010 1430	02/23/2010 0950
500-24183-15	RFW-2B	Water	02/18/2010 1445	02/23/2010 0950
500-24183-16	RFW-6	Water	02/19/2010 0700	02/23/2010 0950
500-24183-17	RFW-12B	Water	02/19/2010 0745	02/23/2010 0950
500-24183-18	RFW-4A	Water	02/19/2010 0830	02/23/2010 0950
500-24183-19FD	RFW-4A DUP	Water	02/19/2010 0830	02/23/2010 0950
500-24183-20	RFW-4B	Water	02/19/2010 0900	02/23/2010 0950
500-24183-21	RFW-9	Water	02/19/2010 1050	02/23/2010 0950
500-24183-22	RFW-11B	Water	02/19/2010 1245	02/23/2010 0950
500-24183-23TB	TRIP BLANK	Water	02/18/2010 0800	02/23/2010 0950



# SAMPLE RESULTS

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-2  
 Lab Sample ID: 500-24183-1

Date Sampled: 02/18/2010 1730  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 02/24/2010 1833			
<b>Prep Method: 5030B</b>		Date Prepared: 02/24/2010 1833			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	3.5	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	62	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-2  
 Lab Sample ID: 500-24183-1

Date Sampled: 02/18/2010 1730  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		72 - 135	
Toluene-d8 (Surr)	95	%		80 - 120	
4-Bromofluorobenzene (Surr)	94	%		77 - 120	
Dibromofluoromethane	102	%		79 - 133	
Method: 8260B Run Type: DL			Date Analyzed: 02/24/2010 1856		
Prep Method: 5030B			Date Prepared: 02/24/2010 1856		
Trichloroethene	410	ug/L	2.4	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	104	%		72 - 135	
Toluene-d8 (Surr)	96	%		80 - 120	
4-Bromofluorobenzene (Surr)	97	%		77 - 120	
Dibromofluoromethane	102	%		79 - 133	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-3  
 Lab Sample ID: 500-24183-2

Date Sampled: 02/19/2010 0945  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed:	02/24/2010	1920	
<b>Prep Method: 5030B</b>		Date Prepared:	02/24/2010	1920	
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	2.8	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	3.4	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-3  
 Lab Sample ID: 500-24183-2

Date Sampled: 02/19/2010 0945  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		72 - 135	
Toluene-d8 (Surr)	93	%		80 - 120	
4-Bromofluorobenzene (Surr)	97	%		77 - 120	
Dibromofluoromethane	102	%		79 - 133	
Method: 8260B Run Type: DL			Date Analyzed: 02/24/2010 1943		
Prep Method: 5030B			Date Prepared: 02/24/2010 1943		
Trichloroethene	130	ug/L	1.2	5.0	5.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	104	%		72 - 135	
Toluene-d8 (Surr)	94	%		80 - 120	
4-Bromofluorobenzene (Surr)	95	%		77 - 120	
Dibromofluoromethane	106	%		79 - 133	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-4  
 Lab Sample ID: 500-24183-3

Date Sampled: 02/19/2010 1200  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 02/24/2010 2007			
<b>Prep Method: 5030B</b>		Date Prepared: 02/24/2010 2007			
Benzene	<5.0	ug/L	0.85	5.0	5.0
Dichlorodifluoromethane	<5.0	ug/L	1.6	5.0	5.0
Chloromethane	<5.0	ug/L	1.2	5.0	5.0
Vinyl chloride	<5.0	ug/L	1.0	5.0	5.0
Bromomethane	<5.0	ug/L	1.9	5.0	5.0
Chloroethane	<5.0	ug/L	1.8	5.0	5.0
Trichlorofluoromethane	<5.0	ug/L	1.0	5.0	5.0
1,1-Dichloroethene	<5.0	ug/L	0.95	5.0	5.0
Carbon disulfide	<25	ug/L	2.8	25	5.0
Acetone	<25	ug/L	8.0	25	5.0
Methylene Chloride	<10	ug/L	3.4	10	5.0
trans-1,2-Dichloroethene	<5.0	ug/L	1.6	5.0	5.0
1,1-Dichloroethane	<5.0	ug/L	1.2	5.0	5.0
2,2-Dichloropropane	<5.0	ug/L	1.2	5.0	5.0
cis-1,2-Dichloroethene	<5.0	ug/L	1.4	5.0	5.0
Methyl Ethyl Ketone	<25	ug/L	12	25	5.0
Bromochloromethane	<5.0	ug/L	1.8	5.0	5.0
Chloroform	<5.0	ug/L	0.75	5.0	5.0
1,1,1-Trichloroethane	<5.0	ug/L	0.90	5.0	5.0
1,1-Dichloropropene	<5.0	ug/L	0.80	5.0	5.0
Carbon tetrachloride	<5.0	ug/L	1.2	5.0	5.0
1,2-Dichloroethane	<5.0	ug/L	1.2	5.0	5.0
1,2-Dichloropropane	<5.0	ug/L	1.0	5.0	5.0
Dibromomethane	<5.0	ug/L	1.5	5.0	5.0
Bromodichloromethane	<5.0	ug/L	0.95	5.0	5.0
cis-1,3-Dichloropropene	<5.0	ug/L	0.85	5.0	5.0
methyl isobutyl ketone	<25	ug/L	4.2	25	5.0
Toluene	<5.0	ug/L	0.95	5.0	5.0
trans-1,3-Dichloropropene	<5.0	ug/L	1.2	5.0	5.0
1,1,2-Trichloroethane	<5.0	ug/L	1.3	5.0	5.0
Tetrachloroethene	22	ug/L	1.1	5.0	5.0
1,3-Dichloropropane	<5.0	ug/L	0.85	5.0	5.0
2-Hexanone	<25	ug/L	4.0	25	5.0
Dibromochloromethane	<5.0	ug/L	1.2	5.0	5.0
1,2-Dibromoethane	<5.0	ug/L	1.8	5.0	5.0
Chlorobenzene	<5.0	ug/L	0.85	5.0	5.0
1,1,1,2-Tetrachloroethane	<5.0	ug/L	0.95	5.0	5.0
Ethylbenzene	<5.0	ug/L	0.90	5.0	5.0
m&p-Xylene	<10	ug/L	1.6	10	5.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-4  
 Lab Sample ID: 500-24183-3

Date Sampled: 02/19/2010 1200  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<5.0	ug/L	1.9	5.0	5.0
Styrene	<5.0	ug/L	0.75	5.0	5.0
Bromoform	<5.0	ug/L	2.1	5.0	5.0
Isopropylbenzene	<5.0	ug/L	1.0	5.0	5.0
Bromobenzene	<5.0	ug/L	1.0	5.0	5.0
1,1,2,2-Tetrachloroethane	<5.0	ug/L	1.4	5.0	5.0
1,2,3-Trichloropropane	<5.0	ug/L	2.4	5.0	5.0
N-Propylbenzene	<5.0	ug/L	0.95	5.0	5.0
2-Chlorotoluene	<5.0	ug/L	0.90	5.0	5.0
1,3,5-Trimethylbenzene	<5.0	ug/L	0.90	5.0	5.0
4-Chlorotoluene	<5.0	ug/L	1.0	5.0	5.0
tert-Butylbenzene	<5.0	ug/L	0.80	5.0	5.0
1,2,4-Trimethylbenzene	<5.0	ug/L	0.70	5.0	5.0
sec-Butylbenzene	<5.0	ug/L	0.80	5.0	5.0
1,3-Dichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
p-Isopropyltoluene	<5.0	ug/L	0.80	5.0	5.0
1,4-Dichlorobenzene	<5.0	ug/L	1.0	5.0	5.0
n-Butylbenzene	<5.0	ug/L	0.90	5.0	5.0
1,2-Dichlorobenzene	<5.0	ug/L	0.85	5.0	5.0
1,2-Dibromo-3-Chloropropane	<10	ug/L	4.8	10	5.0
1,2,4-Trichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
Hexachlorobutadiene	<5.0	ug/L	1.3	5.0	5.0
Naphthalene	<5.0	ug/L	2.2	5.0	5.0
1,2,3-Trichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	103	%		72 - 135	
Toluene-d8 (Surr)	95	%		80 - 120	
4-Bromofluorobenzene (Surr)	95	%		77 - 120	
Dibromofluoromethane	104	%		79 - 133	
Method: 8260B Run Type: DL			Date Analyzed: 02/24/2010 2030		
Prep Method: 5030B			Date Prepared: 02/24/2010 2030		
Trichloroethene	1100	ug/L	12	50	50
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		72 - 135	
Toluene-d8 (Surr)	93	%		80 - 120	
4-Bromofluorobenzene (Surr)	92	%		77 - 120	
Dibromofluoromethane	102	%		79 - 133	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-5  
 Lab Sample ID: 500-24183-4

Date Sampled: 02/18/2010 1130  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 02/24/2010 2054			
<b>Prep Method: 5030B</b>		Date Prepared: 02/24/2010 2054			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	5.9	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-5  
 Lab Sample ID: 500-24183-4

Date Sampled: 02/18/2010 1130  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		72 - 135	
Toluene-d8 (Surr)	97	%		80 - 120	
4-Bromofluorobenzene (Surr)	97	%		77 - 120	
Dibromofluoromethane	104	%		79 - 133	
Method: 8260B Run Type: DL			Date Analyzed: 02/24/2010 2117		
Prep Method: 5030B			Date Prepared: 02/24/2010 2117		
Trichloroethene	150	ug/L	1.2	5.0	5.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	106	%		72 - 135	
Toluene-d8 (Surr)	94	%		80 - 120	
4-Bromofluorobenzene (Surr)	94	%		77 - 120	
Dibromofluoromethane	107	%		79 - 133	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-6  
 Lab Sample ID: 500-24183-5

Date Sampled: 02/18/2010 1440  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed:	02/24/2010	2140	
<b>Prep Method: 5030B</b>		Date Prepared:	02/24/2010	2140	
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	10	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	17	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-6  
 Lab Sample ID: 500-24183-5

Date Sampled: 02/18/2010 1440  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	105	%		72 - 135	
Toluene-d8 (Surr)	94	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		77 - 120	
Dibromofluoromethane	103	%		79 - 133	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-7  
 Lab Sample ID: 500-24183-6

Date Sampled: 02/18/2010 1415  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed:	02/24/2010 2204		
<b>Prep Method: 5030B</b>		Date Prepared:	02/24/2010 2204		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	4.4	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	4.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	9.6	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-7  
 Lab Sample ID: 500-24183-6

Date Sampled: 02/18/2010 1415  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		72 - 135	
Toluene-d8 (Surr)	94	%		80 - 120	
4-Bromofluorobenzene (Surr)	95	%		77 - 120	
Dibromofluoromethane	101	%		79 - 133	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-8  
 Lab Sample ID: 500-24183-7

Date Sampled: 02/18/2010 1400  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed:	02/24/2010 2227		
<b>Prep Method: 5030B</b>		Date Prepared:	02/24/2010 2227		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	24	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	10	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	63	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-8  
 Lab Sample ID: 500-24183-7

Date Sampled: 02/18/2010 1400  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	105	%		72 - 135	
Toluene-d8 (Surr)	92	%		80 - 120	
4-Bromofluorobenzene (Surr)	97	%		77 - 120	
Dibromofluoromethane	105	%		79 - 133	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-9  
 Lab Sample ID: 500-24183-8

Date Sampled: 02/18/2010 1340  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed:	02/24/2010	2251	
<b>Prep Method: 5030B</b>		Date Prepared:	02/24/2010	2251	
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	1.1	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-9  
 Lab Sample ID: 500-24183-8

Date Sampled: 02/18/2010 1340  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	106	%		72 - 135	
Toluene-d8 (Surr)	94	%		80 - 120	
4-Bromofluorobenzene (Surr)	93	%		77 - 120	
Dibromofluoromethane	107	%		79 - 133	
Method: 8260B Run Type: DL			Date Analyzed: 02/24/2010 2314		
Prep Method: 5030B			Date Prepared: 02/24/2010 2314		
Tetrachloroethene	110	ug/L	0.44	2.0	2.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	111	%		72 - 135	
Toluene-d8 (Surr)	94	%		80 - 120	
4-Bromofluorobenzene (Surr)	94	%		77 - 120	
Dibromofluoromethane	111	%		79 - 133	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-9 DUP  
 Lab Sample ID: 500-24183-9

Date Sampled: 02/18/2010 1340  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed:	02/24/2010	2337	
<b>Prep Method: 5030B</b>		Date Prepared:	02/24/2010	2337	
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	0.95 J	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0 *	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-9 DUP  
 Lab Sample ID: 500-24183-9

Date Sampled: 02/18/2010 1340  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	104	%	72 - 135
Toluene-d8 (Surr)	91	%	80 - 120
4-Bromofluorobenzene (Surr)	95	%	77 - 120
Dibromofluoromethane	105	%	79 - 133

Method: 8260B Run Type: DL

Date Analyzed: 02/26/2010 0257

Prep Method: 5030B

Date Prepared: 02/26/2010 0257

Tetrachloroethene	100	ug/L	0.44	2.0	2.0
-------------------	-----	------	------	-----	-----

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	100	%	72 - 135
Toluene-d8 (Surr)	91	%	80 - 120
4-Bromofluorobenzene (Surr)	97	%	77 - 120
Dibromofluoromethane	110	%	79 - 133

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-10  
 Lab Sample ID: 500-24183-10

Date Sampled: 02/18/2010 1330  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 02/26/2010 0320			
<b>Prep Method: 5030B</b>		Date Prepared: 02/26/2010 0320			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: EW-10  
 Lab Sample ID: 500-24183-10

Date Sampled: 02/18/2010 1330  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		72 - 135	
Toluene-d8 (Surr)	91	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		77 - 120	
Dibromofluoromethane	110	%		79 - 133	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-17  
 Lab Sample ID: 500-24183-11

Date Sampled: 02/18/2010 1140  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed:	02/26/2010 0344		
<b>Prep Method: 5030B</b>		Date Prepared:	02/26/2010 0344		
Benzene	1.5	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-17  
 Lab Sample ID: 500-24183-11

Date Sampled: 02/18/2010 1140  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	104	%		72 - 135	
Toluene-d8 (Surr)	93	%		80 - 120	
4-Bromofluorobenzene (Surr)	98	%		77 - 120	
Dibromofluoromethane	110	%		79 - 133	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-1A  
 Lab Sample ID: 500-24183-12

Date Sampled: 02/18/2010 1240  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 02/26/2010 0407			
<b>Prep Method: 5030B</b>		Date Prepared: 02/26/2010 0407			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-1A  
 Lab Sample ID: 500-24183-12

Date Sampled: 02/18/2010 1240  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		72 - 135	
Toluene-d8 (Surr)	91	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		77 - 120	
Dibromofluoromethane	108	%		79 - 133	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-1B  
 Lab Sample ID: 500-24183-13

Date Sampled: 02/18/2010 1800  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed:	02/26/2010 0430		
<b>Prep Method: 5030B</b>		Date Prepared:	02/26/2010 0430		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-1B  
 Lab Sample ID: 500-24183-13

Date Sampled: 02/18/2010 1800  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		72 - 135	
Toluene-d8 (Surr)	92	%		80 - 120	
4-Bromofluorobenzene (Surr)	96	%		77 - 120	
Dibromofluoromethane	110	%		79 - 133	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-2A  
 Lab Sample ID: 500-24183-14

Date Sampled: 02/18/2010 1430  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed:	02/26/2010 0453		
<b>Prep Method: 5030B</b>		Date Prepared:	02/26/2010 0453		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-2A  
 Lab Sample ID: 500-24183-14

Date Sampled: 02/18/2010 1430  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	104	%		72 - 135	
Toluene-d8 (Surr)	91	%		80 - 120	
4-Bromofluorobenzene (Surr)	95	%		77 - 120	
Dibromofluoromethane	110	%		79 - 133	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-24183-1

Client Sample ID: RFW-2B  
 Lab Sample ID: 500-24183-15

Date Sampled: 02/18/2010 1445  
 Date Received: 02/23/2010 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed:	02/26/2010 0516		
<b>Prep Method: 5030B</b>		Date Prepared:	02/26/2010 0516		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0