

Quarterly Groundwater Monitoring Report

Prepared for
Black & Decker (U.S.) Inc.
Hampstead, Maryland
April 2015

Prepared by
WESTON SOLUTIONS, INC.
West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 1st Quarter 2015	2-2
Table 2-2 Groundwater Elevation Data – 1st Quarter 2015	2-3
Table 2-3 Effluent Characteristics Summary – 1st Quarter 2015	2-4
Table 2-4 Summary of Groundwater Analytical Results - February 2015.....	2-5
Table 3-1 Treatment System Maintenance Activities – 1st Quarter 2015.....	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of January through March 2015.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of January through March 2015, the extraction wells were pumping at an average combined rate of approximately 186 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of January through March 2015 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of January through March 2015, approximately 12.41 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (69.7%) and tetrachloroethene (PCE) (30.3%) Analytical results of the groundwater collected from the air stripper for the period of January through March 2015 are included in Appendix C.

A summary of the analytical results from the first quarter (February 2015) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 1st Quarter 2015
Stanley Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
January 2015	6,944,545
February 2015	4,056,998
March 2015	6,169,819

Table 2-2
Groundwater Elevation Data - 1st Quarter 2015
Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV.	TOTAL DEPTH	1/20/2015		2/25/2015		3/18/2015	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NC	DRY	NC	DRY	NC
EW-2	849.21	110	82.47	766.74	81.10	768.11	83.47	765.74
EW-3	846.64	118	90.52	756.12	90.76	755.88	91.56	755.08
EW-4	858.01	97.5	PC	NC	PC	NC	PC	NC
EW-5	864.17	98	86.43	777.74	84.35	779.82	86.23	777.94
EW-6	831.98	115	84.25	747.73	89.69	742.29	93.00	738.98
EW-7	818.38	78	57.43	760.95	56.17	762.21	58.23	760.15
EW-8	811.13	98	92.95	718.18	91.83	719.30	92.56	718.57
EW-9	811.35	141	100.49	710.86	92.37	718.98	92.91	718.44
EW-10	807.74	INA	56.27	751.47	54.49	753.25	55.98	751.76
RFW-1A	864.37	78	50.43	813.94	49.47	814.90	50.43	813.94
RFW-1B	864.23	200	50.46	813.77	49.50	814.73	50.47	813.76
RFW-2A	857.41	35	16.59	840.82	16.38	841.03	17.02	840.39
RFW-2B	857.73	75	16.99	840.74	17.03	840.70	17.56	840.17
RFW-3B	839.21	153	32.94	806.27	33.80	805.41	34.26	804.95
RFW-4A	830.37	62	38.24	792.13	38.01	792.36	38.06	792.31
RFW-4B	830.37	120	38.22	792.15	37.98	792.39	37.56	792.81
RFW-5A	817.50	30	DRY	NC	DRY	NC	DRY	NC
RFW-6	785.04	120	4.21	780.83	4.13	780.91	5.02	780.02
RFW-7	805.14	29	7.46	797.68	7.88	797.26	7.14	798.00
RFW-8	860.07	56	DRY	NC	DRY	NC	DRY	NC
RFW-9	862.02	49	27.24	834.78	26.53	835.49	27.56	834.46
RFW-10	852.06	58	DRY	NC	DRY	NC	DRY	NC
RFW-11A	849.32	72	Damaged	NC	Damaged	NC	Damaged	NC
RFW-11B	849.62	116	60.83	788.79	61.94	787.68	61.53	788.09
RFW-12B	844.87	264	53.31	791.56	52.88	791.99	53.12	791.75
RFW-13	849.11	150	59.26	789.85	64.15	784.96	63.85	785.26
RFW-14B	812.39	281	53.19	759.20	52.69	759.70	52.56	759.83
RFW-16	856.14	41	DRY	NC	DRY	NC	DRY	NC
RFW-17	834.66	60.5	25.76	808.90	25.77	808.89	26.13	808.53
RFW-20	842.49	142	33.81	808.68	33.93	808.56	32.95	809.54
RFW-21	832.65	102	20.97	811.68	21.98	810.67	20.56	812.09
PH-7	805.94	89	28.76	777.18	29.24	776.70	30.05	775.89
PH-9	814.94	98	51.03	763.91	50.94	764.00	50.86	764.08
PH-11	820.68	78	50.94	769.74	50.53	770.15	50.26	770.42
PH-12	828.35	87	51.85	776.50	51.26	777.09	51.93	776.42
B-3	803.02	83	9.56	793.46	10.08	792.94	10.29	792.73
Amoco	842.29	INA	NA	NC	NA	NC	NA	NC
Hamp. Town #22	804.96	INA	1.89	803.07	2.73	802.23	2.08	802.88
Pembroke #1	INA	INA	9.65	NC	11.03	NC	11.21	NC
Pembroke #2	INA	INA	Damaged	NC	Damaged	NC	Damaged	NC
N. Houcks. Rd.	INA	INA	9.89	NC	9.96	NC	10.23	NC
E. Century St.	INA	INA	19.21	NC	19.20	NC	19.18	NC
Lwr. Beckleys. Rd.	INA	INA	52.56	NC	52.43	NC	52.74	NC

NA - Not Available/Not Accessible
NC - Not Calculable
PC - Pump Cycles

Table 2-3
Effluent Characteristics Summary - 1st Quarter 2015
Black & Decker
Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				January 2015	February 2015	March 2015	
001	FLOW	average	MGD	NA	0.235	0.106	0.312
		maximum	MGD	NA	0.962	0.219	0.991
	1,1,1-Trichloroethane	ug/l	5	< 1	< 1	< 1	
	Tetrachloroethylene	ug/l	5	< 1	< 1	< 1	
	Trichloroethylene	ug/l	5	< 1	< 1	< 1	
	Total Residual Chlorine	mg/l	< 0.1	< 0.1	< 0.1	< 0.1	
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		monthly average	mg/l	10	< 5	< 5	< 5
	pH	minimum	STD	6.0	7.2	7.5	7.4
		maximum	STD	8.5	7.8	7.9	8.3
	BOD		mg/l	15	2.0	< 1	4.0
	TSS	maximum	mg/l	30	< 1	< 1	< 1
monthly average		mg/l	20	< 1	< 1	< 1	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.150	0.144	0.147
		maximum	MGD	NA	0.196	0.185	0.289
	Fecal Coliform	MPN/100ml	200	1.0	1.0	1.0	
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.191
		maximum	MGD	NA	NR	NR	0.385
	1,1,1-Trichloroethane	ug/l	NA	NR	NR	< 1	
	Tetrachloroethylene	ug/l	NA	NR	NR	< 1	
	Trichloroethylene	ug/l	NA	NR	NR	< 1	

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

Table 2-4
Summary of Groundwater Analytical Results - February 2015
Stanley Black & Decker
Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	0.6 J	0.8 J	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3.8	1.9	1 U	1 U	1 U	6.7	25	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	180	37	340	110	6.2	4.7	7.3	0.6	0.5 J	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	51	1.6	8.3	4.5	11	11	70	140	100	5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	0.4 J
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

NS = Not Sampled

Table 2-4
Summary of Groundwater Analytical Results - February 2015
Stanley Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	NS	2 U	2 U	NS	2 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	0.6 J	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	0.6 J	0.7 J	1 U	NS	1 U	1 U	NS	8.3	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	0.5 J	0.5 J	2.8	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	1 U	0.7	1 U	27	25	18	NS	1 U	1 U	NS	8.2	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	17	15	36	NS	1 U	1 U	NS	2.7	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	0.3 J	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicate sample
NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
J = Indicates an estimated value.

Table 2-4
Summary of Groundwater Analytical Results - February 2015
Stanley Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	RFW-20	RFW-21	Town #22	Town #23	Trip Blank
		USEPA drinking water method 524.2														
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	NS	2 U	ABD	ABD	ABD	1.1 J	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	1 U	ABD	ABD	ABD	7.9	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	NA	NA	NA	NA	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trichloroethene	ug/L	NS	2.6	190	3.4	NS	1 U	ABD	ABD	ABD	1 U	0.5	0.5 U	0.5 U	0.5 U	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	1 U	7.3	17	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.33 J	0.5 U	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	0.7	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	0.3 J	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division. Samples from all of the other wells are analyzed with USEPA Method 8260.

NS = Not sampled

U = Compound was analyzed but not detected.

ABD = Well has been abandoned

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells EW-4 and RFW-12B and the highest concentration of PCE was detected in the groundwater sample collected from well EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (January through March 2015) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 1st Quarter 2015
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Jan-15	Alarm at the stripper due to faulty heating elements on EW-3 , the heating elements were replaced the well is back online.
Jan-15	Replaced the temperature probe in EW-10.
Jan-15	Multiple alarms at the stripper due to a frozen float in the stripper, each time the float was warmed with a manual heater and the system was back online.
Jan-15	The air stripper went down due to a bad level transmitter. The wells were run in manual mode until the level transmitter was replaced and the stripper was switched back to auto mode.
Mar-15	Getting a 10W Hydro Tank alarm, due to a short in the wiring. The wire was repaired and the system is back online.
Mar-15	Alarm at the air stripper due to a broken pipe in EW-1. Wells 2-5 were turned off until the pipe in EW-1 was repaired. The wells were down for 3 days before the pipe was repaired. The system is back up and running.
Mar-15	Wells 2-5 were turned off due to a flooded electric manhole due to rain and snow melt. Manhole was pumped out and system back online.

4. RECOMMENDATIONS

For the reporting period of January through March 2015, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(JANUARY – MARCH 2015)



ENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group (MD0001881)

Address: 627 Hanover Pike, Hampstead Maryland

Additional Op's & cert # - James Elliott 3738, Ryan Thomas 0781, Keith White 4609, Chris Dallas 6202

Superintendent: Earle Villarreal

Certification # 1017

Month: January

Year: 2015

Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Final Effluent outfall 001										Outfall 101					Outfall 201			Operator								
					Tetrachloroethylene ug/l	1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	TKN mg/l	N+N ug/l	TP mg/l	TN mg/l	O&G mg/l	eColi mpn	Flow MGD	eColi mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l		1,1-Trichloroethane ug/l	Trichloroethene ug/l	Discharge mgd					
1	Clear	0.15000																	0.151000	0"	5.0	1.0	5.0						0.232049	JE	
2	Clear	0.13500																	0.150000	0"	5.0	1.0	5.0						0.212931	JE	
3	Clear	0.13200																	0.161000	0"	5.0	1.0	5.0						0.241576	RT	
4	Clear	0.60600																	0.137000	0"	5.0	1.0	5.0						0.226713	RT	
5	Clear	0.39200	7.18	0.00															0.162000	0"	5.0	1.0	5.0						0.239346	JE	
6	Clear	0.16300																	0.177000	0"	5.0	1.0	5.0						0.230144	JE	
7	Clear	0.18600	7.40	0.00															0.157000	<1	0"	5.0	1.0	5.0						0.225860	JE
8	Clear	0.12700																	0.144000	0"	5.0	1.0	5.0						0.219093	JE	
9	Clear	0.10900																	0.193000	0"	5.0	1.0	5.0						0.202782	JE	
10	Clear	0.96200																	0.160000	0"	5.0	1.0	5.0						0.192644	KW	
11	Clear	0.11000																	0.115000	0"	5.0	1.0	5.0						0.223314	KW	
12	Clear	0.32300	7.76	0.00															0.142000	0"	5.0	1.0	5.0						0.236518	JE	
13	Clear	0.48100																	0.136000	0"	5.0	1.0	5.0						0.237181	CD	
14	Clear	0.12000	7.44	0.00	<1	<1	<1	2.00	<5	0.262	2.60	<0.05	2.9	<5				0.129000	<1	0"	5.0	1.0	5.0	<1	<1	<1			0.188061	CD	
15	Clear	0.16800																	0.164000	0"	5.0	1.0	5.0						0.254368	JE	
16	Clear	0.13400																	0.125000	0"	5.0	1.0	5.0						0.229117	RT	
17	Clear	0.14400																	0.171000	0"	5.0	1.0	5.0						0.250242	KW	
18	Clear	0.13000																	0.130000	0"	5.0	1.0	5.0						0.213598	KW	
19	Clear	0.14800	7.66	0.00															0.152000	0"	5.0	1.0	5.0						0.256407	JE	
20	Clear	0.14800																	0.147000	0"	5.0	1.0	5.0						0.223509	JE	
21	Clear	0.13200																	0.145000	<1	0"	5.0	1.0	5.0						0.218689	CD
22	Clear	0.18400	7.66	0.00															0.162000	0"	5.0	1.0	5.0						0.240890	JE	
23	Clear	0.17200																	0.160000	0"	5.0	1.0	5.0						0.228967	CD	
24	Clear	0.57700																	0.111000	0"	5.0	1.0	5.0						0.226719	RT	
25	Clear	0.45400																	0.133000	0"	5.0	1.0	5.0						0.225017	RT	
26	Clear	0.22400																	0.159000	0"	5.0	1.0	5.0						0.243582	JE	
27	Clear	0.18200	7.73	0.00															0.140000	0"	5.0	1.0	5.0						0.216176	JE	
28	Clear	0.14000	7.58	0.00															0.154000	<1	0"	5.0	1.0	5.0						0.199298	JE
29	Clear	0.12900																	0.196000	0"	5.0	1.0	5.0						0.252522	JE	
30	Clear	0.14100																	0.131000	0"	5.0	1.0	5.0						0.246897	JE	
31	Clear	0.08600																	0.164000	0"	5.0	1.0	5.0						0.110335	JE	
Total		7.28900																	4.658000										6.944545		
Average		0.23513		<0.10	0	0	0	2	0	0	3	0	3	0	#NUM!			0.150258	1.0	#DIV/0!	5.0	1.0	5.0	0.0	0.0	0.0			0.224018		
Minimum		0.08600	7.2	0.00	0	0	0	2	0	0	3	0	3	0			0.111000	0.0	0.0	5.0	1.0	5.0	0.0	0.0	0.0			0.110335	MOR		
Maximum		0.96200	7.8	<0.10	0	0	0	2	0	0	3	0	3	0			0.196000	0.0	0.0	5.0	1.0	5.0	0.0	0.0	0.0			0.256407	2/23/2015		

Handwritten signature/initials

WATER ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group (MD0001881)
Address: 627 Hanover Pike, Hampstead Maryland

Additional Op's & cen # - James Elliott 3738, Ryan Thomas 0781, Dorrance Jones 0763, Keith White 4609, Anthony Phillips 3001, Chris Dallas 6202

Superintendent: Earle Villarreal Certification # 1017

Month: February

Year: 2015

Date	Appearance	Discharge MGD	pH	Cl2 mg/l	Final Effluent outfall 001										Outfall 101					Outfall 201			Operator					
					Tetrachloroethylene ug/l	1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD mg/l	TSS mg/l	TKN mg/l	N+N mg/l	TP mg/l	TN mg/l	O&G mg/l	eColi mpn	Flow MGD	eColi mpn	Basin Inches	Alum Gpd	Hypochlorid Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l		1,1-Trichloroethane ug/l	Trichloroethene ug/l	Discharge mgd		
1	Clear	0.00000															0.155000		0"	5.0	1.0	5.0				0.094268	JE	
2	Clear	0.15200	7.83	0.00													0.089000		0"	5.0	1.0	5.0				0.132738	RT	
3	Clear	0.17000			<1	<1	<1	2.00	6.80	0.93	2.32	<0.05	3.2	<5	42.9	0.133000	<1	0"	5.0	1.0	5.0				0.119179	RT		
4	Clear	0.07600	7.92	0.00													0.185000		0"	5.0	1.0	5.0				0.158010	RT	
5	Clear	0.08900															0.135000		0"	5.0	1.0	5.0				0.152789	JE	
6	Clear	0.01300															0.168000		0"	5.0	1.0	5.0				0.094002	JE	
7	Clear	0.00270															0.136000		0"	5.0	1.0	5.0				0.237080	DJ	
8	Clear	0.09100															0.135000		0"	5.0	2.0	5.0				0.149563	DJ	
9	Clear	0.09100	7.81	0.00													0.138000		0"	5.0	1.0	5.0				0.138966	JE	
10	Clear	0.09200															0.141000	<1	0"	5.0	1.0	5.0				0.132184	JE	
11	Clear	0.10100															0.165000		0"	5.0	1.0	5.0				0.146643	JE	
12	Clear	0.08000	7.86	0.00													0.135000		0"	5.0	1.0	5.0				0.133654	JE	
13	Clear	0.05700															0.168000		0"	5.0	1.0	5.0				0.048569	JE	
14	Clear	0.11900															0.143000		0"	5.0	1.0	5.0				0.079310	KW	
15	Clear	0.08500															0.145000		0"	5.0	1.0	5.0				0.057100	KW	
16	Clear	0.07700															0.172000		0"	5.0	1.0	5.0				0.006560	AP	
17	Clear	0.08700															0.121000		0"	5.0	1.0	5.0				0.003304	CD	
18	Clear	0.10700	7.51	0.00													0.117000	<1	0"	5.0	1.0	5.0				0.029018	JE	
19	Clear	0.11400	7.56	0.00													0.148000		0"	5.0	1.0	5.0				0.015623	JE	
20	Clear	0.10900															0.175000		0"	5.0	1.0	5.0				0.051549	JE	
21	Clear	0.10500															0.143000		0"	5.0	1.0	5.0				0.251107	RT	
22	Clear	0.09000															0.131000		0"	5.0	1.0	5.0				0.216604	RT	
23	Clear	0.10100	7.83	0.00													0.126000		0"	5.0	1.0	5.0				0.249873	JE	
24	Clear	0.20600															0.132000	<1	0"	5.0	1.0	5.0				0.278068	JE	
25	Clear	0.15200															0.139000		0"	5.0	1.0	5.0				0.254354	MW	
26	Clear	0.21900															0.140000		0"	5.0	1.0	5.0				0.294604	JE	
27	Clear	0.20000	7.70	0.00													0.155000		0"	5.0	1.0	5.0				0.241465	JE	
28	Clear	0.18500															0.174000		0"	1.0	1.0	5.0				0.290814	DJ	
29																												
30																												
31																												
Total		2.97070															4.0440										4.056998	
Average		0.10610		<0.10	0	0	0	2	7	1	2	0	3	0	43	0.1444	1.0	#####	4.9	1.0	5.0	#DIV/0!	#DIV/0!	#DIV/0!	0.144893			
Minimum		0.00000	7.5	0.00	0	0	0	2	7	1	2	0	3	0		0.0890	0.0	0.0	1.0	1.0	5.0	0.0	0.0	0.0	0.003304	MOR		
Maximum		0.21900	7.9	<0.10	0	0	0	2	7	1	2	0	3	0		0.1850	0.0	0.0	5.0	2.0	5.0	0.0	0.0	0.0	0.294604	3/23/2015		

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

PWSID # 106-0004

Black & Decker WTP

Superintendent: Earle Villarreal

Month: March

Address: BTR CAPITAL GROUP, Hampstead, MD 21073

Certification #: 1017

Year: 2015

Operated by:

625 Hanover Pike, Hampstead, Carroll County, Maryland

Maryland Environmental Service

Additional Ops & Cert #'s: Ryan Thomas 0781, James Elliott 3738, Dorrance Jones 0763, Martin Whitt 0666, Chris Dallas 6202, Anthony Phillips 3001, Keith White 4609

General			Potable Water			Chemical				Monitoring		Distribution			Raw Water		Comments	
Date	Day	Weather	MGD Total	pH P.O.E	Free Cl2	Na2CO3 Level	Na2CO3 (gpd)	NaOCL Level	NaOCL (gpd)	VOC'S (ppb)	Bacti Pos/Neg	pH su	TRC mg/l	Distribution Location	Oper Int	pH su		Total Raw Water Well (mgd)
1	Sun	Snow	0.0011	7.25	1.17	10.0	0.0	57.0	1.0						DJ		0.227790	
2	Mon	Clear	0.0028	7.62	2.12	10.0	0.0	56.0	1.0			7.46	1.93	1st Floor	JE		0.268729	
3	Tue	Cloudy	0.0063	7.74	2.06	10.0	0.0	55.0	1.0						JE		0.271230	
4	Wed	Cloudy	0.0049	7.58	1.92	10.0	0.0	54.0	1.0			7.49	1.86	Loading Dock	JE		0.256812	
5	Thurs	Rain	0.0029	7.53	2.16	10.0	0.0	53.0	1.0						RT		0.134263	
6	Fri	Clear	0.0059	7.47	2.10	10.0	0.0	52.0	1.0			7.28	1.82	1st Floor	JE	6.70	0.384817	
7	Sat	Clear	0.0030	7.43	1.96	10.0	0.0	51.0	1.0						JE		0.252540	
8	Sun	Clear	0.0017	7.38	2.04	10.0	0.0	50.0	1.0						JE		0.242052	
9	Mon	Clear	0.0042	7.47	2.20	10.0	0.0	60.0	1.0			7.67	2.16	Loading Dock	CD		0.151570	
10	Tue	Cloudy	0.0050	7.26	1.42	10.0	0.0	58.0	2.0						MW		0.180964	
11	Wed	Cloudy	0.0054	7.55	1.65	10.0	0.0	57.0	1.0						JE		0.110782	
12	Thurs	Clear	0.0053	7.62	1.87	10.0	0.0	56.0	1.0			7.66	1.83	Loading Dock	JE		0.113396	
13	Fri	Clear	0.0058	7.38	1.98	10.0	0.0	55.0	1.0						KW		0.105254	
14	Sat	Rain	0.0028	7.22	1.46	10.0	0.0	54.0	1.0						RT		0.167782	
15	Sun	Cloudy	0.0024	7.41	1.42	10.0	0.0	53.0	1.0						RT		0.160704	
16	Mon	Clear	0.0039	7.67	1.51	10.0	0.0	52.0	1.0			7.61	1.64	1st Floor	JE		0.177665	
17	Tue	Cloudy	0.0034	7.75	1.74	10.0	0.0	51.0	1.0						AP	5.65	0.137392	
18	Wed	Clear	0.0063	7.10	1.40	10.0	0.0	50.0	1.0			7.04	1.42	Loading Dock	KW		0.223865	
19	Thurs	Clear	0.0029	7.56	1.27	10.0	0.0	49.0	1.0						JE		0.169326	
20	Fri	Clear	0.0071	7.24	1.36	10.0	0.0	48.0	1.0						JE		0.230321	
21	Sat	Clear	0.0042	7.07	1.54	10.0	0.0	47.0	1.0						DJ		0.208850	
22	Sun	Clear	0.0015	7.39	1.46	10.0	0.0	46.0	1.0						DJ		0.195165	
23	Mon	Clear	0.0032	7.40	1.51	10.0	0.0	45.0	1.0			7.12	1.28	Loading Dock	JE		0.196408	
24	Tue	Clear	0.0045	7.55	1.27	10.0	0.0	44.0	1.0						JE	5.49	0.176338	
25	Wed	Clear	0.0059	7.73	1.22	10.0	0.0	43.0	1.0						JE		0.219577	
26	Thurs	Clear	0.0055	7.62	1.34	10.0	0.0	42.0	1.0						JE		0.210243	
27	Fri	Cloudy	0.0054	7.70	1.33	10.0	0.0	41.0	1.0			7.63	1.14	Loading Dock	RT		0.184246	
28	Sat	Cloudy	0.0031	7.16	1.22	10.0	0.0	40.0	1.0						KW		0.214086	
29	Sun	Clear	0.0021	7.26	1.08	10.0	0.0	39.0	1.0						KW		0.189009	
30	Mon	Cloudy	0.0030	7.19	1.06	10.0	0.0	38.0	1.0						AP		0.197901	
31	Tue	Cloudy	0.0058	7.42	1.51	10.0	0.0	37.0	1.0						RT		0.210742	
Total			0.1273				0.0		32.0								6.169819	
Average			0.0041	7.44	1.59	10.0	0.0	49.5	1.0	####		7.44	1.68			5.95	0.199026	
Minimum			0.0011	7.07	1.06	10.0	0.0	37.0	1.0	0.0		7.04	1.14			5.49	0.105254	
Maximum			0.0071	7.75	2.20	10.0	0.0	60.0	2.0	0.0		7.67	2.16			6.70	0.384817	



**APPENDIX B
DISCHARGE MONITORING REPORTS
(JANUARY - MARCH 2015)**



PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name BTR Hampstead, Inc

Address c/o BTR Captial Group Management

222 Courthouse Ct., Suite 300, Towson MD 21204

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

State Discharge Permit

07-DP-0022

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 15	01	01	TO 15	01	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

PARAMETER (32-37)		(3 Card Only) (46-53)			QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE		MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	****	*****	*****	*****	*****	*****	*****	*****	2	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	****	*****	*****	*****	*****	*****	*****	*****	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
pH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	****	7.2	*****	*****	*****	*****	*****	*****	7.8	(12)	0	TWICE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	****	*****	*****	*****	*****	*****	*****	*****	8.5 DAILY MX	SU		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 C EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	*****	Lbs/day	*****	*****	*****	*****	*****	*****	*****	0	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX	*****	Lbs/day	*****	*****	*****	*****	*****	*****	*****	20 30DA AVG	MG/L		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 1 C EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	*****	Lbs/mo	*****	*****	*****	*****	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL	*****	Lbs/mo	*****	*****	*****	*****	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
SOLIDS, TOTAL SUSPENDED 00530 1 2 C EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	*****	Lbs/yr	*****	*****	*****	*****	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL	*****	Lbs/yr	*****	*****	*****	*****	*****	*****	*****	*****	*****	0	ONCE/ MONTH	Calculated
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	****	*****	*****	*****	*****	*****	*****	*****	0	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	****	*****	*****	*****	*****	*****	*****	*****	10 30DA AVG	MG/L		ONCE/ MONTH	GRAB
NITROGEN, TOTAL (AS N) 00600 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	3	*****	Lbs/day	*****	*****	*****	*****	*****	*****	*****	3	(19)	0	ONCE/ MONTH	COMP -8
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX	*****	Lbs/day	*****	*****	*****	*****	*****	*****	*****	Req. Mon. 30DA AVG	MG/L		ONCE/ MONTH	COMP -8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
Nicole Finneyfrock Property Manager		410	729-8350	15	02	23
TYPED OR PRINTED		AREA CODE	NUMBER	YEAR	MONTH	DAY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PA

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name BTR Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address c/o BTR Capital Group Management

MD0001881

001

Approval expires

222 Courthouse Ct., Suite 300, Towson MD 21204

PERMIT NUMBER

DISCHARGE NUMBER

*** NO DISCHARGE ***

Facility Groundwater Remediation and WWTP

MONITORING PERIOD

NOTE: Read instructions before completing this form

Location 626 Hanover Pike

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	15	01	01		15	01	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

07-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING (3 Card Only) (46-53)			QUALITY OR CONCENTRATION (4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
NITROGEN, TOTAL (AS N) 00600 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	174	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
NITROGEN, TOTAL (AS N) 00600 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	174	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/day	*****	0	0	(19)	0	ONCE/ MONTH	COMP -8
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	DAILY MX	MG/L		ONCE/ MONTH	COMP -8
PHOSPHOROUS, TOTAL (AS P) 00665 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
TETRACHLOROETHYLE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Nicole Finneyfrock Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 19 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410	729-8350	15	02	23
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN	AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DF

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name BTR Hampstead, Inc

Address c/o BTR Captial Group Management

222 Courthouse Cl., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attn:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 15	01	01	TO 15	01	31
(20-21)		(22-23)	(24-25)	(26-27)	(28-29) (30-31)

State Discharge Permit

07-DP-0022

PARAMETER (32-37)		(3 Card Only)			(4 Card Only)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION						
		AVERAGE (46-53)	MAXIMUM (54-61)		MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE SUREMENT	0.2351	0.9620	(03)	*****	*****	*****	*****	0	ONCE/ MONTH	Measured
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	MGD	*****	*****	*****	*****	0	ONCE/ MONTH	Measured
CHLORINE, TOTAL RESIDUAL 50060 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L	0	ONCE/ MONTH	GRAB
E. COLI, MPN 51040 1 0 1	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	*****	(30)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	Req. Mon. GEO MEAN	*****	MPN	0	ONCE/ MONTH	GRAB
TRICHLOROETHENE 78391 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L	0	ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TI

Nicole Finneyfrock
Property Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)


SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGEN

TELEPHONE

410 729-8350

AREA
CODE

NUMBER

DATE

15

02

23

YEAR

MONTH

DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

See non-comp for Ecol.



PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name BTR Hampstead, Inc

Address c/o BTR Capital Group Management

222 Courthouse Ct., Suite 300, Towson MD 21204

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attn: _____

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD

FROM		YEAR	MO	DAY	TO	YEAR	MO	DAY
		15	01	01		15	01	31
		(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit
07-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(3 Card Only) (46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(4 Card Only) (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	150,258	196,000	(07)	*****	*****	*****	****	0	ONCE/ WEEK	Measured/ Recorded
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	Measured/ Recorded
E.COLI, MPN 51040 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	126 DAILY MX	MPN		ONCE/ WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)				TELEPHONE		DATE				
Nicole Finneyrock Property Manager TYPED OR PRINTED					410	729-8350	15	02	23		
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN		AREA CODE	NUMBER	YEAR	MONTH	DAY			

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name BTR Hampstead, Inc

Address c/o BTR Captial Group Management

222 Courthouse Ct., Suite 300, Towson MD 21204

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attn.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 15	02	01	TO	15	02	28
(20-21)		(22-23)		(24-25)		(26-27)
				(28-29)		(30-31)

State Discharge Permit

07-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(3 Card Only) (46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(4 Card Only) (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	2	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
pH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	7.5	*****	7.9	(12)	0	TWICE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	DAILY MN	*****	8.5 DAILY MX	SU		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 C EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	10	Lbs/day	*****	7	7	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 1 C EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	168	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
SOLIDS, TOTAL SUSPENDED 00530 1 2 C EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	168	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	10 30DA AVG	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
NITROGEN, TOTAL (AS N) 00600 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	5	Lbs/day	*****	3	3	(19)	0	ONCE/ MONTH	COMP -8
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	Req. Mon. DAILY MX	MG/L		ONCE/ MONTH	COMP -8
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)				TFI PHONE			DATE			
Nicole Finneyfrock Property Manager TYPED OR PRINTED					SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN			410	729-8350	15	03
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)				AREA CODE	NUMBER	YEAR	MONTH	DAY			

ERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDE)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name BTR Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address c/o BTR Capital Group Management

MD0001881

001

Approval expires

222 Courthouse Ct., Suite 300, Towson MD 21204

PERMIT NUMBER

DISCHARGE NUMBER

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Groundwater Remediation and WWTP

MONITORING PERIOD

State Discharge Permit

Location 626 Hanover Pike

YEAR	MO	DAY	YEAR	MO	DAY
15	02	01	15	02	28

07-DP-0022

Attn:

FROM (20-21) (22-23) (24-25) TO (26-27) (28-29) (30-31)

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (54-61)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
NITROGEN, TOTAL (AS N) 00600 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	81	Lbs/mo	*****	*****	*****	****	0	ONCE/MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/MONTH	Calculated
	SAMPLE MEASUREMENT	*****	254	Lbs/yr	*****	*****	*****	****	0	ONCE/MONTH	Calculated
NITROGEN, TOTAL (AS N) 00600 1 2 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/MONTH	Calculated
	SAMPLE MEASUREMENT	*****	0	Lbs/day	*****	0	0	(19)	0	ONCE/MONTH	COMP -8
	PREMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	DAILY MX	MG/L		ONCE/MONTH	COMP -8
PHOSPHOROUS, TOTAL (AS P) 00665 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/mo	*****	*****	*****	****	0	ONCE/MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/MONTH	Calculated
	SAMPLE MEASUREMENT	*****	0	Lbs/yr	*****	*****	*****	****	0	ONCE/MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/MONTH	Calculated
	SAMPLE MEASUREMENT	*****	0	Lbs/yr	*****	*****	*****	****	0	ONCE/MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		*****	*****	0	(28)	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB
	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
TETRACHLOROETHYLE 34475 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB
	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Nicole Finneyfrock Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PPHONF		DATE		
		410 AREA CODE	729-8350 NUMBER	15 YEAR	03 MONTH	23 DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include
 Facility Name/Location if different)
 Name BTR Hampstead, Inc
 Address c/o BTR Capital Group Management
 222 Courthouse Ct., Suite 300, Towson, MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)
 MD0001881 001
PERMIT NUMBER DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires

*** NO DISCHARGE ***

Facility Groundwater Remediation and WWTP
 Location 626 Hanover Pike
 Attention:

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
15	02	01	TO	15	02	28
(20-21)		(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

State Discharge Permit
 07-DP-0022

NOTE: Read instructions before completing this form

PARAMETER (32-37)		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(3 Card Only)		UNITS	(4 Card Only)		UNITS				
		(46-53) AVERAGE	(54-61) MAXIMUM		(38-45) MINIMUM	(46-53) AVERAGE		(54-61) MAXIMUM			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0.1061	0.2190	(03)	*****	*****	*****	****	0	ONCE/ MONTH	Measured
	PERMIT REQUIREMENT	REPORT	REPORT	MGD	*****	*****	*****	****		ONCE/ MONTH	Measured
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L		ONCE/ MONTH	GRAB
E. COLI, MPN 51040 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	43	*****	(30)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	Req. Mon. GEO MEAN	*****	MPN		ONCE/ MONTH	GRAB
TRICHLOROETHENE 78391 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE Nicole Finneyrock Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410	729-8350	15	03	23
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 Name BTR Hampstead, Inc
 Address c/o BTR Captial Group Management
 222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDE)

DISCHARGE MONITORING REPORT (DMR)

(2-16) MD0001881 (17-19) 101
 PERMIT NUMBER DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires


*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Groundwater Remediation and WWTP
 Location 626 Hanover Pike
 Attn:

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
FROM 15	02	01		15	02	28
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit
 07-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	144,429	185,000	(07)	*****	*****	*****	****	0	ONCE/WEEK	Measured/Recorded	
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/MONTH	Measured/Recorded	
E. COLI, MPN 51040 1 0 1	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/WEEK	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	126 DAILY MX	MPN		ONCE/WEEK	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDULES IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)				SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN			TELEPHONE	DATE			
Nicole Finneyrock Property Manager TYPED OR PRINTED								410 AREA CODE	729-8350 NUMBER	15 YEAR	03 MONTH	23 DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name BTR Hampstead, Inc

Address c/o BTR Captial Group Management

222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-15)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attn:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
15	03	01	15	03	31
FROM			TO		
(20-21)		(22-23)	(24-25)	(26-27)	(28-29) (30-31)

State Discharge Permit

07-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(3 Card Only) (46-53)		(54-61)	(4 Card Only) (38-45)		(54-61)				
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	4	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	****	7.4	*****	8.3	(12)	0	TWICE/ WEEK	GRAB
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	****	DAILY MN	*****	8.5 DAILY MX	SU		TWICE/ WEEK	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	39	Lbs/day	*****	16	16	(19)	0	ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 C	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	1,249	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
SOLIDS, TOTAL SUSPENDED 00530 1 1 C	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	1,418	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
SOLIDS, TOTAL SUSPENDED 00530 1 2 C	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/ MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	10 30DA AVG	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	15	Lbs/day	*****	6	6	(19)	0	ONCE/ MONTH	COMP -8
NITROGEN, TOTAL (AS N) 00600 1 0 0	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	Req. Mon. DAILY MX	MG/L		ONCE/ MONTH	COMP -8
EFFLUENT GROSS VALUE	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)					TELEPHONE		DATE			
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER						410 729-8350		15	04	22	
Nicole Finneyrock Property Manager	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE	NUMBER	YEAR	MONTH	DAY	
TYPED OR PRINTED											

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name BTR Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address c/o BTR Captial Group Management

MD0001881

001

Approval expires

222 Courthouse Ct., Suite 300, Towson MD 21204

PERMIT NUMBER

DISCHARGE NUMBER

Facility Groundwater Remediation and WWTP

MONITORING PERIOD

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Location 626 Hanover Pike

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	15	03	01		15	03	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

07-DP-0022

PARAMETER (32-37)		(3 Card Only) (45-53) QUANTITY OR LOADING			(4 Card Only) (38-45) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (54-55)	MAXIMUM (54-61)	UNITS	MINIMUM (46-53)	AVERAGE (54-61)	MAXIMUM (54-61)	UNITS			
NITROGEN, TOTAL (AS N) 00600 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	478	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
NITROGEN, TOTAL (AS N) 00600 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	732	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/day	*****	0	0	(19)	0	ONCE/ MONTH	COMP -8
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	DAILY MX	MG/L		ONCE/ MONTH	COMP -8
PHOSPHOROUS, TOTAL (AS P) 00665 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	12	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	12	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
TETRACHLOROETHYLE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUES IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFL PHONE		DATE		
Nicole Finneyfrock Property Manager		410	729-8350	15	04	22
TYPED OR PRINTED		AREA CODE	NUMBER	YEAR	MONTH	DAY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name BTR Hampstead, Inc

Address c/o BTR Capital Group Management

222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike


Attn:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 15	03	01	TO 15	03	31
(20-21)		(22-23)	(24-25)	(26-27)	
		(28-29)	(30-31)		

State Discharge Permit

07-DP-0022

PARAMETER (32-37)		(3 Card Only)			(4 Card Only)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION		UNITS				
		AVERAGE (46-53)	MAXIMUM (54-61)		MINIMUM (38-45)	AVERAGE (46-53)					MAXIMUM (54-61)
FLOW IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	0.3117	0.9910	(03)	*****	*****	*****	0	ONCE/MONTH	Measured	
	PERMIT REQUIREMENT	REPORT	REPORT	MGD	*****	*****	*****		ONCE/MONTH	Measured	
EFFLUENT GROSS VALUE CHLORINE, TOTAL RESIDUAL 50060 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	***	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L		ONCE/MONTH	GRAB
E.COLI, MPN 51040 1 0 1	SAMPLE MEASUREMENT	*****	*****	****	*****	12	*****	(30)	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	Req. Mon. GEO MEAN	*****	MPN		ONCE/MONTH	GRAB
TRICHLOROETHENE 78391 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TI Nicole Finneyfrock Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410	729-8350	15	04	22
	SIGNATURE OF PRINCIPAL EXECUTIVE 	AREA CODE	NUMBER	YEAR	MONTH	DAY
	OFFICER OR AUTHORIZED AGENT					

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name BTR Hampstead, Inc

Address c/o BTR Capital Group Management

222 Courthouse Ct., Suite 300, Towson MD 21204

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

State Discharge Permit

07-DP-0022

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
15	03	01	15	03	31
(20-21)		(22-23)		(24-25)	
(26-27)		(28-29)		(30-31)	

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	147,000	289,000	(07)	*****	*****	*****	****	0	ONCE/ WEEK	Measured/ Recorded	
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	Measured/ Recorded	
E. COLI, MPN 51040 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/ WEEK	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	126 DAILY MX	MPN		ONCE/ WEEK	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §§1001 AND 33 U.S.C. §§ 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)							T/F PHONE		DATE		
Nicole Finneyfrack Property Manager	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							410	729-8350	15	04	22
TYPED OR PRINTED								AREA CODE	NUMBER	YFAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name BTR Hampstead, Inc

Address c/o BTR Captial Group Management

222 Courthouse Ct., Suite 300, Towson MD 21204

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

201

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires


*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 15	01	01	TO 15	03	31
(20-21)		(22-23)	(24-25)	(26-27)	
		(28-29)	(30-31)		

State Discharge Permit

07-DP-0022

PARAMETER (32-37)		(3 Card Only)			(4 Card Only)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION							
		(46-53) AVERAGE	(54-61) MAXIMUM		(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS				
34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/Quarter	Grab	
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/Quarter	Grab	
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/Quarter	Grab	
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/Quarter	Grab	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	190,793	384,817	(07)	*****	*****	*****	****	0	Measured	Record	
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	Record	
Total Volatile Organics (VOC) 51415 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/Quarter	Grab	
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	100	UG/L		One/Quarter	Grab	
TRICHLOROETHENE 78391 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/Quarter	Grab	
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/Quarter	Grab	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUES IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS 1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)							TFI PHONE		DATE		
Nicole Finneyrock Property Manager								410	729-8350	15	04	22
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)



APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(JANUARY - MARCH 2015)



QC Laboratories

Analytical Report

Printed 01/29/15 16:49 DE36

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE B
 259 NAJOLLES ROAD
 RE: BTR HAMPSTEAD WWTP
 MILLERSVILLE, MD 21108

Order Number: L5365657
 Project Name: BTR HAMPSTEAD WWTP
 Receive Date: 01-14-2015
 Client Code: MES_A
 Project Location: BTR HAMPSTEAD WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
 Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID Sample Description Samp. Date/Time/Temp Sampled by
 L5365657-1 BTR 001 GRAB 01/14/15 08:50am NA C Customer
 Received Date/Time/Temp 01/14/15 04:30pm 1.3 C Iced (Y/N): Y

Satellite Received Temp 3.6 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

GENERAL CHEMISTRY

Hexane Ext. Material-HEM (oil+grease)	ND	5.00	mg/l	1664B HEM	1		01/20/15 09:00PM RSK
Total Suspended Solids (Delaware)	ND	5.00	mg/l	SM 2540D	1		01/19/15 01:10PM MS3
Biochemical Oxygen Demand, 5 Day (DE)	2.00	2.00	mg/l	SM 5210B	1.5		01/15/15 11:00AM SKJ

GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES

1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		01/26/15 05:33PM JAD
Tetrachloroethene	ND	1.00	ug/l	EPA 624	1		01/26/15 05:33PM JAD
Trichloroethene	ND	1.00	ug/l	EPA 624	1		01/26/15 05:33PM JAD

Sample ID Sample Description Samp. Date/Time/Temp Sampled by
 L5365657-2 BTR 001 COMP 01/14/15 08:47am NA C Customer
 Received Date/Time/Temp 01/14/15 04:30pm 1.3 C Iced (Y/N): Y

Satellite Received Temp 3.6 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

PIN: 17237

Serial Number: 4345173

QC Laboratories

Analytical Report

Printed 01/30/15 14:35 DE36

CHERYL GRIFFIN
MARYLAND ENVIRONMENTAL SERVICE B
259 NAJOLAS ROAD
RE: BTR HAMPSTEAD WWTP
MILLERSVILLE, MD 21108

Order Number: L5409268
Project Name: BTR HAMPSTEAD WWTP
Receive Date: 01-14-2015
Client Code: MES_A
Project Location: BTR HAMPSTEAD WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No: Inv. No: MES_AL0341
PWSID No:

Sample ID Sample Description Samp. Date/Time/Temp Sampled by
L5409268-1 BTR 201 01/14/15 09:03am NA C Customer
Received Date/Time/Temp 01/14/15 04:30pm 1.3 C Iced (Y/N): Y

Satellite Received Temp 3.6 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES

1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
1,1,2,2-Tetrachloroethane	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
1,1,2-Trichloroethane	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
1,1-Dichloroethane	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
1,1-Dichloroethene	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
1,2-Dichlorobenzene	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
1,2-Dichloroethane	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
1,2-Dichloropropane	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
1,3-Dichlorobenzene	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
1,4-Dichlorobenzene	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
2-Chloroethyl vinyl ether	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Benzene	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Bromodichloromethane	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Bromoform	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Bromomethane	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Carbon tetrachloride	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Chlorobenzene	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Chloroethane	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Chloroform	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Chloromethane	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
cis-1,3-Dichloropropene	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Dibromochloromethane	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Ethylbenzene	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Methylene chloride	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Tetrachloroethene	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Toluene	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
trans-1,2-Dichloroethene	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
trans-1,3-Dichloropropene	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Trichloroethene	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ

PIN: 17237

Serial Number: 4348327

QC Laboratories

Analytical Report

Printed 01/30/15 14:35

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample ID L5409268-1 Sample Description BTR 201
Received Date/Time/Temp 01/14/15 04:30pm 1.3 C Iced (Y/N): Y
Samp. Date/Time/Temp 01/14/15 09:03am NA C Sampled by Customer

Satellite Received Temp 3.6 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES continued							
Trichlorofluoromethane	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ
Vinyl chloride	ND	1.00	ug/l	EPA 624	1		01/28/15 04:28PM WJJ



PIN: 17237

Serial Number: 4348327

QC Laboratories

Analytical Report

Printed 01/30/15 19:05 DE36

CHERYL GRIFFIN
MARYLAND ENVIRONMENTAL SERVICE B
259 NAJOLAS ROAD
RE: BTR HAMPSTEAD WWTP
MILLERSVILLE, MD 21108

Order Number: L5425281
Project Name: BTR HAMPSTEAD WWTP
Receive Date: 01-30-2015
Client Code: MES_A
Project Location: BTR HAMPSTEAD WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No: Inv. No: MES_AL0341
PWSID No:

Sample ID	Sample Description	Received Date/Time	Samp. Date/Time/Temp	Sampled by
L5425281-1	BLACK & DECKER 101	01/30/15 11:30am	01/14/15 09:10am	NA C Customer

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY							
E. Coli, MPN Cel(Delaware)	<1.0		MPN/100ml	SM 9221F			01/14/15 02:34PM SUB

Sample Comments:

L5425281-1 :
E. coli was analyzed by Chesapeake Environmental Lab, Inc in Stevensville, MD.



PIN: 17237

Serial Number: 4350519

QC Laboratories

Analytical Report

Printed 02/18/15 15:44 DE36

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE B
 259 NAJOLAS ROAD
 RE: BTR HAMPSTEAD WWTP
 MILLERSVILLE, MD 21108

Order Number: L5410998
 Project Name: BTR HAMPSTEAD WWTP
 Receive Date: 02-03-2015
 Client Code: MES_A
 Project Location: BTR HAMPSTEAD WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
 Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID L5410998-1 Sample Description BTR 001 GRAB
 Received Date/Time/Temp 02/03/15 04:30pm 1.2 C Iced (Y/N): Y
 Samp. Date/Time/Temp 02/03/15 08:45am NA C Sampled by Customer

Satellite Received Temp 1.5 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
GENERAL CHEMISTRY							
Hexane Ext. Material-HEM (oil+grease)	ND	5.00	mg/l	1664B HEM	1		02/04/15 06:20PM RSK
Total Suspended Solids (Delaware)	6.80	4.00	mg/l	SM 2540D	1		02/09/15 10:59AM MS3
Biochemical Oxygen Demand, 5 Day (DE)	2.00	2.00	mg/l	SM 5210B	2		02/04/15 10:15AM SKJ
GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES							
1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		02/13/15 08:24PM JAD
Tetrachloroethene	ND	1.00	ug/l	EPA 624	1		02/13/15 08:24PM JAD
Trichloroethene	ND	1.00	ug/l	EPA 624	1		02/13/15 08:24PM JAD

Sample ID L5410998-2 Sample Description BTR 001 COMP
 Received Date/Time 02/03/15 04:30pm
 Samp. Date/Time/Temp 02/03/15 08:45am NA C Sampled by Customer

Satellite Received Temp 1.5 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

PIN: 17237

Serial Number: 4390445

QC Laboratories

Analytical Report

Printed 02/18/15 11:08 DE36

CHERYL GRIFFIN
MARYLAND ENVIRONMENTAL SERVICE B
259 NAJOLES ROAD
RE: BTR HAMPSTEAD WWTP
MILLERSVILLE, MD 21108

Order Number: L5454858
Project Name: BTR HAMPSTEAD WWTP
Receive Date: 02-16-2015
Client Code: MES_A
Project Location: BTR HAMPSTEAD WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No: Inv. No: MES_AL0341
PWSID No:

Sample ID Sample Description Samp. Date/Time/Temp Sampled by
L5454858-1 BTR 001 02/03/15 09:10am NA C Customer
Received Date/Time 02/16/15 01:30pm

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY							
E. Coli, MPN Cel(Delaware)	42.9		MPN/100ml	SM 9221F			02/03/15 02:19PM SUB

Sample Comments:

L5454858-1 :
E. coli was analyzed by Chesapeake Environmental Lab, Inc in Stevensville, MD.



PIN: 17237

Serial Number: 4388025

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE B
 259 NAJOLAS ROAD
 RE: BTR HAMPSTEAD WWTP
 MILLERSVILLE, MD 21108

Order Number: L5454856
 Project Name: BTR HAMPSTEAD WWTP
 Receive Date: 02-16-2015
 Client Code: MES_A
 Project Location: BTR HAMPSTEAD WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
 Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID	Sample Description			Samp. Date/Time/Temp			Sampled by
L5454856-1	BTR OUTFALL 101			02/03/15 09:20am NA C			Customer
		Received Date/Time 02/16/15 12:45pm					
Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY							
E. Coli, MPN Cel(Delaware)	<1.0		MPN/100ml	SM 9221F			02/03/15 02:21PM SUB

Sample Comments:
 L5454856-1 :
 E. coli was analyzed by Chesapeake Environmental Lab, Inc in Stevensville, MD.



QC Laboratories

Analytical Report

Printed 03/30/15 16:27 DE36

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE B
 259 NAJOLES ROAD
 RE: BTR HAMPSTEAD WWTP
 MILLERSVILLE, MD 21108

Order Number: L5451047
 Project Name: BTR HAMPSTEAD WWTP
 Receive Date: 03-03-2015
 Client Code: MES_A
 Project Location: BTR HAMPSTEAD WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
 Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID L5451047-1 Sample Description BTR 001 GRAB
 Satellite Received Temp 3.5 C Iced (Y/N): Y
 Received Date/Time/Temp 03/03/15 04:30pm 2.1 C Iced (Y/N): Y
 Samp. Date/Time/Temp 03/03/15 09:11am NA C Sampled by Customer

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
GENERAL CHEMISTRY							
Hexane Ext. Material-HEM (oil+grease)	ND	5.00	mg/l	1664B HEM	1		03/16/15 09:45AM RSK
Total Suspended Solids (Delaware)	15.5	5.00	mg/l	SM 2540D	1		03/05/15 10:32AM MS3
Biochemical Oxygen Demand, 5 Day (DE)	4.00	2.00	mg/l	SM 5210B	2		03/04/15 08:20AM SKJ
GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES							
1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		03/09/15 10:44PM JAD
Tetrachloroethene	ND	1.00	ug/l	EPA 624	1		03/09/15 10:44PM JAD
Trichloroethene	ND	1.00	ug/l	EPA 624	1		03/09/15 10:44PM JAD

Sample ID L5451047-2 Sample Description BTR 001 COMP
 Satellite Received Temp 3.5 C Iced (Y/N): Y
 Received Date/Time/Temp 03/03/15 04:30pm 3.5 C Iced (Y/N): Y
 Samp. Date/Time/Temp 03/03/15 09:11am NA C Sampled by Customer

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
GENERAL CHEMISTRY							
Nitrate/nitrite, total as N (Delaware)	3.51	0.500	mg/l	EPA 300.0	10		03/03/15 08:53PM SLD
Kjeldahl nitrogen, as N (Delaware)	2.42	0.200	mg/l	EPA 351.2	1		03/23/15 12:19PM ALW
Phosphorus total as P (Delaware)	0.151	0.0500	mg/l	EPA 365.4	1		03/27/15 11:57AM ALW
Ammonia, as N (Delaware)	ND	0.200	mg/l	SM 4500NH3-G	1		03/05/15 11:44AM ALW

PIN: 17237

Serial Number: 4478430

QC Laboratories

Analytical Report

Printed 03/16/15 10:54 DE36

CHERYL GRIFFIN
MARYLAND ENVIRONMENTAL SERVICE B
259 NAJOLLES ROAD
RE: BTR HAMPSTEAD WWTP
MILLERSVILLE, MD 21108

Order Number: L5493354
Project Name: BTR HAMPSTEAD WWTP
Receive Date: 03-03-2015
Client Code: MES_A
Project Location: BTR HAMPSTEAD WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No: Inv. No: MES_AL0341
PWSID No:

Sample ID Sample Description Samp. Date/Time/Temp Sampled by
L5493354-1 BLACK & DECKER 001 03/03/15 09:05am NA C Customer
Received Date/Time 03/03/15 01:50pm

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY							
E. Coli, MPN Cel(Delaware)	12.4		MPN/100ml	SM 9223B			03/03/15 02:51PM SUB

Sample Comments:

L5493354-1 :
E. coli was analyzed by Chesapeake Environmental Lab, Inc in Stevensville, MD.



PIN: 17237

Serial Number: 4442525

QC Laboratories

Analytical Report

Printed 03/16/15 10:59 DE36

CHERYL GRIFFIN
MARYLAND ENVIRONMENTAL SERVICE B
259 NAJOLAS ROAD
RE: BTR HAMPSTEAD WWTP
MILLERSVILLE, MD 21108

Order Number: L5493767
Project Name: BTR HAMPSTEAD WWTP
Receive Date: 03-10-2015
Client Code: MES_A
Project Location: BTR HAMPSTEAD WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BTR WWTP, BTR HAMPSTEAD WWTP

P.O. No: Inv. No: MES_AL0341
 PWSID No:

Sample ID Sample Description Samp. Date/Time/Temp Sampled by
L5493767-1 BLACK & DECKER 101 03/10/15 09:49am NA C Customer
 Received Date/Time 03/10/15 01:15pm

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY							
E. Coli, MPN Cel(Delaware)	<1.0		MPN/100ml	SM 9223B			03/10/15 02:20PM SUB

Sample Comments:

L5493767-1 :
E. coli was analyzed by Chesapeake Environmental Lab, Inc in Stevensville, MD.



PIN: 17237

Serial Number: 4442605

APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(FEBRUARY 2015)



TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.
TestAmerica Chicago
2417 Bond Street
University Park, IL 60484
Tel: (708)534-5200

TestAmerica Job ID: 500-92688-1
Client Project/Site: Black and Decker

For:
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, Pennsylvania 19380

Attn: Mr. Tom Cornuet



Authorized for release by:
3/9/2015 8:32:43 AM

Richard Wright, Senior Project Manager
(708)534-5200
richard.wright@testamericainc.com

LINKS

Review your project
results through
Total Access

Have a Question?

 **Ask
The
Expert**

Visit us at:
www.testamericainc.com

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.



Table of Contents

Cover Page	1
Table of Contents	2
Case Narrative	3
Detection Summary	4
Method Summary	7
Sample Summary	8
Client Sample Results	9
Definitions	61
QC Association	62
Surrogate Summary	63
QC Sample Results	64
Chronicle	80
Certification Summary	85
Chain of Custody	86
Receipt Checklists	89



Case Narrative

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Job ID: 500-92688-1

Laboratory: TestAmerica Chicago

Narrative

Job Narrative
500-92688-1

Comments

No additional comments.

Receipt

The samples were received on 2/27/2015 11:05 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 4.0° C.

GC/MS VOA

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.



Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-2

Lab Sample ID: 500-92688-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	3.8		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	180		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	51		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-3

Lab Sample ID: 500-92688-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	1.9		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	37		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	1.6		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-4

Lab Sample ID: 500-92688-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Tetrachloroethene	8.3		1.0	0.17	ug/L	1		8260B	Total/NA
Trichloroethene - DL	340		2.5	0.95	ug/L	5		8260B	Total/NA

Client Sample ID: EW-5

Lab Sample ID: 500-92688-4

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	110		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	4.5		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-6

Lab Sample ID: 500-92688-5

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	6.2		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	11		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-7

Lab Sample ID: 500-92688-6

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethane	0.63	J	1.0	0.19	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	6.7		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	4.7		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	11		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-8

Lab Sample ID: 500-92688-7

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethane	0.81	J	1.0	0.19	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	25		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	7.3		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	70		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-9

Lab Sample ID: 500-92688-8

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.61		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	140		1.0	0.17	ug/L	1		8260B	Total/NA

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-9 Dup

Lab Sample ID: 500-92688-9

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.47	J	0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	100		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-10

Lab Sample ID: 500-92688-10

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Toluene	0.44	J	0.50	0.11	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-1A

Lab Sample ID: 500-92688-11

No Detections.

Client Sample ID: RFW-1B

Lab Sample ID: 500-92688-12

No Detections.

Client Sample ID: RFW-2A

Lab Sample ID: 500-92688-13

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.67		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-2B

Lab Sample ID: 500-92688-14

No Detections.

Client Sample ID: RFW-3B

Lab Sample ID: 500-92688-15

No Detections.

Client Sample ID: RFW-4A

Lab Sample ID: 500-92688-16

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.61	J	1.0	0.12	ug/L	1		8260B	Total/NA
Chloroform	0.54	J	1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	27		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	17		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-4A Dup

Lab Sample ID: 500-92688-17

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.68	J	1.0	0.12	ug/L	1		8260B	Total/NA
Chloroform	0.52	J	1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	25		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	15		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-4B

Lab Sample ID: 500-92688-18

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	2.8		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	18		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	36		1.0	0.17	ug/L	1		8260B	Total/NA

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1



Client Sample ID: RFW-6

Lab Sample ID: 500-92688-19

No Detections.

Client Sample ID: RFW-7

Lab Sample ID: 500-92688-20

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Toluene	0.32	J	0.50	0.11	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-9

Lab Sample ID: 500-92688-21

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethene	0.58	J	1.0	0.31	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	8.3		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	8.2		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	2.7		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-11B

Lab Sample ID: 500-92688-22

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	2.6		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-12B

Lab Sample ID: 500-92688-23

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	190		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	7.3		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-13

Lab Sample ID: 500-92688-24

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	3.4		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	17		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-17

Lab Sample ID: 500-92688-25

No Detections.

Client Sample ID: Trip Blank

Lab Sample ID: 500-92688-26

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Acetone	7.9		5.0	1.3	ug/L	1		8260B	Total/NA
Methylene Chloride	1.1	J	5.0	0.68	ug/L	1		8260B	Total/NA
Toluene	0.71		0.50	0.11	ug/L	1		8260B	Total/NA
m&p-Xylene	0.31	J	1.0	0.26	ug/L	1		8260B	Total/NA

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Method Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Method	Method Description	Protocol	Laboratory
8260B	VOC	SW846	TAL CHI

Protocol References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200



Sample Summary

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
500-92688-1	EW-2	Water	02/26/15 12:15	02/27/15 11:05
500-92688-2	EW-3	Water	02/26/15 11:10	02/27/15 11:05
500-92688-3	EW-4	Water	02/26/15 11:00	02/27/15 11:05
500-92688-4	EW-5	Water	02/25/15 09:15	02/27/15 11:05
500-92688-5	EW-6	Water	02/25/15 14:00	02/27/15 11:05
500-92688-6	EW-7	Water	02/25/15 14:15	02/27/15 11:05
500-92688-7	EW-8	Water	02/25/15 14:25	02/27/15 11:05
500-92688-8	EW-9	Water	02/25/15 14:35	02/27/15 11:05
500-92688-9	EW-9 Dup	Water	02/25/15 14:35	02/27/15 11:05
500-92688-10	EW-10	Water	02/26/15 12:40	02/27/15 11:05
500-92688-11	RFW-1A	Water	02/25/15 09:10	02/27/15 11:05
500-92688-12	RFW-1B	Water	02/25/15 17:30	02/27/15 11:05
500-92688-13	RFW-2A	Water	02/25/15 10:35	02/27/15 11:05
500-92688-14	RFW-2B	Water	02/25/15 10:50	02/27/15 11:05
500-92688-15	RFW-3B	Water	02/25/15 14:20	02/27/15 11:05
500-92688-16	RFW-4A	Water	02/26/15 08:15	02/27/15 11:05
500-92688-17	RFW-4A Dup	Water	02/26/15 08:15	02/27/15 11:05
500-92688-18	RFW-4B	Water	02/26/15 08:40	02/27/15 11:05
500-92688-19	RFW-6	Water	02/25/15 11:40	02/27/15 11:05
500-92688-20	RFW-7	Water	02/25/15 13:10	02/27/15 11:05
500-92688-21	RFW-9	Water	02/25/15 12:30	02/27/15 11:05
500-92688-22	RFW-11B	Water	02/26/15 10:50	02/27/15 11:05
500-92688-23	RFW-12B	Water	02/26/15 13:00	02/27/15 11:05
500-92688-24	RFW-13	Water	02/25/15 15:30	02/27/15 11:05
500-92688-25	RFW-17	Water	02/25/15 15:05	02/27/15 11:05
500-92688-26	Trip Blank	Water	02/25/15 08:00	02/27/15 11:05



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-2

Lab Sample ID: 500-92688-1

Date Collected: 02/26/15 12:15

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 12:04	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 12:04	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 12:04	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 12:04	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 12:04	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 12:04	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 12:04	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 12:04	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 12:04	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 12:04	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 12:04	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 12:04	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			03/03/15 12:04	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 12:04	1
cis-1,2-Dichloroethene	3.8		1.0	0.12	ug/L			03/03/15 12:04	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 12:04	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 12:04	1
Chloroform	<1.0		1.0	0.20	ug/L			03/03/15 12:04	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 12:04	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 12:04	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 12:04	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 12:04	1
Trichloroethene	180		0.50	0.19	ug/L			03/03/15 12:04	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 12:04	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 12:04	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 12:04	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 12:04	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 12:04	1
Toluene	<0.50		0.50	0.11	ug/L			03/03/15 12:04	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 12:04	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 12:04	1
Tetrachloroethene	51		1.0	0.17	ug/L			03/03/15 12:04	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 12:04	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 12:04	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 12:04	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 12:04	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 12:04	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 12:04	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 12:04	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 12:04	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 12:04	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 12:04	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 12:04	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 12:04	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 12:04	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 12:04	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 12:04	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 12:04	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 12:04	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-2

Lab Sample ID: 500-92688-1

Date Collected: 02/26/15 12:15

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 12:04	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 12:04	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 12:04	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 12:04	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 12:04	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 12:04	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 12:04	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 12:04	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 12:04	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 12:04	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 12:04	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 12:04	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 12:04	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 12:04	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 12:04	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	96		75 - 125		03/03/15 12:04	1
Toluene-d8 (Surr)	97		75 - 120		03/03/15 12:04	1
4-Bromofluorobenzene (Surr)	95		75 - 120		03/03/15 12:04	1
Dibromofluoromethane	85		75 - 120		03/03/15 12:04	1



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-3

Lab Sample ID: 500-92688-2

Date Collected: 02/26/15 11:10

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 12:32	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 12:32	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 12:32	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 12:32	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 12:32	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 12:32	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 12:32	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 12:32	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 12:32	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 12:32	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 12:32	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 12:32	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			03/03/15 12:32	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 12:32	1
cis-1,2-Dichloroethene	1.9		1.0	0.12	ug/L			03/03/15 12:32	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 12:32	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 12:32	1
Chloroform	<1.0		1.0	0.20	ug/L			03/03/15 12:32	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 12:32	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 12:32	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 12:32	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 12:32	1
Trichloroethene	37		0.50	0.19	ug/L			03/03/15 12:32	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 12:32	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 12:32	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 12:32	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 12:32	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 12:32	1
Toluene	<0.50		0.50	0.11	ug/L			03/03/15 12:32	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 12:32	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 12:32	1
Tetrachloroethene	1.6		1.0	0.17	ug/L			03/03/15 12:32	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 12:32	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 12:32	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 12:32	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 12:32	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 12:32	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 12:32	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 12:32	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 12:32	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 12:32	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 12:32	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 12:32	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 12:32	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 12:32	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 12:32	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 12:32	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 12:32	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 12:32	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-3

Lab Sample ID: 500-92688-2

Date Collected: 02/26/15 11:10

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 12:32	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 12:32	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 12:32	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 12:32	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 12:32	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 12:32	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 12:32	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 12:32	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 12:32	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 12:32	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 12:32	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 12:32	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 12:32	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 12:32	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 12:32	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	95		75 - 125		03/03/15 12:32	1
Toluene-d8 (Surr)	97		75 - 120		03/03/15 12:32	1
4-Bromofluorobenzene (Surr)	96		75 - 120		03/03/15 12:32	1
Dibromofluoromethane	85		75 - 120		03/03/15 12:32	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-4

Lab Sample ID: 500-92688-3

Date Collected: 02/26/15 11:00

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 13:00	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 13:00	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 13:00	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 13:00	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 13:00	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 13:00	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 13:00	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 13:00	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 13:00	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 13:00	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 13:00	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 13:00	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			03/03/15 13:00	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 13:00	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			03/03/15 13:00	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 13:00	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 13:00	1
Chloroform	<1.0		1.0	0.20	ug/L			03/03/15 13:00	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 13:00	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 13:00	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 13:00	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 13:00	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 13:00	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 13:00	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 13:00	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 13:00	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 13:00	1
Toluene	<0.50		0.50	0.11	ug/L			03/03/15 13:00	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 13:00	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 13:00	1
Tetrachloroethene	8.3		1.0	0.17	ug/L			03/03/15 13:00	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 13:00	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 13:00	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 13:00	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 13:00	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 13:00	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 13:00	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 13:00	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 13:00	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 13:00	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 13:00	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 13:00	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 13:00	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 13:00	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 13:00	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 13:00	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 13:00	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 13:00	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 13:00	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-4

Lab Sample ID: 500-92688-3

Date Collected: 02/26/15 11:00

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 13:00	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 13:00	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 13:00	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 13:00	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 13:00	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 13:00	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 13:00	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 13:00	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 13:00	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 13:00	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 13:00	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 13:00	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 13:00	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 13:00	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	97		75 - 125		03/03/15 13:00	1
Toluene-d8 (Surr)	97		75 - 120		03/03/15 13:00	1
4-Bromofluorobenzene (Surr)	95		75 - 120		03/03/15 13:00	1
Dibromofluoromethane	87		75 - 120		03/03/15 13:00	1

Method: 8260B - VOC - DL

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Trichloroethene	340		2.5	0.95	ug/L			03/03/15 13:28	5

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	98		75 - 125		03/03/15 13:28	5
Toluene-d8 (Surr)	97		75 - 120		03/03/15 13:28	5
4-Bromofluorobenzene (Surr)	94		75 - 120		03/03/15 13:28	5
Dibromofluoromethane	88		75 - 120		03/03/15 13:28	5

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-5

Lab Sample ID: 500-92688-4

Date Collected: 02/25/15 09:15

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 13:56	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 13:56	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 13:56	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 13:56	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 13:56	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 13:56	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 13:56	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 13:56	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 13:56	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 13:56	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 13:56	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 13:56	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			03/03/15 13:56	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 13:56	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			03/03/15 13:56	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 13:56	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 13:56	1
Chloroform	<1.0		1.0	0.20	ug/L			03/03/15 13:56	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 13:56	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 13:56	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 13:56	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 13:56	1
Trichloroethene	110		0.50	0.19	ug/L			03/03/15 13:56	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 13:56	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 13:56	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 13:56	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 13:56	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 13:56	1
Toluene	<0.50		0.50	0.11	ug/L			03/03/15 13:56	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 13:56	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 13:56	1
Tetrachloroethene	4.5		1.0	0.17	ug/L			03/03/15 13:56	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 13:56	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 13:56	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 13:56	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 13:56	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 13:56	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 13:56	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 13:56	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 13:56	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 13:56	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 13:56	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 13:56	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 13:56	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 13:56	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 13:56	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 13:56	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 13:56	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 13:56	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-5

Lab Sample ID: 500-92688-4

Date Collected: 02/25/15 09:15

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 13:56	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 13:56	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 13:56	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 13:56	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 13:56	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 13:56	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 13:56	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 13:56	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 13:56	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 13:56	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 13:56	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 13:56	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 13:56	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 13:56	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 13:56	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	94		75 - 125		03/03/15 13:56	1
Toluene-d8 (Surr)	98		75 - 120		03/03/15 13:56	1
4-Bromofluorobenzene (Surr)	96		75 - 120		03/03/15 13:56	1
Dibromofluoromethane	86		75 - 120		03/03/15 13:56	1



TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-6

Lab Sample ID: 500-92688-5

Date Collected: 02/25/15 14:00

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 14:24	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 14:24	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 14:24	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 14:24	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 14:24	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 14:24	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 14:24	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 14:24	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 14:24	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 14:24	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 14:24	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 14:24	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			03/03/15 14:24	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 14:24	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			03/03/15 14:24	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 14:24	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 14:24	1
Chloroform	<1.0		1.0	0.20	ug/L			03/03/15 14:24	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 14:24	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 14:24	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 14:24	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 14:24	1
Trichloroethene	6.2		0.50	0.19	ug/L			03/03/15 14:24	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 14:24	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 14:24	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 14:24	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 14:24	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 14:24	1
Toluene	<0.50		0.50	0.11	ug/L			03/03/15 14:24	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 14:24	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 14:24	1
Tetrachloroethene	11		1.0	0.17	ug/L			03/03/15 14:24	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 14:24	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 14:24	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 14:24	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 14:24	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 14:24	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 14:24	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 14:24	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 14:24	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 14:24	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 14:24	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 14:24	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 14:24	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 14:24	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 14:24	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 14:24	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 14:24	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 14:24	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-6

Lab Sample ID: 500-92688-5

Date Collected: 02/25/15 14:00

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 14:24	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 14:24	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 14:24	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 14:24	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 14:24	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 14:24	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 14:24	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 14:24	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 14:24	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 14:24	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 14:24	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 14:24	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 14:24	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 14:24	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 14:24	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	98		75 - 125		03/03/15 14:24	1
Toluene-d8 (Surr)	98		75 - 120		03/03/15 14:24	1
4-Bromofluorobenzene (Surr)	95		75 - 120		03/03/15 14:24	1
Dibromofluoromethane	88		75 - 120		03/03/15 14:24	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-7

Lab Sample ID: 500-92688-6

Date Collected: 02/25/15 14:15

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 14:51	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 14:51	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 14:51	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 14:51	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 14:51	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 14:51	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 14:51	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 14:51	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 14:51	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 14:51	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 14:51	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 14:51	1
1,1-Dichloroethane	0.63	J	1.0	0.19	ug/L			03/03/15 14:51	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 14:51	1
cis-1,2-Dichloroethene	6.7		1.0	0.12	ug/L			03/03/15 14:51	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 14:51	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 14:51	1
Chloroform	<1.0		1.0	0.20	ug/L			03/03/15 14:51	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 14:51	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 14:51	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 14:51	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 14:51	1
Trichloroethene	4.7		0.50	0.19	ug/L			03/03/15 14:51	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 14:51	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 14:51	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 14:51	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 14:51	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 14:51	1
Toluene	<0.50		0.50	0.11	ug/L			03/03/15 14:51	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 14:51	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 14:51	1
Tetrachloroethene	11		1.0	0.17	ug/L			03/03/15 14:51	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 14:51	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 14:51	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 14:51	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 14:51	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 14:51	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 14:51	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 14:51	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 14:51	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 14:51	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 14:51	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 14:51	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 14:51	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 14:51	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 14:51	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 14:51	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 14:51	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 14:51	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-7

Lab Sample ID: 500-92688-6

Date Collected: 02/25/15 14:15

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 14:51	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 14:51	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 14:51	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 14:51	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 14:51	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 14:51	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 14:51	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 14:51	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 14:51	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 14:51	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 14:51	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 14:51	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 14:51	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 14:51	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 14:51	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	98		75 - 125		03/03/15 14:51	1
Toluene-d8 (Surr)	96		75 - 120		03/03/15 14:51	1
4-Bromofluorobenzene (Surr)	95		75 - 120		03/03/15 14:51	1
Dibromofluoromethane	88		75 - 120		03/03/15 14:51	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-8
Date Collected: 02/25/15 14:25
Date Received: 02/27/15 11:05

Lab Sample ID: 500-92688-7
Matrix: Water

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 15:20	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 15:20	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 15:20	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 15:20	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 15:20	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 15:20	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 15:20	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 15:20	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 15:20	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 15:20	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 15:20	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 15:20	1
1,1-Dichloroethane	0.81	J	1.0	0.19	ug/L			03/03/15 15:20	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 15:20	1
cis-1,2-Dichloroethene	25		1.0	0.12	ug/L			03/03/15 15:20	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 15:20	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 15:20	1
Chloroform	<1.0		1.0	0.20	ug/L			03/03/15 15:20	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 15:20	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 15:20	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 15:20	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 15:20	1
Trichloroethene	7.3		0.50	0.19	ug/L			03/03/15 15:20	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 15:20	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 15:20	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 15:20	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 15:20	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 15:20	1
Toluene	<0.50		0.50	0.11	ug/L			03/03/15 15:20	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 15:20	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 15:20	1
Tetrachloroethene	70		1.0	0.17	ug/L			03/03/15 15:20	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 15:20	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 15:20	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 15:20	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 15:20	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 15:20	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 15:20	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 15:20	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 15:20	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 15:20	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 15:20	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 15:20	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 15:20	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 15:20	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 15:20	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 15:20	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 15:20	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 15:20	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-8

Lab Sample ID: 500-92688-7

Date Collected: 02/25/15 14:25

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 15:20	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 15:20	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 15:20	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 15:20	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 15:20	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 15:20	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 15:20	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 15:20	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 15:20	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 15:20	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 15:20	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 15:20	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 15:20	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 15:20	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 15:20	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	97		75 - 125		03/03/15 15:20	1
Toluene-d8 (Surr)	97		75 - 120		03/03/15 15:20	1
4-Bromofluorobenzene (Surr)	95		75 - 120		03/03/15 15:20	1
Dibromofluoromethane	88		75 - 120		03/03/15 15:20	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-9

Lab Sample ID: 500-92688-8

Date Collected: 02/25/15 14:35

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 15:48	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 15:48	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 15:48	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 15:48	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 15:48	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 15:48	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 15:48	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 15:48	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 15:48	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 15:48	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 15:48	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 15:48	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			03/03/15 15:48	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 15:48	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			03/03/15 15:48	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 15:48	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 15:48	1
Chloroform	<1.0		1.0	0.20	ug/L			03/03/15 15:48	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 15:48	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 15:48	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 15:48	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 15:48	1
Trichloroethene	0.61		0.50	0.19	ug/L			03/03/15 15:48	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 15:48	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 15:48	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 15:48	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 15:48	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 15:48	1
Toluene	<0.50		0.50	0.11	ug/L			03/03/15 15:48	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 15:48	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 15:48	1
Tetrachloroethene	140		1.0	0.17	ug/L			03/03/15 15:48	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 15:48	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 15:48	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 15:48	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 15:48	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 15:48	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 15:48	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 15:48	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 15:48	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 15:48	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 15:48	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 15:48	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 15:48	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 15:48	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 15:48	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 15:48	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 15:48	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 15:48	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-9

Lab Sample ID: 500-92688-8

Date Collected: 02/25/15 14:35

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 15:48	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 15:48	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 15:48	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 15:48	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 15:48	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 15:48	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 15:48	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 15:48	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 15:48	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 15:48	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 15:48	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 15:48	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 15:48	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 15:48	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 15:48	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	100		75 - 125		03/03/15 15:48	1
Toluene-d8 (Surr)	102		75 - 120		03/03/15 15:48	1
4-Bromofluorobenzene (Surr)	103		75 - 120		03/03/15 15:48	1
Dibromofluoromethane	91		75 - 120		03/03/15 15:48	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-9 Dup

Lab Sample ID: 500-92688-9

Date Collected: 02/25/15 14:35

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 16:16	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 16:16	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 16:16	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 16:16	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 16:16	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 16:16	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 16:16	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 16:16	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 16:16	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 16:16	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 16:16	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 16:16	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			03/03/15 16:16	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 16:16	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			03/03/15 16:16	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 16:16	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 16:16	1
Chloroform	<1.0		1.0	0.20	ug/L			03/03/15 16:16	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 16:16	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 16:16	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 16:16	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 16:16	1
Trichloroethene	0.47	J	0.50	0.19	ug/L			03/03/15 16:16	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 16:16	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 16:16	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 16:16	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 16:16	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 16:16	1
Toluene	<0.50		0.50	0.11	ug/L			03/03/15 16:16	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 16:16	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 16:16	1
Tetrachloroethene	100		1.0	0.17	ug/L			03/03/15 16:16	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 16:16	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 16:16	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 16:16	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 16:16	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 16:16	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 16:16	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 16:16	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 16:16	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 16:16	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 16:16	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 16:16	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 16:16	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 16:16	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 16:16	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 16:16	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 16:16	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 16:16	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-9 Dup

Lab Sample ID: 500-92688-9

Date Collected: 02/25/15 14:35

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 16:16	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 16:16	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 16:16	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 16:16	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 16:16	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 16:16	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 16:16	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 16:16	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 16:16	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 16:16	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 16:16	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 16:16	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 16:16	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 16:16	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 16:16	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	97		75 - 125		03/03/15 16:16	1
Toluene-d8 (Surr)	97		75 - 120		03/03/15 16:16	1
4-Bromofluorobenzene (Surr)	98		75 - 120		03/03/15 16:16	1
Dibromofluoromethane	89		75 - 120		03/03/15 16:16	1



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-10

Lab Sample ID: 500-92688-10

Date Collected: 02/26/15 12:40

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 16:44	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 16:44	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 16:44	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 16:44	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 16:44	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 16:44	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 16:44	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 16:44	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 16:44	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 16:44	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 16:44	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 16:44	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			03/03/15 16:44	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 16:44	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			03/03/15 16:44	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 16:44	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 16:44	1
Chloroform	<1.0		1.0	0.20	ug/L			03/03/15 16:44	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 16:44	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 16:44	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 16:44	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 16:44	1
Trichloroethene	<0.50		0.50	0.19	ug/L			03/03/15 16:44	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 16:44	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 16:44	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 16:44	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 16:44	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 16:44	1
Toluene	0.44	J	0.50	0.11	ug/L			03/03/15 16:44	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 16:44	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 16:44	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			03/03/15 16:44	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 16:44	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 16:44	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 16:44	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 16:44	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 16:44	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 16:44	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 16:44	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 16:44	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 16:44	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 16:44	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 16:44	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 16:44	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 16:44	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 16:44	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 16:44	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 16:44	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 16:44	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: EW-10

Lab Sample ID: 500-92688-10

Date Collected: 02/26/15 12:40

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 16:44	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 16:44	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 16:44	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 16:44	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 16:44	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 16:44	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 16:44	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 16:44	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 16:44	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 16:44	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 16:44	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 16:44	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 16:44	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 16:44	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 16:44	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	95		75 - 125					03/03/15 16:44	1
Toluene-d8 (Surr)	98		75 - 120					03/03/15 16:44	1
4-Bromofluorobenzene (Surr)	96		75 - 120					03/03/15 16:44	1
Dibromofluoromethane	86		75 - 120					03/03/15 16:44	1



TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-92688-11

Date Collected: 02/25/15 09:10

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 17:13	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 17:13	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 17:13	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 17:13	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 17:13	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 17:13	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 17:13	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 17:13	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 17:13	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 17:13	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 17:13	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 17:13	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			03/03/15 17:13	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 17:13	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			03/03/15 17:13	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 17:13	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 17:13	1
Chloroform	<1.0		1.0	0.20	ug/L			03/03/15 17:13	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 17:13	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 17:13	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 17:13	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 17:13	1
Trichloroethene	<0.50		0.50	0.19	ug/L			03/03/15 17:13	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 17:13	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 17:13	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 17:13	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 17:13	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 17:13	1
Toluene	<0.50		0.50	0.11	ug/L			03/03/15 17:13	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 17:13	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 17:13	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			03/03/15 17:13	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 17:13	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 17:13	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 17:13	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 17:13	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 17:13	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 17:13	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 17:13	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 17:13	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 17:13	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 17:13	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 17:13	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 17:13	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 17:13	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 17:13	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 17:13	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 17:13	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 17:13	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-92688-11

Date Collected: 02/25/15 09:10

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 17:13	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 17:13	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 17:13	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 17:13	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 17:13	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 17:13	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 17:13	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 17:13	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 17:13	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 17:13	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 17:13	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 17:13	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 17:13	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 17:13	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 17:13	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		75 - 125		03/03/15 17:13	1
Toluene-d8 (Surr)	99		75 - 120		03/03/15 17:13	1
4-Bromofluorobenzene (Surr)	102		75 - 120		03/03/15 17:13	1
Dibromofluoromethane	94		75 - 120		03/03/15 17:13	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-92688-12

Date Collected: 02/25/15 17:30

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 17:40	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 17:40	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 17:40	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 17:40	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 17:40	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 17:40	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 17:40	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 17:40	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 17:40	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 17:40	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 17:40	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 17:40	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			03/03/15 17:40	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 17:40	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			03/03/15 17:40	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 17:40	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 17:40	1
Chloroform	<1.0		1.0	0.20	ug/L			03/03/15 17:40	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 17:40	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 17:40	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 17:40	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 17:40	1
Trichloroethene	<0.50		0.50	0.19	ug/L			03/03/15 17:40	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 17:40	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 17:40	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 17:40	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 17:40	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 17:40	1
Toluene	<0.50		0.50	0.11	ug/L			03/03/15 17:40	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 17:40	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 17:40	1
Tetrachloroethane	<1.0		1.0	0.17	ug/L			03/03/15 17:40	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 17:40	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 17:40	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 17:40	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 17:40	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 17:40	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 17:40	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 17:40	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 17:40	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 17:40	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 17:40	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 17:40	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 17:40	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 17:40	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 17:40	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 17:40	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 17:40	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 17:40	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-92688-12

Date Collected: 02/25/15 17:30

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 17:40	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 17:40	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 17:40	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 17:40	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 17:40	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 17:40	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 17:40	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 17:40	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 17:40	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 17:40	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 17:40	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 17:40	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 17:40	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 17:40	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 17:40	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	99		75 - 125		03/03/15 17:40	1
Toluene-d8 (Surr)	96		75 - 120		03/03/15 17:40	1
4-Bromofluorobenzene (Surr)	98		75 - 120		03/03/15 17:40	1
Dibromofluoromethane	91		75 - 120		03/03/15 17:40	1



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-92688-13

Date Collected: 02/25/15 10:35

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 18:08	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 18:08	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 18:08	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 18:08	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 18:08	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 18:08	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 18:08	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 18:08	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 18:08	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 18:08	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 18:08	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 18:08	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			03/03/15 18:08	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 18:08	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			03/03/15 18:08	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 18:08	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 18:08	1
Chloroform	<1.0		1.0	0.20	ug/L			03/03/15 18:08	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 18:08	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 18:08	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 18:08	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 18:08	1
Trichloroethene	0.67		0.50	0.19	ug/L			03/03/15 18:08	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 18:08	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 18:08	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 18:08	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 18:08	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 18:08	1
Toluene	<0.50		0.50	0.11	ug/L			03/03/15 18:08	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 18:08	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 18:08	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			03/03/15 18:08	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 18:08	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 18:08	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 18:08	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 18:08	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 18:08	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 18:08	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 18:08	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 18:08	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 18:08	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 18:08	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 18:08	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 18:08	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 18:08	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 18:08	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 18:08	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 18:08	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 18:08	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-92688-13

Date Collected: 02/25/15 10:35

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 18:08	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 18:08	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 18:08	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 18:08	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 18:08	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 18:08	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 18:08	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 18:08	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 18:08	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 18:08	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 18:08	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 18:08	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 18:08	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 18:08	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 18:08	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	101		75 - 125		03/03/15 18:08	1
Toluene-d8 (Surr)	100		75 - 120		03/03/15 18:08	1
4-Bromofluorobenzene (Surr)	97		75 - 120		03/03/15 18:08	1
Dibromofluoromethane	89		75 - 120		03/03/15 18:08	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-92688-14

Date Collected: 02/25/15 10:50

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 18:36	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 18:36	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 18:36	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 18:36	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 18:36	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 18:36	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 18:36	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 18:36	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 18:36	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 18:36	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 18:36	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 18:36	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			03/03/15 18:36	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 18:36	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			03/03/15 18:36	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 18:36	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 18:36	1
Chloroform	<1.0		1.0	0.20	ug/L			03/03/15 18:36	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 18:36	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 18:36	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 18:36	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 18:36	1
Trichloroethene	<0.50		0.50	0.19	ug/L			03/03/15 18:36	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 18:36	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 18:36	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 18:36	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 18:36	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 18:36	1
Toluene	<0.50		0.50	0.11	ug/L			03/03/15 18:36	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 18:36	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 18:36	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			03/03/15 18:36	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 18:36	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 18:36	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 18:36	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 18:36	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 18:36	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 18:36	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 18:36	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 18:36	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 18:36	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 18:36	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 18:36	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 18:36	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 18:36	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 18:36	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 18:36	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 18:36	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 18:36	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-92688-14

Date Collected: 02/25/15 10:50

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 18:36	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 18:36	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 18:36	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 18:36	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 18:36	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 18:36	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 18:36	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 18:36	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 18:36	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 18:36	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 18:36	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 18:36	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 18:36	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 18:36	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 18:36	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	99		75 - 125		03/03/15 18:36	1
Toluene-d8 (Surr)	96		75 - 120		03/03/15 18:36	1
4-Bromofluorobenzene (Surr)	96		75 - 120		03/03/15 18:36	1
Dibromofluoromethane	89		75 - 120		03/03/15 18:36	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-92688-15

Date Collected: 02/25/15 14:20

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 19:04	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 19:04	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 19:04	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 19:04	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 19:04	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 19:04	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 19:04	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 19:04	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 19:04	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 19:04	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 19:04	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 19:04	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			03/03/15 19:04	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 19:04	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			03/03/15 19:04	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 19:04	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 19:04	1
Chloroform	<1.0		1.0	0.20	ug/L			03/03/15 19:04	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 19:04	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 19:04	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 19:04	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 19:04	1
Trichloroethene	<0.50		0.50	0.19	ug/L			03/03/15 19:04	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 19:04	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 19:04	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 19:04	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 19:04	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 19:04	1
Toluene	<0.50		0.50	0.11	ug/L			03/03/15 19:04	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 19:04	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 19:04	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			03/03/15 19:04	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 19:04	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 19:04	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 19:04	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 19:04	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 19:04	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 19:04	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 19:04	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 19:04	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 19:04	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 19:04	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 19:04	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 19:04	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 19:04	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 19:04	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 19:04	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 19:04	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 19:04	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-92688-15

Date Collected: 02/25/15 14:20

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 19:04	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 19:04	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 19:04	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 19:04	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 19:04	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 19:04	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 19:04	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 19:04	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 19:04	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 19:04	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 19:04	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 19:04	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 19:04	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 19:04	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 19:04	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		75 - 125		03/03/15 19:04	1
Toluene-d8 (Surr)	99		75 - 120		03/03/15 19:04	1
4-Bromofluorobenzene (Surr)	99		75 - 120		03/03/15 19:04	1
Dibromofluoromethane	87		75 - 120		03/03/15 19:04	1



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: RFW-4A

Lab Sample ID: 500-92688-16

Date Collected: 02/26/15 08:15

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			03/03/15 17:41	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			03/03/15 17:41	1
Chloromethane	<1.0		1.0	0.18	ug/L			03/03/15 17:41	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			03/03/15 17:41	1
Bromomethane	<1.0		1.0	0.31	ug/L			03/03/15 17:41	1
Chloroethane	<1.0		1.0	0.34	ug/L			03/03/15 17:41	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			03/03/15 17:41	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			03/03/15 17:41	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			03/03/15 17:41	1
Acetone	<5.0		5.0	1.3	ug/L			03/03/15 17:41	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			03/03/15 17:41	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			03/03/15 17:41	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			03/03/15 17:41	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			03/03/15 17:41	1
cis-1,2-Dichloroethene	0.61	J	1.0	0.12	ug/L			03/03/15 17:41	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			03/03/15 17:41	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			03/03/15 17:41	1
Chloroform	0.54	J	1.0	0.20	ug/L			03/03/15 17:41	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			03/03/15 17:41	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			03/03/15 17:41	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			03/03/15 17:41	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 17:41	1
Trichloroethene	27		0.50	0.19	ug/L			03/03/15 17:41	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			03/03/15 17:41	1
Dibromomethane	<1.0		1.0	0.33	ug/L			03/03/15 17:41	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			03/03/15 17:41	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			03/03/15 17:41	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			03/03/15 17:41	1
Toluene	<0.50		0.50	0.11	ug/L			03/03/15 17:41	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			03/03/15 17:41	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			03/03/15 17:41	1
Tetrachloroethene	17		1.0	0.17	ug/L			03/03/15 17:41	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			03/03/15 17:41	1
2-Hexanone	<5.0		5.0	0.56	ug/L			03/03/15 17:41	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			03/03/15 17:41	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			03/03/15 17:41	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			03/03/15 17:41	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			03/03/15 17:41	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			03/03/15 17:41	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			03/03/15 17:41	1
o-Xylene	<0.50		0.50	0.068	ug/L			03/03/15 17:41	1
Styrene	<1.0		1.0	0.10	ug/L			03/03/15 17:41	1
Bromoform	<1.0		1.0	0.28	ug/L			03/03/15 17:41	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 17:41	1
Bromobenzene	<1.0		1.0	0.25	ug/L			03/03/15 17:41	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			03/03/15 17:41	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			03/03/15 17:41	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 17:41	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			03/03/15 17:41	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-92688-1

Client Sample ID: RFW-4A

Lab Sample ID: 500-92688-16

Date Collected: 02/26/15 08:15

Matrix: Water

Date Received: 02/27/15 11:05

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			03/03/15 17:41	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			03/03/15 17:41	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 17:41	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			03/03/15 17:41	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			03/03/15 17:41	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 17:41	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			03/03/15 17:41	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			03/03/15 17:41	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			03/03/15 17:41	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			03/03/15 17:41	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			03/03/15 17:41	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			03/03/15 17:41	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			03/03/15 17:41	1
Naphthalene	<1.0		1.0	0.16	ug/L			03/03/15 17:41	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			03/03/15 17:41	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	96		75 - 125		03/03/15 17:41	1
Toluene-d8 (Surr)	88		75 - 120		03/03/15 17:41	1
4-Bromofluorobenzene (Surr)	90		75 - 120		03/03/15 17:41	1
Dibromofluoromethane	87		75 - 120		03/03/15 17:41	1

