

QUARTERLY GROUNDWATER MONITORING REPORT

Prepared for

**BLACK & DECKER (U.S.) INC.
Hampstead, Maryland**

October 1998

Prepared by

**Roy F. Weston, Inc.
One Weston Way
West Chester, Pennsylvania 19380**

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
1	INTRODUCTION	1-1
2	SITE CHARACTERISTICS	2-1
	2.1 Hydraulic Properties	2-1
	2.2 Effluent Characteristics	2-1
	2.3 Groundwater Quality Data	2-1
3	OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM	3-1
4	RECOMMENDATIONS	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
2-1	Treatment System Pumping Records – 3rd Quarter 1998	2-3
2-2	Groundwater Elevation Data – 3rd Quarter 1998	2-4
2-3	Effluent Characteristics Summary – 3rd Quarter 1998	2-5
2-4	Summary of Groundwater Analytical Results - August 1998	2-6
3-1	Treatment System Maintenance Activities – 3rd Quarter 1998	3-2

SECTION 1

INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period: the quantities of groundwater pumped, treated, and discharged; the calculation of quantities of contaminants removed from groundwater; a summary of all sampling analyses; an explanation of all operational or other problems encountered, and the manner in which each problem was resolved; copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit; and recommendations for changes to the Interim Groundwater Treatment System. This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site which is maintained at the Hampstead Public Library.

SECTION 2

SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of July through September 1998.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. At the time the water level measurements were collected, the extraction wells were pumping at an average combined rate of approximately 158 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of July through September 1998 are Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of July through September 1998, approximately 157 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and

treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (79 %) and tetrachlorethene (PCE) (21 %). Analytical results of the groundwater collected at the inlet to the air stripper for the period of July through September 1998 are included in Appendix C.

A summary of the analytical results from the third quarter (August 1998) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete analytical data package is included in Appendix D. As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-2 and the highest concentration of PCE was detected in the groundwater sample collected from extraction well EW-9. VOCs detected at lower concentrations were 1,2-dichloroethene and 1,1,1-trichloroethane. The remainder of VOCs present were detected at levels well below the Federal Maximum Contaminant Levels (MCL).

Table 2-1
Treatment System Pumping Records - 3rd Quarter 1998
Black & Decker
Hampstead, Maryland

Date	Water pumped (gallons)
Jul-98	7,189,264
Aug-98	7,302,213
Sep-98	6,834,425

Table 2-2
Groundwater Elevation Data - 3rd Quarter 1998
Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV	TOTAL DEPTH	07/23/98		08/18/98		09/24/98	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	NA	--	NA	--	NA	--
EW-2	849.21	110	80.19	769.02	80.74	768.47	81.11	768.10
EW-3	846.64	118	86.33	760.31	87.36	759.28	87.67	758.97
EW-4	858.01	97.5	87.42	770.59	88.43	769.58	88.94	769.07
EW-5	864.17	98	83.11	781.06	87.94	776.23	88.31	775.86
EW-6	831.98	115	57.12	774.86	59.12	772.86	60.41	771.57
EW-7	818.38	78	31.46	786.92	37.44	780.94	38.74	779.64
EW-8	811.13	98	73.11	738.02	74.21	736.92	74.94	736.19
EW-9	811.35	141	75.67	735.68	74.58	736.77	74.63	736.72
EW-10	807.74	NA	48.01	759.73	45.99	761.75	46.51	761.23
RFW-1A	864.37	78	47.51	816.86	49.29	815.08	50.11	814.26
RFW-1B	864.23	200	47.52	816.71	49.33	814.90	50.10	814.13
RFW-2A	857.41	35	12.45	844.96	14.77	842.64	14.43	842.98
RFW-2B	857.73	75	13.12	844.61	15.41	842.32	15.02	842.71
RFW-3B	839.21	153	26.86	812.35	26.77	812.44	27.23	811.98
RFW-4A	830.37	62	35.06	795.31	34.86	795.51	35.21	795.16
RFW-4B	830.37	120	34.98	795.39	34.81	795.56	35.17	795.20
RFW-5A	817.50	30	DRY	--	DRY	--	DRY	--
RFW-6	785.04	120	2.43	782.61	3.14	781.90	2.78	782.26
RFW-7	805.14	29	6.86	798.28	6.83	798.31	6.47	798.67
RFW-8	860.07	56	DRY	--	DRY	--	DRY	--
RFW-9	862.02	49	24.12	837.90	24.11	837.91	24.43	837.59
RFW-10	852.06	58	57.16	794.90	57.31	--	58.09	793.97
RFW-11A	849.32	72	67.79	781.53	67.78	781.54	67.88	781.44
RFW-11B	849.62	116	75.85	773.77	75.88	773.74	75.94	773.68
RFW-12B	844.87	264	52.81	792.06	52.43	792.44	52.53	792.34
RFW-13	849.11	150	58.21	790.90	59.11	790.00	59.34	789.77
RFW-14B	812.39	281	38.09	774.30	38.20	774.19	38.31	774.08
RFW-16	856.14	41	37.91	818.23	38.23	817.91	38.74	817.40
RFW-17	834.66	60.5	25.11	809.55	25.08	809.58	25.17	809.49
RFW-18	843.67	50	5.74	837.93	6.36	837.31	6.46	837.21
RFW-19	858.28	60	3.81	854.47	3.22	855.06	3.30	854.98
RFW-20	842.49	142	32.67	809.82	32.84	809.65	33.16	809.33
RFW-21	832.65	102	19.73	812.92	19.22	813.43	19.42	813.23
PH-7	805.94	89	28.11	777.83	28.00	777.94	28.08	777.86
PH-9	814.94	98	30.87	784.07	31.09	783.85	31.13	783.81
PH-11	820.68	78	37.94	782.74	38.59	782.09	38.48	782.20
PH-12	828.35	87	40.61	787.74	41.17	787.18	41.42	786.93
B-2	807.68	100	5.94	801.74	5.81	801.87	5.87	801.81
B-3	803.02	83	7.31	795.71	6.94	796.08	7.01	796.01
Amoco	842.29	NA	21.22	821.07	21.40	820.89	21.63	820.66
Hamp. Town #22	804.96	NA	0.94	--	0.69	--	0.78	--
Pembroke #1	NA	NA	10.43	--	10.11	--	10.87	--
Pembroke #2	NA	NA	NA	--	NA	--	NA	--
N. Houcks. Rd.	NA	NA	NA	--	NA	--	NA	--
E. Century St.	NA	NA	11.26	--	11.23	--	11.19	--
Lwr. Beckleys. Rd.	NA	NA	48.11	--	47.36	--	47.84	--

NA - Not Available/Not Accessible

Table 2-3
Effluent Characteristics Summary - XX Quarter 19XX
Black & Decker
Hampstead, Maryland

2-5

Discharge Number	Parameter	Units	Permit Limits	DMR DATE		
				July 1998	August 1998	September 1998
001	FLOW	average	MGD	NA	0.202	0.179
		maximum	MGD	NA	0.246	0.719
	1,1,1-Trichloroethane	ug/l	5	< 5	< 5	< 5
	Tetrachloroethylene	ug/l	5	< 5	< 5	< 5
	Trichloroethylene	ug/l	5	< 5	< 5	< 5
	Total Residual Chlorine	mg/l	<0.1	<0.1	<0.1	<0.1
	Oil & Grease	maximum	mg/l	15	< 5	< 5
		quarterly average	mg/l	10	NR	NR
	pH	minimum	STD	6.0	6.18	6.71
		maximum	STD	8.5	7.22	7.86
	BOD	mg/l	15	3	4	3
	TSS	maximum	mg/l	30	18	9
		quarterly average	mg/l	20	NR	NR
101 (Monitoring Point)	FLOW	average	MGD	NA	0.473	0.463
		maximum	MGD	NA	0.473	0.470
	Fecal Coliform	MPN/100ml	200	< 2	< 2	< 2
201 (Monitoring Point)	FLOW	average	MGD	NA	0.240	0.236
		maximum	MGD	NA	0.271	0.249
	1,1,1-Trichloroethane	ug/l	NA	< 5	< 5	< 5
	Tetrachloroethylene	ug/l	NA	< 5	< 5	11
	Trichloroethylene	ug/l	NA	< 5	< 5	< 5

NA - Not Applicable

NR - Not Reported

Table 2-4
Summary of Groundwater Analytical Results - August 1998
Black & Decker
Hampstead, Maryland

2-6

PARAMETER	Units	EW-1	EW-2	EW-2 DUP (20)	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-10	RFW-1A	RFW-1B	RFW-2A
Chloromethane	ug/L	NS	200 U	200 U	50 U	200 U	100 U	10 U	10 U	10 U	50 U	10 U	10 U	10 U	10 U
Bromomethane	ug/L	NS	200 U	200 U	50 U	200 U	100 U	10 U	10 U	10 U	50 U	10 U	10 U	10 U	10 U
Vinyl Chloride	ug/L	NS	200 U	200 U	50 U	200 U	100 U	10 U	10 U	10 U	50 U	10 U	10 U	10 U	10 U
Chloroethanane	ug/L	NS	200 U	200 U	50 U	200 U	100 U	10 U	10 U	10 U	50 U	10 U	10 U	10 U	10 U
Methylene Chloride	ug/L	NS	480 B	460 B	130 B	67 JB	31 JB	24 B	2 JB	2 JB	12 JB	2 JB	2 JB	2 JB	2 JB
Acetone	ug/L	NS	200 U	200 U	14 JB	200 U	100 U	10 U	10 U	10 U	50 U	10 U	10 U	6 JB	10 U
Carbon Disulfide	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
1,1-Dichloroethane	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	1 J	1 J	25 U	5 U	5 U	5 U	5 U
1,2-Dichloroethene (total)	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	8	31	25 U	5 U	5 U	5 U	5 U
Chloroform	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
1,2-Dichloroethane	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
2-Butanone	ug/L	NS	200 U	200 U	50 U	200 U	100 U	10 U	10 U	10 U	50 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
Carbon Tetrachloride	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
Bromodichloromethane	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
1,2-Dichloropropane	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
cis-1,3-Dichloropropene	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
Trichloroethene	ug/L	NS	2400	2400	830	2200	1500	12	12	18	8 J	5 U	5 U	5 U	2 J
Dibromochloromethane	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
1,1,2-Trichloroethane	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
Benzene	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
Trans-1,3-Dichloropropene	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
Bromoform	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
4-Methyl-2-pentanone	ug/L	NS	200 U	200 U	50 U	200 U	100 U	10 U	10 U	10 U	50 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	200 U	200 U	50 U	200 U	100 U	10 U	10 U	10 U	50 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	76 JB	81 JB	13 JB	39 JB	26 JB	53 B	28	170	730	72	1 J	5 U	5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
Toluene	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
Chlorobenzene	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
Ethylbenzene	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
Styrene	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U
Xylene (total)	ug/L	NS	100 U	100 U	25 U	100 U	50 U	5 U	5 U	5 U	25 U	5 U	5 U	5 U	5 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

B = Indicates that the analyte was found in the associated blank as well as in the sample.

DUP = Duplicate sample

NS = Not sampled

(2.5) = Dilution factor.

Table 2-4
Summary of Groundwater Analytical Results - August 1998
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-2B	RFW-3B	RFW-4A	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10	RFW-11A	RFW-11B	(DUP)	RFW-12B
		(1)													(20)
Chloromethane	ug/L	10 U	10 U	10 U	10 U	NS	10 U	10 U	NS	10 U	NS	10 U	10 U	10 U	200 U
Bromomethane	ug/L	10 U	10 U	10 U	10 U	NS	10 U	10 U	NS	10 U	NS	10 U	10 U	10 U	200 U
Vinyl Chloride	ug/L	10 U	10 U	10 U	10 U	NS	10 U	10 U	NS	10 U	NS	10 U	10 U	10 U	200 U
Chloroethanane	ug/L	10 U	10 U	10 U	10 U	NS	10 U	10 U	NS	10 U	NS	10 U	10 U	10 U	200 U
Methylene Chloride	ug/L	2 JB	2 JB	3 JB	2 JB	NS	2 JB	2 JB	NS	5 U	NS	2 JB	22 B	3 JB	66 JB
Acetone	ug/L	10 U	6 JB	10 U	6 JB	NS	7 JB	10 U	NS	10 U	NS	10 U	10 U	10 U	200 U
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
1,1-Dichloroethene	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
1,1-Dichloroethane	ug/L	5 U	1 J	5 U	5 U	NS	5 U	5 U	NS	3 J	NS	5 U	5 U	5 U	100 U
1,2-Dichloroethene (total)	ug/L	5 U	44	2 J	3 J	NS	1 J	5 U	NS	9	NS	5 U	5 U	5 U	100 U
Chloroform	ug/L	5 U	5 U	1 J	2 J	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
1,2-Dichloroethane	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
2-Butanone	ug/L	10 U	10 U	10 U	10 U	NS	10 U	10 U	NS	10 U	NS	10 U	10 U	10 U	200 U
1,1,1-Trichloroethane	ug/L	5 U	3 J	5 U	5 U	NS	5 U	5 U	NS	2 J	NS	5 U	5 U	5 U	100 U
Carbon Tetrachloride	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
Bromodichloromethane	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
1,2-Dichloropropane	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
cis-1,3-Dichloropropene	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
Trichloroethene	ug/L	5 U	23	100	110	NS	15	10	NS	24	NS	78	80	76	2900
Dibromochloromethane	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
1,1,2-Trichloroethane	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
Benzene	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
Trans-1,3-Dichloropropene	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
Bromoform	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
4-Methyl-2-pentanone	ug/L	10 U	10 U	10 U	10 U	NS	10 U	10 U	NS	10 U	NS	10 U	10 U	10 U	200 U
2-Hexanone	ug/L	10 U	10 U	10 U	10 U	NS	10 U	10 U	NS	10 U	NS	10 U	10 U	10 U	200 U
Tetrachloroethene	ug/L	5 U	36	120 B	170	NS	13	5 U	NS	11	NS	1 J	2 JB	2 J	54 JB
1,1,2,2-Tetrachloroethane	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
Toluene	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
Chlorobenzene	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
Ethylbenzene	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
Styrene	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U
Xylene (total)	ug/L	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS	5 U	5 U	5 U	100 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

NS = Not sampled

B = Indicates that the analyte was found in the associated blank as well as in the sample.

(2.5) = Dilution factor.

Table 2-4
Summary of Groundwater Analytical Results - August 1998
Black & Decker
Hampstead, Maryland

2-8

PARAMETER	Units	RFW-13	RFW-16	RFW-17	RFW-18	RFW-19	RFW-20	RFW-21	Town #2	Town #2	Leister Dairy	Leister Res. #1	Leister Res. #2	Field Blank	Trip Blank
Chloromethane	ug/L	10 U	NS	10 U	10 U	10 U	10 U	10 U							
Bromomethane	ug/L	10 U	NS	10 U	10 U	10 U	10 U	10 U							
Vinyl Chloride	ug/L	10 U	NS	10 U	10 U	10 U	10 U	10 U							
Chloroethanane	ug/L	10 U	NS	10 U	10 U	10 U	10 U	10 U							
Methylene Chloride	ug/L	2 JB	NS	2 JB	2 JB	2 JB	2 JB	3 JB							
Acetone	ug/L	4 JB	10 U	3 JB	10 U	10 U	6 JB	10 U	10 U	NS	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethane	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
1,2-Dichloroethene (total)	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
Chloroform	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	25	5 U
1,2-Dichloroethane	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
2-Butanone	ug/L	10 U	NS	10 U	10 U	10 U	10 U	10 U							
1,1,1-Trichloroethane	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
Carbon Tetrachloride	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
Bromodichloromethane	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	9	5 U
1,2-Dichloropropane	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
cis-1,3-Dichloropropene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
Trichloroethene	ug/L	9	2 J	5 U	5 U	5 U	10	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
Dibromochloromethane	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	2 J	5 U
1,1,2-Trichloroethane	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
Benzene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
Trans-1,3-Dichloropropene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
Bromoform	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
4-Methyl-2-pentanone	ug/L	10 U	NS	10 U	10 U	10 U	10 U	10 U							
2-Hexanone	ug/L	10 U	NS	10 U	10 U	10 U	10 U	10 U							
Tetrachloroethene	ug/L	55 B	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
1,1,2,2-Tetrachloroethane	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
Toluene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
Chlorobenzene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
Ethylbenzene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
Styrene	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U
Xylene (total)	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	5 U	5 U	5 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

B = Indicates that the analyte was found in the associated blank as well as in the sample.

DUP = Duplicate sample

NS = Not sampled

(2.5) = Dilution factor.

SECTION 3

OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (July through September 1998) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate, or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 3rd Quarter 1998
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
July 1998	EW-3 down because of high water alarm. A pinhole hole was found in the flow meter control valve. The Valve was replaced, EW-3 back on line.
September 1998	Bad shaft in blower #1, put blower #2 on line. Blower #1 fixed and back on line.

SECTION 4

RECOMMENDATIONS

For the reporting period of July through September 1998, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. Operation of the extraction system as currently configured will continue, adjusting pumping rates as necessary according to the amount of groundwater recharge. Operation of the treatment system as currently configured will also continue, because the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A

GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

(July – September 1998)

MONTH / YEAR

BLACK DECKER
AIR STRIPPER # 2
OPERATING RECORD

PAST MONTH READING

341517312July 1998

Date	Day	Time	Integ. Reading	GPD	Pump # 12	Pump # 11
1	W	0830	341741419	271358	17164	17193
2	T	1025	342012777	↑	17164	17219
3	F					
4	S					
5	S			880741		
6	M	0910	342893518	248651	17164	17313
7	T	0930	343142169	250049	17188	17313
8	W	1020	343392218	238024	17213	17313
9	T	1030	343630242	222110	17237	17313
10	F	0935	343852352	↑	17260	17313
11	S					
12	S			696009		
13	M	1005	344548361	228135	17332	17313
14	T	1015	344976496	236361	17332	17339
15	W	1100	345012857	2152810	17332	17362
16	T	0940	345228143	232242	17332	17384
17	F	1005	345460385	↑	17332	17409
18	S					
19	S			679103		
20	M	0930	346139488	222161	17332	17479
21	T	0915	3463611649	241834	17358	17479
22	W	1030	346603483	231554	17364	17497
23	T	1045	346835037	226353	17364	17538
24	F	1040	347061390	↑	17364	17545
25	S				17364	17678
26	S			688018		
27	M	1100	347749408	236330	17364	17618
28	T	1045	347985438	225368	17388	17618
29	W	0920	348211106	257184	17410	17618
30	T	1050	348468292	222926	17410	17643
31	F	0915	348691318	239465	17410	17666
Total				7189264		
Average				239642		

=3.3..

NEXT MONTH READING 349409612 on Aug. 3

MONTH / YEAR

BLACK DECKER
AIR STRIPPER # 2
OPERATING RECORD

PAST MONTH READING

348691218Aug. 98

Date	Day	Time	Integ. Reading	GPD	Pump # 12	Pump # 11
1				↑		
2				478929		
3	M	0920	349409612	249254	17426	17672
4	T	1010	349658866	239644	17501	17672
5	W	1010	349898512	241860	17525	17672
6	T	1025	350140372	237852	17549	17672
7	F	1010	350378224	↑	17573	17672
8						
9				719402		
10	M	1025	351097626	226277	17645	17672
11	T	0925	351323903	233233	17668	17672
12	W	0905	351557136	241089	17692	17672
13	T	0935	351798285	245559	17716	17672
14	F	1035	352043784	↑	17741	17672
15						
16				699821		
17	M	1100	352743605	234789	17813	17672
18	T	1000	352978394	237738	17813	17696
19	W	1010	353216132	227877	17813	1720
20	T	0935	353444009	230546	17813	17744
21	F	0915	353674555	↑	17813	17768
22						
23				704189		
24	M	0945	354378744	245120	17813	17840
25	T	1100	354623864	219976	17838	17840
26	W	0945	354843840	237975	17861	17840
27	T	1020	355081815	226980	17885	17840
28	F	1000	355308795	↑	17909	17840
29						
30				696701		
31	M	1005	356005494	227400	17981	17840
Total				7,302,213		
Average				235,555		

NEXT MONTH READING 356232894 on Sept. 1

BLACK DECKER
AIR STRIPPER # 2
OPERATING RECORD

MONTH / YEAR

Sept. 98

PAST MONTH READING

356005496

Date	Day	Time	Integ. Reading	GPD	Pump # 12	Pump # 11
1	T	0945	356232894	230560	17981	17864
2	W	0950	356263456	208145	17981	17888
3	T	0730	356671601	↑	17981	17909
4	F					
5						
6						
7	M			1169057		
8	T	0935	357840658	228023	17981	18032
9	W	0925	358068681	234789	18085	18032
10	T	1000	358303470	234804	18029	18032
11	F	1040	358538274	↑	18054	18032
12						
13				676788		
14	M	0945	359215054	225304	18125	18032
15	T	0935	359440358	231442	18125	18055
16	W	0956	3596071800	228472	18125	18079
17	T	1005	359900272	225269	18125	18104
18	F	1000	360125541	↑	18125	18128
19						
20				692063		
21	M	1105	360817604	218240	18125	18261
22	T	1015	361035844	230478	18148	18201
23	W	1040	361266322	222950	18173	18201
24	T	1020	361489272	216564	18194	18201
25	F	0936	361705836	↑	18220	18201
26						
27				680517		
28	M	1005	362386353	227715	18292	18201
29	T	1015	362614068	221391	18314	18201
30	W	1000	362835459	231862	18340	18201
Total				6,834,425		
Average				227,814		

NEXT MONTH READING 363067321

APPENDIX B
DISCHARGE MONITORING REPORTS
(July – September 1998)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)
NAME: BLACK & DECKER (U.S.) INC.
ADDRESS: 626 HANOVER PIKE
HAMPSTEAD, MD. 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
OMB No.2040-0004

FACILITY:
LOCATION: CARROLL COUNTY

MD0001881			001			
PERMIT NUMBER			DISCHARGE NUMBER			
(2-16)			(17-19)			
MONITORING PERIOD						
FROM	YEAR	MO	DAY	YEAR	MO	DAY
	98	07	01	98	07	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)	

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (54-61)			QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS					
FLOW	SAMPLE MEASUREMENT	0.202	0.246	MGD							0	Measured/Recorded	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT										Measured/Recorded
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5			ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT							5					1/MONTH
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5			ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT							5					1/MONTH
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5			ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT							5					1/MONTH
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT						<0.1			mg/l	0	3/MONTH	GRAB
	PERMIT REQUIREMENT							<0.1					1/MONTH
OIL & GREASE	SAMPLE MEASUREMENT						<5			mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT							10	15				1/MONTH
pH	SAMPLE MEASUREMENT				6.18		7.22			STD	0	2/WEEK	GRAB
	PERMIT REQUIREMENT					6.00		8.50					2/WEEK
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)								TELEPHONE	DATE		
LaVere N. Grimes Facilities Manager								SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		410-239-5555	98 08 04		
TYPED OR PRINTED										AREA CODE/NUMBER	YEAR MO DAY		

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BLACK & DECKER (U.S.) INC.**
ADDRESS: **626 HANOVER PIKE**
HAMPSTEAD, MD. 21074

FACILITY:

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
OMB No.2040-0004**MD0001881****001**

PERMIT NUMBER

DISCHARGE NUMBER

(2-16)

(17-19)

MONITORING PERIOD

FROM	YEAR	MO	DAY	YEAR	MO	DAY
	98	07	01	98	07	31

(20-21)

(22-23)

(24-25)

(26-27)

(28-29)

(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(3 Card Only) (46-53)			(4 Card Only) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
BOD	SAMPLE MEASUREMENT						3	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						15				
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT						18	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						20				
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THIS SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						<i>LaVere N. Grimes</i>		TELEPHONE	DATE
LaVere N. Grimes Facilities Manager								SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		410-239-5555	98 08 04
TYPED OR PRINTED										AREA CODE-NUMBER	10.3

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)
NAME: BLACK & DECKER (U.S.) INC.
ADDRESS: 626 HANOVER PIKE
HAMPSTEAD, MD. 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No.2040-0004

FACILITY:
LOCATION: CARROLL COUNTY

MD0001881			101		
PERMIT NUMBER			DISCHARGE NUMBER		
(2-16)			(17-19)		
MONITORING PERIOD					
FROM	YEAR 98	MO 07	DAY 01	TO	YEAR 98
	(20-21)	(22-23)	(24-25)	(26-27)	(28-29)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) (46-53) (54-61)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.473	0.473	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								Cont Measure/Record
FECAL COLIFORM	SAMPLE MEASUREMENT						<2	MPN/ 100ml	0	GRAB	
	PERMIT REQUIREMENT										200
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						<i>LaVere N. Grimes</i>		TELEPHONE	DATE
LaVere N. Grimes Facilities Manager											
TYPED OR PRINTED								SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE NUMBER	YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)
NAME: BLACK & DECKER (U.S.) INC.
ADDRESS: 626 HANOVER PIKE
HAMPSTEAD, MD. 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)


FORM APPROVED
OMB No.2040-0004

FACILITY:

LOCATION: CARROLL COUNTY

MD0001881			201		
PERMIT NUMBER			DISCHARGE NUMBER		
(2-16)			(17-19)		
MONITORING PERIOD					
FROM		YEAR 98	MO 07	DAY 01	TO 98 07 31
		(20-21)	(22-23)	(24-25)	(26-27) (28-29) (30-31)

NOTE: Read Instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) (46-53) (54-61)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.24	0.271	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								Cont Measure/Record
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT								N/A		
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT								N/A		
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT								N/A		
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 46 U.S.C. § 100 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)								TELEPHONE	DATE
LaVere N. Grimes Facilities Manager								SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		410-239-5555	98 08 04
TYPED OR PRINTED										AREA CODE-NUMBER	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)
NAME: BLACK & DECKER (U.S.) INC.
ADDRESS: 626 HANOVER PIKE
HAMPSTEAD, MD. 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
OMB No.2040-0004

FACILITY:
LOCATION: CARROLL COUNTY

MD0001881			001		
PERMIT NUMBER			DISCHARGE NUMBER		
(2-16)			(17-19)		
MONITORING PERIOD					
FROM	YEAR (20-21)	MO (22-23)	DAY (24-25)	YEAR (26-27)	MO (28-29)
	98	08	01	98	08

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (54-61)				QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS						
FLOW	SAMPLE MEASUREMENT	0.179	0.719	MGD								0	Measured/Recorded	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT											Measured/Recorded
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5				ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT							5						1/MONTH
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5				ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT							5						1/MONTH
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5				ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT							5						1/MONTH
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT						<0.1				mg/l	0	4/MONTH	GRAB
	PERMIT REQUIREMENT							<0.1						1/MONTH
OIL & GREASE	SAMPLE MEASUREMENT						<5				mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT							10	15					1/MONTH
pH	SAMPLE MEASUREMENT				6.71		7.86				STD	0	2/WEEK	GRAB
	PERMIT REQUIREMENT					6.00		8.50						2/WEEK
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)								<i>LaVere N. Grimes</i>		TELEPHONE	DATE	
LaVere N. Grimes Facilities Manager										SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		410-239-5555	98 09 02	
TYPED OR PRINTED												AREA CODE-NUMBER	YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)
NAME: BLACK & DECKER (U.S.) INC.
ADDRESS: 626 HANOVER PIKE
HAMPSTEAD, MD. 21074

FACILITY:

LOCATION: CARROLL COUNTY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
OMB No.2040-0004

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

(2-16)

(17-19)

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	98	08	01		98	08	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)	

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(3 Card Only) (46-53)			(4 Card Only) (54-61)				QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS						
BOD	SAMPLE MEASUREMENT						4				0	1/MONTH	GRAB
	PERMIT REQUIREMENT						15					1/MONTH	GRAB
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT						9				0	1/MONTH	GRAB
	PERMIT REQUIREMENT						20	30				1/MONTH	GRAB
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER

**LaVere N. Grimes
Facilities Manager**

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 46 USC § 1001 AND 33 USC § 1319 (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

LaVere N. Grimes

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

410-239-5555

98 | 09 | 02

AREA CODE-NUMBER

10.3

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)
NAME: BLACK & DECKER (U.S.) INC.
ADDRESS: 626 HANOVER PIKE
HAMPSTEAD, MD. 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No.2040-0004

FACILITY:
LOCATION: CARROLL COUNTY

MD0001881	101
PERMIT NUMBER	DISCHARGE NUMBER

(2-16) (17-19)

MONITORING PERIOD								
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY	
	98	08	01		98	08	31	

(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (54-61)			QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-66)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS					
FLOW	SAMPLE MEASUREMENT	0.463	0.470	MGD							0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT										Cont Measure/Record
FECAL COLIFORM	SAMPLE MEASUREMENT							<2		MPN/ 100ml	0	GRAB	
	PERMIT REQUIREMENT							200					1/WEEK
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 16 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)								<i>LaVere N. Grimes</i>		TELEPHONE	DATE
LaVere N. Grimes Facilities Manager										SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		410-239-5555	98 09 02
TYPED OR PRINTED												AREA CODE-NUMBER	YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)
NAME: BLACK & DECKER (U.S.) INC.
ADDRESS: 626 HANOVER PIKE
HAMPSTEAD, MD. 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
OMB No.2040-0004

FACILITY:

LOCATION: CARROLL COUNTY

MD0001881	201
PERMIT NUMBER	DISCHARGE NUMBER

(2-16) (17-19)

MONITORING PERIOD

FROM	YEAR 98	MO 08	DAY 01	TO	YEAR 98	MO 08	DAY 31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read Instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) (46-53)			QUANTITY OR LOADING (54-61)			QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS					
FLOW	SAMPLE MEASUREMENT	0.236	0.249	MGD							0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT										Cont Measure/Record
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT							<5		ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT								N/A				1/MONTH
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT							<5		ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT								N/A				1/MONTH
TRICHLOROETHYLENE	SAMPLE MEASUREMENT							<5		ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT								N/A				1/MONTH
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)								TELEPHONE		DATE	
LaVere N. Grimes Facilities Manager		<i>LaVere N. Grimes</i>								410-239-5555		98 09 02	
TYPED OR PRINTED										AREA CODE NUMBER			

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)
NAME: BLACK & DECKER (U.S.) INC.
ADDRESS: 626 HANOVER PIKE
HAMPSTEAD, MD. 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
OMB No.2040-0004

FACILITY:
LOCATION: CARROLL COUNTY

MD0001881 (2-16)			001 (17-19)				
PERMIT NUMBER			DISCHARGE NUMBER				
MONITORING PERIOD							
FROM		YEAR 98	MO 09	DAY 01	TO YEAR 98	MO 09	DAY 30
		(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) (46-53)			QUANTITY OR LOADING (54-61)			(4 Card Only)			QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS								
FLOW	SAMPLE MEASUREMENT	0.132	0.154	MGD									0	Measured/Recorded		
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT												Measured/Recorded	
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5					ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT							5							1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5					ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT							5							1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5					ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT							5							1/MONTH	GRAB
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT						<0.1					mg/l	0	4/MONTH	GRAB	
	PERMIT REQUIREMENT							<0.1							1/MONTH	GRAB
OIL & GREASE	SAMPLE MEASUREMENT					<5	<5					mg/l	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT						10	15							1/MONTH	GRAB
pH	SAMPLE MEASUREMENT				6.68		7.34					STD	0	2/WEEK	GRAB	
	PERMIT REQUIREMENT					6.00		8.50							2/WEEK	GRAB
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN: AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)											TELEPHONE	DATE		
LaVere N. Grimes Facilities Manager		<i>LaVere N. Grimes</i>											410-239-5555	98 10 07		
TYPED OR PRINTED													AREA CODE-NUMBER	YEAR MO DAY		

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)
NAME: BLACK & DECKER (U.S.) INC.
ADDRESS: 626 HANOVER PIKE
HAMPSTEAD, MD. 21074

FACILITY:

LOCATION: CARROLL COUNTY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No.2040-0004

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

(2-16)

(17-19)

MONITORING PERIOD

FROM	YEAR 98	MO 09	DAY 01	TO	YEAR 98	MO 09	DAY 30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read Instructions before completing this form.

PARAMETER (32-37)	(3 Card Only) (46-53) (54-61)			(4 Card Only)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
BOD	SAMPLE MEASUREMENT					3		0	1/MONTH	GRAB	
	PERMIT REQUIREMENT					15			1/MONTH	GRAB	
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT				12	10		0	1/MONTH	GRAB	
	PERMIT REQUIREMENT				20	30			1/MONTH	GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE! THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 46 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)								TELEPHONE	DATE
LaVere N. Grimes Facilities Manager								410-239-5555		98 10 07	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						AREA CODE-NUMBER		103	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)
NAME: BLACK & DECKER (U.S.) INC.
ADDRESS: 626 HANOVER PIKE
HAMPSTEAD, MD. 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
OMB No.2040-0004

FACILITY:
LOCATION: CARROLL COUNTY

MD0001881			101		
PERMIT NUMBER			DISCHARGE NUMBER		
(2-16)			(17-19)		
MONITORING PERIOD					
FROM	YEAR 98	MO 09	DAY 01	TO	YEAR 98
	(20-21)	(22-23)	(24-25)	(26-27)	(28-29)
DAY 30					

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (54-61)				QUALITY OR CONCENTRATION	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
FLOW	SAMPLE MEASUREMENT	0.475	0.500	MGD						0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								Cont Measure/Record	
FECAL COLIFORM	SAMPLE MEASUREMENT						<2	MPN/ 100ml	0	1/WEEK	GRAB	
	PERMIT REQUIREMENT						200				1/WEEK	GRAB
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 16 U.S.C. § 1061 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)								TELEPHONE	DATE	
LaVere N. Grimes Facilities Manager								SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		410-239-5555	98 10 07	
TYPED OR PRINTED										AREA CODE-NUMBER	YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)
NAME: BLACK & DECKER (U.S.) INC.
ADDRESS: 626 HANOVER PIKE
HAMPSTEAD, MD, 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
OMB No.2040-0004

FACILITY:

LOCATION: CARROLL COUNTY

MD0001881			201		
PERMIT NUMBER			DISCHARGE NUMBER		
(2-16)			(17-19)		
MONITORING PERIOD					
FROM	YEAR 98	MO 09	DAY 01	TO	YEAR 98
	(20-21)	(22-23)	(24-25)	(26-27)	(28-29)

NOTE: Read Instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) (46-53)			QUANTITY OR LOADING (54-61)				(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS							
FLOW	SAMPLE MEASUREMENT	0.228	0.235	MGD									0	Cont Measure/Record	Cont Measure/Record
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT												
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT								<5				ppb	0 1/MONTH	GRAB
	PERMIT REQUIREMENT								N/A						
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT								11				ppb	0 1/MONTH	GRAB
	PERMIT REQUIREMENT								N/A						
TRICHLOROETHYLENE	SAMPLE MEASUREMENT								<5				ppb	0 1/MONTH	GRAB
	PERMIT REQUIREMENT								N/A						
	SAMPLE MEASUREMENT														
	PERMIT REQUIREMENT														
	SAMPLE MEASUREMENT														
	PERMIT REQUIREMENT														
	SAMPLE MEASUREMENT														
	PERMIT REQUIREMENT														
	SAMPLE MEASUREMENT														
	PERMIT REQUIREMENT														

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THIS INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

LaVere N. Grimes
Facilities Manager

TYPED OR PRINTED


SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE DATE

410-239-5555 98 | 10 | 07

AREA CODE-NUMBER

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

APPENDIX C

GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

(July – September 1998)



Gascoyne Laboratories, Inc.

YOUR **ON-TIME** QUALITY LAB...

(410) 633-1800

(800) GAS-COYN

FAX NO.

(410) 633-5443

www.gascoyne.com

Baltimore, MD 21224

REPORT OF ANALYSIS

Page 4 of 14

Report no: 9803704

Client: Black & Decker Company

Sample Id: Collected samples by: Gascoyne Labs, Inc. AIR STRIPPER#2(Pre); grab, on 01-Jul-1998(08:37)
Laboratory Sample Number: 980014544

Parameter	Test Results	Reporting Limit	Method	Analyst	Date of Analysis
Acrolein	<500 ppb	500 ppb	EPA-624	THP	09-Jul-98(03:09)
Acrylonitrile	<500 ppb	500 ppb	EPA-624	THP	09-Jul-98(03:09)
Benzene	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
Bromomethane	<50 ppb	50 ppb	EPA-624	THP	09-Jul-98(03:09)
Carbon Tetrachloride	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
Chlorobenzene	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
Chloromethane	<50 ppb	50 ppb	EPA-624	THP	09-Jul-98(03:09)
1,2-Dichloropropane	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
1,1,1-Trichloroethane	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
1,1-Dichloroethane	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
Chloroethane	<50 ppb	50 ppb	EPA-624	THP	09-Jul-98(03:09)
2-Chloroethylvinyl Ether	<50 ppb	50 ppb	EPA-624	THP	09-Jul-98(03:09)
Chloroform	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
1,1-Dichloroethene	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
trans-1,2-Dichloroethene	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
1,2-Dichloroethane	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
cis-1,3-Dichloropropene	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
trans-1,3-Dichloropropene	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
1,3-Dichloropropene	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
Ethylbenzene	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
Methylene Chloride	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
1,1,2-Trichloroethane	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
Bromodichloromethane	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
Bromoform	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
Dibromochloromethane	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
Trichlorofluoromethane	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
1,1,2,2-Tetrachloroethane	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
Tetrachloroethene	190 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
Toluene	<25 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
Trichloroethene	760 ppb	25 ppb	EPA-624	THP	09-Jul-98(03:09)
Vinyl Chloride	<50 ppb	50 ppb	EPA-624	THP	09-Jul-98(03:09)



Gascoyne Laboratories, Inc.

YOUR **ON-TIME** QUALITY LAB...

Baltimore, MD 21224

REPORT OF ANALYSIS

(410) 633-1800

(800) GAS-COYN

FAX NO.

(410) 633-5443

www.gascoyne.com

Page 5 of 14

Report no: 9803704

Client: Black & Decker Company

Sample Id: Collected samples by: Gascoyne Labs, Inc. AIR STRIPPER#2(Pre); grab, on 01-Jul-1998(08:37)
Laboratory Sample Number: 980014544

Parameter	Test Results	Reporting Limit	Method	Analyst	Date of Analysis
Dibromofluoromethane(surrogate)	96 % Rec	NA	EPA-624	THP	09-Jul-98(03:09)
1,2-Dichloroethane-d4(surrogate)	100 % Rec	NA	EPA-624	THP	09-Jul-98(03:09)
Toluene-d8(surrogate)	95 % Rec	NA	EPA-624	THP	09-Jul-98(03:09)
Bromofluorobenzene(surrogate)	107 % Rec	NA	EPA-624	THP	09-Jul-98(03:09)



Gascoyne Laboratories, Inc.

YOUR **ON-TIME** QUALITY LAB...

Baltimore, MD 21224

(410) 633-1800

(800) GAS-COYN

FAX NO.
(410) 633-5443

www.gascoyne.com

REPORT OF ANALYSIS

Page 6 of 14

Report no: 9803704

Client: Black & Decker Company

Sample Id: Collected samples by: Gascoyne Labs, Inc. OUTFALL 201; grab, on 01-Jul-1998(08:38)
Laboratory Sample Number: 980014545

Parameter	Test Results	Reporting Limit	Method	Analyst	Date of Analysis
Acrolein	<100 ppb	100 ppb	EPA-624	THP	09-Jul-98(03:40)
Acrylonitrile	<100 ppb	100 ppb	EPA-624	THP	09-Jul-98(03:40)
Benzene	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
Bromomethane	<10 ppb	10 ppb	EPA-624	THP	09-Jul-98(03:40)
Carbon Tetrachloride	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
Chlorobenzene	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
Chloromethane	<10 ppb	10 ppb	EPA-624	THP	09-Jul-98(03:40)
1,2-Dichloropropane	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
1,1,1-Trichloroethane	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
1,1-Dichloroethane	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
Chloroethane	<10 ppb	10 ppb	EPA-624	THP	09-Jul-98(03:40)
2-Chloroethylvinyl Ether	<10 ppb	10 ppb	EPA-624	THP	09-Jul-98(03:40)
Chloroform	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
1,1-Dichloroethene	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
trans-1,2-Dichloroethene	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
1,2-Dichloroethane	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
cis-1,3-Dichloropropene	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
trans-1,3-Dichloropropene	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
1,3-Dichloropropene	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
Ethylbenzene	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
Methylene Chloride	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
1,1,2-Trichloroethane	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
Bromodichloromethane	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
Bromoform	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
Dibromochloromethane	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
Trichlorofluoromethane	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
1,1,2,2-Tetrachloroethane	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
Tetrachloroethene	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
Toluene	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
Trichloroethene	<5 ppb	5 ppb	EPA-624	THP	09-Jul-98(03:40)
Vinyl Chloride	<10 ppb	10 ppb	EPA-624	THP	09-Jul-98(03:40)

Gascoyne Laboratories, Inc.



YOUR **ON-TIME** QUALITY LAB...

Baltimore, MD 21224

REPORT OF ANALYSIS

(410) 633-1800

(800) GAS-COYN

FAX NO.

(410) 633-5443

www.gascoyne.com

Page 7 of 14

Report no: 9803704

Client: Black & Decker Company

Sample Id: Collected samples by: Gascoyne Labs, Inc. OUTFALL 201; grab, on 01-Jul-1998(08:38)
Laboratory Sample Number: 980014545

Parameter	Test Results	Reporting Limit	Method	Analyst	Date of Analysis
Dibromofluoromethane(surrogate)	98 % Rec	NA	EPA-624	THP	09-Jul-98(03:40)
1,2-Dichloroethane-d4(surrogate)	92 % Rec	NA	EPA-624	THP	09-Jul-98(03:40)
Toluene-d8(surrogate)	96 % Rec	NA	EPA-624	THP	09-Jul-98(03:40)
Bromofluorobenzene(surrogate)	104 % Rec	NA	EPA-624	THP	09-Jul-98(03:40)



Gascoyne Laboratories, Inc.

YOUR **ON-TIME** QUALITY LAB...

(410) 633-1800

(800) GAS-COYN

FAX NO.

(410) 633-5443

www.gascoyne.com

Baltimore, MD 21224

REPORT OF ANALYSIS

Page 6 of 17

Report no: 9804415

Client: Black & Decker Company

Sample Id: Collected samples by: Gascoyne Labs, Inc. AIR STRIPPER#2(PRE); grab, on 05-Aug-1998(07:55)
Laboratory Sample Number: 980016987

Parameter	Test Results	Reporting Limit	Method	Analyst	Date of Analysis
Acrolein	<500 ppb	500 ppb	EPA-624	THP	11-Aug-98(03:55)
Acrylonitrile	<500 ppb	500 ppb	EPA-624	THP	11-Aug-98(03:55)
Benzene	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
Bromomethane	<50 ppb	50 ppb	EPA-624	THP	11-Aug-98(03:55)
Carbon Tetrachloride	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
Chlorobenzene	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
Chloromethane	<50 ppb	50 ppb	EPA-624	THP	11-Aug-98(03:55)
1,2-Dichloropropane	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
1,1,1-Trichloroethane	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
1,1-Dichloroethane	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
Chloroethane	<50 ppb	50 ppb	EPA-624	THP	11-Aug-98(03:55)
2-Chloroethylvinyl Ether	<50 ppb	50 ppb	EPA-624	THP	11-Aug-98(03:55)
Chloroform	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
1,1-Dichloroethene	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
trans-1,2-Dichloroethene	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
1,2-Dichloroethane	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
cis-1,3-Dichloropropene	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
trans-1,3-Dichloropropene	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
1,3-Dichloropropene	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
Ethylbenzene	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
Methylene Chloride	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
1,1,2-Trichloroethane	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
Bromodichloromethane	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
Bromoform	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
Dibromochloromethane	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
Trichlorofluoromethane	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
1,1,2,2-Tetrachloroethane	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
Tetrachloroethene	190 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
Toluene	<25 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
Trichloroethene	800 ppb	25 ppb	EPA-624	THP	11-Aug-98(03:55)
Vinyl Chloride	<50 ppb	50 ppb	EPA-624	THP	11-Aug-98(03:55)

Gascoyne Laboratories, Inc.



YOUR **ON-TIME** QUALITY LAB...

Baltimore, MD 21224

REPORT OF ANALYSIS

(410) 633-1800

(800) GAS-COYN

FAX NO.
(410) 633-5443

www.gascoyne.com

Page 7 of 17

Report no: 9804415

Client: Black & Decker Company

Sample Id: Collected samples by: Gascoyne Labs, Inc. AIR STRIPPER#2(PRE); grab, on 05-Aug-1998(07:55)
Laboratory Sample Number: 980016987

Parameter	Test Results	Reporting Limit	Method	Analyst	Date of Analysis
Dibromofluoromethane(surrogate)	106 % Rec	NA	EPA-624	THP	11-Aug-98(03:55)
1,2-Dichloroethane-d4(surrogate)	106 % Rec	NA	EPA-624	THP	11-Aug-98(03:55)
Toluene-d8(surrogate)	96 % Rec	NA	EPA-624	THP	11-Aug-98(03:55)
Bromofluorobenzene(surrogate)	105 % Rec	NA	EPA-624	THP	11-Aug-98(03:55)



Gascoyne Laboratories, Inc.

YOUR **ON-TIME** QUALITY LAB...

(410) 633-1800

(800) GAS-COYN

FAX NO.

(410) 633-5443

www.gascoyne.com

REPORT OF ANALYSIS

Page 8 of 17

Report no: 9804415

Client: Black & Decker Company

Sample Id: Collected samples by: Gascoyne Labs, Inc. OUTFALL 201; grab, on 05-Aug-1998(07:57)

Laboratory Sample Number: 980016988

Parameter	Test Results	Reporting Limit	Method	Analyst	Date of Analysis
Acrolein	<100 ppb	100 ppb	EPA-624	THP	11-Aug-98(04:26)
Acrylonitrile	<100 ppb	100 ppb	EPA-624	THP	11-Aug-98(04:26)
Benzene	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
Bromomethane	<10 ppb	10 ppb	EPA-624	THP	11-Aug-98(04:26)
Carbon Tetrachloride	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
Chlorobenzene	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
Chloromethane	<10 ppb	10 ppb	EPA-624	THP	11-Aug-98(04:26)
1,2-Dichloropropane	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
1,1,1-Trichloroethane	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
1,1-Dichloroethane	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
Chloroethane	<10 ppb	10 ppb	EPA-624	THP	11-Aug-98(04:26)
2-Chloroethylvinyl Ether	<10 ppb	10 ppb	EPA-624	THP	11-Aug-98(04:26)
Chloroform	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
1,1-Dichloroethene	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
trans-1,2-Dichloroethene	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
1,2-Dichloroethane	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
cis-1,3-Dichloropropene	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
trans-1,3-Dichloropropene	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
1,3-Dichloropropene	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
Ethylbenzene	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
Methylene Chloride	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
1,1,2-Trichloroethane	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
Bromodichloromethane	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
Bromoform	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
Dibromochloromethane	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
Trichlorofluoromethane	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
1,1,2,2-Tetrachloroethane	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
Tetrachloroethene	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
Toluene	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
Trichloroethene	<5 ppb	5 ppb	EPA-624	THP	11-Aug-98(04:26)
Vinyl Chloride	<10 ppb	10 ppb	EPA-624	THP	11-Aug-98(04:26)

Please see reverse side for explanation of terms and other information.

Gascoyne Laboratories, Inc.



YOUR **ON-TIME** QUALITY LAB...

Baltimore, MD 21224

REPORT OF ANALYSIS

(410) 633-1800

(800) GAS-COYN

FAX NO.

(410) 633-5443

www.gascoyne.com

Page 9 of 17

Report no: 9804415

Client: Black & Decker Company

Sample Id: Collected samples by: Gascoyne Labs, Inc. OUTFALL 201; grab, on 05-Aug-1998(07:57)
Laboratory Sample Number: 980016988

Parameter	Test Results	Reporting Limit	Method	Analyst	Date of Analysis
Dibromofluoromethane(surrogate)	106 % Rec	NA	EPA-624	THP	11-Aug-98(04:26)
1,2-Dichloroethane-d4(surrogate)	104 % Rec	NA	EPA-624	THP	11-Aug-98(04:26)
Toluene-d8(surrogate)	95 % Rec	NA	EPA-624	THP	11-Aug-98(04:26)
Bromofluorobenzene(surrogate)	102 % Rec	NA	EPA-624	THP	11-Aug-98(04:26)



Gascoyne Laboratories, Inc.

YOUR **ON-TIME** QUALITY LAB...

(410) 633-1800

(800) GAS-COYN

FAX NO.
(410) 633-5443

www.gascoyne.com

Baltimore, MD 21224

REPORT OF ANALYSIS

Page 4 of 15

Report no: 9805067

Client: Black & Decker Company

Sample Id: Collected samples by: Gascoyne Labs, Inc. AIR STRIPPER#2(PRE); grab, on 03-Sep-1998(07:31)
Laboratory Sample Number: 980019475

Parameter	Test Results	Laboratory Reporting Limit	Method	Analyst	Date of Analysis
Acrolein	<500 ppb	500 ppb	EPA-624	THP	12-Sep-98(11:25)
Acrylonitrile	<500 ppb	500 ppb	EPA-624	THP	12-Sep-98(11:25)
Benzene	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
Bromomethane	<50 ppb	50 ppb	EPA-624	THP	12-Sep-98(11:25)
Carbon Tetrachloride	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
Chlorobenzene	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
Chloromethane	<50 ppb	50 ppb	EPA-624	THP	12-Sep-98(11:25)
1,2-Dichloropropane	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
1,1,1-Trichloroethane	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
1,1-Dichloroethane	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
Chloroethane	<50 ppb	50 ppb	EPA-624	THP	12-Sep-98(11:25)
2-Chloroethylvinyl Ether	<50 ppb	50 ppb	EPA-624	THP	12-Sep-98(11:25)
Chloroform	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
1,1-Dichloroethene	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
trans-1,2-Dichloroethene	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
1,2-Dichloroethane	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
cis-1,3-Dichloropropene	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
trans-1,3-Dichloropropene	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
1,3-Dichloropropene	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
Ethylbenzene	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
Methylene Chloride	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
1,1,2-Trichloroethane	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
Bromodichloromethane	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
Bromoform	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
Dibromochloromethane	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
Trichlorofluoromethane	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
1,1,2,2-Tetrachloroethane	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
Tetrachloroethene	170 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
Toluene	<25 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
Trichloroethene	520 ppb	25 ppb	EPA-624	THP	12-Sep-98(11:25)
Vinyl Chloride	<50 ppb	50 ppb	EPA-624	THP	12-Sep-98(11:25)



Gascoyne Laboratories, Inc.

YOUR **ON-TIME** QUALITY LAB...

Baltimore, MD 21224

REPORT OF ANALYSIS

(410) 633-1800

(800) GAS-COYN

FAX NO.

(410) 633-5443

www.gascoyne.com

Page 5 of 15

Report no: 9805067

Client: Black & Decker Company

Sample Id: Collected samples by: Gascoyne Labs, Inc. AIR STRIPPER#2(PRE); grab, on 03-Sep-1998(07:31)
Laboratory Sample Number: 980019475

Parameter	Test Results	Laboratory Reporting Limit	Method	Analyst	Date of Analysis
Dibromofluoromethane(surrogate)	98 % Rec	NA	EPA-624	THP	12-Sep-98(11:25)
1,2-Dichloroethane-d4(surrogate)	104 % Rec	NA	EPA-624	THP	12-Sep-98(11:25)
Toluene-d8(surrogate)	104 % Rec	NA	EPA-624	THP	12-Sep-98(11:25)
Bromofluorobenzene(surrogate)	110 % Rec	NA	EPA-624	THP	12-Sep-98(11:25)



Gascoyne Laboratories, Inc.

YOUR **ON-TIME** QUALITY LAB...

Baltimore, MD 21224

(410) 633-1800

(800) GAS-COYN

FAX NO.
(410) 633-5443

www.gascoyne.com

REPORT OF ANALYSIS

Page 6 of 15

Report no: 9805067

Client: Black & Decker Company

Sample Id: Collected samples by: Gascoyne Labs, Inc. OUTFALL 201; grab, on 03-Sep-1998(07:29)

Laboratory Sample Number: 980019476

Parameter	Test Results	Laboratory Reporting Limit	Method	Analyst	Date of Analysis
Acrolein	<100 ppb	100 ppb	EPA-624	THP	12-Sep-98(11:56)
Acrylonitrile	<100 ppb	100 ppb	EPA-624	THP	12-Sep-98(11:56)
Benzene	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
Bromomethane	<10 ppb	10 ppb	EPA-624	THP	12-Sep-98(11:56)
Carbon Tetrachloride	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
Chlorobenzene	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
Chloromethane	<10 ppb	10 ppb	EPA-624	THP	12-Sep-98(11:56)
1,2-Dichloropropane	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
1,1,1-Trichloroethane	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
1,1-Dichloroethane	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
Chloroethane	<10 ppb	10 ppb	EPA-624	THP	12-Sep-98(11:56)
2-Chloroethylvinyl Ether	<10 ppb	10 ppb	EPA-624	THP	12-Sep-98(11:56)
Chloroform	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
1,1-Dichloroethene	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
trans-1,2-Dichloroethene	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
1,2-Dichloroethane	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
cis-1,3-Dichloropropene	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
trans-1,3-Dichloropropene	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
1,3-Dichloropropene	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
Ethylbenzene	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
Methylene Chloride	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
1,1,2-Trichloroethane	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
Bromodichloromethane	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
Bromoform	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
Dibromochloromethane	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
Trichlorofluoromethane	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
1,1,2,2-Tetrachloroethane	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
Tetrachloroethene	11 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
Toluene	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
Trichloroethene	<5 ppb	5 ppb	EPA-624	THP	12-Sep-98(11:56)
Vinyl Chloride	<10 ppb	10 ppb	EPA-624	THP	12-Sep-98(11:56)



Gascoyne Laboratories, Inc.

YOUR **ON-TIME** QUALITY LAB...

Baltimore, MD 21224
REPORT OF ANALYSIS

(410) 633-1800

(800) GAS-COYN

FAX NO.
(410) 633-5443

www.gascoyne.com

Page 7 of 15

Report no: 9805067

Client: Black & Decker Company

Sample Id: Collected samples by: Gascoyne Labs, Inc. OUTFALL 201; grab, on 03-Sep-1998(07:29)
Laboratory Sample Number: 980019476

Parameter	Test Results	Laboratory Reporting Limit	Method	Analyst	Date of Analysis
Dibromofluoromethane(surrogate)	102 % Rec	NA	EPA-624	THP	12-Sep-98(11:56)
1,2-Dichloroethane-d4(surrogate)	106 % Rec	NA	EPA-624	THP	12-Sep-98(11:56)
Toluene-d8(surrogate)	104 % Rec	NA	EPA-624	THP	12-Sep-98(11:56)
Bromofluorobenzene(surrogate)	109 % Rec	NA	EPA-624	THP	12-Sep-98(11:56)

APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(August 1998)



a division of Recra Environmental, Inc.
Virtual Laboratories Everywhere

**Recra LabNet Philadelphia
Analytical Report**

**Client : BLACK & DECKER-HAMPSTEAD
RFW# : 9808L402**

**W.O. #: 02501-004-001-0200-00
Date Received: 08-20-98**

GC/MS VOLATILE

The set of samples consisted of thirty-eight (38) water samples collected on 08-18,19-98.

The samples and their associated QC samples were analyzed according to criteria set forth in Recra OPs based on SW 846 Method 8260 for TCL Volatile target compounds on 08-29,30,31-98 and 09-01-98.

The following is a summary of the QC results accompanying these sample results and a description of any problems encountered during their analyses:

1. The cooler temperature(s) upon receipt has been recorded on the chain-of-custody.
2. The required holding time for analysis was met.
3. Non-target compounds were detected in these samples.
4. Eight (8) samples required dilution (ranging from five-fold to 20-fold) because they contained high levels of target compounds.
5. Three (3) of one-hundred-fifty (150) surrogate recoveries were outside EPA QC limits. The analysis of RFW-17 fulfilled the reanalysis requirement for its associated matrix spike samples. The recovery of Bromofluorobenzene for the method blank spike 98LVN368-MB1 BS was slightly high. All blank spike recoveries were within QC limits; consequently, there was minimal impact on the data and reanalysis was not performed. A copy of the Sample Discrepancy Report (SDR) has been included in this data package.
6. All matrix spike recoveries were within EPA QC limits.
7. All blank spike recoveries were within EPA QC limits.
8. The method blanks contained the common laboratory contaminants Methylene Chloride and Acetone and the target compounds Chloromethane and Tetrachloroethene at levels less than the CRQL.

for J. Michael Taylor
J. Michael Taylor
Vice President
Philadelphia Analytical Laboratory

mmz\voa\08-402v.cn

10-28-98
Date

The results presented in this report relate only to the analytical testing and conditions of the samples at receipt and during storage. All pages of this report are integral parts of the analytical data. Therefore, this report should only be reproduced in its entirety of 72 pages.

GLOSSARY OF VOA DATA

DATA QUALIFIERS

- U** = Compound was analyzed for but not detected. The associated numerical value is the estimated sample quantitation limit which is included and corrected for dilution and percent moisture.
- J** = Indicates an estimated value. This flag is used under the following circumstances: 1) when estimating a concentration for tentatively identified compounds (TICs) where a 1:1 response is assumed; or 2) when the mass spectral data indicate the presence of a compound that meets the identification criteria but the result is less than the specified detection limit but greater than zero. For example, if the limit of detection is 10 ug/L and a concentration of 3 ug/L is calculated, it is reported as 3J.
- B** = This flag is used when the analyte is found in the associated blank as well as in the sample. It indicates possible/probable blank contamination. This flag is also used for a TIC as well as for a positively identified TCL compound.
- E** = Indicates that the compound was detected beyond the calibration range and was subsequently analyzed at a dilution.
- D** = Identifies all compounds identified in an analysis at a secondary dilution factor.
- I** = Interference.
- NQ** = Result qualitatively confirmed but not able to quantify.
- N** = Indicates presumptive evidence of a compound. This flag is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It is applied to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the N code is not used.
- X** = This flag is used for a TIC compound which is quantified relative to a response factor generated from a daily calibration standard (rather than quantified relative to the closest internal standard).
- Y** = Additional qualifiers used as required are explained in the case narrative.

GLOSSARY OF VOA DATA

ABBREVIATIONS

- BS** = Indicates blank spike in which reagent grade water is spiked with the CLP matrix spike solutions and carried through all the steps in the method. Spike recoveries are reported.
- BSD** = Indicates blank spike duplicate.
- MS** = Indicates matrix spike.
- MSD** = Indicates matrix spike duplicate.
- DL** = Suffix added to sample number to indicate that results are from a diluted analysis.
- NA** = Not Applicable.
- DF** = Dilution Factor.
- NR** = Not Required.
- SP, Z** = Indicates Spiked Compound.

Recra LabNet Philadelphia Sample Discrepancy Report (SDR) SDR #:

98VT350

Initiator: Meureen Brundage RFW Batch: 9808L40X
 Date: 9/1/98 Samples: Blank Spike
 Client: Black & Decker - Memphis Method: SW846/MCAWW/CLPI 8/00

Parameter: MSDAA
 Matrix: Water
 Prep Batch: 982VM368

1. Reason for SDR

a. COC Discrepancy Tech Profile Error Client Request Sampler Error on C-O-C
 Transcription Error Wrong Test Code Other _____

b. General Discrepancy

Missing Sample/Extract Container Broken Wrong Sample Pulled Label ID's Illegible
 Hold Time Exceeded Insufficient Sample Preservation Wrong Received Past Hold
 Improper Bottle Type Not Amenable to Analysis

Note: Verified by [Log-In] or [Prep Group] (circle)...signature/date: _____

c. QC Problem (Include all relevant specific results; attach data if necessary)

Surrogate recovery for 4-BFB was 11% in the blank spike. The QC limit is 116. All of the spikes were within QC limits. The surrogates and spikes in the associated MS & MSD samples were within QC limits.

2. Known or Probable Causes(s)

3. Discussion and Proposed Action

Other Description:

- Re-log
 - Entire Batch
 - Following Samples: _____
- Re-leach
- Re-extract
- Re-digest
- Revise EDD
- Change Test Code to _____
- Place On/Take Off Hold (circle)

Report blank spike and narrate.

MW 9/1/98

4. Project Manager Instructions...signature/date:

9/1/98

- Concur with Proposed Action
- Disagree with Proposed Action; See Instruction
- Include in Case Narrative
- Client Contacted: _____
- Date/Person: _____
- Add
- Cancel

5. Final Action...signature/date:

Other Explanation:

- Verified re-[log][leach][extract][digest][analysis] (circle)
- Included in Case Narrative
- Hard Copy COC Revised
- Electronic COC Revised
- EDD Corrections Completed

MD 10/1/98

When Final Action has been recorded, forward original to QA Specialist for distribution and filing.

Route	Distribution of <u>Completed SDR</u>
<input type="checkbox"/>	X Initiator
<input type="checkbox"/>	X Lab Manager: <u>Michael Taylor</u>
<input type="checkbox"/>	X Project Mgr: <u>Mike Young</u>
<input type="checkbox"/>	X Section Mgr: Siery/Durke/Daniels
<input type="checkbox"/>	X QA (file): Racioppi
<input type="checkbox"/>	Data Management: Feldman
<input type="checkbox"/>	Sample Prep: Schnell/Doughty/Kauffman

Route	Distribution of <u>Completed SDR</u>
<input type="checkbox"/>	Metals: Doughty
<input type="checkbox"/>	Inorganic: Perrone
<input type="checkbox"/>	GC/LC: Rycklak/Schnell
<input type="checkbox"/>	MS: LeMin/McIntyre/Taylor/Kasdras
<input type="checkbox"/>	Log-in: Toder
<input type="checkbox"/>	Admin: Soos
<input type="checkbox"/>	Other: _____

Recra LabNet - Lionville Laboratory

Volatile by GC/MS, HSL List

Report Date: 10/26/98 15:20

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 1a

Sample Information	Cust ID:	RFW-20	RFW-21	EW-2	EW-2 DUP	EW-3	EW-4
	RFW#:	001	002	003	004	005	006
	Matrix:	WATER	WATER	WATER	WATER	WATER	WATER
	D.F.:	1.00	1.00	20.0	20.0	5.00	20.0
	Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L
Surrogate Recovery	Toluene-d8	101 %	101 %	102 %	104 %	103 %	107 %
	Bromofluorobenzene	100 %	99 %	106 %	99 %	105 %	109 %
	1,2-Dichloroethane-d4	97 %	97 %	106 %	104 %	109 %	114 %
	Chloromethane	10 U	10 U	200 U	200 U	50 U	200 U
	Bromomethane	10 U	10 U	200 U	200 U	50 U	200 U
	Vinyl Chloride	10 U	10 U	200 U	200 U	50 U	200 U
	Chloroethane	10 U	10 U	200 U	200 U	50 U	200 U
	Methylene Chloride	2 BJ	2 BJ	480 B	460 B	130 B	67 BJ
	Acetone	6 BJ	10 U	200 U	200 U	14 BJ	200 U
	Carbon Disulfide	5 U	5 U	100 U	100 U	25 U	100 U
	1,1-Dichloroethene	5 U	5 U	100 U	100 U	25 U	100 U
	1,1-Dichloroethane	5 U	5 U	100 U	100 U	25 U	100 U
	1,2-Dichloroethene (total)	5 U	5 U	100 U	100 U	25 U	100 U
	Chloroform	5 U	5 U	100 U	100 U	25 U	100 U
	1,2-Dichloroethane	5 U	5 U	100 U	100 U	25 U	100 U
	2-Butanone	10 U	10 U	200 U	200 U	50 U	200 U
	1,1,1-Trichloroethane	5 U	5 U	100 U	100 U	25 U	100 U
	Carbon Tetrachloride	5 U	5 U	100 U	100 U	25 U	100 U
	Bromodichloromethane	5 U	5 U	100 U	100 U	25 U	100 U
	1,2-Dichloropropane	5 U	5 U	100 U	100 U	25 U	100 U
	cis-1,3-Dichloropropene	5 U	5 U	100 U	100 U	25 U	100 U
	Trichloroethene	10 U	5 U	2400	2400	830	2200
	Dibromochloromethane	5 U	5 U	100 U	100 U	25 U	100 U
	1,1,2-Trichloroethane	5 U	5 U	100 U	100 U	25 U	100 U
	Benzene	5 U	5 U	100 U	100 U	25 U	100 U
	Trans-1,3-Dichloropropene	5 U	5 U	100 U	100 U	25 U	100 U
	Bromoform	5 U	5 U	100 U	100 U	25 U	100 U
	4-Methyl-2-pentanone	10 U	10 U	200 U	200 U	50 U	200 U
	2-Hexanone	10 U	10 U	200 U	200 U	50 U	200 U
	Tetrachloroethene	5 U	5 U	76 BJ	81 BJ	13 BJ	39 BJ
	1,1,2,2-Tetrachloroethane	5 U	5 U	100 U	100 U	25 U	100 U
	Toluene	5 U	5 U	100 U	100 U	25 U	100 U

*= Outside of EPA CLP QC limits.

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 1b

Cust ID:	RFW-20	RFW-21	EW-2	EW-2 DUP	EW-3	EW-4
----------	--------	--------	------	----------	------	------

RFW#:	001	002	003	004	005	006
-------	-----	-----	-----	-----	-----	-----

Chlorobenzene	5 U	5 U	100 U	100 U	25 U	100 U
Ethylbenzene	5 U	5 U	100 U	100 U	25 U	100 U
Styrene	5 U	5 U	100 U	100 U	25 U	100 U
Xylene (total)	5 U	5 U	100 U	100 U	25 U	100 U

*= Outside of EPA CLP QC limits.

006

Recra LabNet - Lionville Laboratory

Volatile by GC/MS, HSL List

Report Date: 10/26/98 15:20

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 2a

Sample Information	Cust ID:	EW-5	EW-6	EW-6	EW-6	EW-7	EW-8
Sample	RFW#:	007	008	008 MS	008 MSD	009	010
Information	Matrix:	WATER	WATER	WATER	WATER	WATER	WATER
	D.F.:	10.0	1.00	1.00	1.00	1.00	1.00
	Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L
Toluene-d8		106 %	109 %	100 %	100 %	100 %	99 %
Surrogate	Bromofluorobenzene	105 %	102 %	102 %	101 %	99 %	98 %
Recovery	1,2-Dichloroethane-d4	110 %	101 %	109 %	107 %	99 %	94 %
Chloromethane		100 U	10 U	10 U	10 U	10 U	10 U
Bromomethane		100 U	10 U	10 U	10 U	10 U	10 U
Vinyl Chloride		100 U	10 U	10 U	10 U	10 U	10 U
Chloroethane		100 U	10 U	10 U	10 U	10 U	10 U
Methylene Chloride		31 BJ	24 B	3 BJ	3 BJ	2 BJ	2 BJ
Acetone		100 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide		50 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene		50 U	5 U	70 %	70 %	5 U	5 U
1,1-Dichloroethane		50 U	5 U	5 U	5 U	1 J	1 J
1,2-Dichloroethene (total)		50 U	5 U	5 U	5 U	8	31
Chloroform		50 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloroethane		50 U	5 U	5 U	5 U	5 U	5 U
2-Butanone		100 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane		50 U	5 U	5 U	5 U	5 U	5 U
Carbon Tetrachloride		50 U	5 U	5 U	5 U	5 U	5 U
Bromodichloromethane		50 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloropropane		50 U	5 U	5 U	5 U	5 U	5 U
cis-1,3-Dichloropropene		50 U	5 U	5 U	5 U	5 U	5 U
Trichloroethene		1500	12	90 %	88 %	12	18
Dibromochloromethane		50 U	5 U	5 U	5 U	5 U	5 U
1,1,2-Trichloroethane		50 U	5 U	5 U	5 U	5 U	5 U
Benzene		50 U	5 U	88 %	86 %	5 U	5 U
Trans-1,3-Dichloropropene		50 U	5 U	5 U	5 U	5 U	5 U
Bromoform		50 U	5 U	5 U	5 U	5 U	5 U
4-Methyl-2-pentanone		100 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone		100 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene		26 BJ	53 B	44 B	47 B	28	170
1,1,2,2-Tetrachloroethane		50 U	5 U	5 U	5 U	5 U	5 U
Toluene		50 U	5 U	94 %	92 %	5 U	5 U

*= Outside of EPA CLP QC limits.

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 2b

Cust ID:	EW-5	EW-6	EW-6	EW-6	EW-7	EW-8
----------	------	------	------	------	------	------

RFW#:	007	008	008 MS	008 MSD	009	010
-------	-----	-----	--------	---------	-----	-----

Chlorobenzene	50	U	5	U	94	%	93	%	5	U	5	U
Ethylbenzene	50	U	5	U	5	U	5	U	5	U	5	U
Styrene	50	U	5	U	5	U	5	U	5	U	5	U
Xylene (total)	50	U	5	U	5	U	5	U	5	U	5	U

*= Outside of EPA CLP QC limits.

008

Recra LabNet - Lionville Laboratory

Volatile by GC/MS, HSL List

Report Date: 10/26/98 15:20

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 3a

Sample Information	Cust ID:	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A						
	RFW#:	011	012	013	014	015	016						
	Matrix:	WATER	WATER	WATER	WATER	WATER	WATER						
	D.F.:	1.00	1.00	1.00	1.00	1.00	1.00						
	Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L						
Surrogate Recovery	Toluene-d8	102	%	100	%	103	%	100	%	101	%	105	%
	Bromofluorobenzene	100	%	99	%	98	%	96	%	98	%	102	%
	1,2-Dichloroethane-d4	96	%	94	%	93	%	94	%	95	%	103	%
	Chloromethane	10	U	10	U	10	U	10	U	10	U	10	U
	Bromomethane	10	U	10	U	10	U	10	U	10	U	10	U
	Vinyl Chloride	10	U	10	U	10	U	10	U	10	U	10	U
	Chloroethane	10	U	10	U	10	U	10	U	10	U	10	U
	Methylene Chloride	2	BJ	2	BJ	2	BJ	2	BJ	2	BJ	3	BJ
	Acetone	10	U	6	BJ	10	U	10	U	6	BJ	10	U
	Carbon Disulfide	5	U	5	U	5	U	5	U	5	U	5	U
	1,1-Dichloroethene	5	U	5	U	5	U	5	U	5	U	5	U
	1,1-Dichloroethane	5	U	5	U	5	U	5	U	5	U	5	U
	1,2-Dichloroethene (total)	5	U	5	U	5	U	5	U	1	J	5	U
	Chloroform	5	U	5	U	5	U	5	U	44		2	J
	1,2-Dichloroethane	5	U	5	U	5	U	5	U	5	U	1	J
	2-Butanone	10	U	10	U	10	U	10	U	10	U	10	U
	1,1,1-Trichloroethane	5	U	5	U	5	U	5	U	3	J	5	U
	Carbon Tetrachloride	5	U	5	U	5	U	5	U	5	U	5	U
	Bromodichloromethane	5	U	5	U	5	U	5	U	5	U	5	U
	1,2-Dichloropropane	5	U	5	U	5	U	5	U	5	U	5	U
	cis-1,3-Dichloropropene	5	U	5	U	5	U	5	U	5	U	5	U
	Trichloroethene	5	U	5	U	2	J	5	U	23		100	
	Dibromochloromethane	5	U	5	U	5	U	5	U	5	U	5	U
	1,1,2-Trichloroethane	5	U	5	U	5	U	5	U	5	U	5	U
	Benzene	5	U	5	U	5	U	5	U	5	U	5	U
	Trans-1,3-Dichloropropene	5	U	5	U	5	U	5	U	5	U	5	U
	Bromoform	5	U	5	U	5	U	5	U	5	U	5	U
	4-Methyl-2-pentanone	10	U	10	U	10	U	10	U	10	U	10	U
	2-Hexanone	10	U	10	U	10	U	10	U	10	U	10	U
	Tetrachloroethene	1	J	5	U	5	U	5	U	36		120	B
	1,1,2,2-Tetrachloroethane	5	U	5	U	5	U	5	U	5	U	5	U
	Toluene	5	U	5	U	5	U	5	U	5	U	5	U

*= Outside of EPA CLP QC limits.

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 3b

Cust ID: RFW-1A RFW-1B RFW-2A RFW-2B RFW-3B RFW-4A

RFW#: 011 012 013 014 015 016

Chlorobenzene	5 U	5 U	5 U	5 U	5 U	5 U
Ethylbenzene	5 U	5 U	5 U	5 U	5 U	5 U
Styrene	5 U	5 U	5 U	5 U	5 U	5 U
Xylene (total)	5 U	5 U	5 U	5 U	5 U	5 U

*= Outside of EPA CLP QC limits.

010

Recra LabNet - Lionville Laboratory

Volatile by GC/MS, HSL List

Report Date: 10/26/98 15:20

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 4a

	Cust ID:	RFW-4B	RFW-6	RFW-7	RFW-9	RFW-10	RFW-11A
Sample Information	RFW#:	017	018	019	020	021	022
	Matrix:	WATER	WATER	WATER	WATER	WATER	WATER
	D.F.:	1.00	1.00	1.00	1.00	10.0	1.00
	Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L
Toluene-d8		104 %	106 %	105 %	103 %	103 %	104 %
Surrogate	Bromofluorobenzene	107 %	105 %	101 %	103 %	103 %	94 %
Recovery	1,2-Dichloroethane-d4	113 %	110 %	107 %	108 %	104 %	98 %
Chloromethane		10 U	10 U	10 U	10 U	100 U	10 U
Bromomethane		10 U	10 U	10 U	10 U	100 U	10 U
Vinyl Chloride		10 U	10 U	10 U	10 U	100 U	10 U
Chloroethane		10 U	10 U	10 U	10 U	100 U	10 U
Methylene Chloride		2 BJ	2 BJ	2 BJ	5 U	24 BJ	2 BJ
Acetone		6 BJ	7 BJ	10 U	10 U	100 U	10 U
Carbon Disulfide		5 U	5 U	5 U	5 U	50 U	5 U
1,1-Dichloroethene		5 U	5 U	5 U	5 U	50 U	5 U
1,1-Dichloroethane		5 U	5 U	5 U	3 J	50 U	5 U
1,2-Dichloroethene (total)		3 J	1 J	5 U	9	50 U	5 U
Chloroform		2 J	5 U	5 U	5 U	50 U	5 U
1,2-Dichloroethane		5 U	5 U	5 U	5 U	50 U	5 U
2-Butanone		10 U	10 U	10 U	10 U	100 U	10 U
1,1,1-Trichloroethane		5 U	5 U	5 U	2 J	50 U	5 U
Carbon Tetrachloride		5 U	5 U	5 U	5 U	50 U	5 U
Bromodichloromethane		5 U	5 U	5 U	5 U	50 U	5 U
1,2-Dichloropropane		5 U	5 U	5 U	5 U	50 U	5 U
cis-1,3-Dichloropropene		5 U	5 U	5 U	5 U	50 U	5 U
Trichloroethene		110	15	10	24	1400	78
Dibromochloromethane		5 U	5 U	5 U	5 U	50 U	5 U
1,1,2-Trichloroethane		5 U	5 U	5 U	5 U	50 U	5 U
Benzene		5 U	5 U	5 U	5 U	50 U	5 U
Trans-1,3-Dichloropropene		5 U	5 U	5 U	5 U	50 U	5 U
Bromoform		5 U	5 U	5 U	5 U	50 U	5 U
4-Methyl-2-pentanone		10 U	10 U	10 U	10 U	100 U	10 U
2-Hexanone		10 U	10 U	10 U	10 U	100 U	10 U
Tetrachloroethene		170	13	5 U	11	25 J	1 J
1,1,2,2-Tetrachloroethane		5 U	5 U	5 U	5 U	50 U	5 U
Toluene		5 U	5 U	5 U	5 U	50 U	5 U

*= Outside of EPA CLP QC limits.

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 4b

Cust ID: RFW-4B RFW-6 RFW-7 RFW-9 RFW-10 RFW-11A

RFW#: 017 018 019 020 021 022

Chlorobenzene	5 U	5 U	5 U	5 U	50 U	5 U
Ethylbenzene	5 U	5 U	5 U	5 U	50 U	5 U
Styrene	5 U	5 U	5 U	5 U	50 U	5 U
Xylene (total)	5 U	5 U	5 U	5 U	50 U	5 U

*= Outside of EPA CLP QC limits.

012

Recra LabNet - Lionville Laboratory

Volatile by GC/MS, HSL List

Report Date: 10/26/98 15:20

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 5a

	Cust ID: RFW-11B DUP	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17			
Sample Information	RFW#:	023	024	025	026	027	028	013	
	Matrix:	WATER	WATER	WATER	WATER	WATER	WATER	WATER	
	D.F.:	1.00	1.00	20.0	1.00	1.00	1.00	1.00	
	Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L	
Toluene-d8	95	%	105	%	104	%	101	%	
Surrogate	Bromofluorobenzene	98	%	96	%	106	%	95	%
Recovery	1,2-Dichloroethane-d4	97	%	98	%	111	%	97	%
Chloromethane	10	U	10	U	200	U	10	U	
Bromomethane	10	U	10	U	200	U	10	U	
Vinyl Chloride	10	U	10	U	200	U	10	U	
Chloroethane	10	U	10	U	200	U	10	U	
Methylene Chloride	3	JB	22	B	66	BJ	2	BJ	
Acetone	10	U	10	U	200	U	4	BJ	
Carbon Disulfide	5	U	5	U	100	U	5	U	
1,1-Dichloroethene	5	U	5	U	100	U	5	U	
1,1-Dichloroethane	5	U	5	U	100	U	5	U	
1,2-Dichloroethene (total)	5	U	5	U	100	U	5	U	
Chloroform	5	U	5	U	100	U	5	U	
1,2-Dichloroethane	5	U	5	U	100	U	5	U	
2-Butanone	10	U	10	U	200	U	10	U	
1,1,1-Trichloroethane	5	U	5	U	100	U	5	U	
Carbon Tetrachloride	5	U	5	U	100	U	5	U	
Bromodichloromethane	5	U	5	U	100	U	5	U	
1,2-Dichloropropane	5	U	5	U	100	U	5	U	
cis-1,3-Dichloropropene	5	U	5	U	100	U	5	U	
Trichloroethene	76		80		2900		9		
Dibromochloromethane	5	U	5	U	100	U	5	U	
1,1,2-Trichloroethane	5	U	5	U	100	U	5	U	
Benzene	5	U	5	U	100	U	5	U	
Trans-1,3-Dichloropropene	5	U	5	U	100	U	5	U	
Bromoform	5	U	5	U	100	U	5	U	
4-Methyl-2-pentanone	10	U	10	U	200	U	10	U	
2-Hexanone	10	U	10	U	200	U	10	U	
Tetrachloroethene	2	J	2	BJ	54	BJ	55	B	
1,1,2,2-Tetrachloroethane	5	U	5	U	100	U	5	U	
Toluene	5	U	5	U	100	U	5	U	

*= Outside of EPA CLP QC limits.

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 5b

Cust ID: RFW-11B DUP

RFW-11B

RFW-12B

RFW-13

RFW-16

RFW-17

RFW#:

023

024

025

026

027

028

Chlorobenzene _____

5 U

5 U

100 U

5 U

5 U

5 U

Ethylbenzene _____

5 U

5 U

100 U

5 U

5 U

5 U

Styrene _____

5 U

5 U

100 U

5 U

5 U

5 U

Xylene (total) _____

5 U

5 U

100 U

5 U

5 U

5 U

*= Outside of EPA CLP QC limits.

100%

Recra LabNet - Lionville Laboratory

Volatile by GC/MS, HSL List

Report Date: 10/26/98 15:20

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 6a

	Cust ID:	RFW-17	RFW-17	RFW-18	RFW-19	EW-9	EW-10
Sample Information	RFW#:	028 MS	028 MSD	029	030	031	032 G
	Matrix:	WATER	WATER	WATER	WATER	WATER	WATER
	D.F.:	1.00	1.00	1.00	1.00	5.00	1.00
	Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L
Toluene-d8		96 %	93 %	99 %	101 %	98 %	101 %
Surrogate	Bromofluorobenzene	101 %	97 %	100 %	102 %	103 %	100 %
Recovery	1,2-Dichloroethane-d4	121 * %	116 * %	106 %	101 %	104 %	105 %
Chloromethane		10 U	2 BJ	10 U	10 U	50 U	10 U
Bromomethane		10 U	10 U	10 U	10 U	50 U	10 U
Vinyl Chloride		10 U	10 U	10 U	10 U	50 U	10 U
Chloroethane		10 U	10 U	10 U	10 U	50 U	10 U
Methylene Chloride		2 BJ	2 BJ	2 BJ	2 BJ	12 BJ	2 BJ
Acetone		10 U	10 U	10 U	10 U	50 U	10 U
Carbon Disulfide		5 U	5 U	5 U	5 U	25 U	5 U
1,1-Dichloroethene		71 %	71 %	5 U	5 U	25 U	5 U
1,1-Dichloroethane		5 U	5 U	5 U	5 U	25 U	5 U
1,2-Dichloroethene (total)		5 U	5 U	5 U	5 U	25 U	5 U
Chloroform		5 U	5 U	5 U	5 U	25 U	5 U
1,2-Dichloroethane		5 U	5 U	5 U	5 U	25 U	5 U
2-Butanone		10 U	10 U	10 U	10 U	50 U	10 U
1,1,1-Trichloroethane		5 U	5 U	5 U	5 U	25 U	5 U
Carbon Tetrachloride		5 U	5 U	5 U	5 U	25 U	5 U
Bromodichloromethane		5 U	5 U	5 U	5 U	25 U	5 U
1,2-Dichloropropane		5 U	5 U	5 U	5 U	25 U	5 U
cis-1,3-Dichloropropene		5 U	5 U	5 U	5 U	25 U	5 U
Trichloroethene		88 %	86 %	5 U	5 U	8 J	5 U
Dibromochloromethane		5 U	5 U	5 U	5 U	25 U	5 U
1,1,2-Trichloroethane		5 U	5 U	5 U	5 U	25 U	5 U
Benzene		96 %	92 %	5 U	5 U	25 U	5 U
Trans-1,3-Dichloropropene		5 U	5 U	5 U	5 U	25 U	5 U
Bromoform		5 U	5 U	5 U	5 U	25 U	5 U
4-Methyl-2-pentanone		10 U	10 U	10 U	10 U	50 U	10 U
2-Hexanone		10 U	10 U	10 U	10 U	50 U	10 U
Tetrachloroethene		5 U	5 U	5 U	5 U	730	72
1,1,2,2-Tetrachloroethane		5 U	5 U	5 U	5 U	25 U	5 U
Toluene		97 %	96 %	5 U	5 U	25 U	5 U

*= Outside of EPA CLP QC limits.

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 6b

Cust ID: RFW-17

RFW-17

RFW-18

RFW-19

EW-9

EW-10

RFW#: 028 MS

028 MSD

029

030

031

032

Chlorobenzene _____

95 %

95 %

5 U

5 U

25 U

5 U

Ethylbenzene _____

5 U

5 U

5 U

5 U

25 U

5 U

Styrene _____

5 U

5 U

5 U

5 U

25 U

5 U

Xylene (total) _____

5 U

5 U

5 U

5 U

25 U

5 U

*= Outside of EPA CLP QC limits.

016

Recra LabNet - Lionville Laboratory

Volatile by GC/MS, HSL List

Report Date: 10/26/98 15:20

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 7a

Cust ID:	HAMP-22	LEISTER-1	LEISTER-2	LEISTER-DAIR	TRIP BLANK	FB-RFW-7	
Sample Information	RFW#:	033	034	035	036	037	038
	Matrix:	WATER	WATER	WATER	WATER	WATER	WATER
	D.F.:	1.00	1.00	1.00	1.00	1.00	1.00
	Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L
Toluene-d8		90 %	100 %	99 %	101 %	100 %	102 %
Surrogate	Bromofluorobenzene	98 %	97 %	99 %	104 %	111 %	95 %
Recovery	1,2-Dichloroethane-d4	112 %	101 %	102 %	105 %	102 %	96 %
<hr/>							
Chloromethane		10 U	10 U	10 U	10 U	10 U	10 U
Bromomethane		10 U	10 U	10 U	10 U	10 U	10 U
Vinyl Chloride		10 U	10 U	10 U	10 U	10 U	10 U
Chloroethane		10 U	10 U	10 U	10 U	10 U	10 U
Methylene Chloride		2 BJ	2 BJ	2 BJ	2 BJ	3 BJ	2 BJ
Acetone		10 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide		5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene		5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloroethene (total)		5 U	5 U	5 U	5 U	5 U	5 U
Chloroform		5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloroethane		5 U	5 U	5 U	5 U	5 U	25
2-Butanone		10 U	10 U	10 U	10 U	10 U	5 U
1,1,1-Trichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
Carbon Tetrachloride		5 U	5 U	5 U	5 U	5 U	5 U
Bromodichloromethane		5 U	5 U	5 U	5 U	5 U	9
1,2-Dichloropropane		5 U	5 U	5 U	5 U	5 U	5 U
cis-1,3-Dichloropropene		5 U	5 U	5 U	5 U	5 U	5 U
Trichloroethene		5 U	5 U	5 U	5 U	5 U	5 U
Dibromochloromethane		5 U	5 U	5 U	5 U	5 U	2 J
1,1,2-Trichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
Benzene		5 U	5 U	5 U	5 U	5 U	5 U
Trans-1,3-Dichloropropene		5 U	5 U	5 U	5 U	5 U	5 U
Bromoform		5 U	5 U	5 U	5 U	5 U	5 U
4-Methyl-2-pentanone		10 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone		10 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene		5 U	5 U	5 U	5 U	5 U	5 U
1,1,2,2-Tetrachloroethane		5 U	5 U	5 U	5 U	5 U	5 U
Toluene		5 U	5 U	5 U	5 U	5 U	5 U

*= Outside of EPA CLP QC limits.

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 7b

Cust ID: HAMP-22 LEISTER-1 LEISTER-2 LEISTER-DAIR TRIP BLANK

FB-RFW-7

Y

RFW#:	033	034	035	036	037	038
Chlorobenzene	5 U	5 U	5 U	5 U	5 U	5 U
Ethylbenzene	5 U	5 U	5 U	5 U	5 U	5 U
Styrene	5 U	5 U	5 U	5 U	5 U	5 U
Xylene (total)	5 U	5 U	5 U	5 U	5 U	5 U

*= Outside of EPA CLP QC limits.

Recra LabNet - Lionville Laboratory

Volatile s by GC/MS, HSL List

Report Date: 10/26/98 15:20

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 8a

Sample Information	Cust ID:	VBLKAW	VBLKAU	VBLKAU BS	VBLKAT	VBLKTF	VBLKAS
	RFW#:	98LVH400-MB1	98LVN368-MB1	98LVN368-MB1	98LVN367-MB1	98LVH402-MB1	98LVN365-MB1
	Matrix:	WATER	WATER	WATER	WATER	WATER	WATER
	D.F.:	1.00	1.00	1.00	1.00	1.00	1.00
	Units:	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L
Surrogate	Toluene-d8	102 %	108 %	103 %	100 %	97 %	95 %
Recovery	Bromofluorobenzene	101 %	109 %	117 * %	100 %	98 %	97 %
	1,2-Dichloroethane-d4	99 %	108 %	109 %	105 %	99 %	100 %
<hr/>							
Chloromethane		10 U	10 U	10 U	1 J	10 U	10 U
Bromomethane		10 U					
Vinyl Chloride		10 U					
Chloroethane		10 U					
Methylene Chloride		2 J	4 J	3 BJ	3 J	3 J	2 J
Acetone		3 J	3 J	10 U	4 J	6 J	3 J
Carbon Disulfide		5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene		5 U	5 U	73 %	5 U	5 U	5 U
1,1-Dichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloroethene (total)		5 U	5 U	5 U	5 U	5 U	5 U
Chloroform		5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
2-Butanone		10 U					
1,1,1-Trichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
Carbon Tetrachloride		5 U	5 U	5 U	5 U	5 U	5 U
Bromodichloromethane		5 U	5 U	5 U	5 U	5 U	5 U
1,2-Dichloropropane		5 U	5 U	5 U	5 U	5 U	5 U
cis-1,3-Dichloropropene		5 U	5 U	5 U	5 U	5 U	5 U
Trichloroethene		5 U	5 U	87 %	5 U	5 U	5 U
Dibromochloromethane		5 U	5 U	5 U	5 U	5 U	5 U
1,1,2-Trichloroethane		5 U	5 U	5 U	5 U	5 U	5 U
Benzene		5 U	5 U	87 %	5 U	5 U	5 U
Trans-1,3-Dichloropropene		5 U	5 U	5 U	5 U	5 U	5 U
Bromoform		5 U	5 U	5 U	5 U	5 U	5 U
4-Methyl-2-pentanone		10 U					
2-Hexanone		10 U					
Tetrachloroethene		5 U	2 J	5 U	5 U	5 U	5 U
1,1,2,2-Tetrachloroethane		5 U	5 U	5 U	5 U	5 U	5 U
Toluene		5 U	5 U	96 %	5 U	5 U	5 U

*= Outside of EPA CLP QC limits.

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 8b

Cust ID: VBLKAW

VBLKAU

VBLKAU BS

VBLKAT

VBLKTF

VBLKAS

RFW#: 98LVH400-MB1 98LVN368-MB1 98LVN368-MB1 98LVN367-MB1 98LVH402-MB1 98LVN365-MB1

Chlorobenzene _____

5

U

5

U

95

%

5

U

5

U

5

U

Ethylbenzene _____

5

U

5

U

5

U

5

U

5

U

5

U

Styrene _____

5

U

5

U

5

U

5

U

5

U

5

U

Xylene (total) _____

5

U

5

U

5

U

5

U

5

U

5

U

*= Outside of EPA CLP QC limits.

020

Recra LabNet - Lionville Laboratory

Volatiles by GC/MS, HSL List

Report Date: 10/26/98 15:20

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPTON **Work Order:** 02501004001 **Page:** 9a

Cust ID: VBLKVT VBLKVT BS

Sample RFW#: 98LVN363-MB1 98LVN363-MB1
Information Matrix: WATER WATER
D.F.: 1.00 1.00
Units: UG/L UG/L

Toluene-d8	98	%	98
Surrogate Bromofluorobenzene	98	%	96
Recovery 1,2-Dichloroethane-d4	107	%	109
=====fl=====			
Chloromethane	2	J	10
Bromomethane	10	U	10
Vinyl Chloride	10	U	10
Chloroethane	10	U	10
Methylene Chloride	2	J	2
Acetone	4	J	10
Carbon Disulfide	5	U	5
1,1-Dichloroethene	5	U	85
1,1-Dichloroethane	5	U	5
1,2-Dichloroethene (total)	5	U	5
Chloroform	5	U	5
1,2-Dichloroethane	5	U	5
2-Butanone	10	U	10
1,1,1-Trichloroethane	5	U	5
Carbon Tetrachloride	5	U	5
Bromodichloromethane	5	U	5
1,2-Dichloropropane	5	U	5
cis-1,3-Dichloropropene	5	U	5
Trichloroethene	5	U	93
Dibromochloromethane	5	U	5
1,1,2-Trichloroethane	5	U	5
Benzene	5	U	96
Trans-1,3-Dichloropropene	5	U	5
Bromoform	5	U	5
4-Methyl-2-pentanone	10	U	10
2-Hexanone	10	U	10
Tetrachloroethene	5	U	5
1,1,2,2-Tetrachloroethane	5	U	5
Toluene	5	U	102

* = Outside of EPA CLP QC limits.

120

RFW Batch Number: 9808L402

Client: BLACK&DECKER-HAMPSTEAD

Work Order: 02501004001 Page: 9b

Cust ID: VBLKVT

VBLKVT BS

RFW#: 98LVN363-MB1 98LVN363-MB1

Chlorobenzene _____

5 U 99 %

Ethylbenzene _____

5 U 5 U

Styrene _____

5 U 5 U

Xylene (total) _____

5 U 5 U

*= Outside of EPA CLP QC limits.

022

1E

CLIENT SAMPLE NO.

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDSLab Name: Recra.LabNetWork Order: 02501004001

RFW-20

Client: BLACK&DECKER-HAMPSTEADMatrix: WATER Lab Sample ID: 9808L402-001Sample wt/vol: 5.00 (g/mL) ML Lab File ID: h083006Level: (low/med) LOW Date Received: 08/20/98% Moisture: not dec. Date Analyzed: 08/30/98Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

RFW-21

Lab Name: Recra.LabNet Work Order: 02501004001

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-002

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: h083007

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/30/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNetWork Order: 02501004001

EW-2

Client: BLACK&DECKER-HAMPSTEADMatrix: WATERLab Sample ID: 9808L402-003Sample wt/vol: 5.00 (g/mL) MLLab File ID: n083133Level: (low/med) LOWDate Received: 08/20/98% Moisture: not dec. Date Analyzed: 08/31/98Column: (pack/cap) CAPDilution Factor: 20.0

CONCENTRATION UNITS:

Number TICs found: 1(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1. 75456	METHANE, CHLORODIFLUORO-	3.818	200	NJ

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

EW-2 DUP

Lab Name: Recra.LabNet Work Order: 02501004001

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-004

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083134

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/31/98

Column: (pack/cap) CAP Dilution Factor: 20.0

CONCENTRATION UNITS:

Number TICs found: 1 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1. 75456	METHANE, CHLORODIFLUORO-	3.816	200	NJ

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNetWork Order: 02501004001

EW-3

Client: BLACK&DECKER-HAMPSTEADMatrix: WATER Lab Sample ID: 9808L402-005Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083130Level: (low/med) LOW Date Received: 08/20/98% Moisture: not dec. Date Analyzed: 08/31/98Column: (pack/cap) CAP Dilution Factor: 5.00

CONCENTRATION UNITS:

Number TICs found: 1 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1. 75456	METHANE, CHLORODIFLUORO-	3.815	60	NJ

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNet Work Order: 02501004001

EW-4

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER

Lab Sample ID: 9808L402-006

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: n083135

Level: (low/med) LOW

Date Received: 08/20/98

% Moisture: not dec.

Date Analyzed: 08/31/98

Column: (pack/cap) CAP

Dilution Factor: 20.0

CONCENTRATION UNITS:

Number TICs found: 0

(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNet Work Order: 02501004001

EW-5

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-007

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083137

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/31/98

Column: (pack/cap) CAP Dilution Factor: 10.0

CONCENTRATION UNITS:
Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
=====	=====	=====	=====	=====
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

EW-6

Lab Name: Recra.LabNet Work Order: 02501004001

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-008

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083128

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/31/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 1 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1. 75456	METHANE, CHLORODIFLUORO-	3.828	10	NJ

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDSLab Name: Recra.LabNetWork Order: 02501004001

EW-7

Client: BLACK&DECKER-HAMPSTEADMatrix: WATER Lab Sample ID: 9808L402-009Sample wt/vol: 5.00 (g/mL) ML Lab File ID: h083014Level: (low/med) LOW Date Received: 08/20/98% Moisture: not dec. Date Analyzed: 08/30/98Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

EW-8

Lab Name: Recra.LabNet Work Order: 02501004001

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-010

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: h083015

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/30/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNetWork Order: 02501004001

RFW-1A

Client: BLACK&DECKER-HAMPSTEADMatrix: WATER Lab Sample ID: 9808L402-011Sample wt/vol: 5.00 (g/mL) ML Lab File ID: h083016Level: (low/med) LOW Date Received: 08/20/98% Moisture: not dec. Date Analyzed: 08/30/98Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNet Work Order: 02501004001

RFW-1B

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-012

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: h083017

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/30/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
=====	=====	=====	=====	=====
1.				

1E

CLIENT SAMPLE NO.

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDSLab Name: Recra.LabNetWork Order: 02501004001

RFW-2A

Client: BLACK&DECKER-HAMPSTEADMatrix: WATERLab Sample ID: 9808L402-013Sample wt/vol: 5.00 (g/mL) MLLab File ID: h083018Level: (low/med) LOWDate Received: 08/20/98% Moisture: not dec. Date Analyzed: 08/30/98Column: (pack/cap) CAPDilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
=====	=====	=====	=====	=====
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

RFW-2B

Lab Name: Recra.LabNet Work Order: 02501004001

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-014

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: h083019

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/30/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNet Work Order: 02501004001

RFW-3B

Client: BLACK&DECKER-HAMPSTEADMatrix: WATER Lab Sample ID: 9808L402-015Sample wt/vol: 5.00 (g/mL) ML Lab File ID: h083020Level: (low/med) LOW Date Received: 08/20/98% Moisture: not dec. _____ Date Analyzed: 08/30/98Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

RFW-4A

Lab Name: Recra.LabNet Work Order: 02501004001

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-016

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083138

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/31/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNet Work Order: 02501004001

RFW-4B

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-017

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083121

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/31/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNet Work Order: 02501004001

RFW-6

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-018

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083120

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/31/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNetWork Order: 02501004001RFW-7Client: BLACK&DECKER-HAMPSTEADMatrix: WATER Lab Sample ID: 9808L402-019Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083119Level: (low/med) LOW Date Received: 08/20/98% Moisture: not dec. Date Analyzed: 08/31/98Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

RFW-9

Lab Name: Recra.LabNet Work Order: 02501004001

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-020

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083118

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/31/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNet Work Order: 02501004001

RFW-10

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-021

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083117

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. _____ Date Analyzed: 08/31/98

Column: (pack/cap) CAP Dilution Factor: 10.0

CONCENTRATION UNITS:

Number TICs found: 1 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.	UNKNOWN	6.156	70	J

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

RFW-11A

Lab Name: Recra.LabNet Work Order: 02501004001

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-022

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083116

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/31/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNetWork Order: 02501004001

RFW-11B DUP

Client: BLACK&DECKER-HAMPSTEADMatrix: WATER Lab Sample ID: 9808L402-023Sample wt/vol: 5.00 (g/mL) ML Lab File ID: h083116Level: (low/med) LOW Date Received: 08/20/98% Moisture: not dec. Date Analyzed: 08/31/98Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

RFW-11B

Lab Name: Recra.LabNet Work Order: 02501004001

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-024

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083127

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/31/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 1 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1. 75456	METHANE, CHLORODIFLUORO-	3.834	10	NJ

1E

CLIENT SAMPLE NO.

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDSLab Name: Recra.LabNetWork Order: 02501004001

RFW-12B

Client: BLACK&DECKER-HAMPSTEADMatrix: WATERLab Sample ID: 9808L402-025Sample wt/vol: 5.00 (g/mL) MLLab File ID: n083136Level: (low/med) LOWDate Received: 08/20/98% Moisture: not dec. Date Analyzed: 08/31/98Column: (pack/cap) CAPDilution Factor: 20.0

CONCENTRATION UNITS:

Number TICs found: 0(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

RFW-13

Lab Name: Recra.LabNet Work Order: 02501004001

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-026

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083111

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/31/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
=====	=====	=====	=====	=====
1.				

1E

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNetWork Order: 02501004001

RFW-16

Client: BLACK&DECKER-HAMPSTEADMatrix: WATERLab Sample ID: 9808L402-027Sample wt/vol: 5.00 (g/mL) MLLab File ID: n083023Level: (low/med) LOWDate Received: 08/20/98% Moisture: not dec. Date Analyzed: 08/30/98Column: (pack/cap) CAPDilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
=====	=====	=====	=====	=====
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

RFW-17

Lab Name: Recra.LabNet Work Order: 02501004001

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-028

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n082919

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/30/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 1 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.	UNKNOWN	9.401	8	J

1E

CLIENT SAMPLE NO.

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDSLab Name: Recra.LabNetWork Order: 02501004001

RFW-18

Client: BLACK&DECKER-HAMPSTEADMatrix: WATER Lab Sample ID: 9808L402-029Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083021Level: (low/med) LOW Date Received: 08/20/98% Moisture: not dec. _____ Date Analyzed: 08/30/98Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

RFW-19

Lab Name: Recra.LabNet Work Order: 02501004001

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-030

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083020

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/30/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E

CLIENT SAMPLE NO.

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDSLab Name: Recra.LabNetWork Order: 02501004001

EW-9

Client: BLACK&DECKER-HAMPSTEADMatrix: WATER Lab Sample ID: 9808L402-031Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083110Level: (low/med) LOW Date Received: 08/20/98% Moisture: not dec. Date Analyzed: 08/31/98Column: (pack/cap) CAP Dilution Factor: 5.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
=====	=====	=====	=====	=====
1.				

1E

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNetWork Order: 02501004001

EW-10

Client: BLACK&DECKER-HAMPSTEADMatrix: WATER Lab Sample ID: 9808L402-032Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083018Level: (low/med) LOW Date Received: 08/20/98% Moisture: not dec. Date Analyzed: 08/30/98Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNet Work Order: 02501004001HAMP-22Client: BLACK&DECKER-HAMPSTEADMatrix: WATER Lab Sample ID: 9808L402-033Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083017Level: (low/med) LOW Date Received: 08/20/98% Moisture: not dec. _____ Date Analyzed: 08/30/98Column: (pack/cap) CAP Dilution Factor: 1.00CONCENTRATION UNITS:
Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

LEISTER-1

Lab Name: Recra.LabNet Work Order: 02501004001

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-034

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083022

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/30/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNetWork Order: 02501004001LEISTER-2Client: BLACK&DECKER-HAMPSTEADMatrix: WATERLab Sample ID: 9808L402-035Sample wt/vol: 5.00 (g/mL) MLLab File ID: n083015Level: (low/med) LOWDate Received: 08/20/98% Moisture: not dec. Date Analyzed: 08/30/98Column: (pack/cap) CAPDilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 2(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1. 1634044	PROPANE, 2-METHOXY-2-METHYL-	9.386	500	NJ
2. 994058	BUTANE, 2-METHOXY-2-METHYL-	13.104	30	J

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNet Work Order: 02501004001

|LEISTER-DAIRY

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-036

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083014

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/30/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

TRIP BLANK

Lab Name: Recra.LabNetWork Order: 02501004001Client: BLACK&DECKER-HAMPSTEADMatrix: WATER Lab Sample ID: 9808L402-037Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083012Level: (low/med) LOW Date Received: 08/20/98% Moisture: not dec. Date Analyzed: 08/30/98Column: (pack/cap) CAP Dilution Factor: 1.00CONCENTRATION UNITS:
Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

FB-RFW-7

Lab Name: Recra.LabNet Work Order: 02501004001

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 9808L402-038

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083013

Level: (low/med) LOW Date Received: 08/20/98

% Moisture: not dec. Date Analyzed: 08/30/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:
Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E

CLIENT SAMPLE NO.

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDSLab Name: Recra.LabNetWork Order: 02501004001

VBLKAW

Client: BLACK&DECKER-HAMPSTEADMatrix: WATERLab Sample ID: 98LVH400-MB1Sample wt/vol: 5.00 (g/mL) MLLab File ID: h083005Level: (low/med) LOWDate Received: 08/30/98

% Moisture: not dec. _____

Date Analyzed: 08/30/98Column: (pack/cap) CAPDilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNet Work Order: 02501004001

VBLKAU

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER

Lab Sample ID: 98LVN368-MB1

Sample wt/vol: 5.00 (g/mL) ML

Lab File ID: n083125

Level: (low/med) LOW

Date Received: 08/31/98

% Moisture: not dec.

Date Analyzed: 08/31/98

Column: (pack/cap) CAP

Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0

(ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNet Work Order: 02501004001

VBLKAT

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 98LVN367-MB1

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083107

Level: (low/med) LOW Date Received: 08/31/98

% Moisture: not dec. _____ Date Analyzed: 08/31/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E
VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

VBLKTF

Lab Name: Recra.LabNet Work Order: 02501004001

Client: BLACK&DECKER-HAMPSTEAD

Matrix: WATER Lab Sample ID: 98LVH402-MB1

Sample wt/vol: 5.00 (g/mL) ML Lab File ID: h083115

Level: (low/med) LOW Date Received: 08/31/98

% Moisture: not dec. Date Analyzed: 08/31/98

Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:
Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

1E

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

Lab Name: Recra.LabNetWork Order: 02501004001

VBLKAS

Client: BLACK&DECKER-HAMPSTEADMatrix: WATER Lab Sample ID: 98LVN365-MB1Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n083011Level: (low/med) LOW Date Received: 08/30/98% Moisture: not dec. Date Analyzed: 08/30/98Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
=====	=====	=====	=====	=====
1.				

1E

VOLATILE ORGANICS ANALYSIS SHEET
TENTATIVELY IDENTIFIED COMPOUNDS

CLIENT SAMPLE NO.

VBLKVT

Lab Name: Recra.LabNet Work Order: 02501004001Client: BLACK&DECKER-HAMPSTEADMatrix: WATER Lab Sample ID: 98LVN363-MB1Sample wt/vol: 5.00 (g/mL) ML Lab File ID: n082905Level: (low/med) LOW Date Received: 08/29/98% Moisture: not dec. Date Analyzed: 08/29/98Column: (pack/cap) CAP Dilution Factor: 1.00

CONCENTRATION UNITS:

Number TICs found: 0 (ug/L or ug/Kg) UG/L

CAS NUMBER	COMPOUND NAME	RT	EST. CONC.	Q
1.				

Recra LabNet - Lionville Laboratory
 VOA ANALYTICAL DATA PACKAGE FOR
 BLACK&DECKER-HAMPSTEAD

DATE RECEIVED: 08/20/98

RFW LOT # :9808L402

CLIENT ID	RFW #	MTX	PREP #	COLLECTION	EXTR/PREP	ANALYSIS
RFW-20	001	W	98LVH400	08/18/98	N/A	08/30/98
RFW-21	002	W	98LVH400	08/18/98	N/A	08/30/98
EW-2	003	W	98LVN368	08/18/98	N/A	08/31/98
EW-2 DUP	004	W	98LVN368	08/18/98	N/A	08/31/98
EW-3	005	W	98LVN368	08/19/98	N/A	08/31/98
EW-4	006	W	98LVN368	08/19/98	N/A	08/31/98
EW-5	007	W	98LVN368	08/18/98	N/A	08/31/98
EW-6	008	W	98LVN368	08/19/98	N/A	08/31/98
EW-6	008 MS	W	98LVN368	08/19/98	N/A	08/31/98
EW-6	008 MSD	W	98LVN368	08/19/98	N/A	08/31/98
EW-7	009	W	98LVH400	08/19/98	N/A	08/30/98
EW-8	010	W	98LVH400	08/19/98	N/A	08/30/98
RFW-1A	011	W	98LVH400	08/18/98	N/A	08/30/98
RFW-1B	012	W	98LVH400	08/18/98	N/A	08/30/98
RFW-2A	013	W	98LVH400	08/18/98	N/A	08/30/98
RFW-2B	014	W	98LVH400	08/18/98	N/A	08/30/98
RFW-3B	015	W	98LVH400	08/19/98	N/A	08/30/98
RFW-4A	016	W	98LVN368	08/19/98	N/A	08/31/98
RFW-4B	017	W	98LVN367	08/19/98	N/A	08/31/98
RFW-6	018	W	98LVN367	08/19/98	N/A	08/31/98
RFW-7	019	W	98LVN367	08/18/98	N/A	08/31/98
RFW-9	020	W	98LVN367	08/19/98	N/A	08/31/98
RFW-10	021	W	98LVN367	08/19/98	N/A	08/31/98
RFW-11A	022	W	98LVN367	08/19/98	N/A	08/31/98
RFW-11B DUP	023	W	98LVH402	08/19/98	N/A	08/31/98
RFW-11B	024	W	98LVN368	08/19/98	N/A	08/31/98
RFW-12B	025	W	98LVN368	08/19/98	N/A	08/31/98
RFW-13	026	W	98LVN367	08/19/98	N/A	08/31/98
RFW-16	027	W	98LVN365	08/19/98	N/A	08/30/98
RFW-17	028	W	98LVN363	08/18/98	N/A	08/30/98
RFW-17	028 MS	W	98LVN363	08/18/98	N/A	08/30/98
RFW-17	028 MSD	W	98LVN363	08/18/98	N/A	08/30/98
RFW-18	029	W	98LVN365	08/18/98	N/A	08/30/98
RFW-19	030	W	98LVN365	08/18/98	N/A	08/30/98
EW-9	031	W	98LVN367	08/19/98	N/A	08/31/98
EW-10	032	W	98LVN365	08/19/98	N/A	08/30/98
HAMP-22	033	W	98LVN365	08/19/98	N/A	08/30/98
LEISTER-1	034	W	98LVN365	08/18/98	N/A	08/30/98

Recra LabNet - Lionville Laboratory
 VOA ANALYTICAL DATA PACKAGE FOR
 BLACK&DECKER-HAMPSTEAD

DATE RECEIVED: 08/20/98

RFW LOT # :9808L402

CLIENT ID	RFW #	MTX	PREP #	COLLECTION	EXTR/PREP	ANALYSIS
LEISTER-2	035	W	98LVN365	08/18/98	N/A	08/30/98
LEISTER-DAIRY	036	W	98LVN365	08/18/98	N/A	08/30/98
TRIP BLANK	037	W	98LVN365	08/18/98	N/A	08/30/98
FB-RFW-7	038	W	98LVN365	08/18/98	N/A	08/30/98

LAB QC:

VBLKAW	MB1	W	98LVH400	N/A	N/A	08/30/98
VBLKAU	MB1	W	98LVN368	N/A	N/A	08/31/98
VBLKAU	MB1 BS	W	98LVN368	N/A	N/A	09/01/98
VBLKAT	MB1	W	98LVN367	N/A	N/A	08/31/98
VBLKTF	MB1	W	98LVH402	N/A	N/A	08/31/98
VBLKAS	MB1	W	98LVN365	N/A	N/A	08/30/98
VBLKVT	MB1	W	98LVN363	N/A	N/A	08/29/98
VBLKVT	MB1 BS	W	98LVN363	N/A	N/A	08/29/98

RECRA LabNet Use Only

9808L402

(7) GCMS ROA,
Custody Transfer Record/Lab Work Request Page 1 of 4

FIELD PERSONNEL: COMPLETE ONLY SHADED AREAS



Client B&D Black+Decker-Hampstead
 Est. Final Proj. Sampling Date _____
 Project # 025D1-004-00-0200-00
 Project Contact/Phone # Greg E.
 RECRA Project Manager Mike Young
 QC SW846 Del STD TAT 28 day
 Date Rec'd 8/90/98 Date Due 9/17/98
 Account # _____

MATRIX CODES:
 S - Soil
 SE - Sediment
 SO - Solid
 SL - Sludge
 W - Water
 O - Oil
 A - Air
 DS - Drum Solids
 DL - Drum Liquids
 L - EP/TCLP Leachate
 WI - Wipe
 X - Other
 F - Fish

Lab ID	Client ID/Description	Matrix QC Chosen (✓)	Refrigerator #			ANALYSES REQUESTED →	ORGANIC			INORG					
			#/Type Container	Liquid	1		VOA	BNA	Pest PCB	Hg	Metal				
				Solid	2										
			Volume	Liquid	40mL										
				Solid											
			Preservatives	HCl											
601	RFW-2D		Matrix	Date Collected	Time Collected	RELAH	↓ RECRA LabNet Use Only ↓								
12	RFW-01			W 8/18	X										
3	EW-2														
4	EW-2P														
5	EW-3			3/19											
6	EW-4														
7	EW-5														
8	EW-6			8/18											
9	EW-7			8/19											
10	EW-8														

Special Instructions:

DATE/REVISONS:

0009027 sediment on bottom
 029, 030. samples have same ID
 3. no time collected on COC
 4. can not match w/HGS (w/PM)
 8/24/98 5. 029 has correct ID
 6. Q30 FD shq w/ RFW/PM, COC
 7. 030 has correct ID

• Relinquished by	Received by	Date	Time
<u>Hicks</u>	<u>Henry</u>	8-20-98	1145

Relinquished by	Received by	Date	Time

Discrepancies Between Samples Labels and COC Record? Y or N			
NOTES:			

RECRA LabNet Use Only	
Samples were:	
1) Shipped	or Hand Delivered <input checked="" type="checkbox"/>
COC Tape was:	
1) Present on Outer Package	<input checked="" type="checkbox"/> Y or N
2) Unbroken on Outer Package	<input checked="" type="checkbox"/> Y or N
3) Present on Sample	<input checked="" type="checkbox"/> Y or N
4) Unbroken on Sample	<input checked="" type="checkbox"/> Y or N
COC Record Present Upon Sample Rec'd	
5) Received Within Holding Times	<input checked="" type="checkbox"/> Y or N
Cooler Temp	<input checked="" type="checkbox"/> 6 C