

Quarterly Groundwater Monitoring Report

Prepared for

Black & Decker (U.S.) Inc.

Hampstead, Maryland

October 2005

Prepared by

WESTON SOLUTIONS, INC.

West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A – GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B – DISCHARGE MONITORING REPORTS

APPENDIX C – GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D – GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 3 rd Quarter 2005	2-2
Table 2-2 Groundwater Elevation Data – 3 rd Quarter 2005.....	2-3
Table 2-3 Effluent Characteristics Summary – 3 rd Quarter 2005	2-4
Table 2-4 Summary of Groundwater Analytical Results – August 2005	2-6
Table 3-1 Treatment System Maintenance Activities – 3 rd Quarter 2005	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of July through September 2005.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. At the time the water level measurements were collected, the extraction wells were pumping at an average combined rate of 166 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of July through September 2005 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of July through September 2005, approximately 41 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (70 %) and tetrachlorethene (PCE) (30 %). Analytical results of the groundwater collected at the inlet to the air stripper for the period of July through September 2005 are included in Appendix C.

Table 2-1
Treatment System Pumping Records - 3rd Quarter 2005
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
July 2005	7,238,781
August 2005	7,117,255
September 2005	6,741,037

Table 2-2
Groundwater Elevation Data - 3rd Quarter 2005
Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV.	TOTAL DEPTH	7/13/2005		8/18/2005		9/30/05	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NA	DRY	NA	DRY	NA
EW-2	849.21	110	91.42	757.79	101.30	747.91	92.84	756.37
EW-3	846.64	118	88.18	758.46	89.43	757.21	89.40	757.24
EW-4	858.01	97.5	NA	NA	NA	NA	NA	NA
EW-5	864.17	98	90.89	773.28	90.66	773.51	91.47	772.70
EW-6	831.98	115	82.11	749.87	82.72	749.26	83.67	748.31
EW-7	818.38	78	42.13	776.25	38.45	779.93	49.41	768.97
EW-8	811.13	98	43.58	767.55	44.81	766.32	47.38	763.75
EW-9	811.35	141	94.73	716.62	104.50	706.85	96.88	714.47
EW-10	807.74	NA	44.86	762.88	42.71	765.03	48.00	759.74
RFW-1A	864.37	78	50.43	813.94	49.43	814.94	51.55	812.82
RFW-1B	864.23	200	50.45	813.78	49.46	814.77	51.58	812.65
RFW-2A	857.41	35	13.07	844.34	15.71	841.70	14.11	843.30
RFW-2B	857.73	75	13.84	843.89	16.32	841.41	14.68	843.05
RFW-3B	839.21	153	27.26	811.95	30.37	808.84	29.32	809.89
RFW-4A	830.37	62	36.96	793.41	37.90	792.47	38.77	791.60
RFW-4B	830.37	120	36.84	793.53	37.76	792.61	38.70	791.67
RFW-5A	817.50	30	DRY	NA	DRY	NA	DRY	NA
RFW-6	785.04	120	2.94	782.10	3.99	781.05	4.23	780.81
RFW-7	805.14	29	7.57	797.57	7.51	797.63	8.19	796.95
RFW-8	860.07	56	DRY	NA	DRY	NA	DRY	NA
RFW-9	862.02	49	25.11	836.91	26.43	835.59	27.43	834.59
RFW-10	852.06	58	DRY	NA	DRY	NA	DRY	NA
RFW-11A	849.32	72	NA	NA	NA	NA	NA	NA
RFW-11B	849.62	116	71.11	778.51	70.14	779.48	72.46	777.16
RFW-12B	844.87	264	51.47	793.40	51.42	793.45	55.69	789.18
RFW-13	849.11	150	59.13	789.98	58.93	790.18	60.31	788.80
RFW-14B	812.39	281	33.91	778.48	34.43	777.96	34.44	777.95
RFW-16	856.14	41	DRY	NA	DRY	NA	DRY	856.14
RFW-17	834.66	60.5	25.99	808.67	27.01	807.65	27.76	806.90
RFW-20	842.49	142	33.47	809.02	34.14	808.35	34.11	808.38
RFW-21	832.65	102	21.26	811.39	21.76	810.89	22.69	809.96
PH-7	805.94	89	19.00	786.94	19.56	786.38	19.76	786.18
PH-9	814.94	98	31.17	783.77	32.90	782.04	33.13	781.81
PH-11	820.68	78	42.03	778.65	42.38	778.30	43.94	776.74
PH-12	828.35	87	42.93	785.42	43.67	784.68	44.27	784.08
B-3	803.02	83	NA	NA	NA	NA	NA	NA
Amoco	842.29	NA	NA	NA	NA	NA	NA	NA
Hamp. Town #22	804.96	NA	31.40	773.56	29.56	775.40	19.57	785.39
Pembroke #1	NA	NA	11.99	NA	12.35	NA	12.68	NA
Pembroke #2	NA	NA	NA	NA	NA	NA	NA	NA
N. Houcks. Rd.	NA	NA	10.18	NA	10.80	NA	9.89	NA
E. Century St.	NA	NA	29.11	NA	26.53	NA	27.59	NA
Lwr. Beckleys. Rd.	NA	NA	52.26	NA	NA	NA	54.26	NA

NA - Not Available/Not Accessible

Table 2-3
Effluent Characteristics Summary - 3rd Quarter 2005
Black & Decker
Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				July 2005	August 2005	September 2005	
001	FLOW	average	MGD	NA	0.338	0.113	0.057
		maximum	MGD	NA	1.141	1.141	0.064
	1,1,1-Trichloroethane	ug/l	5	< 5	< 5	< 5	
	Tetrachloroethylene	ug/l	5	< 5	< 5	< 5	
	Trichloroethylene	ug/l	5	< 5	< 5	< 5	
	Total Residual Chlorine	mg/l	< 0.1	< 0.1	< 0.1	< 0.1	
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		quarterly average	mg/l	10	NR	NR	< 5
	pH	minimum	STD	6.0	6.20	6.10	6.30
		maximum	STD	8.5	7.00	6.90	6.70
	BOD		mg/l	15	5.0	< 2	7.0
	TSS	maximum	mg/l	30	13.0	8.0	14.0
quarterly average		mg/l	20	NR	NR	12.0	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.257	0.260	0.237
		maximum	MGD	NA	0.290	0.268	0.277
	Fecal Coliform	MPN/100ml	200	< 2	< 2	< 2	
201 (Monitoring Point)	FLOW	average	MGD	NA	0.234	0.230	0.225
		maximum	MGD	NA	0.277	0.278	0.273
	1,1,1-Trichloroethane	ug/l	NA	< 5	< 5	< 5	
	Tetrachloroethylene	ug/l	NA	< 5	< 5	< 5	
	Trichloroethylene	ug/l	NA	< 5	< 5	< 5	

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

A summary of the analytical results from the third quarter (August 2005) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete analytical data package is included in Appendix D. As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater samples collected from extraction well EW-9. The remainder of VOC's present were detected at levels well below the Federal Maximum Contaminant Levels (MCL).

Table 2-4
Summary of Groundwater Analytical Results - August 2005
Black & Decker
Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-5 (DUP)	EW-6	EW-7	EW-8	EW-9	EW-10
Chloromethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Acetone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	5 U	1 J	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 J	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	4	2.4	5 U	1 U	1 U	1 U	5.3	21	1.2	1 U
Chloroform	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	740	230	950	410	390	8.8	4.4	10	2.3	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	68	5.5	27	13	13	21	6.9	63	180	10
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
J = Indicates an estimated value.

Table 2-4
Summary of Groundwater Analytical Results - August 2005
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1.2	1 U	1 U	1 U	NS	1 U	1 U	NS	1.6	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.2	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	10	1.8	1.7	6.6	NS	1.6	1 U	NS	12	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	1.3	1.2	0.9 J	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	2	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	1.5	1 U	7.9	56	55	18	NS	9.9	11	NS	21	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	8.2	65	63	60	NS	6.8	1 U	NS	5	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicate sample
NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
J = Indicates an estimated value.

Table 2-4
Summary of Groundwater Analytical Results - August 2005
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	RFW-20	RFW-21	Town #22	Town #23	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	NA	NA	NA	NA	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1.1	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	6.6	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	31	550	3.1	NS	1 U	1.5	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	1 U	40	16	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	1 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division. Samples from all of the other wells are analyzed with USEPA Method 8260.

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (July through September 2005) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 3rd Quarter 2005
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Jul-05	Replaced the integrater for the flow meter in well EW-8.
Aug-05	Replaced the integrater for the flow meter in well EW-2.

4. RECOMMENDATIONS

For the reporting period of July through September 2005, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(JULY - SEPTEMBER 2005)

Month / Year

July 2005

Black & Decker
Air Stripper # 2
Operating Record

Past Month Reading

37618663

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	F	1040	37846003	↑	25938	25904
2						
3						
4	Holiday			939078		
5	T	1035	38785081	238789	25938	26000
6	W	1100	39023876	231664	25902	26000
7	T	1045	39255534	259760	25986	26000
8	F	1320	39515494	↑	26013	26000
9						
10				698558		
11	M	1245	40214052	241825	26084	26000
12	T	1325	40455877	225144	26084	26025
13	W	1240	40681021	201524	26084	26048
14	T	0920	40882545	276965	26084	26069
15	F	1335	41159510	↑	26084	26097
16						
17				679722		
18	M	1130	41839232	234951	26084	26167
19	T	1135	42074183	235961	26108	26167
20	W	1150	42310144	215928	26132	26167
21	T	1005	42526072	232012	26154	26167
22	F	0950	42758084	↑	26178	26167
23						
24				725988		
25	M	1240	43484072	197635	26253	26167
26	T	0908	43681707	264207	26253	26187
27	W	1220	43945914	234173	26253	26215
28	T	1225	44180087	211741	26253	26239
29	F	1020	44391828	↑	26253	26261
30						
31				692956		
Total				7238781		
Average				233509		

40214054

0 1 15

Month / Year

Aug. 2005

Black & Decker
Air Stripper # 2
Operating Record

Past Month Reading

44391828

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	M	1005	45084784	232348	26253	26332
2	T	1000	45317132	230874	26277	26332
3	W	0955	45548006	250766	26301	26332
4	T	1155	45798772	225543	26327	26332
5	F	1120	46024315	↑	26351	26332
6						
7				699135		
8	M	1200	46723450	223698	26423	26332
9	T	1115	46947148	219553	26423	26356
10	W	1010	47166701	237719	26423	26379
11	T	1055	4740420	225935	26423	26404
12	F	1030	47630355	↑	26423	26427
13						
14				691545		
15	M	1040	48321900	236567	26423	26499
16	T	1125	48558467	277914	26448	26499
17	W	435 ^{pm}	48736381	183728	26477	26499
18	T	1155	49020109	223809	26496	26499
19	F	1120	49243918	↑	26520	26499
20						
21				675816		
22	M	1010	49919734	225639	26591	26499
23	T	0955	50145373	236097	26591	26523
24	W	1045	50381470	229356	26591	26548
25	T	1055	50610856	219593	26591	26572
26	F	1005	50830444	↑	26591	26595
27						
28				694946		
29	M	1120	51525395	212925	26591	26668
30	T	0955	51738320	235438	26591	26691
31	W	1040	51973758	228281	26591	26715
Total				7117255		
Average				229589		

Next Month Reading 52202039

Date 9-1-05

Month / Year

Sept. 2005

Black & Decker
Air Stripper # 2
Operating Record

Past Month Reading

51973758

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	T	1046	52262039	231731	26615	26715
2	F	1115	52433770	↑	26639	26715
3	S					
4	S					
5	M	0605	53064839	631069		
6	T	1100	53337593	272754	26700	26715
7	W	1315	53584705	247112	26735	26715
8	T	1125	53792649	207944	26735	26742
9	F	1225	54037848	245199	26735	26764
10	S			↑	26735	26790
11	S					
12	M	1140	54695951	658103		
13	T	1230	54929318	233367	26735	26860
14	W	1130	55143854	214536	26760	26860
15	T	1130	55368974	225120	26783	26860
16	F	0935	55574909	205935	26807	26860
17	S			↑	26829	26860
18	S					
19	M	1225	56272728	697819		
20	T	1130	56487275	214547	26904	26860
21	W	1050	56704698	217423	26904	26883
22	T	0830	56905815	201117	26904	26906
23	F	0850	57129456	223641	26904	26928
24	S			↑	26904	26952
25	S					
26	M	1055	57820838	691382		
27	T	1105	58044331	223493	26904	27027
28	W	1025	58260491	216160	26928	27027
29	T	1040	58484951	224460	26951	27027
30	F	1150	58717096	232145	26976	27027
31				225980	27101	27027
Total				6741037		
Average				224701		

Next Month Reading 52262039

**APPENDIX B
DISCHARGE MONITORING REPORTS
(JULY - SEPTEMBER 2005)**

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)


NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MD0001881	001				
PERMIT NUMBER	DISCHARGE NUMBER				
(2-16)	(17-19)				
MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2005	07	01	05	07	31

FORM APPROVED
 OMB No.2040-0004

FROM (20-21) (22-23) (24-25) TO (26-27) (28-29) (30-31) NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53) (54-61)			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-69)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW		0.338	1.141	MGD				0	Measured/Recorded	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT						Measured/Recorded	
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						5		1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						5		1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						5		1/MONTH	GRAB
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT						<0.1	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					0.011	0.019		1/MONTH	GRAB
OIL & GREASE	SAMPLE MEASUREMENT						<5	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					10	<5		1/MONTH	GRAB
pH	SAMPLE MEASUREMENT				6.20		7.00	0	2/WEEK	GRAB
	PERMIT REQUIREMENT				6.00		8.50		2/WEEK	GRAB
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREON AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1919. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)					SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE	DATE
Michael A. Clark Principal									410-374-9025	05 08 02
TYPED OR PRINTED							AREA CODE-NUMBER	YEAR MO DAY		
COMMENT AND EXPLANATION OF ANY VIOLATIONS										

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.
 EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland, 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER
001
 DISCHARGE NUMBER

FORM APPROVED
 OMB No. 2040-0004

MONITORING PERIOD
 FROM YEAR **2005** MO **07** DAY **01** TO YEAR **05** MO **07** DAY **31**

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT PERMIT REQUIREMENT	(3 Card Only) (48-53) QUANTITY OR LOADING (54-61)			(4 Card Only) (38-48) QUALITY OR CONCENTRATION (48-59) (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
BOD	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT								0	1/MONTH	GRAB
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT								0	1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREON AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 18 U.S.C. § 1519. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						TELEPHONE		DATE	
Michael A. Clark Principal								410-374-9025		05 08 02	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						AREA CODE-NUMBER		YEAR MO DAY	
COMMENT AND EXPLANATION OF ANY VIOLATIONS		(Reference all attachments here)									

*Averages for TSS and Oil & Grease are reported quarterly.
 EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER (2-16)

101
 DISCHARGE NUMBER (17-19)

FORM APPROVED
 OMB No. 2040-0004

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2005	07	01	05	07	31

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW	SAMPLE MEASUREMENT	0.257	0.290	MGD				0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT						Cont Measure/Record	
FECAL COLIFORM	SAMPLE MEASUREMENT					<2	MPN/100ml	0	1/WEEK	GRAB
	PERMIT REQUIREMENT					200			1/WEEK	GRAB
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER

Michael A. Clark
Principal

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 21 U.S.C. § 1919. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Emil Weddle

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE DATE

410-374-8025

05 | 08 | 02

AREA CODE-NUMBER

YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)


MD0001881
 PERMIT NUMBER
 201
 DISCHARGE NUMBER

FORM APPROVED
 OMB No. 2040-0004

MONITORING PERIOD
 FROM YEAR 2005 MO 07 DAY 01 TO YEAR 05 MO 07 DAY 31

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (48-53)			QUALITY OR CONCENTRATION (4 Card Only) (29-31)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-66)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	0.234	0.277	MGD						0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								
1,1,1-TRICHLOROETHANE						<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT					N/A			1/MONTH	GRAB	
TETRACHLOROETHYLENE						<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT					N/A			1/MONTH	GRAB	
TRICHLOROETHYLENE						<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT					N/A			1/MONTH	GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NOTE: Read instructions before completing this form.

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 19 U.S.C. § 1001 AND 33 U.S.C. § 1319. Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.	TELEPHONE	DATE
Michael A. Clark Principal TYPED OR PRINTED		 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	410-374-9025

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)


MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

FORM APPROVED
 OMB No. 2040-0004

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2005	08	01	05	08	31

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) (46-53)			(4 Card Only) (38-45)				NO. EX (62-65)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)		
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS					
FLOW		0.113	1.141	MGD					0	Measured/Recorded			
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Measured/Recorded			
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH GRAB			
	PERMIT REQUIREMENT						5	ppb		1/MONTH GRAB			
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH GRAB			
	PERMIT REQUIREMENT						5	ppb		1/MONTH GRAB			
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH GRAB			
	PERMIT REQUIREMENT						5	ppb		1/MONTH GRAB			
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT						<0.1	mg/l	0	1/MONTH GRAB			
	PERMIT REQUIREMENT						0.011	0.015		1/MONTH GRAB			
OIL & GREASE	SAMPLE MEASUREMENT						<5	mg/l	0	1/MONTH GRAB			
	PERMIT REQUIREMENT						10	<5		1/MONTH GRAB			
pH	SAMPLE MEASUREMENT				6.10		6.90	STD	0	2/WEEK GRAB			
	PERMIT REQUIREMENT				6.00		6.50	STD		2/WEEK GRAB			
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include: Fine up to \$10,000 and/or maximum imprisonment of between 6 months and 3 years.)											
Michael A. Clark Principal		 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT								TELEPHONE		DATE	
TYPED OR PRINTED										410-374-9025		05 09 06	
COMMENT AND EXPLANATION OF ANY VIOLATIONS										AREA CODE-NUMBER		YEAR MO DAY	

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-99) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland, 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER
 (2-16)

001
 DISCHARGE NUMBER
 (17-19)

FORM APPROVED
 OMB No.2040-0004

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2005	08	01	05	08	31

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) (46-53)			(4 Card Only) (38-45)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-66)	SAMPLE TYPE (68-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
BOD	SAMPLE MEASUREMENT								0	1/MONTH	GRAB
	PERMIT REQUIREMENT							mg/l			
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT								0	1/MONTH	GRAB
	PERMIT REQUIREMENT					20	30	mg/l			
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319 (Penalties under these statutes may include: fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)							TELEPHONE	DATE	
Michael A. Clark Principal		<i>Earl Wedder</i>							410-374-9025	05 08 06	
TYPED OR PRINTED									SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER
101
 DISCHARGE NUMBER

FORM APPROVED
 OMB No. 2040-0004

MONITORING PERIOD
 FROM YEAR **2005** MO **08** DAY **01** TO YEAR **05** MO **08** DAY **31**

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.260	0.268	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								
FECAL COLIFORM	SAMPLE MEASUREMENT					<2		MPN/ 100ml	0	1/WEEK	GRAB
	PERMIT REQUIREMENT					200					
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER: **Michael A. Clark**
 Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. 33 USC § 1311 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT: *Earl Wedole*

TELEPHONE: **410-374-9025**
 DATE: **05 | 09 | 06**

COMMENT AND EXPLANATION OF ANY VIOLATIONS: _____
 (Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER
 (2-16)

201
 DISCHARGE NUMBER
 (17-18)

FORM APPROVED
 OMB No.2040-0004

MONITORING PERIOD
 FROM YEAR MO DAY TO YEAR MO DAY
2005 08 01 **05 08 31**
 (20-21) (22-23) (24-26) (28-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (46-61)			QUALITY OR CONCENTRATION (62-81)				NO. EX (82-83)	FREQUENCY OF ANALYSIS (84-88)	SAMPLE TYPE (89-92)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS (62-65)	MINIMUM (66-69)	AVERAGE (70-73)	MAXIMUM (74-77)	UNITS (78-81)			
FLOW	SAMPLE MEASUREMENT	0.230	0.278	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER

Michael A. Clark
Principal

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include: Fines up to \$10,000 and/or maximum imprisonment of between 6 months and 3 years.)

Earl Wedde
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE DATE

410-374-8025

05 | 09 | 08

AREA CODE-NUMBER

YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MD0001851
 PERMIT NUMBER
 (2-16)

001
 DISCHARGE NUMBER
 (17-18)

FORM APPROVED
 OMB No.2040-0004

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	2005	09	01		05	09	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (45-53)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
FLOW		0.057	0.064	MGD					0	Measured/Recorded		
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Measured/Recorded		
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT						5			1/MONTH	GRAB	
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT						5			1/MONTH	GRAB	
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT						5			1/MONTH	GRAB	
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT						<0.1	mg/l	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT						0.011	0.015		1/MONTH	GRAB	
OIL & GREASE	SAMPLE MEASUREMENT						<5	<5	0	1/MONTH	GRAB	
	PERMIT REQUIREMENT						10	<5		1/MONTH	GRAB	
pH	SAMPLE MEASUREMENT				6.30		6.70	STD	0	2/WEEK	GRAB	
	PERMIT REQUIREMENT				6.00		6.50			2/WEEK	GRAB	
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY DEDUCTION OF THESE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 19 U.S.C. § 1001 AND 22 U.S.C. § 1219. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)							TELEPHONE		DATE	
Michael A. Clark Principal									410-374-9025		05 10 04	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							AREA CODE-NUMBER		YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 8-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**

Suite 420E
Washington, DC 20004

FACILITY: **Hampstead, Maryland, 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

(2-16)

(17-18)

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	2005	09	01		05	09	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) (48-53)			(4 Card Only)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		QUANTITY OR LOADING (54-61)			QUALITY OR CONCENTRATION						
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD	SAMPLE MEASUREMENT						7.0		0	1/MONTH	GRAB
	PERMIT REQUIREMENT						15	mg/l		1/MONTH	GRAB
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT					12.0	14.0		0	1/MONTH	GRAB
	PERMIT REQUIREMENT					20	30	mg/l		1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 19 D.C. § 1961 AND 23 D.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						TELEPHONE		DATE	
Michael A. Clark Principal								410-374-9025		05 10 04	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						AREA CODE-NUMBER		YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.
 EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881 **101**
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD
 FROM YEAR MO DAY TO YEAR MO DAY
2005 09 01 05 09 30

FORM APPROVED
 OMB No. 20-40-0004

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (42-53)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
FLOW	SAMPLE MEASUREMENT	0.237	0.277	MGD					0	Cont Measure/Record		
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record		
FECAL COLIFORM	SAMPLE MEASUREMENT						<2	MPN/ 100ml	0	1/WEEK	GRAB	
	PERMIT REQUIREMENT						200			1/WEEK	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 23 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 3 years.)							TELEPHONE		DATE	
Michael A. Clark Principal									Emil Weddler		410-374-9025	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							AREA CODE-NUMBER		YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No. 2040-0004

MD0001881 **201**
 PERMIT NUMBER DISCHARGE NUMBER

(2-10)

(17-18)

MONITORING PERIOD

FROM: YEAR **2005** MO **09** DAY **01** TO: YEAR **05** MO **09** DAY **30**
(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) (40-53) QUANTITY OR LOADING (54-61)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-66)	SAMPLE TYPE (67-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.225	0.273	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record	
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
 Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY DUTY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 23 U.S.C. § 3219. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Wedder
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
410-374-9025
 AREA CODE-NUMBER

DATE
05 | 10 | 04
 YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(JULY - SEPTEMBER 2005)



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 1

Client: BTR Hampstead, LLC	Client Sample ID: Air Stripper 2 (Pre)
Report No: 0507213	
Project: Hampstead-Monthly	Lab ID: 0507213-002
Matrix: WASTEWATER	Collection Date: 7/13/2005 11:18

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
VOLATILE ORGANIC COMPOUNDS (EPA 624)				Analyst: MLS
Prep. Method: <u>NA</u>	Prep. Date: <u>NA</u>	Prep Analyst: <u>NA</u>		
Chloromethane	< 10	10	µg/L	7/15/2005 1:15
Vinyl chloride	< 10	10	µg/L	7/15/2005 1:15
Bromomethane	< 10	10	µg/L	7/15/2005 1:15
Chloroethane	< 10	10	µg/L	7/15/2005 1:15
Acrolein	< 100	100	µg/L	7/15/2005 1:15
1,1-Dichloroethene	< 5.0	5.0	µg/L	7/15/2005 1:15
Methylene chloride	< 5.0	5.0	µg/L	7/15/2005 1:15
Acrylonitrile	< 100	100	µg/L	7/15/2005 1:15
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	7/15/2005 1:15
1,1-Dichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:15
Chloroform	< 5.0	5.0	µg/L	7/15/2005 1:15
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:15
Carbon tetrachloride	< 5.0	5.0	µg/L	7/15/2005 1:15
Benzene	< 5.0	5.0	µg/L	7/15/2005 1:15
1,2-Dichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:15
Trichloroethene	180	5.0	µg/L	7/15/2005 1:15
1,2-Dichloropropane	< 5.0	5.0	µg/L	7/15/2005 1:15
Bromodichloromethane	< 5.0	5.0	µg/L	7/15/2005 1:15
2-Chloroethyl vinyl ether	< 10	10	µg/L	7/15/2005 1:15
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	7/15/2005 1:15
Toluene	< 5.0	5.0	µg/L	7/15/2005 1:15
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	7/15/2005 1:15
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:15
Tetrachloroethene	89	5.0	µg/L	7/15/2005 1:15
Dibromochloromethane	< 5.0	5.0	µg/L	7/15/2005 1:15
Chlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:15
Ethylbenzene	< 5.0	5.0	µg/L	7/15/2005 1:15
Bromoform	< 5.0	5.0	µg/L	7/15/2005 1:15
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	7/15/2005 1:15
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:15
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:15



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 2

Client: BTR Hampstead, LLC
Report No: 0507213
Project: Hampstead-Monthly
Matrix: WASTEWATER

Client Sample ID: Air Stripper 2 (Pre)
Lab ID: 0507213-002
Collection Date: 7/13/2005 11:18

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:15



Microbac

www.microbac.com

Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 3

Client: BTR Hampstead, LLC

Client Sample ID: Outfall 201 (Post)

Report No: 0507213

Project: Hampstead-Monthly

Lab ID: 0507213-003

Matrix: WASTEWATER

Collection Date: 7/13/2005 11:17

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst: NA

Chloromethane	< 10	10	µg/L	7/15/2005 1:47
Vinyl chloride	< 10	10	µg/L	7/15/2005 1:47
Bromomethane	< 10	10	µg/L	7/15/2005 1:47
Chloroethane	< 10	10	µg/L	7/15/2005 1:47
Acrolein	< 100	100	µg/L	7/15/2005 1:47
1,1-Dichloroethene	< 5.0	5.0	µg/L	7/15/2005 1:47
Methylene chloride	< 5.0	5.0	µg/L	7/15/2005 1:47
Acrylonitrile	< 100	100	µg/L	7/15/2005 1:47
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	7/15/2005 1:47
1,1-Dichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:47
Chloroform	< 5.0	5.0	µg/L	7/15/2005 1:47
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:47
Carbon tetrachloride	< 5.0	5.0	µg/L	7/15/2005 1:47
Benzene	< 5.0	5.0	µg/L	7/15/2005 1:47
1,2-Dichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:47
Trichloroethene	< 5.0	5.0	µg/L	7/15/2005 1:47
1,2-Dichloropropane	< 5.0	5.0	µg/L	7/15/2005 1:47
Bromodichloromethane	< 5.0	5.0	µg/L	7/15/2005 1:47
2-Chloroethyl vinyl ether	< 10	10	µg/L	7/15/2005 1:47
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	7/15/2005 1:47
Toluene	< 5.0	5.0	µg/L	7/15/2005 1:47
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	7/15/2005 1:47
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	7/15/2005 1:47
Tetrachloroethene	< 5.0	5.0	µg/L	7/15/2005 1:47
Dibromochloromethane	< 5.0	5.0	µg/L	7/15/2005 1:47
Chlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:47
Ethylbenzene	< 5.0	5.0	µg/L	7/15/2005 1:47
Bromoform	< 5.0	5.0	µg/L	7/15/2005 1:47
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	7/15/2005 1:47
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:47
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:47



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 4

Client: BTR Hampstead, LLC
Report No: 0507213
Project: Hampstead-Monthly
Matrix: WASTEWATER

Client Sample ID: Outfall 201 (Post)
Lab ID: 0507213-003
Collection Date: 7/13/2005 11:17

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	7/15/2005 1:47



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 1

Client:	BTR Hampstead, LLC	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0508125		
Project:	Hampstead-Monthly	Lab ID:	0508125-002
Matrix:	WASTEWATER	Collection Date:	8/4/2005 8:22

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
VOLATILE ORGANIC COMPOUNDS (EPA 624)				
Prep. Method: <u>NA</u>	Prep. Date: <u>NA</u>		Prep Analyst: <u>NA</u>	Analyst: MLS
Chloromethane	< 10	10	µg/L	8/9/2005 2:15
Vinyl chloride	< 10	10	µg/L	8/9/2005 2:15
Bromomethane	< 10	10	µg/L	8/9/2005 2:15
Chloroethane	< 10	10	µg/L	8/9/2005 2:15
Acrolein	< 100	100	µg/L	8/9/2005 2:15
1,1-Dichloroethene	< 5.0	5.0	µg/L	8/9/2005 2:15
Methylene chloride	< 5.0	5.0	µg/L	8/9/2005 2:15
Acrylonitrile	< 100	100	µg/L	8/9/2005 2:15
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	8/9/2005 2:15
1,1-Dichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:15
Chloroform	< 5.0	5.0	µg/L	8/9/2005 2:15
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:15
Carbon tetrachloride	< 5.0	5.0	µg/L	8/9/2005 2:15
Benzene	< 5.0	5.0	µg/L	8/9/2005 2:15
1,2-Dichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:15
Trichloroethene	130	5.0	µg/L	8/9/2005 2:15
1,2-Dichloropropane	< 5.0	5.0	µg/L	8/9/2005 2:15
Bromodichloromethane	< 5.0	5.0	µg/L	8/9/2005 2:15
2-Chloroethyl vinyl ether	< 10	10	µg/L	8/9/2005 2:15
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	8/9/2005 2:15
Toluene	< 5.0	5.0	µg/L	8/9/2005 2:15
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	8/9/2005 2:15
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:15
Tetrachloroethene	66	5.0	µg/L	8/9/2005 2:15
Dibromochloromethane	< 5.0	5.0	µg/L	8/9/2005 2:15
Chlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:15
Ethylbenzene	< 5.0	5.0	µg/L	8/9/2005 2:15
Bromoform	< 5.0	5.0	µg/L	8/9/2005 2:15
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	8/9/2005 2:15
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:15
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:15



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800
Fax: 410-633-6553
www.gascoyne.com

Test Results

Page 2

Client:	BTR Hampstead, LLC	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0508125	Lab ID:	0508125-002
Project:	Hampstead-Monthly	Collection Date:	8/4/2005 8:22
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:15



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 3

Client:	BTR Hampstead, LLC	Client Sample ID:	Outfall 201 (Post)
Report No:	0508125		
Project:	Hampstead-Monthly	Lab ID:	0508125-003
Matrix:	WASTEWATER	Collection Date:	8/4/2005 8:21

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
VOLATILE ORGANIC COMPOUNDS (EPA 624)				Analyst: MLS
Prep. Method: <u>NA</u>	Prep. Date: <u>NA</u>	Prep Analyst: <u>NA</u>		
Chloromethane	< 10	10	µg/L	8/9/2005 2:47
Vinyl chloride	< 10	10	µg/L	8/9/2005 2:47
Bromomethane	< 10	10	µg/L	8/9/2005 2:47
Chloroethane	< 10	10	µg/L	8/9/2005 2:47
Acrolein	< 100	100	µg/L	8/9/2005 2:47
1,1-Dichloroethene	< 5.0	5.0	µg/L	8/9/2005 2:47
Methylene chloride	< 5.0	5.0	µg/L	8/9/2005 2:47
Acrylonitrile	< 100	100	µg/L	8/9/2005 2:47
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	8/9/2005 2:47
1,1-Dichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:47
Chloroform	< 5.0	5.0	µg/L	8/9/2005 2:47
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:47
Carbon tetrachloride	< 5.0	5.0	µg/L	8/9/2005 2:47
Benzene	< 5.0	5.0	µg/L	8/9/2005 2:47
1,2-Dichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:47
Trichloroethene	< 5.0	5.0	µg/L	8/9/2005 2:47
1,2-Dichloropropane	< 5.0	5.0	µg/L	8/9/2005 2:47
Bromodichloromethane	< 5.0	5.0	µg/L	8/9/2005 2:47
2-Chloroethyl vinyl ether	< 10	10	µg/L	8/9/2005 2:47
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	8/9/2005 2:47
Toluene	< 5.0	5.0	µg/L	8/9/2005 2:47
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	8/9/2005 2:47
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	8/9/2005 2:47
Tetrachloroethene	< 5.0	5.0	µg/L	8/9/2005 2:47
Dibromochloromethane	< 5.0	5.0	µg/L	8/9/2005 2:47
Chlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:47
Ethylbenzene	< 5.0	5.0	µg/L	8/9/2005 2:47
Bromoform	< 5.0	5.0	µg/L	8/9/2005 2:47
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	8/9/2005 2:47
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:47
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:47



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 4

Client:	BTR Hampstead, LLC	Client Sample ID:	Outfall 201 (Post)
Report No:	0508125	Lab ID:	0508125-003
Project:	Hampstead-Monthly	Collection Date:	8/4/2005 8:21
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	8/9/2005 2:47



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 1

Client: BTR Hampstead, LLC Client Sample ID: Air Stripper 2 (Pre)
 Report No: 0509193
 Project: Hampstead-Monthly Lab ID: 0509193-002
 Matrix: WASTEWATER Collection Date: 9/7/2005 11:05

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst: NA

Chloromethane	< 10	10	µg/L	9/12/2005 19:18
Vinyl chloride	< 10	10	µg/L	9/12/2005 19:18
Bromomethane	< 10	10	µg/L	9/12/2005 19:18
Chloroethane	< 10	10	µg/L	9/12/2005 19:18
Acrolein	< 100	100	µg/L	9/12/2005 19:18
1,1-Dichloroethene	< 5.0	5.0	µg/L	9/12/2005 19:18
Methylene chloride	< 5.0	5.0	µg/L	9/12/2005 19:18
Acrylonitrile	< 100	100	µg/L	9/12/2005 19:18
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	9/12/2005 19:18
1,1-Dichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:18
Chloroform	< 5.0	5.0	µg/L	9/12/2005 19:18
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:18
Carbon tetrachloride	< 5.0	5.0	µg/L	9/12/2005 19:18
Benzene	< 5.0	5.0	µg/L	9/12/2005 19:18
1,2-Dichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:18
Trichloroethene	180	5.0	µg/L	9/12/2005 19:18
1,2-Dichloropropane	< 5.0	5.0	µg/L	9/12/2005 19:18
Bromodichloromethane	< 5.0	5.0	µg/L	9/12/2005 19:18
2-Chloroethyl vinyl ether	< 10	10	µg/L	9/12/2005 19:18
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	9/12/2005 19:18
Toluene	< 5.0	5.0	µg/L	9/12/2005 19:18
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	9/12/2005 19:18
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:18
Tetrachloroethene	53	5.0	µg/L	9/12/2005 19:18
Dibromochloromethane	< 5.0	5.0	µg/L	9/12/2005 19:18
Chlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:18
Ethylbenzene	< 5.0	5.0	µg/L	9/12/2005 19:18
Bromoform	< 5.0	5.0	µg/L	9/12/2005 19:18
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	9/12/2005 19:18
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:18
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:18



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 2

Client: BTR Hampstead, LLC
Report No: 0509193
Project: Hampstead-Monthly
Matrix: WASTEWATER

Client Sample ID: Air Stripper 2 (Pre)
Lab ID: 0509193-002
Collection Date: 9/7/2005 11:05

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:18



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 3

Client: BTR Hampstead, LLC
 Report No: 0509193
 Project: Hampstead-Monthly
 Matrix: WASTEWATER

Client Sample ID: Outfall 201 (Post)
 Lab ID: 0509193-003
 Collection Date: 9/7/2005 11:06

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst: NA

Chloromethane	< 10	10	µg/L	9/12/2005 19:51
Vinyl chloride	< 10	10	µg/L	9/12/2005 19:51
Bromomethane	< 10	10	µg/L	9/12/2005 19:51
Chloroethane	< 10	10	µg/L	9/12/2005 19:51
Acrolein	< 100	100	µg/L	9/12/2005 19:51
1,1-Dichloroethene	< 5.0	5.0	µg/L	9/12/2005 19:51
Methylene chloride	< 5.0	5.0	µg/L	9/12/2005 19:51
Acrylonitrile	< 100	100	µg/L	9/12/2005 19:51
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	9/12/2005 19:51
1,1-Dichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:51
Chloroform	< 5.0	5.0	µg/L	9/12/2005 19:51
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:51
Carbon tetrachloride	< 5.0	5.0	µg/L	9/12/2005 19:51
Benzene	< 5.0	5.0	µg/L	9/12/2005 19:51
1,2-Dichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:51
Trichloroethene	< 5.0	5.0	µg/L	9/12/2005 19:51
1,2-Dichloropropane	< 5.0	5.0	µg/L	9/12/2005 19:51
Bromodichloromethane	< 5.0	5.0	µg/L	9/12/2005 19:51
2-Chloroethyl vinyl ether	< 10	10	µg/L	9/12/2005 19:51
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	9/12/2005 19:51
Toluene	< 5.0	5.0	µg/L	9/12/2005 19:51
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	9/12/2005 19:51
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	9/12/2005 19:51
Tetrachloroethene	< 5.0	5.0	µg/L	9/12/2005 19:51
Dibromochloromethane	< 5.0	5.0	µg/L	9/12/2005 19:51
Chlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:51
Ethylbenzene	< 5.0	5.0	µg/L	9/12/2005 19:51
Bromoform	< 5.0	5.0	µg/L	9/12/2005 19:51
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	9/12/2005 19:51
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:51
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:51



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800
Fax: 410-633-6553
www.gascoyne.com

Test Results

Page 4

Client: BTR Hampstead, LLC **Client Sample ID:** Outfall 201 (Post)
Report No: 0509193 **Lab ID:** 0509193-003
Project: Hampstead-Monthly **Collection Date:** 9/7/2005 11:06
Matrix: WASTEWATER

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	9/12/2005 19:51

**APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(AUGUST 2005)**

STL Chicago
2417 Bond Street
University Park, IL 60466

Tel: 708 534 5200 Fax: 708 534 5211
www.stl-inc.com

SEVERN TRENT LABORATORIES
ANALYTICAL REPORT

JOB NUMBER: 239396


Prepared For:

Weston Solutions, Inc.
Building 5-2
1400 Weston Way
West Chester, PA 19380-1499

Project: Black & Decker

Attention: Tom Cornuet

Date: 09/30/2005


Signature

Name: Richard C. Wright

Title: Project Manager

E-Mail: rwright@stl-inc.com

9/30/05
Date

STL Chicago
2417 Bond Street
University Park, IL 60466

PHONE: (708) 534-5200


FAX...: (708) 534-5211

This Report Contains (113) Pages

**Severn Trent Laboratories Chicago
GC/MS Case Narrative**

Weston Solutions
Black and Decker
JOB Number: 239396
VOA DATA:

1. All of the samples were analyzed within the 14-day hold time from the date of collection.
2. All Method Blank target compounds were below reporting limits.
3. The LCS (Laboratory Control Samples) had all five-controlled spike recoveries within the in-house generated QC limits.
4. Matrix Spike/Matrix Spike Duplicate analyses were not performed on this sample set.
5. The volatile samples had all surrogate recoveries within the in-house generated QC limits.
6. The water samples were prepared using Method 5030 and analyzed following SW846 Method 8260B and 8000B. All calibration criteria are met per method or SOP (for minimum R values for certain compounds). The low point in the initial calibration verifies the base reporting limits. The target compounds were quantitated using the initial calibration.
7. The volatile samples had all internal standard areas and retention times within the SOP acceptance limits as compared to the corresponding calibration verification standard.
8. The water samples were analyzed using a 10-mL purge volume. An initial dilution was required on sample 22 due to sample matrix. Secondary dilutions for target compounds were required on samples 13, 20, 21, 22, 23, 24, and 28. The results and reporting limits were adjusted to account for the dilution performed.



Gary Rynkar
GC/MS Section Manager

9/2/5
Date

STL Chicago is part of Severn Trent Laboratories, Inc.

SAMPLE INFORMATION
Date: 09/30/2005

Job Number.: 239396
Customer....: Weston Solutions, Inc.
Attn.....: Tom Cornuet

Project Number.....: 20005711
Customer Project ID....: BLACK AND DECKER
Project Description....: Black & Decker

Laboratory Sample ID	Customer Sample ID	Sample Matrix	Date Sampled	Time Sampled	Date Received	Time Received
239396-1	RFW-1A	Water	08/18/2005	10:00	08/20/2005	09:00
239396-2	RFW-1B	Water	08/19/2005	11:00	08/20/2005	09:00
239396-3	RFW-2A	Water	08/18/2005	08:55	08/20/2005	09:00
239396-4	RFW-2B	Water	08/18/2005	09:20	08/20/2005	09:00
239396-5	RFW-3B	Water	08/19/2005	08:40	08/20/2005	09:00
239396-6	RFW-4A	Water	08/19/2005	08:45	08/20/2005	09:00
239396-7	RFW-4A DUP	Water	08/19/2005	08:45	08/20/2005	09:00
239396-8	RFW-4B	Water	08/19/2005	10:15	08/20/2005	09:00
239396-9	RFW-6	Water	08/19/2005	08:10	08/20/2005	09:00
239396-10	RFW-7	Water	08/18/2005	13:20	08/20/2005	09:00
239396-11	RFW-9	Water	08/19/2005	12:40	08/20/2005	09:00
239396-12	RFW-11B	Water	08/19/2005	12:00	08/20/2005	09:00
239396-13	RFW-12B	Water	08/19/2005	11:45	08/20/2005	09:00
239396-14	RFW-13	Water	08/18/2005	14:20	08/20/2005	09:00
239396-15	RFW-17	Water	08/18/2005	12:15	08/20/2005	09:00
239396-16	LEISTER-1	Water	08/18/2005	16:20	08/20/2005	09:00
239396-17	LEISTER-2	Water	08/18/2005	16:30	08/20/2005	09:00
239396-18	LEISTER-DAIRY	Water	08/18/2005	16:25	08/20/2005	09:00
239396-19	TRIP BLANK	Water	08/18/2005	08:00	08/20/2005	09:00
239396-20	EW-2	Water	08/19/2005	11:30	08/20/2005	09:00
239396-21	EW-3	Water	08/19/2005	10:30	08/20/2005	09:00
239396-22	EW-4	Water	08/19/2005	10:15	08/20/2005	09:00
239396-23	EW-5	Water	08/19/2005	10:45	08/20/2005	09:00
239396-24	EW-5 DUP	Water	08/19/2005	10:45	08/20/2005	09:00
239396-25	EW-6	Water	08/18/2005	13:40	08/20/2005	09:00
239396-26	EW-7	Water	08/18/2005	13:45	08/20/2005	09:00

STL Chicago is part of Severn Trent Laboratories, Inc.

SAMPLE INFORMATION
Date:

Job Number.: 239396
Customer...: Weston Solutions, Inc.
Attr.....: Tom Cornuet

Project Number.....: 20005711
Customer Project ID....: BLACK AND DECKER
Project Description....: Black & Decker

Laboratory Sample ID	Customer Sample ID	Sample Matrix	Date Sampled	Time Sampled	Date Received	Time Received
239396-27	EW-8	Water	08/18/2005	14:00	08/20/2005	09:00
239396-28	EW-9	Water	08/18/2005	14:05	08/20/2005	09:00
239396-29	EW-10	Water	08/19/2005	08:20	08/20/2005	09:00

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-1A
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 10:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-1
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics										
	Dichlorodifluoromethane	1.0	U	0.12	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Chloromethane	1.0	U	0.20	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Vinyl chloride	1.0	U	0.16	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Bromomethane	1.0	U	0.59	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Chloroethane	1.0	U	0.32	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Trichlorofluoromethane	1.0	U	0.14	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,1-Dichloroethene	1.0	U	0.25	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Carbon disulfide	5.0	U	0.15	5.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Acetone	5.0	U	1.4	5.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Methylene chloride	1.0	U	0.24	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	trans-1,2-Dichloroethene	1.0	U	0.29	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,1-Dichloroethane	1.0	U	0.15	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	2,2-Dichloropropane	1.0	U	0.17	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	cis-1,2-Dichloroethene	1.0	U	0.20	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	2-Butanone (MEK)	5.0	U	1.0	5.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Bromochloromethane	1.0	U	0.27	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Chloroform	1.0	U	0.14	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,1,1-Trichloroethane	1.0	U	0.17	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,1-Dichloropropene	1.0	U	0.38	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Carbon tetrachloride	1.0	U	0.34	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Benzene	1.0	U	0.23	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2-Dichloroethane	1.0	U	0.25	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Trichloroethene	1.0	U	0.13	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2-Dichloropropane	1.0	U	0.19	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Dibromomethane	1.0	U	0.21	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Bromodichloromethane	1.0	U	0.22	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	cis-1,3-Dichloropropene	1.0	U	0.15	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U	0.92	5.0	1.00000	ug/L	158795		08/30/05 2227	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-1A
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 10:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-1
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-1A
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 10:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-1
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0		U	0.35	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2-Dichlorobenzene	1.0		U	0.29	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2-Dibromo-3-chloropropane	1.0		U	0.41	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2,4-Trichlorobenzene	1.0		U	0.36	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Hexachlorobutadiene	1.0		U	0.36	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	Naphthalene	1.0		U	0.37	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj
	1,2,3-Trichlorobenzene	1.0		U	0.43	1.0	1.00000	ug/L	158795		08/30/05 2227	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-1B
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 11:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-2
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
82608	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/30/05 2252	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-1B
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 11:00
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-2
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date: 09/30/2005				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: RFW-1B Date Sampled.....: 08/19/2005 Time Sampled.....: 11:00 Sample Matrix.....: Water			Laboratory Sample ID: 239396-2 Date Received.....: 08/20/2005 Time Received.....: 09:00									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/30/05 2252	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Corruet

Customer Sample ID: RFW-2A
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 08:55
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-3
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Trichloroethene	1.5	U		0.13	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/30/05 2316	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-2A
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 08:55
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-3
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-2A
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 08:55
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-3
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/30/05 2316	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-2B
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 09:20
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-4
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
82608	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/30/05 2340	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-2B
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 09:20
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-4
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/30/05 2340	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2340	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/30/05 2340	jd

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date: 09/30/2005				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: RFW-2B			Laboratory Sample ID: 239396-4									
Date Sampled.....: 08/18/2005			Date Received.....: 08/20/2005									
Time Sampled.....: 09:20			Time Received.....: 09:00									
Sample Matrix.....: Water												
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/30/05 2340	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-3B
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:40
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-5
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,1-Dichloroethane	1.2	U	H	0.25	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	trans-1,2-Dichloroethane	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	cis-1,2-Dichloroethane	10	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Trichloroethene	7.9	U		0.13	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0004	jdj

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date: 09/30/2005				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER			ATTN: Tom Cornuet						
Customer Sample ID: RFW-3B Date Sampled.....: 08/19/2005 Time Sampled.....: 08:40 Sample Matrix.....: Water			Laboratory Sample ID: 239396-5 Date Received.....: 08/20/2005 Time Received.....: 09:00									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Tetrachloroethene	8.2	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-38
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:40
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-5
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RE	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0004	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date:09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Corbett

Customer Sample ID: RFW-4A
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-6
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
82608	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	cis-1,2-Dichloroethene	1.8	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Chloroform	1.3	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Trichloroethene	56	U		0.13	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0028	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Corhuet

Customer Sample ID: RFW-4A
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-6
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Tetrachloroethene	65			0.18	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj

* In Description = Dry Wgt.

Job Number: 239396		LABORATORY TEST RESULTS						Date: 09/30/2005				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: RFW-4A Date Sampled.....: 08/19/2005 Time Sampled.....: 08:45 Sample Matrix.....: Water			Laboratory Sample ID: 239396-6 Date Received.....: 08/20/2005 Time Received.....: 09:00									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0028	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-4A DUP
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-7
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	cis-1,2-Dichloroethene	1.7	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Chloroform	1.2	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Trichloroethene	55	U		0.13	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0053	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-4A DUP
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-7
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Tetrachloroethene	63	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-4A DUP
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:45
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-7
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	NOL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0053	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date:09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Corruet

Customer Sample ID: RFW-4B
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:15
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-8
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	cis-1,2-Dichloroethene	6.6	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Chloroform	0.94	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Trichloroethene	18	U		0.13	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0117	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-4B
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:15
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-B
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MOL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Tetrachloroethene	60			0.18	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396 Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc. PROJECT: BLACK AND DECKER ATTN: Tom Cornuet

Customer Sample ID: RFW-4B
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 10:15
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-8
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0117	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-6
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:10
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-9
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	cis-1,2-Dichloroethene	1.6	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Trichloroethene	9.9	U		0.13	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0141	jd
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0141	jd

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-6
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:10
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-9
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	PDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Tetrachloroethane	6.8	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-6
 Date Sampled.....: 08/19/2005
 Time Sampled.....: 08:10
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-9
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	158795		08/31/05 0141	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 239396

Date: 09/30/2005

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-7
 Date Sampled.....: 08/18/2005
 Time Sampled.....: 13:20
 Sample Matrix.....: Water

Laboratory Sample ID: 239396-10
 Date Received.....: 08/20/2005
 Time Received.....: 09:00

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MOL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Bromochloromethane	1.0	U	*	0.27	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Trichloroethene	11	U	H	0.13	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	158795		08/31/05 0206	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	158795		08/31/05 0206	jdj

* In Description = Dry Wgt.