

**Quarterly Groundwater Monitoring Report**

Prepared for

**Black & Decker (U.S.) Inc.**

Hampstead, Maryland

October 2007

Prepared by

**WESTON SOLUTIONS, INC.**

West Chester, Pennsylvania 19380-1499

---

## TABLE OF CONTENTS

---

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES .....	2-1
2.2 EFFLUENT CHARACTERISTICS .....	2-1
2.3 GROUNDWATER QUALITY DATA .....	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

---

## LIST OF APPENDICES

---

**APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS**

**APPENDIX B - DISCHARGE MONITORING REPORTS**

**APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS**

**APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE**

---

## LIST OF TABLES

---

Table	Page
Table 2-1 Treatment System Pumping Records – 3rd Quarter 2007 .....	2-2
Table 2-2 Groundwater Elevation Data – 3rd Quarter 2007.....	2-3
Table 2-3 Effluent Characteristics Summary – 3rd Quarter 2007.....	2-4
Table 2-4 Summary of Groundwater Analytical Results - August 2007.....	2-5
Table 3-1 Treatment System Maintenance Activities – 3rd Quarter 2007 .....	3-2

## 1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

## **2. SITE CHARACTERISTICS**

### **2.1 HYDRAULIC PROPERTIES**

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of July through September 2007.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of July through September 2007, the extraction wells were pumping at an average combined rate of approximately 163 gallons per minute (gpm).

### **2.2 EFFLUENT CHARACTERISTICS**

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of July through September 2007 are included in Appendix B.

### **2.3 GROUNDWATER QUALITY DATA**

For the reporting period of July through September 2007, approximately 24 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (86 %) and tetrachloroethene (PCE) (14 %). Analytical results of the groundwater collected from the air stripper for the period of January through March 2007 are included in Appendix C.

A summary of the analytical results from the first quarter (August 2007) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

**Table 2-1**  
**Treatment System Pumping Records - 3rd Quarter 2007**  
**Black & Decker**  
**Hampstead, Maryland**

<b>Date</b>	<b>Water Pumped (gallons)</b>
July 2007	6,777,770
August 2007	6,598,950
September 2007	6,694,100

**Table 2-2**  
**Groundwater Elevation Data - 3rd Quarter 2007**  
**Black & Decker**  
**Hampstead, Maryland**

WELL NO.	TOC ELEV.	TOTAL DEPTH	7/23/2007		8/6/2007		9/11/2007	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NA	DRY	NA	DRY	NA
EW-2	849.21	110	75.82	773.39	76.74	772.47	77.31	771.90
EW-3	846.64	118	89.13	757.51	88.47	758.17	89.50	757.14
EW-4	858.01	97.5	NA	NA	NA	NA	NA	NA
EW-5	864.17	98	64.80	799.37	66.24	797.93	66.56	797.61
EW-6	831.98	115	89.88	742.10	85.11	746.87	86.42	745.56
EW-7	818.38	78	48.53	769.85	44.13	774.25	45.81	772.57
EW-8	811.13	98	64.22	746.91	72.72	738.41	74.31	736.82
EW-9	811.35	141	103.78	707.57	102.94	708.41	103.48	707.87
EW-10	807.74	NA	56.30	751.44	56.71	751.03	57.10	750.64
RFW-1A	864.37	78	49.26	815.11	47.09	817.28	47.15	817.22
RFW-1B	864.23	200	49.31	814.92	47.12	817.11	47.19	817.04
RFW-2A	857.41	35	14.98	842.43	17.53	839.88	17.60	839.81
RFW-2B	857.73	75	15.11	842.62	18.04	839.69	18.11	839.62
RFW-3B	839.21	153	30.12	809.09	33.77	805.44	34.06	805.15
RFW-4A	830.37	62	37.78	792.59	37.12	793.25	37.80	792.57
RFW-4B	830.37	120	37.14	793.23	37.08	793.29	37.77	792.60
RFW-5A	817.50	30	DRY	NA	DRY	NA	DRY	NA
RFW-6	785.04	120	4.32	780.72	4.19	780.85	4.40	780.64
RFW-7	805.14	29	7.67	797.47	7.41	797.73	7.83	797.31
RFW-8	860.07	56	DRY	NA	DRY	NA	DRY	NA
RFW-9	862.02	49	25.61	836.41	27.77	834.25	27.74	834.28
RFW-10	852.06	58	DRY	NA	DRY	NA	DRY	NA
RFW-11A	849.32	72	NA	NA	NA	NA	NA	NA
RFW-11B	849.62	116	70.32	779.30	67.58	782.04	67.66	781.96
RFW-12B	844.87	264	54.08	790.79	49.79	795.08	50.55	794.32
RFW-13	849.11	150	61.89	787.22	59.33	789.78	60.17	788.94
RFW-14B	812.39	281	53.11	759.28	51.74	760.65	52.26	760.13
RFW-16	856.14	41	DRY	NA	DRY	NA	DRY	NA
RFW-17	834.66	60.5	27.38	807.28	27.27	807.39	28.71	805.95
RFW-20	842.49	142	35.13	807.36	35.19	807.30	35.26	807.23
RFW-21	832.65	102	24.14	808.51	22.91	809.74	23.64	809.01
PH-7	805.94	89	28.40	777.54	34.00	771.94	36.12	769.82
PH-9	814.94	98	36.31	778.63	34.88	780.06	34.83	780.11
PH-11	820.68	78	44.80	775.88	45.29	775.39	45.23	775.45
PH-12	828.35	87	47.66	780.69	47.74	780.61	47.80	780.55
B-3	803.02	83	NA	NA	8.63	794.39	8.84	794.18
Amoco	842.29	NA	NA	NA	NA	NA	NA	NA
Hamp. Town #22	804.96	NA	39.44	765.52	26.53	778.43	23.12	781.84
Pembroke #1	NA	NA	14.46	NA	14.98	NA	16.32	NA
Pembroke #2	NA	NA	NA	NA	NA	NA	NA	NA
N. Houcks. Rd.	NA	NA	9.08	NA	8.74	NA	9.53	NA
E. Century St.	NA	NA	12.81	NA	12.01	NA	12.26	NA
Lwr. Beckleys. Rd.	NA	NA	NA	NA	52.89	NA	53.44	NA

NA - Not Available/Not Accessible

**Table 2-3**  
**Effluent Characteristics Summary - 3rd Quarter 2007**  
**Black & Decker**  
**Hampstead, Maryland**

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				July 2007	August 2007	September 2007	
001	FLOW	average	MGD	NA	0.120	0.090	0.160
		maximum	MGD	NA	0.195	0.129	0.209
	1,1,1-Trichloroethane		ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene		ug/l	5	< 1	< 1	< 1
	Trichloroethylene		ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	< 5	8.0
		quarterly average	mg/l	10	0	0	8.0
	pH	minimum	STD	6.0	6.80	6.60	7.10
		maximum	STD	8.5	8.20	8.20	7.70
	BOD		mg/l	15	8.0	6.0	4.0
TSS	maximum	mg/l	30	18.0	16.0	10.0	
	quarterly average	mg/l	20	18.0	16.0	10.0	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.075	0.088	0.139
		maximum	MGD	NA	0.296	0.520	0.630
	Fecal Coliform		MPN/100ml	200	1.0	4.0	13.0
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.218
		maximum	MGD	NA	NR	NR	0.256
	1,1,1-Trichloroethane		ug/l	NA	NR	NR	< 1
	Tetrachloroethylene		ug/l	NA	NR	NR	< 1
	Trichloroethylene		ug/l	NA	NR	NR	< 1

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported



Table 2-4  
 Summary of Groundwater Analytical Results - August 2007  
 Black & Decker  
 Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	2.3	2.4	1 U	1 U	1 U	5.8	19	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1.4	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	480	220	1600	210	9.2	5.5	11	1.7	1.8	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	68	5.3	31	13	21	12	82	190	220	4.6
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.  
 J = Indicates an estimated value.

**Table 2-4**  
**Summary of Groundwater Analytical Results - August 2007**  
**Black & Decker**  
**Hampstead, Maryland**

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4B	RFW-4B (DUP)	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.3	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	5.4	1	4	3.6	NS	1 U	1 U	NS	14	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	1.1	1.8	1.7	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.5	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	1	1 U	1 U	41	55	54	NS	2	5.2	NS	18	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	1.9	38	120	96	NS	2.6	1 U	NS	6.4	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicated sample  
NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.  
J = Indicates an estimated value.

**Table 2-4**  
**Summary of Groundwater Analytical Results - August 2007**  
**Black & Decker**  
**Hampstead, Maryland**

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	USEPA drinking water method 524.2				
												RFW-20	RFW-21	Town #22	Town #23	Trip Blank
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	1 U	1 U	1 U	NS	1.5	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	NA	NA	NA	NA	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	5.5	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trichloroethene	ug/L	NS	16	370	3.9	NS	1 U	1 U	1 U	NS	1 U	1	0.5 U	0.5 U	0.5 U	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	5 U	5 U	NS	5 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	1 U	34	19	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	NS	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division. Samples from all of the other wells are analyzed with USEPA Method 8260.

NS = Not sampled

U = Compound was analyzed but not detected.

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from wells RFW-4B and EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

### 3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (July through September 2007) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

**Table 3-1**  
**Treatment System Maintenance Activities - 3rd Quarter 2007**  
**Black & Decker**  
**Hampstead, Maryland**

<b>Date</b>	<b>Event/Corrective Action</b>
<b>Jul-07</b>	Micro-Tech Designs onsite for periodic calibration the of the Wet Well, Air Stripper and the Chemical feed.
<b>Aug-07</b>	The pumps that drain the air stripper column were cycling. The valve in the ceiling was adjusted to create a steady flow. This caused pressure to build in the system. Wells EW-3 & EW-8 were turned off temporarily to reduce the pressure. There was added demand to the system due to a 300-ton chiller used within the facility. The chiller was drawing additional water from the system. The additional demand caused the instability in the pumps that drain the air stripper column. The two wells were off for 66 hours until the pressure could be reduced in the system. All wells are running again.

#### 4. RECOMMENDATIONS

For the reporting period of July through September 2007, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

---

**APPENDIX A**  
**GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS**  
**(JULY – SEPTEMBER 2007)**

---



MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:  
Maryland Environmental Service  
259 Najoles Road, Millersville MD

Facility: BTR Capital Group  
Address: 626 Hanover Pike, Hampstead Maryland

Permit Number: 02-DP-0022  
Operator: Justin Myers  
Certification # 8406

Month: JULY  
Year: # 2007

Date	Appearance	Final Effluent outfall 001									Outfall 101					Outfall 201			Comments		
		Discharge MGD	pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD <sub>5</sub> mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l		Trichloroethene ug/l	Discharge mgd
1	clr	0.0740								0.00000		1.0	0.0	0.0	0.0				0.204465		
2	clr	0.0860								0.19100		1.0	10.0	6.0	3.3				0.224121		
3	clr	0.0760	7.2	0.00						0.29600	< 2	3.0	15.0	6.0	4.7				0.187321		
4	clr	0.0950								0.21400		6.0	15.0	7.0	3.0				0.251244		
5	cldy	0.0830	6.8	0.00						0.20300		8.0	2.0	7.0	1.7				0.215354		
6	clr	0.0880								0.00000		8.0	0.0	0.0	0.0				0.222376		
7	clr	0.0900								0.00000		9.0	0.0	0.0	0.0				0.239155		
8	clr	0.0750								0.00000		9.0	0.0	0.0	0.0				0.210498		
9	clr	0.0880								0.00000		8.0	0.0	0.0	0.0				0.227667		
10	clr	0.0850								0.00000		7.0	0.0	0.0	0.0				0.218605		
11	clr	0.0810	8.0	0.00						0.00000		7.0	0.0	0.0	0.0				0.194059		
12	clr	0.0880								0.00000		6.0	0.0	0.0	0.0				0.246741		
13	clr	0.0970	8.2	0.00						0.00000		5.0	0.0	0.0	0.0				0.210747		
14	clr	0.0840								0.00000		5.0	0.0	0.0	0.0				0.211085		
15	clr	0.0740								0.00000		5.0	0.0	0.0	0.0				0.219219		
16	clr	0.0940	8.2	0.00						0.00000		4.0	0.0	0.0	0.0				0.231934		
17	clr	0.0850								0.24400		4.0	20.0	8.0	1.5				0.228703		
18	clr	0.0780								0.22100		7.0	20.0	6.0	3.9				0.201598		
19	cldy	0.1720								0.16800		10.0	10.0	6.0	3.8				0.205881		
20	clr	0.1640	8.0	0.00						0.00000		10.0	0.0	0.0	0.0				0.205113		
21	clr	0.1630								0.00000		10.0	0.0	0.0	0.0				0.211619		
22	clr	0.1620								0.00000		9.0	0.0	0.0	0.0				0.232067		
23	clr	0.1740								0.00000		9.0	0.0	0.0	0.0				0.243585		
24	clr	0.1840	7.0	0.00						0.00000		8.0	5.0	8.0	0.0				0.212439		
25	clr	0.1660			< 1.00	< 1.00	< 1.00	8.0	18.0	< 5.0	0.25700	< 2	11.0	5.0	6.0	3.1	< 1	< 1	< 1	0.213187	
26	clr	0.1680								0.24100		14.0	5.0	5.0	3.0				0.221510		
27	clr	0.1950	6.9	0.00						0.23900		14.0	0.5	2.0	3.0				0.236898		
28	clr	0.1560								0.03600		14.0	0.0	0.0	2.8				0.203975		
29	clr	0.1560								0.00000		14.0	0.0	0.0	0.0				0.227755		
30	clr	0.1610								0.00000		14.0	0.0	0.0	0.0				0.206030		
31	clr	0.1710	7.9	0.00						0.00000		13.0	0.0	0.0	0.0				0.212820		
Total		3.7130	68.2	0.00	0.0	0.0	0.0	8	18	0	2.31000	2	253.0	107.5	67.0	33.8	0.00	0.00	0.00	6.77777	
Average		0.1198	7.6	<0.10	0.0	0.0	0.0	8	18	0	0.07452	1	8.2	3.5	2.2	1.1	0.00	0.00	0.00	0.21864	
Minimum		0.0740	6.8	0.00	0.0	0.0	0.0	8	18	0	0.00000	1	1.0	0.0	0.0	0.0	0.00	0.00	0.00	0.18732	
Maximum		0.1950	8.2	<0.10	0.0	0.0	0.0	8	18	0	0.29600	1	14.0	20.0	8.0	4.7	0.00	0.00	0.00	0.25124	MOR 3-15-07

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:  
Maryland Environmental Service  
259 Najoles Road, Millersville MD

Facility: BTR Capital Group  
Address: 626 Hanover Pike, Hampstead Maryland

Permit Number: 02-DP-0022  
Operator: Justin Myers  
Certification # 8406

Month: August  
Year: # 2007

Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Final Effluent outfall 001						Outfall 101					Outfall 201			Comments		
					Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethylene ug/l	BOD <sub>5</sub> mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l		Trichloroethylene ug/l	Discharge mgd
1	clear	0.1000									0.00000		14.0	0.0	0.0	0.0				0.229486	
2	clear	0.0760									0.00000		14.0	0.0	0.0	0.0				0.196801	
3	clear	0.0960	8.2	0.00							0.00000		14.0	0.0	0.0	0.0				0.208201	
4	clear	0.0880									0.00000		14.0	0.0	0.0	0.0				0.228884	
5	clear	0.0850									0.00000		14.0	0.0	0.0	0.0				0.204506	
6	clear	0.0890									0.18300		10.0	15.0	6.0	2.3				0.209853	
7	clear	0.0890	6.7	0.00							0.19500	4	12.0	15.0	8.0	3.3				0.253401	
8	clear	0.0850			< 1.00	< 1.00	< 1.00	6.0	16.0	< 5.1	0.26800		12.0	5.0	8.0	3.4				0.230016	
9	clear	0.0870	6.6	0.00							0.25600		14.0	15.0	7.0	5.0				0.227382	
10	clear	0.0820									0.25400		14.0	20.0	6.0	2.0				0.210172	
11	clear	0.0860									0.25000		14.0	5.0	6.0	3.4				0.227367	
12	clear	0.0900									0.00000		14.0	0.0	0.0	3.7				0.256003	
13	clear	0.0900									0.00000		14.0	0.0	0.0	0.0				0.169435	
14	clear	0.0880	7.3	0.00							0.00000		14.0	0.0	0.0	0.0				0.132206	
15	clear	0.0850									0.00000		14.0	0.0	0.0	0.0				0.187270	
16	clear	0.0800	7.4	0.00							0.00000		14.0	0.0	0.0	0.0				0.218523	
17	clear	0.0970									0.00000		14.0	0.0	0.0	0.0				0.233240	
18	clear	0.0790									0.00000		14.0	0.0	0.0	0.0				0.205632	
19	clear	0.0790									0.00000		14.0	0.0	0.0	0.0				0.222005	
20	clear	0.0820									0.00000		14.0	0.0	0.0	0.0				0.229600	
21	clear	0.0760	6.6	0.00							0.00000		11.0	0.0	0.0	0.0				0.195841	
22	clear	0.0910									0.00000		10.0	0.0	0.0	0.0				0.243062	
23	clear	0.0710									0.00000		9.0	0.0	0.0	0.0				0.206983	
24	clear	0.0820	6.8	0.00							0.00000		8.0	0.0	0.0	0.0				0.203631	
25	clear	0.0730									0.00000		7.0	6.0	0.0	0.0				0.200610	
26	clear	0.0780									0.00000		6.0	0.0	0.0	0.0				0.217204	
27	clear	0.1240									0.00000		6.0	0.0	0.0	0.0				0.212340	
28	clear	0.1290	7.1	0.00							0.21600		5.0	0.0	0.0	0.0				0.213735	
29	clear	0.1130									0.27900		7.0	0.0	0.0	0.0				0.205886	
30	clear	0.1080	7.0	0.00							0.30400		10.0	0.0	0.0	0.0				0.211457	
31	clear	0.1220									0.52000		12.0	0.0	0.0	0.0				0.208218	
Total		2.8000	63.7	0.00	0.0	0.0	0.0	6	16	0	2.72500	4	363.0	81.0	41.0	23.1	0.00	0.00	0.00	6.59895	
Average		0.0903	7.1	<0.10	0.0	0.0	0.0	6	16	0	0.08790	4	11.7	2.6	1.3	0.7	#DIV/0!	#DIV/0!	#####	0.21287	
Minimum		0.0710	6.6	0.00	0.0	0.0	0.0	6	16	0	0.00000	4	5.0	0.0	0.0	0.0	0.00	0.00	0.00	0.13221	
Maximum		0.1290	8.2	<0.10	0.0	0.0	0.0	6	16	0	0.52000	4	14.0	20.0	8.0	5.0	0.00	0.00	0.00	0.25600	MOR 3-15-07

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:  
Maryland Environmental Service  
259 Najoles Road, Millersville MD

Facility: BTR Capital Group  
Address: 626 Hanover Pike, Hampstead Maryland

Permit Number: 02-DP-0022  
Operator: Justin Myers  
Certification # 8406

Month: Sept  
Year: # 2007

006/008

MES/TECH ENG SERVICES

10/25/2007 14:31 FAX 4107298340

Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Final Effluent outfall 001					Outfall 101					Outfall 201				Comments			
					Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD, mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l		Trichloroethene ug/l	Discharge mgd	
1	clear	0.1160									0.00000		12.0	0.0	0.0	0.0				0.213490		
2	clear	0.0940									0.00000		14.0	0.0	0.0	0.0				0.181319		
3	clear	0.1210									0.00000		9.0	0.0	0.0	0.0				0.233673		
4	clear	0.1090	7.3	0.00							0.00000		7.0	0.0	0.0	0.0				0.211704		
5	clear	0.1690									0.31500		4.0	5.0	4.0	3.0				0.199536		
6	clear	0.1770	7.4	0.00							0.35700	13	7.0	10.0	3.0	4.3				0.209575		
7	clear	0.1730									0.37600		10.0	10.0	6.0	2.0				0.193160		
8	clear	0.1980									0.40700		14.0	15.0	4.0	3.3				0.234268		
9	clear	0.1600									0.00000		14.0	0.0	0.0	2.1				0.196039		
10	clear	0.1780									0.00000		14.0	0.0	0.0	0.0				0.216000		
11	clear	0.2090	7.3	0.00							0.00000		11.0	0.0	0.0	0.0				0.237962		
12	clear	0.1730									0.00000		9.0	0.0	0.0	0.0				0.233729		
13	clear	0.1690	7.7	0.00							0.00000		8.0	0.0	0.0	0.0				0.251199		
14	clear	0.1750									0.00000		7.0	0.0	0.0	0.0				0.221231		
15	clear	0.1630									0.00000		6.0	0.0	0.0	0.0				0.228765		
16	clear	0.1630									0.00000		5.0	0.0	0.0	0.0				0.228785		
17	clear	0.1710									0.00000		5.0	0.0	0.0	0.0				0.245043		
18	clear	0.1610	7.4	0.00							0.24100		5.0	10.0	6.0	5.0				0.223899		
19	clear	0.1690			< 1.00	< 1.00	< 1.00	4.0	10.0	8.4	0.25000	2	7.0	15.0	6.0	5.0				0.231663		
20	clear	0.1860	7.1	0.00							0.31000		11.0	5.0	2.0	1.9				0.252853		
21	clear	0.1500									0.00000		9.0	0.0	0.0	0.0				0.195334		
22	clear	0.1610									0.00000		8.0	0.0	0.0	0.0				0.220658		
23	clear	0.1730									0.00000		8.0	0.0	0.0	0.0				0.247072		
24	clear	0.1620									0.29300		5.0	20.0	6.0	1.5				0.220646		
25	clear	0.1780	7.3	0.00							0.30500		9.0	20.0	3.0	1.7				0.239564		
26	clear	0.1600									0.33400	< 2	11.0	15.0	3.0	5.0				0.218883		
27	clear	0.1620	7.3	0.00							0.35400		14.0	25.0	6.0	2.0				0.222123		
28	clear	0.1450									0.63000		14.0	10.0	2.5	1.7				0.223136		
29	clear	0.1210									0.00000		14.0	0.0	0.0	0.0				0.223136		
30	clear	0.1630									0.00000		14.0	0.0	0.0	0.0				0.239652		
31																						
Total		4.8090	58.8	0.00	0.0	0.0	0.0	4	10	8	4.17200	16	285.0	160.0	51.5	38.5	0.00	0.00	0.00	6.69410		
Average		0.1603	7.4	<0.10	0.0	0.0	0.0	4	10	8	0.13907	5	9.5	5.3	1.7	1.3	#DIV/0!	#DIV/0!	#DIV/0!	0.22314		
Minimum		0.0940	7.1	0.00	0.0	0.0	0.0	4	10	8	0.00000	1	4.0	0.0	0.0	0.0	0.00	0.00	0.00	0.18132		
Maximum		0.2090	7.7	<0.10	0.0	0.0	0.0	4	10	8	0.63000	13	14.0	25.0	6.0	5.0	0.00	0.00	0.00	0.25285	MOR 3-15-07	



---

**APPENDIX B  
DISCHARGE MONITORING REPORTS  
(JULY - SEPTEMBER 2007)**

---



PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)  
 NAME **AG/GFI Hampstead, Inc**  
 ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
**DISCHARGE MONITORING REPORT (DMR)**  
 (2-16) (17-19)

State Discharge Permit  
**02-DP-0022**

Form Approved. 12345  
 OMB No. 2040-0004.  
 Approval expires 05-31-98

**MD0001881** PERMIT NUMBER  
**001** DISCHARGE NUMBER

**Hampstead, MD 21074**  
 FACILITY **Black and Decker WWTP**  
 LOCATION **626 Hanover Pike**  
 ATTN:

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
07	07	01	TO	07	07	31	
(20-21)		(22-23)		(24-25)		(26-27)	
(28-29)		(30-31)					

\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE (3 Card Only 46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-43)	AVERAGE (46-53)	MAXIMUM (54-61)				UNITS
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	8	( 19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15	MG/L		ONE/MONTH	GRAB
pH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	6.8	*****	8.2	( 12)	0	TWO/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	8.5	SU		TWO/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	18	18	( 19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	20	30	MG/L		ONE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	119774	195000	( 07)	*****	*****	*****		0	MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	( 19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.011	0.019	MG/L		ONE/MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE			
<b>Jim Harkins, Director MES</b>			<b>410 729-8350</b>	<b>07</b>	<b>08</b>	<b>21</b>
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)  
 NAME **AG/GFI Hampstead, Inc**  
 ADDRESS **626 Hanover Pike**  
**Hampstead, MD 21074**  
 FACILITY **Black and Decker WWTP**  
 LOCATION **626 Hanover Pike**  
 ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
**DISCHARGE MONITORING REPORT (DMR)**  
 (2-16) (17-19)

**State Discharge Permit**  
**02-DP-0022**

**MD0001881**  
 PERMIT NUMBER


**001**  
 DISCHARGE NUMBER

Form Approved. 12345  
 OMB No. 2040-0004.  
 Approval expires 05-31-98

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	07	01		07	07	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING (34-61)			QUANTITY OR CONCENTRATION (46-61)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (3 Card Only 46-53)	MAXIMUM	UNITS	MINIMUM (4 Card Only 38-45)	AVERAGE	MAXIMUM				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****		*****	*****	0		0	ONE/MONTH	GRAB
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	( 19)	0	ONE/MONTH	GRAB
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER <b>Jim Harkins, Director MES</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE <b>410 729-8350</b>	DATE			
			AREA CODE	NUMBER	YEAR	MO
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 					

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)



PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

**Hampstead, MD 21074**

FACILITY **Blask and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)  
(2-16) (17-19)

State Discharge Permit  
02-DP-0022

**MD0001881**  
PERMIT NUMBER

**101**  
DISCHARGE NUMBER

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98


MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
07	07	01		07	07	31	
(20-21)		(22-23)		(24-25)		(26-27)	
				(28-29)		(30-31)	

\*\*\* NO DISCHARGE  \*\*\*  
NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (34-61)			QUANTITY OR CONCENTRATION (38-45)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS (38-45)	MINIMUM (46-53)	AVERAGE (54-61)	MAXIMUM (54-61)				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	74516	296000	( 07 )	*****	*****	*****		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	REPORT *****	REPORT *****	GPD	*****	*****	*****	****		ONE/MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	( 30 )	0	TWO/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200	MPN		TWO/WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
**Jim Harkins, Director MES**  
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE  
**410 729-8350**  
AREA CODE NUMBER

DATE  
**07 08 21**  
YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**  
 ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
 DISCHARGE MONITORING REPORT (DMR)

State Discharge Permit  
 02-DP-0022

MD0001881  
 PERMIT NUMBER

001  
 DISCHARGE NUMBER

Form Approved. 12345  
 OMB No. 2040-0004  
 Approval expires 05-31-98

**Hampstead, MD 21074**  
 FACILITY **Black and Decker WWTP**  
 LOCATION **626 Hanover Pike**  
 ATTN:


MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	08	01	07	08	31
(20-21)		(22-23)		(24-25)	
		(26-27)		(28-29)	
		(30-31)			

\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (46-53)			QUANTITY OR CONCENTRATION (46-53)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-65)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	6	( 19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15	MG/L		ONE/MONTH	GRAB
pH 00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	6.6	*****	8.2	( 12)	0	TWO/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	8.5	SU		TWO/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	16	16	( 19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	20	30	MG/L		ONE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	*****	129000	( 07)	*****	*****	*****	*****		0	MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	<0.1	<0.1	( 19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.01	0.019	MG/L		ONE/MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	0		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	****	*****	*****	0		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
**Jim Harkins, Director MES**  
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  


TELEPHONE  
 410 729-8350  
 DATE  
 07 09 27  
 AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)  
 NAME **AG/GFI Hampstead, Inc**  
 ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
 DISCHARGE MONITORING REPORT (DMR)  
 (2-16) (17-19)

State Discharge Permit  
 02-DP-0022

Form Approved. 12345  
 OMB No. 2040-0004.  
 Approval expires 05-31-98

**MD0001881**  
 PERMIT NUMBER


**001**  
 DISCHARGE NUMBER

**Hampstead, MD 21074**  
 FACILITY **Black and Decker WWTP**  
 LOCATION **626 Hanover Pike**  
 ATTN:

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	08	01		07	08	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)				UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****		*****	*****	0		0	ONE/MONTH	GRAB	
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB	
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	( 19)	0	ONE/MONTH	GRAB	
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****		*****	10	15	MG/L		ONE/MONTH	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  <b>Jim Harkins, Director MES</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			410	729-8350	07	09	27
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here.)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)  
 NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**  
**Hampstead, MD 21074**

FACILITY **Black and Decker WWTP**  
 LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
 DISCHARGE MONITORING REPORT (DMR)  
 (2-16) (17-19)

State Discharge Permit  
 02-DP-0022

**MD0001881**  
 PERMIT NUMBER


**101**  
 DISCHARGE NUMBER

Form Approved. 12345  
 OMB No. 2040-0004.  
 Approval expires 05-31-98

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	08	01		07	08	31
(20-21)		(22-23)		(24-25)		(26-27)
				(28-29)		(30-31)

\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only (46-53) (54-61))			QUANTITY OR CONCENTRATION (4 Card Only (38-45) (46-53) (54-61))			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	87903	520000	( 07)	*****	*****	*****		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONE/MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		*****	*****	4	( 30)	0	TWO/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200	MPN		TWO/WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  <b>Jim Harkins, Director MES</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE  <b>410 729-8350</b>	DATE			
			AREA CODE	NUMBER	YEAR	MO
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 					

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME **AG/GFI Hampstead, Inc**  
 Facility Name/Location if different

ADDRESS **626 Hanover Pike**

**Hampstead, MD 21074**

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
**DISCHARGE MONITORING REPORT (DMR)**  
 (2-16) (17-19)

**MD0001881**  
 PERMIT NUMBER

**001**  
 DISCHARGE NUMBER

**State Discharge Permit**  
**02-DP-0022**

Form Approved. **12345**  
 OMB No. 2040-0004.  
 Approval expires 05-31-98

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
07	09	01		07	09	30	
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)	


\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

002/008  
 MES/TECH ENG SERVICES  
 4107298340  
 10/25/2007 14:25 FAX

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	*****	4	( 19)	0	ONE/MONTH	GRAB
pH		*****	*****	****	7.1	*****	7.7	( 12)	0	TWO/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	10	10	( 19)	0	ONE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE		160300	209000	( 07) GPD	*****	*****	*****	****	0	MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	<0.1	<0.1	( 19)	0	ONE/MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	*****	0	ug/l	0	ONE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	*****	0	ug/l	0	ONE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
**Jim Harkins, Director MES**  
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
410	729-8350	07	10	23
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)  
 NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**  
**Hampstead, MD 21074**  
 FACILITY **Black and Decker WWTP**  
 LOCATION **626 Hanover Pike**  
 ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
**DISCHARGE MONITORING REPORT (DMR)**  
 (2-16) (17-19)

**MD0001881**  
 PERMIT NUMBER

**001**  
 DISCHARGE NUMBER

**State Discharge Permit**  
**02-DP-0022**

Form Approved. 12345  
 OMB No. 2040-0004.  
 Approval expires 05-31-98

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	09	01		07	09	30
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)

\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) (46-53) QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45) QUANTITY OR CONCENTRATION (46-53) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE	*****	*****		****	*****	*****	0	ug/l	0	ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0 EFFLUENT GROSS VALUE	*****	*****		****	*****	8	8	( 19)	0	ONE/MONTH	GRAB
	SAMPLE MEASUREMENT							MG/L			
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
**Jim Harkins, Director MES**  
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

*[Signature]*  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
410	729-8350	07	10	23
AREA CODE	NUMBER	YEAR	MO	DAY

003/008  
 MES/TECH ENG SERVICES  
 FAX 4107298340  
 FAX 14:26  
 10/25/2007

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME **AG/GFI Hampstead, Inc**  
 Facility Name/Location (if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

**Hampstead, MD 21074**

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
**DISCHARGE MONITORING REPORT (DMR)**  
 (2-16) (17-19)

State Discharge Permit  
**02-DP-0022**

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

**MD0001881**

PERMIT NUMBER

**101**

DISCHARGE NUMBER

**MONITORING PERIOD**

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	07	09	01		07	09	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

004/008

MES/TECH ENG SERVICES

4107298340


14:27 FAX

10/25/2007

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE		139067	630000	( 07) GPD	*****	*****	*****	****	0	ONE/MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	*****	13	(30) MPN	0	TWO/WEEK	GRAB
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										
	SAMPLE MEASUREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
**Jim Harkins, Director MES**  
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
410	729-8350	07	10	23
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)



PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)  
 NAME **AG/GFI Hampstead, Inc**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
**DISCHARGE MONITORING REPORT (DMR)**  
 (2-16) (17-19)

State Discharge Permit  
**02-DP-0022**

Form Approved. 12345  
 OMB No. 2040-0004.  
 Approval expires 05-31-98

005/008

ADDRESS **626 Hanover Pike**  
**Hampstead, MD 21074**  
 FACILITY **Black and Decker WWTP**  
 LOCATION **626 Hanover Pike**  
 ATTN:

**MD0001881**  
 PERMIT NUMBER

**201**  
 DISCHARGE NUMBER

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
07	07	01		07	09	30	
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)	

\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form.

MES/TECH ENG SERVICES

FAX 4107298340


FAX 14:29

10/25/2007

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE		218161	256003	( 07 ) GPD	*****	*****	*****	0	MEASURED	RECORD
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	0	0	0	ONE/ QUARTER	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	0	0	0	ONE/ QUARTER	GRAB
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	0	0	0	ONE/ QUARTER	GRAB
	SAMPLE MEASUREMENT									
	SAMPLE MEASUREMENT									
	SAMPLE MEASUREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
**Jim Harkins, Director MES**  
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
410	729-8350	07	10	23
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Quarterly Report!



---

**APPENDIX C**  
**GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS**  
**(JULY - SEPTEMBER 2007)**

---



**REPORT OF ANALYSIS**

Maryland Environmental Services (A)  
259 Najoles Road  
Millersville, MD 21108

Order Number: A07071329  
Project Name: Black & Decker WWTP  
Receive Date: 7/25/2007  
Client Code: MES\_A  
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A07071329-01** **Sample Date: 7/25/2007 10:15**

Site: Black & Decker 001  
Client Sample ID:  
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
BOD-5	8	mg/L	2	SM 5210 B	7/26/2007 10:00:00 AM	SKent
Total Suspended Solids	18	mg/L	5	SM 2540D	7/27/2007 11:46:00 AM	JMcGuire

**Sample # A07071329-01A** **Sample Date: 7/25/2007 10:15**

Site: Black & Decker 001  
Client Sample ID: A  
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	<5	mg/L	5	EPA 1664	7/25/2007 5:45:00 PM	SHess

**Sample # A07071329-01B** **Sample Date: 7/25/2007 10:15**

Site: Black & Decker 001  
Client Sample ID: B  
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	8/1/2007 4:41:00 PM	IMcMullen
Tetrachloroethene	<1	ug/L	1	EPA 8260B	8/1/2007 4:41:00 PM	IMcMullen
Trichloroethene	<1	ug/L	1	EPA 8260B	8/1/2007 4:41:00 PM	IMcMullen

Approved:   
Quality Assurance Manager

Reported: 8/17/2007 7:01:15 AM

RDL = Reporting Detection Limit    N/A = Not Applicable  
Laboratory Certification Numbers: Delaware - DE00011    Maryland - #138    Pennsylvania - 68-335    New Jersey - DE568



**ATLANTIC COAST**  
Laboratories, Incorporated

630 Churchmans Road  
Newark, Delaware 19702  
302-266-9121 • 454-8720 (FAX)  
WWW.ATLANTICCOASTLABS.COM

**REPORT OF ANALYSIS**

Maryland Environmental Services (A)  
259 Najoles Road  
Millersville, MD 21108

Order Number: A07071332  
Project Name: Black & Decker WWTP  
Receive Date: 7/25/2007  
Client Code: MES\_A  
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A07071332-01** **Sample Date: 7/25/2007 10:40**

Site: Black & Decker 201  
Client Sample ID:  
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	8/1/2007 5:12:00 PM	IMcMullen
Tetrachloroethene	<1	ug/L	1	EPA 8260B	8/1/2007 5:12:00 PM	IMcMullen
Trichloroethene	<1	ug/L	1	EPA 8260B	8/1/2007 5:12:00 PM	IMcMullen

Approved:   
Quality Assurance Manager

Reported: 8/17/2007 7:01:17 AM

RDL = Reporting Detection Limit    N/A = Not Applicable  
Laboratory Certification Numbers: Delaware - DE00011    Maryland - #138    Pennsylvania - 68-335    New Jersey - DE568



630 Churchmans Road  
 Newark, Delaware 19702  
 302-266-9121 • 454-8720 (FAX)  
 WWW.ATLANTICCOASTLABS.COM

**REPORT OF ANALYSIS**

Maryland Environmental Services (A)  
 259 Najoles Road  
 Millersville, MD 21108

Order Number: A07080436  
 Project Name: Black & Decker WWTP  
 Receive Date: 8/8/2007  
 Client Code: MES\_A  
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A07080436-01** **Sample Date: 8/8/2007 10:55**

Site: Black & Decker 001  
 Client Sample ID:  
 Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
BOD-5	6	mg/L	2	SM 5210 B	8/9/2007 11:00:00 AM	SKent
Total Suspended Solids	16	mg/L	8	SM 2540D	8/9/2007 12:15:00 PM	MTinnerello

**Sample # A07080436-01A** **Sample Date: 8/8/2007 10:55**

Site: Black & Decker 001  
 Client Sample ID: A  
 Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	<5.1	mg/L	5.1	EPA 1664	8/14/2007 10:00:00 AM	WVanArsdall

**Sample # A07080436-01B** **Sample Date: 8/8/2007 10:55**

Site: Black & Decker 001  
 Client Sample ID: B  
 Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	8/10/2007 6:52:00 PM	IMcMullen
Tetrachloroethene	<1	ug/L	1	EPA 8260B	8/10/2007 6:52:00 PM	IMcMullen
Trichloroethene	<1	ug/L	1	EPA 8260B	8/10/2007 6:52:00 PM	IMcMullen

Approved:   
 Laboratory Operations Manager

Reported: 8/29/2007 12:06:35 PM

RDL = Reporting Detection Limit    N/A = Not Applicable  
 Laboratory Certification Numbers: Delaware - DE00011    Maryland - #138    Pennsylvania - 68-335    New Jersey - DE568



**ATLANTIC COAST**  
Laboratories, Incorporated

630 Churchmans Road  
Newark, Delaware 19702  
302-266-9121 • 454-8720 (FAX)  
WWW.ATLANTICCOASTLABS.COM

**REPORT OF ANALYSIS**

Maryland Environmental Services (A)  
259 Najoles Road  
Millersville, MD 21108

Order Number: A07091004  
Project Name: Black & Decker WWTP  
Receive Date: 9/20/2007  
Client Code: MES\_A  
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A07091004-01** **Sample Date: 9/19/2007 11:25**

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	9/26/2007 11:47:00 PM	IMcMullen
Tetrachloroethene	<1	ug/L	1	EPA 8260B	9/26/2007 11:47:00 PM	IMcMullen
Trichlorofluoromethane	<1	ug/L	1	EPA 8260B	9/26/2007 11:47:00 PM	IMcMullen

Approved:

*Warren Van Arsdale*  
Quality Assurance Manager

Reported:

10/1/2007 7:04:05 AM

RDL = Reporting Detection Limit    N/A = Not Applicable

Laboratory Certification Numbers: Delaware - DE00011    Maryland - #138    Pennsylvania - 68-335    New Jersey - DE568



**ATLANTIC COAST**  
Laboratories, Incorporated

630 Churchmans Road  
Newark, Delaware 19702  
302-266-9121 • 454-8720 (FAX)  
WWW.ATLANTICCOASTLABS.COM

**REPORT OF ANALYSIS**

Maryland Environmental Services (A)  
259 Najoles Road  
Millersville, MD 21108

Order Number: A07090959  
Project Name: Black & Decker WWTP  
Receive Date: 9/19/2007  
Client Code: MES\_A  
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A07090959-01**

**Sample Date: 9/19/2007 11:25**

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
BOD-5	4	mg/L	2	SM 5210 B	9/20/2007 11:00:00 AM	SKent
Total Suspended Solids	10	mg/L	4	SM 2540D	9/24/2007 3:15:00 PM	JMcGuire

**Sample # A07090959-01A**

**Sample Date: 9/19/2007 11:25**

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID: A

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	8.4	mg/L	5.2	EPA 1664	9/30/2007 4:30:00 PM	SHess

Approved:

*Walter Van Antwerp*  
Quality Assurance Manager

Reported:

10/9/2007 7:12:12 AM

RDL = Reporting Detection Limit

N/A = Not Applicable

Laboratory Certification Numbers:

Delaware - DE00011

Maryland - #138

Pennsylvania - 68-335

New Jersey - DE568

---

**APPENDIX D**  
**GROUNDWATER ANALYTICAL DATA PACKAGE**  
**(AUGUST 2007)**

---

## ANALYTICAL REPORT

Job Number: 500-5884-1

Job Description: Black and Decker

For:


Weston Solutions, Inc.

1400 Weston Way

PO BOX 2653

West Chester, PA 19380

Attention: Mr. Tom Cornuet



---

Richard C Wright  
Project Manager II  
rwright@stl-inc.com  
08/23/2007

These test results meet all the requirements of NELAC for accredited parameters.

The Lab Certification ID# is 100201.

All questions regarding this test report should be directed to the TestAmerica Project Manager whose signature appears on this report. All pages of this report are integral parts of the analytical data. Therefore, this report should be

TestAmerica Laboratories, Inc.

TestAmerica Chicago 2417 Bond Street, University Park, IL 60466

Tel (708) 534-5200 Fax (708) 534-5211 [www.testamericainc.com](http://www.testamericainc.com)





**Job Narrative**  
**500-J5884-1**

**Comments**

No additional comments.

**Receipt**

All samples were received in good condition within temperature requirements.

**GC/MS VOA**

The following sample was diluted due to the abundance of target analytes: 18.  
Elevated reporting limits (RLs) are provided.

No other analytical or quality issues were noted.

## EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
<b>500-5884-3</b> Trichloroethene	<b>RFW-2A</b>	1.0	1.0	ug/L	8260B
<b>500-5884-5</b> cis-1,2-Dichloroethene Tetrachloroethene	<b>RFW-3B</b>	5.4 1.9	1.0 1.0	ug/L ug/L	8260B 8260B
<b>500-5884-6</b> cis-1,2-Dichloroethene Chloroform Trichloroethene Tetrachloroethene	<b>RFW-4A</b>	1.0 1.1 41 38	1.0 1.0 1.0 1.0	ug/L ug/L ug/L ug/L	8260B 8260B 8260B 8260B
<b>500-5884-7</b> cis-1,2-Dichloroethene Chloroform Trichloroethene Tetrachloroethene	<b>RFW-4B</b>	4.0 1.8 55 120	1.0 1.0 1.0 10	ug/L ug/L ug/L ug/L	8260B 8260B 8260B 8260B
<b>500-5884-8</b> cis-1,2-Dichloroethene Chloroform Trichloroethene Tetrachloroethene	<b>RFW-4B-DUP</b>	3.6 1.7 54 96	1.0 1.0 1.0 1.0	ug/L ug/L ug/L ug/L	8260B 8260B 8260B 8260B
<b>500-5884-9</b> Trichloroethene Tetrachloroethene	<b>RFW-6</b>	2.0 2.6	1.0 1.0	ug/L ug/L	8260B 8260B
<b>500-5884-10</b> Trichloroethene	<b>RFW-7</b>	5.2	1.0	ug/L	8260B

## EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
<b>500-5884-11</b>	<b>RFW-9</b>				
1,1-Dichloroethene		1.0	1.0	ug/L	8260B
1,1-Dichloroethane		1.3	1.0	ug/L	8260B
cis-1,2-Dichloroethene		14	1.0	ug/L	8260B
1,1,1-Trichloroethane		1.5	1.0	ug/L	8260B
Trichloroethene		18	1.0	ug/L	8260B
Tetrachloroethene		6.4	1.0	ug/L	8260B
<b>500-5884-12</b>	<b>RFW-11B</b>				
Trichloroethene		16	1.0	ug/L	8260B
<b>500-5884-13</b>	<b>RFW-12B</b>				
cis-1,2-Dichloroethene		5.5	1.0	ug/L	8260B
Trichloroethene		370	10	ug/L	8260B
Tetrachloroethene		34	1.0	ug/L	8260B
<b>500-5884-14</b>	<b>RFW-13</b>				
Trichloroethene		3.9	1.0	ug/L	8260B
Tetrachloroethene		19	1.0	ug/L	8260B
<b>500-5884-15</b>	<b>RFW-17</b>				
Methylene Chloride		1.5	1.0	ug/L	8260B
<b>500-5884-16</b>	<b>EW-2</b>				
cis-1,2-Dichloroethene		2.3	1.0	ug/L	8260B
Trichloroethene		480	10	ug/L	8260B
Tetrachloroethene		68	1.0	ug/L	8260B
<b>500-5884-17</b>	<b>EW-3</b>				
cis-1,2-Dichloroethene		2.4	1.0	ug/L	8260B
Trichloroethene		220	10	ug/L	8260B
Tetrachloroethene		5.3	1.0	ug/L	8260B
<b>500-5884-18</b>	<b>EW-4</b>				
Trichloroethene		1600	50	ug/L	8260B
Tetrachloroethene		31	5.0	ug/L	8260B

TestAmerica Chicago

**EXECUTIVE SUMMARY - Detections**

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
<b>500-5884-19</b>	<b>EW-5</b>				
1,1,1-Trichloroethane		1.4	1.0	ug/L	8260B
Trichloroethene		210	10	ug/L	8260B
Tetrachloroethene		13	1.0	ug/L	8260B
<b>500-5884-20</b>	<b>EW-6</b>				
Trichloroethene		9.2	1.0	ug/L	8260B
Tetrachloroethene		21	1.0	ug/L	8260B
<b>500-5884-21</b>	<b>EW-7</b>				
cis-1,2-Dichloroethene		5.8	1.0	ug/L	8260B
Trichloroethene		5.5	1.0	ug/L	8260B
Tetrachloroethene		12	1.0	ug/L	8260B
<b>500-5884-22</b>	<b>EW-8</b>				
cis-1,2-Dichloroethene		19	1.0	ug/L	8260B
Trichloroethene		11	1.0	ug/L	8260B
Tetrachloroethene		82	1.0	ug/L	8260B
<b>500-5884-23</b>	<b>EW-9</b>				
Trichloroethene		1.7	1.0	ug/L	8260B
Tetrachloroethene		190	10	ug/L	8260B
<b>500-5884-24</b>	<b>EW-9 DUP</b>				
Trichloroethene		1.8	1.0	ug/L	8260B
Tetrachloroethene		220	10	ug/L	8260B
<b>500-5884-25</b>	<b>EW-10</b>				
Tetrachloroethene		4.6	1.0	ug/L	8260B

# METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Description	Lab Location	Method	Preparation Method
<b>Matrix: Water</b>			
VOC	TAL CHI	SW846 8260B	
Purge-and-Trap	TAL CHI		SW846 5030B

### Lab References:

TAL CHI = TestAmerica Chicago

### Method References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

# SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-5884-1

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
500-5884-1	RFW-1A	Water	08/06/2007 0810	08/09/2007 0950
500-5884-2	RFW-1B	Water	08/06/2007 1725	08/09/2007 0950
500-5884-3	RFW-2A	Water	08/06/2007 0900	08/09/2007 0950
500-5884-4	RFW-2B	Water	08/06/2007 0920	08/09/2007 0950
500-5884-5	RFW-3B	Water	08/06/2007 1815	08/09/2007 0950
500-5884-6	RFW-4A	Water	08/07/2007 0845	08/09/2007 0950
500-5884-7	RFW-4B	Water	08/07/2007 0950	08/09/2007 0950
500-5884-8	RFW-4B-DUP	Water	08/07/2007 0950	08/09/2007 0950
500-5884-9	RFW-6	Water	08/07/2007 0700	08/09/2007 0950
500-5884-10	RFW-7	Water	08/07/2007 0955	08/09/2007 0950
500-5884-11	RFW-9	Water	08/07/2007 1725	08/09/2007 0950
500-5884-12	RFW-11B	Water	08/07/2007 0715	08/09/2007 0950
500-5884-13	RFW-12B	Water	08/07/2007 0935	08/09/2007 0950
500-5884-14	RFW-13	Water	08/06/2007 1435	08/09/2007 0950
500-5884-15	RFW-17	Water	08/06/2007 1030	08/09/2007 0950
500-5884-16	EW-2	Water	08/07/2007 0940	08/09/2007 0950
500-5884-17	EW-3	Water	08/07/2007 0950	08/09/2007 0950
500-5884-18	EW-4	Water	08/07/2007 1000	08/09/2007 0950
500-5884-19	EW-5	Water	08/07/2007 1010	08/09/2007 0950
500-5884-20	EW-6	Water	08/07/2007 1139	08/09/2007 0950
500-5884-21	EW-7	Water	08/07/2007 1215	08/09/2007 0950
500-5884-22	EW-8	Water	08/07/2007 1320	08/09/2007 0950
500-5884-23	EW-9	Water	08/07/2007 1240	08/09/2007 0950
500-5884-24	EW-9 DUP	Water	08/07/2007 1240	08/09/2007 0950
500-5884-25	EW-10	Water	08/07/2007 1225	08/09/2007 0950
500-5884-26	LEISTER-1	Water	08/06/2007 1315	08/09/2007 0950
500-5884-27	LEISTER-DAIRY	Water	08/06/2007 1320	08/09/2007 0950
500-5884-28	TRIP BLANK	Water	08/06/2007 1200	08/09/2007 0950

# SAMPLE RESULTS

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-1A  
 Lab Sample ID: 500-5884-1

Date Sampled: 08/06/2007 0810  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/15/2007 1137			
<b>Prep Method: 5030B</b>		Date Prepared: 08/15/2007 1137			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-1A  
 Lab Sample ID: 500-5884-1

Date Sampled: 08/06/2007 0810  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	103	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	98	%		75 - 120	
Dibromofluoromethane	100	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-1B  
 Lab Sample ID: 500-5884-2

Date Sampled: 08/06/2007 1725  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/15/2007 1200			
<b>Prep Method: 5030B</b>		Date Prepared: 08/15/2007 1200			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-1B  
 Lab Sample ID: 500-5884-2

Date Sampled: 08/06/2007 1725  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	111	%		70 - 125	
Toluene-d8 (Surr)	105	%		75 - 120	
4-Bromofluorobenzene (Surr)	102	%		75 - 120	
Dibromofluoromethane	106	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-2A  
 Lab Sample ID: 500-5884-3

Date Sampled: 08/06/2007 0900  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/15/2007 1223			
<b>Prep Method: 5030B</b>		Date Prepared: 08/15/2007 1223			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-2A  
 Lab Sample ID: 500-5884-3

Date Sampled: 08/06/2007 0900  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	111	%		70 - 125	
Toluene-d8 (Surr)	104	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	106	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-2B  
 Lab Sample ID: 500-5884-4

Date Sampled: 08/06/2007 0920  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/15/2007 1246			
<b>Prep Method: 5030B</b>		Date Prepared: 08/15/2007 1246			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-2B  
 Lab Sample ID: 500-5884-4

Date Sampled: 08/06/2007 0920  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	113	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	102	%		75 - 120	
Dibromofluoromethane	108	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-3B  
 Lab Sample ID: 500-5884-5

Date Sampled: 08/06/2007 1815  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/15/2007 1308			
<b>Prep Method: 5030B</b>		Date Prepared: 08/15/2007 1308			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	5.4	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	1.9	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-3B  
 Lab Sample ID: 500-5884-5

Date Sampled: 08/06/2007 1815  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	113	%		70 - 125	
Toluene-d8 (Surr)	102	%		75 - 120	
4-Bromofluorobenzene (Surr)	101	%		75 - 120	
Dibromofluoromethane	109	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-4A  
 Lab Sample ID: 500-5884-6

Date Sampled: 08/07/2007 0845  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/15/2007 1415			
<b>Prep Method: 5030B</b>		Date Prepared: 08/15/2007 1415			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	1.1	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	41	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	38	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-4A  
 Lab Sample ID: 500-5884-6

Date Sampled: 08/07/2007 0845  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	115	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	112	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-4B  
 Lab Sample ID: 500-5884-7

Date Sampled: 08/07/2007 0950  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/15/2007 1438			
<b>Prep Method: 5030B</b>		Date Prepared: 08/15/2007 1438			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	4.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	1.8	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	55	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-4B  
 Lab Sample ID: 500-5884-7

Date Sampled: 08/07/2007 0950  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	104	%		75 - 120	
4-Bromofluorobenzene (Surr)	103	%		75 - 120	
Dibromofluoromethane	113	%		75 - 120	
Method: 8260B Run Type: DL				Date Analyzed: 08/15/2007 1509	
Prep Method: 5030B				Date Prepared: 08/15/2007 1509	
Tetrachloroethene	120	ug/L	1.8	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	105	%		75 - 120	
4-Bromofluorobenzene (Surr)	101	%		75 - 120	
Dibromofluoromethane	112	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-4B-DUP  
 Lab Sample ID: 500-5884-8

Date Sampled: 08/07/2007 0950  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/15/2007 1533			
<b>Prep Method: 5030B</b>		Date Prepared: 08/15/2007 1533			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	3.6	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	1.7	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	54	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	96	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-4B-DUP  
 Lab Sample ID: 500-5884-8

Date Sampled: 08/07/2007 0950  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	116	%		70 - 125	
Toluene-d8 (Surr)	105	%		75 - 120	
4-Bromofluorobenzene (Surr)	99	%		75 - 120	
Dibromofluoromethane	111	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-6  
 Lab Sample ID: 500-5884-9

Date Sampled: 08/07/2007 0700  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/15/2007 1619			
<b>Prep Method: 5030B</b>		Date Prepared: 08/15/2007 1619			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	2.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	2.6	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-6  
 Lab Sample ID: 500-5884-9

Date Sampled: 08/07/2007 0700  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate					
1,2-Dichloroethane-d4 (Surr)	116	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	111	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-7  
 Lab Sample ID: 500-5884-10

Date Sampled: 08/07/2007 0955  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/15/2007 1642			
<b>Prep Method: 5030B</b>		Date Prepared: 08/15/2007 1642			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	5.2	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-7  
 Lab Sample ID: 500-5884-10

Date Sampled: 08/07/2007 0955  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	116	%		70 - 125	
Toluene-d8 (Surr)	104	%		75 - 120	
4-Bromofluorobenzene (Surr)	103	%		75 - 120	
Dibromofluoromethane	117	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-9  
 Lab Sample ID: 500-5884-11

Date Sampled: 08/07/2007 1725  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/15/2007 1705			
<b>Prep Method: 5030B</b>		Date Prepared: 08/15/2007 1705			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	1.3	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	14	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	1.5	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	18	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	6.4	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-9  
 Lab Sample ID: 500-5884-11

Date Sampled: 08/07/2007 1725  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	116	%		70 - 125	
Toluene-d8 (Surr)	104	%		75 - 120	
4-Bromofluorobenzene (Surr)	99	%		75 - 120	
Dibromofluoromethane	115	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-11B  
 Lab Sample ID: 500-5884-12

Date Sampled: 08/07/2007 0715  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/16/2007 1052			
<b>Prep Method: 5030B</b>		Date Prepared: 08/16/2007 1052			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	16	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-11B  
 Lab Sample ID: 500-5884-12

Date Sampled: 08/07/2007 0715  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	104	%		75 - 120	
4-Bromofluorobenzene (Surr)	97	%		75 - 120	
Dibromofluoromethane	116	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-12B  
 Lab Sample ID: 500-5884-13

Date Sampled: 08/07/2007 0935  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/16/2007 1138			
<b>Prep Method: 5030B</b>		Date Prepared: 08/16/2007 1138			
Trichloroethene	370	ug/L	1.3	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	117	%		70 - 125	
Toluene-d8 (Surr)	105	%		75 - 120	
4-Bromofluorobenzene (Surr)	96	%		75 - 120	
Dibromofluoromethane	120	%		75 - 120	
<b>Method: 8260B Run Type: DL</b>		Date Analyzed: 08/16/2007 1115			
<b>Prep Method: 5030B</b>		Date Prepared: 08/16/2007 1115			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	5.5	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-12B  
 Lab Sample ID: 500-5884-13

Date Sampled: 08/07/2007 0935  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Tetrachloroethene	34	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	115	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	101	%		75 - 120	
Dibromofluoromethane	119	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-13  
 Lab Sample ID: 500-5884-14

Date Sampled: 08/06/2007 1435  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/16/2007 1201			
<b>Prep Method: 5030B</b>		Date Prepared: 08/16/2007 1201			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	3.9	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	19	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-13  
 Lab Sample ID: 500-5884-14

Date Sampled: 08/06/2007 1435  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	115	%		70 - 125	
Toluene-d8 (Surr)	104	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	119	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-17  
 Lab Sample ID: 500-5884-15

Date Sampled: 08/06/2007 1030  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/17/2007 1305			
<b>Prep Method: 5030B</b>		Date Prepared: 08/17/2007 1305			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	1.5	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: RFW-17  
 Lab Sample ID: 500-5884-15

Date Sampled: 08/06/2007 1030  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0 *	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0 *	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0 *	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0 *	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	106	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-2  
 Lab Sample ID: 500-5884-16

Date Sampled: 08/07/2007 0940  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/16/2007 1247			
<b>Prep Method: 5030B</b>		Date Prepared: 08/16/2007 1247			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	2.3	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	68	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-2  
 Lab Sample ID: 500-5884-16

Date Sampled: 08/07/2007 0940  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	116	%		70 - 125	
Toluene-d8 (Surr)	104	%		75 - 120	
4-Bromofluorobenzene (Surr)	96	%		75 - 120	
Dibromofluoromethane	115	%		75 - 120	
Method: 8260B	Run Type: DL		Date Analyzed: 08/20/2007 1125		
Prep Method: 5030B			Date Prepared: 08/20/2007 1125		
Trichloroethene	480	ug/L	1.3	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	99	%		75 - 120	
Dibromofluoromethane	105	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-3  
 Lab Sample ID: 500-5884-17

Date Sampled: 08/07/2007 0950  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/20/2007 1148			
<b>Prep Method: 5030B</b>		Date Prepared: 08/20/2007 1148			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	2.4	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	5.3	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-3  
 Lab Sample ID: 500-5884-17

Date Sampled: 08/07/2007 0950  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	110	%		70 - 125	
Toluene-d8 (Surr)	102	%		75 - 120	
4-Bromofluorobenzene (Surr)	101	%		75 - 120	
Dibromofluoromethane	106	%		75 - 120	
Method: 8260B Run Type: DL			Date Analyzed: 08/20/2007 1212		
Prep Method: 5030B			Date Prepared: 08/20/2007 1212		
Trichloroethene	220	ug/L	1.3	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	108	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-4  
 Lab Sample ID: 500-5884-18

Date Sampled: 08/07/2007 1000  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/20/2007 1235			
<b>Prep Method: 5030B</b>		Date Prepared: 08/20/2007 1235			
Benzene	<5.0	ug/L	1.2	5.0	5.0
Dichlorodifluoromethane	<5.0	ug/L	0.60	5.0	5.0
Chloromethane	<5.0	ug/L	1.0	5.0	5.0
Vinyl chloride	<5.0	ug/L	0.80	5.0	5.0
Bromomethane	<5.0	ug/L	3.0	5.0	5.0
Chloroethane	<5.0	ug/L	1.6	5.0	5.0
Trichlorofluoromethane	<5.0	ug/L	0.70	5.0	5.0
1,1-Dichloroethene	<5.0	ug/L	1.3	5.0	5.0
Carbon disulfide	<25	ug/L	0.75	25	5.0
Acetone	<25	ug/L	7.0	25	5.0
Methylene Chloride	<5.0	ug/L	1.2	5.0	5.0
trans-1,2-Dichloroethene	<5.0	ug/L	1.5	5.0	5.0
1,1-Dichloroethane	<5.0	ug/L	0.75	5.0	5.0
2,2-Dichloropropane	<5.0	ug/L	0.85	5.0	5.0
cis-1,2-Dichloroethene	<5.0	ug/L	1.0	5.0	5.0
2-Butanone (MEK)	<25	ug/L	5.0	25	5.0
Bromochloromethane	<5.0	ug/L	1.4	5.0	5.0
Chloroform	<5.0	ug/L	0.70	5.0	5.0
1,1,1-Trichloroethane	<5.0	ug/L	0.85	5.0	5.0
1,1-Dichloropropene	<5.0	ug/L	1.9	5.0	5.0
Carbon tetrachloride	<5.0	ug/L	1.7	5.0	5.0
1,2-Dichloroethane	<5.0	ug/L	1.3	5.0	5.0
1,2-Dichloropropane	<5.0	ug/L	0.95	5.0	5.0
Dibromomethane	<5.0	ug/L	1.1	5.0	5.0
Bromodichloromethane	<5.0	ug/L	1.1	5.0	5.0
cis-1,3-Dichloropropene	<5.0	ug/L	0.75	5.0	5.0
4-Methyl-2-pentanone (MIBK)	<25	ug/L	4.6	25	5.0
Toluene	<5.0	ug/L	0.90	5.0	5.0
trans-1,3-Dichloropropene	<5.0	ug/L	0.80	5.0	5.0
1,1,2-Trichloroethane	<5.0	ug/L	1.2	5.0	5.0
Tetrachloroethene	31	ug/L	0.90	5.0	5.0
1,3-Dichloropropane	<5.0	ug/L	1.1	5.0	5.0
2-Hexanone	<25	ug/L	5.0	25	5.0
Dibromochloromethane	<5.0	ug/L	1.1	5.0	5.0
1,2-Dibromoethane	<5.0	ug/L	1.7	5.0	5.0
Chlorobenzene	<5.0	ug/L	0.75	5.0	5.0
1,1,1,2-Tetrachloroethane	<5.0	ug/L	1.7	5.0	5.0
Ethylbenzene	<5.0	ug/L	1.1	5.0	5.0
m&p-Xylene	<10	ug/L	1.8	10	5.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-4  
 Lab Sample ID: 500-5884-18

Date Sampled: 08/07/2007 1000  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<5.0	ug/L	0.95	5.0	5.0
Styrene	<5.0	ug/L	0.90	5.0	5.0
Bromoform	<5.0	ug/L	1.6	5.0	5.0
Isopropylbenzene	<5.0	ug/L	1.0	5.0	5.0
Bromobenzene	<5.0	ug/L	1.1	5.0	5.0
1,1,2,2-Tetrachloroethane	<5.0	ug/L	1.7	5.0	5.0
1,2,3-Trichloropropane	<5.0	ug/L	1.8	5.0	5.0
N-Propylbenzene	<5.0	ug/L	0.80	5.0	5.0
2-Chlorotoluene	<5.0	ug/L	0.80	5.0	5.0
1,3,5-Trimethylbenzene	<5.0	ug/L	0.90	5.0	5.0
4-Chlorotoluene	<5.0	ug/L	0.90	5.0	5.0
tert-Butylbenzene	<5.0	ug/L	0.80	5.0	5.0
1,2,4-Trimethylbenzene	<5.0	ug/L	1.3	5.0	5.0
sec-Butylbenzene	<5.0	ug/L	0.95	5.0	5.0
1,3-Dichlorobenzene	<5.0	ug/L	1.1	5.0	5.0
p-Isopropyltoluene	<5.0	ug/L	1.5	5.0	5.0
1,4-Dichlorobenzene	<5.0	ug/L	1.3	5.0	5.0
n-Butylbenzene	<5.0	ug/L	1.8	5.0	5.0
1,2-Dichlorobenzene	<5.0	ug/L	1.5	5.0	5.0
1,2-Dibromo-3-Chloropropane	<5.0	ug/L	2.1	5.0	5.0
1,2,4-Trichlorobenzene	<5.0	ug/L	1.8	5.0	5.0
Hexachlorobutadiene	<5.0	ug/L	1.8	5.0	5.0
Naphthalene	<5.0	ug/L	1.9	5.0	5.0
1,2,3-Trichlorobenzene	<5.0	ug/L	2.2	5.0	5.0
Surrogate			Acceptance Limits		
1,2-Dichloroethane-d4 (Surr)	112	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	103	%		75 - 120	
Dibromofluoromethane	109	%		75 - 120	
<b>Method: 8260B Run Type: DL</b>			Date Analyzed: 08/20/2007 1258		
<b>Prep Method: 5030B</b>			Date Prepared: 08/20/2007 1258		
Trichloroethene	1600	ug/L	6.5	50	50
Surrogate			Acceptance Limits		
1,2-Dichloroethane-d4 (Surr)	116	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	102	%		75 - 120	
Dibromofluoromethane	109	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-5  
 Lab Sample ID: 500-5884-19

Date Sampled: 08/07/2007 1010  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/20/2007 1322			
<b>Prep Method: 5030B</b>		Date Prepared: 08/20/2007 1322			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	1.4	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	13	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-5  
 Lab Sample ID: 500-5884-19

Date Sampled: 08/07/2007 1010  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	112	%		70 - 125	
Toluene-d8 (Surr)	102	%		75 - 120	
4-Bromofluorobenzene (Surr)	101	%		75 - 120	
Dibromofluoromethane	111	%		75 - 120	
Method: 8260B Run Type: DL			Date Analyzed: 08/20/2007 1345		
Prep Method: 5030B			Date Prepared: 08/20/2007 1345		
Trichloroethene	210	ug/L	1.3	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	113	%		70 - 125	
Toluene-d8 (Surr)	101	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	112	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-6  
 Lab Sample ID: 500-5884-20

Date Sampled: 08/07/2007 1139  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/20/2007 1408			
<b>Prep Method: 5030B</b>		Date Prepared: 08/20/2007 1408			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	9.2	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	21	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-6  
 Lab Sample ID: 500-5884-20

Date Sampled: 08/07/2007 1139  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	115	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	102	%		75 - 120	
Dibromofluoromethane	111	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-7  
 Lab Sample ID: 500-5884-21

Date Sampled: 08/07/2007 1215  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/20/2007 1431			
<b>Prep Method: 5030B</b>		Date Prepared: 08/20/2007 1431			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	5.8	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	5.5	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	12	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-7  
 Lab Sample ID: 500-5884-21

Date Sampled: 08/07/2007 1215  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	113	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	99	%		75 - 120	
Dibromofluoromethane	111	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-8  
 Lab Sample ID: 500-5884-22

Date Sampled: 08/07/2007 1320  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/20/2007 1455			
<b>Prep Method: 5030B</b>		Date Prepared: 08/20/2007 1455			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	19	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	11	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
Tetrachloroethene	82	ug/L	0.18	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-8  
 Lab Sample ID: 500-5884-22

Date Sampled: 08/07/2007 1320  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	113	%		70 - 125	
Toluene-d8 (Surr)	103	%		75 - 120	
4-Bromofluorobenzene (Surr)	96	%		75 - 120	
Dibromofluoromethane	108	%		75 - 120	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-9  
 Lab Sample ID: 500-5884-23

Date Sampled: 08/07/2007 1240  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/20/2007 1541			
<b>Prep Method: 5030B</b>		Date Prepared: 08/20/2007 1541			
Benzene	<1.0	ug/L	0.23	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.12	1.0	1.0
Chloromethane	<1.0	ug/L	0.20	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.16	1.0	1.0
Bromomethane	<1.0	ug/L	0.59	1.0	1.0
Chloroethane	<1.0	ug/L	0.32	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.14	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.25	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.15	5.0	1.0
Acetone	<5.0	ug/L	1.4	5.0	1.0
Methylene Chloride	<1.0	ug/L	0.24	1.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.29	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.15	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.20	1.0	1.0
2-Butanone (MEK)	<5.0	ug/L	1.0	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.27	1.0	1.0
Chloroform	<1.0	ug/L	0.14	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.38	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.34	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
Trichloroethene	1.7	ug/L	0.13	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.19	1.0	1.0
Dibromomethane	<1.0	ug/L	0.21	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.22	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.15	1.0	1.0
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	0.92	5.0	1.0
Toluene	<1.0	ug/L	0.18	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.22	1.0	1.0
2-Hexanone	<5.0	ug/L	0.99	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.33	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.33	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.21	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.36	2.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-5884-1

Client Sample ID: EW-9  
 Lab Sample ID: 500-5884-23

Date Sampled: 08/07/2007 1240  
 Date Received: 08/09/2007 0950  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.19	1.0	1.0
Styrene	<1.0	ug/L	0.18	1.0	1.0
Bromoform	<1.0	ug/L	0.32	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.22	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.34	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.35	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.16	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.26	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.19	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.29	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.25	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.35	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.29	1.0	1.0
1,2-Dibromo-3-Chloropropane	<1.0	ug/L	0.41	1.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.36	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.36	1.0	1.0
Naphthalene	<1.0	ug/L	0.37	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.43	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	116	%		70 - 125	
Toluene-d8 (Surr)	102	%		75 - 120	
4-Bromofluorobenzene (Surr)	99	%		75 - 120	
Dibromofluoromethane	113	%		75 - 120	
Method: 8260B	Run Type: DL		Date Analyzed: 08/20/2007 1604		
Prep Method: 5030B			Date Prepared: 08/20/2007 1604		
Tetrachloroethene	190	ug/L	1.8	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		70 - 125	
Toluene-d8 (Surr)	101	%		75 - 120	
4-Bromofluorobenzene (Surr)	100	%		75 - 120	
Dibromofluoromethane	115	%		75 - 120	