

**Quarterly Groundwater Monitoring Report**

Prepared for

**Black & Decker (U.S.) Inc.**

Hampstead, Maryland

October 2010

Prepared by

**WESTON SOLUTIONS, INC.**

West Chester, Pennsylvania 19380-1499

---

## TABLE OF CONTENTS

---

Section	Page
1. INTRODUCTION .....	1-1
2. SITE CHARACTERISTICS .....	2-1
2.1 HYDRAULIC PROPERTIES .....	2-1
2.2 EFFLUENT CHARACTERISTICS .....	2-1
2.3 GROUNDWATER QUALITY DATA .....	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS .....	4-1

---

## LIST OF APPENDICES

---

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

---

## LIST OF TABLES

---

<b>Table</b>	<b>Page</b>
Table 2-1 Treatment System Pumping Records – 3rd Quarter 2010 .....	2-2
Table 2-2 Groundwater Elevation Data – 3rd Quarter 2010.....	2-3
Table 2-3 Effluent Characteristics Summary – 3rd Quarter 2010.....	2-4
Table 2-4 Summary of Groundwater Analytical Results - August 2010 .....	2-5
Table 3-1 Treatment System Maintenance Activities – 3rd Quarter 2010.....	3-2

## 1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

## **2. SITE CHARACTERISTICS**

### **2.1 HYDRAULIC PROPERTIES**

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of July through September 2010.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of July through September 2010, the extraction wells were pumping at an average combined rate of approximately 169 gallons per minute (gpm).

### **2.2 EFFLUENT CHARACTERISTICS**

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of July through September 2010 are included in Appendix B.

### **2.3 GROUNDWATER QUALITY DATA**

For the reporting period of July through September 2010, approximately 15.8 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (86.7 %) and tetrachloroethene (PCE) (13.3 %). Analytical results of the groundwater collected from the air stripper for the period of July through September 2010 are included in Appendix C.

A summary of the analytical results from the third quarter (August 2010) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

**Table 2-1**  
**Treatment System Pumping Records - 3rd Quarter 2010**  
**Black & Decker**  
**Hampstead, Maryland**

<b>Date</b>	<b>Water Pumped (gallons)</b>
<b>July 2010</b>	7,505,570
<b>August 2010</b>	7,175,989
<b>September 2010</b>	6,655,915

**Table 2-2**  
**Groundwater Elevation Data - 3rd Quarter 2010**  
**Black & Decker**  
**Hampstead, Maryland**

WELL NO.	TOC ELEV.	TOTAL DEPTH	7/15/2010		8/18/2010		9/7/2010	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NC	DRY	NC	DRY	NC
EW-2	849.21	110	86.11	763.10	93.61	755.60	94.10	755.11
EW-3	846.64	118	83.87	762.77	86.71	759.93	88.40	758.24
EW-4	858.01	97.5	PC	NC	PC	NC	PC	NC
EW-5	864.17	98	90.14	774.03	91.17	773.00	91.25	772.92
EW-6	831.98	115	92.60	739.38	98.67	733.31	99.26	732.72
EW-7	818.38	78	46.03	772.35	45.28	773.10	52.60	765.78
EW-8	811.13	98	93.31	717.82	92.84	718.29	92.51	718.62
EW-9	811.35	141	102.00	709.35	102.00	709.35	103.00	708.35
EW-10	807.74	INA	49.73	758.01	52.69	755.05	54.60	753.14
RFW-1A	864.37	78	49.01	815.36	51.37	813.00	51.63	812.74
RFW-1B	864.23	200	49.06	815.17	51.39	812.84	51.67	812.56
RFW-2A	857.41	35	15.11	842.30	17.02	840.39	16.83	840.58
RFW-2B	857.73	75	15.52	842.21	17.61	840.12	17.17	840.56
RFW-3B	839.21	153	29.71	809.50	34.93	804.28	34.86	804.35
RFW-4A	830.37	62	35.54	794.83	36.51	793.86	36.43	793.94
RFW-4B	830.37	120	35.43	794.94	36.48	793.89	36.39	793.98
RFW-5A	817.50	30	DRY	NC	DRY	NC	DRY	NC
RFW-6	785.04	120	5.01	780.03	3.11	781.93	2.61	782.43
RFW-7	805.14	29	7.92	797.22	6.32	798.82	7.42	797.72
RFW-8	860.07	56	DRY	NC	DRY	NC	DRY	NC
RFW-9	862.02	49	26.13	835.89	26.47	835.55	26.47	835.55
RFW-10	852.06	58	DRY	NC	DRY	NC	DRY	NC
RFW-11A	849.32	72	Damaged	NC	Damaged	NC	Damaged	NC
RFW-11B	849.62	116	62.12	787.50	63.41	786.21	63.89	785.73
RFW-12B	844.87	264	50.93	793.94	49.95	794.92	50.11	794.76
RFW-13	849.11	150	58.61	790.50	58.11	791.00	59.61	789.50
RFW-14B	812.39	281	53.21	759.18	54.02	758.37	54.26	758.13
RFW-16	856.14	41	DRY	NC	DRY	NC	DRY	NC
RFW-17	834.66	60.5	23.89	810.77	25.81	808.85	26.41	808.25
RFW-20	842.49	142	31.41	811.08	33.48	809.01	34.10	808.39
RFW-21	832.65	102	19.29	813.36	21.05	811.60	21.34	811.31
PH-7	805.94	89	25.41	780.53	29.90	776.04	29.01	776.93
PH-9	814.94	98	39.80	775.14	41.62	773.32	38.67	776.27
PH-11	820.68	78	51.47	769.21	51.88	768.80	51.28	769.40
PH-12	828.35	87	51.81	776.54	53.97	774.38	53.79	774.56
B-3	803.02	83	10.02	793.00	10.55	792.47	9.91	793.11
Amoco	842.29	INA	NA	NC	NA	NC	NA	NC
Hamp. Town #22	804.96	INA	3.89	801.07	3.43	801.53	4.76	800.20
Pembroke #1	INA	INA	11.83	NC	12.33	NC	12.21	NC
Pembroke #2	INA	INA	Damaged	NC	Damaged	NC	Damaged	NC
N. Houcks. Rd.	INA	INA	10.53	NC	10.89	NC	9.83	NC
E. Century St.	INA	INA	19.08	NC	19.58	NC	19.74	NC
Lwr. Beckleys. Rd.	INA	INA	55.87	NC	55.69	NC	54.73	NC

NA - Not Available/Not Accessible

NC - Not Calculable

INA - Information not available

PC - Pump Cycles

Table 2-3  
 Effluent Characteristics Summary - 3rd Quarter 2010  
 Black & Decker  
 Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				July 2010	August 2010	September 2010	
001	FLOW	average	MGD	NA	0.129	0.142	0.102
		maximum	MGD	NA	0.236	0.338	0.130
	1,1,1-Trichloroethane		ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene		ug/l	5	< 1	< 1	< 1
	Trichloroethylene		ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		quarterly average	mg/l	10	< 5	< 5	< 5
	pH	minimum	STD	6.0	6.6	6.5	6.5
		maximum	STD	8.5	8.4	7.6	6.9
	BOD		mg/l	15	3.0	3.0	3.0
	TSS	maximum	mg/l	30	0.0	5.0	7.0
quarterly average		mg/l	20	0.0	5.0	7.0	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.217	0.203	0.208
		maximum	MGD	NA	0.327	0.248	0.288
	Fecal Coliform		MPN/100ml	200	1.0	1.0	1.0
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.232
		maximum	MGD	NA	NR	NR	0.287
	1,1,1-Trichloroethane		ug/l	NA	NR	NR	< 1
	Tetrachloroethylene		ug/l	NA	NR	NR	< 1
	Trichloroethylene		ug/l	NA	NR	NR	< 1

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported



**Table 2-4**  
**Summary of Groundwater Analytical Results - August 2010**  
**Black & Decker**  
**Hampstead, Maryland**

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3.4	2.2	1 U	1 U	1 U	2.2	20	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	380	76	920	130	7.4	2	8	1 U	1 U	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	50	2.5	19	4.2	15	4.8	52	84	83	1.6
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.  
J = Indicates an estimated value.

**Table 2-4**  
**Summary of Groundwater Analytical Results - August 2010**  
**Black & Decker**  
**Hampstead, Maryland**

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	NS	2 U	2 U	NS	2 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.2	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.3	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	2.6	0.9 J	0.9 J	2	NS	1 U	1 U	NS	16	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	0.8 J	0.8 J	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	37	36	17	NS	1.2	4.4	NS	14	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	29	29	29	NS	1.7	1 U	NS	6.5	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicate sample  
NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.  
J = Indicates an estimated value.

**Table 2-4**  
**Summary of Groundwater Analytical Results - August 2010**  
**Black & Decker**  
**Hampstead, Maryland**

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	RFW-20	RFW-21	Town #22	Town #23	Trip Blank
		USEPA drinking water method 524.2														
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	NS	NS	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	NS	NS	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	NS	2 U	ABD	ABD	ABD	2 U	0.5 U	0.5 U	NS	NS	0.5 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	NA	NA	NS	NS	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	2.9	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Trichloroethene	ug/L	NS	6.2	180	2.8	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	NS	NS	10 U
Tetrachloroethene	ug/L	NS	1 U	17	15	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	NS	NS	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division.  
 Samples from all of the other wells are analyzed with USEPA Method 8260.  
 NS = Not sampled  
 U = Compound was analyzed but not detected.  
 ABD = Well has been abandoned

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from well EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

### 3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (July through September 2010) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

**Table 3-1**  
**Treatment System Maintenance Activities - 3rd Quarter 2010**  
**Black & Decker**  
**Hampstead, Maryland**

Date	Event/Corrective Action
Jul-10	Alarm at the air stripper due to high wet well, reset the system. The system is back online.
Jul-10	Turn EW-3 off for 1 hour to replace a leaking valve. EW-3 back online.
Jul-10	Alarm at air stripper. A 4-inch plastic butterfly valve broke it was replaced it with a spool piece of pipe. The air stripper is back online.
Aug-10	Alarm at the air stripper due to a bad control relay in EW - 6. Replaced the control relay in EW - 6, well is back online.
Aug-10	Alarm at the air stripper due to a power outage, reset the system. The system is back online.
Aug-10	Installed a new 4-inch butterfly valve, the stripper was down for three hours, the system is back online.
Aug-10	Alarm at the air stripper, EW-9 is down due to a bad control relay. The control relay is replaced the well is back online.
Aug-10	Alarm at the air stripper, high column and blower failure. Reset the system, the stripper is back online.

#### 4. RECOMMENDATIONS

For the reporting period of July through September 2010, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

---

**APPENDIX A**  
**GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS**  
**(JULY – SEPTEMBER 2010)**

---



MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Superintendent: Earle Villarreal Certification # 1017

**Black & Decker WTP**

PWSID # 106 0004 County: Carroll

Operated by:  
Maryland Environmental Service

Address: BTR CAPITAL GROUP, Hampstead, MD 21073  
625 Hanover Pike, Hampstead, Carroll County, Maryland

Month: July  
Year: 2010

GENERAL			DOMESTIC WATER				CHEMICAL					MONITORING			DISTRIBUTION		RAW WATER		Comments	
Date	Day	Weather	Flow meter reading	MGD Total FQIR	pH P.O.E	Free Cl2	Na2CO3 Level	Na2CO3 (gpd)	NaOCL Level	NaOCL (gpd)	VOC'S (ppb)	Bacti Pos/Neg	pH su	TRC mg/l	DISTRIBUTION LOCATION	Operator Initials	pH su	TOTAL RAW WATER:WELL (mgd)		
1	Thurs	Clear	0	0.0020	7.5	1.26	40.00	1.00	67.00	0.00						djones		0.216367		
2	Fri	Clear	0	0.0076	7.1	1.31	38.00	2.00	67.00	0.00			7.33	1.02	Admin 2nd Fl	djones		0.271661		
3	Sat	Clear	0	0.0000	7.6	1.18	38.00	0.00	67.00	0.00						djones		0.192132		
4	Sun	Clear	0	0.0025	7.8	1.05	37.00	1.00	67.00	0.00						bm		0.271567		
5	Mon	Clear	0	0.0000	7.8	1.34	37.00	0.00	67.00	0.00						bm		0.247666		
6	Tue	Clear	0	0.0025	7.8	1.20	36.00	1.00	67.00	0.00						bm		0.256844		
7	Wed	Clear	0	0.0054	7.6	1.32	35.00	1.00	67.00	0.00						bm		0.222859		
8	Thurs	Clear	0	0.0029	9.0	1.17	34.00	1.00	67.00	0.00						fs		0.242040		
9	Fri	Clear	0	0.0076	7.1	1.28	32.00	2.00	67.00	0.00			6.7	0.77	Eng Lab	djones	4.60	0.286802		
10	Sat	Rain	0	0.0000	8.2	1.07	32.00	32.00	67.00	0.00						mw		0.237200		
11	Sun	Clear	0	0.0024	8.2	1.23	31.00	31.00	67.00	0.00						mw		0.249631		
12	Mon	Cloudy	0	0.0027	7.0	1.27	30.00	30.00	67.00	0.00						djones		0.216187		
13	Tue	Cloudy	0	0.0055	7.5	1.24	28.00	28.00	67.00	0.00			6.5	0.92	Eng Lab	djones		0.249075	Absent	
14	Wed	Rain	0	0.0053	7.5	1.25	27.00	27.00	67.00	0.00			7.3	1.08	Admin 1st Fl	djones	4.67	0.270425		
15	Thurs	Clear	0	0.0068	7.7	1.30	26.00	26.00	67.00	0.00						djones		0.233102		
16	Fri	Clear	0	0.0051	7.3	1.26	45.00	45.00	67.00	0.00			7.1	1.02	Admin 2nd Fl	djones		0.230416		
17	Sat	Clear	0	0.0025	7.5	1.14	44.00	44.00	67.00	0.00						djones		0.208760		
18	Sun	Clear	0	0.0000	7.3	1.04	44.00	44.00	67.00	0.00						djones		0.243565		
19	Mon	Cloudy	0	0.0050	7.4	1.05	43.00	43.00	67.00	0.00						dsmith		0.270921		
20	Tue	Cloudy	0	0.0050	7.7	1.64	42.00	42.00	67.00	0.00						jdowns		0.236877		
21	Wed	Cloudy	0	0.0050	8.3	1.58	40.00	40.00	67.00	0.00			7.8	1.25	Eng Lab	djones		0.267500		
22	Thurs	Clear	0	0.0039	8.1	1.44	38.00	2.00	67.00	0.00						djones	4.55	0.207500		
23	Fri	Clear	0	0.0064	8.3	1.46	36.00	2.00	67.00	0.00			7.9	1.07	Eng Lab	bm		0.262364		
24	Sat	Clear	0	0.0023	8.2	1.40	35.00	1.00	67.00	0.00						dsmith		0.190588		
25	Sun	Clear	0	0.0000	8.1	1.35	35.00	0.00	67.00	0.00						dsmith		0.240076		
26	Mon	Clear	0	0.0043	8.3	1.40	34.00	1.00	67.00	0.00						dsmith		0.270304		
27	Tue	Clear	0	0.0060	7.5	1.45	32.00	2.00	67.00	0.00			7.1	1.08	Admin 1st Fl	bm		0.251378		
28	Wed	Clear	0	0.0052	6.9	1.33	30.00	2.00	67.00	0.00						gd		0.244726		
29	Thurs	Cloudy	0	0.0052	8.4	1.64	28.00	2.00	67.00	0.00						gd		0.247213		
30	Fri	Clear	0	0.0037	8.4	1.18	27.00	1.00	67.00	0.00			8.3	0.99	Admin 2nd Fl	gd		0.229091		
31	Sat	Clear	0	0.0046	7.0	1.10	25.00	2.00	67.00	0.00						gd		0.240733		
Total				0.1174	239.9	39.93	1079.0	456.00	2077.0	0.00	0.0	0.0	66	9					7.505570	
Average				0.0038	7.74	1.29	34.81	14.71	67.00	0.00	0.0	0.0	7.34	1.02					0.242115	
Minimum				0.0000	6.94	1.04	25.00	0.00	67.00	0.00	0.0	0.0	6.52	0.77					0.190588	MOR
Maximum				0.0076	8.95	1.64	45.00	45.00	67.00	0.00	0.0	0.0	8.29	1.25					0.286802	12/04/08

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Superintendent: Earle Villarreal Certification # 1017

**Black & Decker WTP**

**PWSID # 106 0004** County: Carroll  
 Address: BTR CAPITAL GROUP, Hampstead, MD 21073  
 625 Hanover Pike, Hampstead, Carroll County, Maryland

Operated by  
 Maryland Environmental Service

Month: August

Year: 2010



GENERAL (DOMESTIC WATER)			CHEMICAL								MONITORING		DISTRIBUTION		RAW WATER		Comments		
Date	Day	Weather	Flow meter reading 0	MGD Total FQIR	pH P.O.E	Free Cl2	Na2CO3 Level	Na2CO3 (gpd)	NaOCl Level	NaOCl (gpd)	VOC'S (ppb)	Bacti Pos/Neg	pH su	TRC mg/l	DISTRIBUTION LOCATION	Operator Initials		pH su	TOTAL RAW WATER WELL (mgd)
1	Sun	Clear	0	0.0000	6.6	1.16	25.00	0.00	67.00	0.00						gd		0.218796	
2	Mon	Cloudy	0	0.0026	7.0	1.18	24.00	1.00	67.00	0.00			6.70	0.65	Eng Lab	djones		0.228394	
3	Tue	Cloudy	0	0.0071	7.3	1.24	21.00	3.00	67.00	0.00						djones		0.264380	
4	Wed	Cloudy	0	0.0051	7.2	1.33	38.00	3.00	67.00	0.00			7.0	1.14	Admin 1st Fl	djones		0.234729	
5	Thur	Cloudy	0	0.0060	7.1	1.27	36.00	2.00	67.00	0.00						djones		0.228993	
6	Fri	Clear	0	0.0108	6.9	1.08	34.00	2.00	67.00	0.00			6.8	0.97	Admin 2nd Fl	djones	4.97	0.241216	
7	Sat	Clear	0	0.0082	6.7	1.21	31.00	3.00	67.00	0.00						djones		0.184680	
8	Sun	Clear	0	0.0108	6.8	1.20	28.00	3.00	65.00	2.00						djones		0.238240	
9	Mon	Clear	0	0.0120	8.0	1.51	43.00	5.00	65.00	0.00			6.9	1.20	Eng Lab	gd		0.270252	
10	Tue	Clear	0	0.0040	7.0	1.54	41.00	2.00	65.00	0.00						bm		0.221330	
11	Wed	Clear	0	0.0070	7.0	1.73	39.00	2.00	65.00	0.00			6.7	1.33	Loading Dock	djones		0.253174	
12	Thur	Cloudy	0	0.0050	7.1	1.67	38.00	1.00	65.00	0.00						djones	4.75	0.231394	
13	Fri	Rain	0	0.0049	7.2	1.61	37.00	1.00	65.00	0.00			6.8	1.44	Admin 2nd Fl	djones		0.236565	
14	Sat	Cloudy	0	0.0023	7.2	1.60	36.00	1.00	65.00	0.00						dsmith		0.164308	
15	Sun	Cloudy	0	0.0000	7.2	1.65	36.00	0.00	65.00	0.00						dsmith		0.239848	
16	Mon	Cloudy	0	0.0048	6.8	1.42	34.00	2.00	65.00	0.00			6.9	1.32	Admin 1st Fl	djones		0.265990	
17	Tue	Cloudy	0	0.0028	7.4	1.45	33.00	1.00	65.00	0.00						djones		0.212410	
18	Wed	Rain	0	0.0075	7.3	1.55	31.00	2.00	65.00	0.00			7.1	1.27	Eng Lab	djones	4.76	0.264988	
19	Thur	Clear	0	0.0048	7.7	1.48	30.00	1.00	65.00	0.00						djones		0.241343	
20	Fri	Clear	0	0.0051	7.6	1.56	28.00	2.00	65.00	0.00			6.8	1.32	Admin 2nd Fl	djones		0.225647	
21	Sat	Clear	0	0.0024	6.7	1.35	27.00	1.00	65.00	0.00						gd		0.218093	
22	Sun	Cloudy	0	0.0000	7.0	1.20	27.00	0.00	65.00	0.00						gd		0.220939	
23	Mon	Clear	0	0.0051	7.0	1.40	26.00	1.00	65.00	0.00			7.4	1.07	Loading Dock	djones		0.246286	
24	Tue	Cloudy	0	0.0052	7.5	1.24	46.00	2.00	65.00	0.00						djones		0.232305	
25	Wed	Cloudy	0	0.0051	7.0	1.22	45.00	1.00	65.00	0.00			7.0	0.99	Eng Lab	djones	4.83	0.224457	
26	Thur	Clear	0	0.0050	7.4	1.26	43.00	2.00	65.00	0.00						djones		0.214047	
27	Fri	Clear	0	0.0052	7.0	1.27	42.00	1.00	65.00	0.00			7.0	0.98	Admin 1st Fl	djones		0.247906	
28	Sat	Clear	0	0.0024	7.1	1.06	41.00	1.00	65.00	0.00						djones		0.185807	
29	Sun	Clear	0	0.0000	7.6	1.05	41.00	0.00	65.00	0.00						djones		0.230857	
30	Mon	Clear	0	0.0051	7.6	1.18	39.00	2.00	65.00	0.00			6.9	0.90	Eng Lab	bm		0.271477	
31	Tue	Clear	0	0.0049	7.3	1.07	38.00	1.00	65.00	0.00						bm		0.217138	
Total				0.1512	222.0	41.74	1078.0	49.00	2029.0	2.00	0.0	0.0	90	14					7.175989
Average				0.0049	7.16	1.35	34.77	1.58	65.45	0.06	0.0	0.0	6.90	1.13					0.231484
Minimum				0.0000	6.61	1.05	21.00	0.00	65.00	0.00	0.0	0.0	6.65	0.65					0.164308
Maximum				0.0120	7.97	1.73	46.00	5.00	67.00	2.00	0.0	0.0	7.37	1.44					0.271477

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Superintendent: Earle Villarreal Certification # 1017

**Black & Decker WTP**

PWSID # 106 0004 County: Carroll  
 Address: BTR CAPITAL GROUP, Hampstead, MD 21073  
 625 Hanover Pike, Hampstead, Carroll County, Maryland

Month: September

Operated by  
 Maryland Environmental Service

Year: 2010

GENERAL (DOMESTIC WATER)				CHEMICAL							MONITORING				DISTRIBUTION		RAW WATER		Comments
Date	Day	Weather	Flow meter reading "	MGD Total FQIR	pH P.O.E	Free Cl2	Na2CO3 Level	Na2CO3 (gpd)	NaOCl Level	NaOCl (gpd)	VOC'S (ppb)	Bacti Pos/Neg	pH su	TRC mg/l	DISTRIBUTION LOCATION	Operator Initials	pH su	TOTAL RAW WATER WELL (mgd)	
1	Wed	Clear	0	0.0052	6.9	1.07	37.00	1.00	64.00	0.00			7.02	0.94	Loading Dock	Djones		0.236397	
2	Thur	Clear	0	0.0041	7.2	1.11	36.00	1.00	64.00	0.00						Djones	4.68	0.204273	
3	Fri	Cloudy	0	0.0059	7.2	1.43	35.00	1.00	64.00	0.00			6.81	1.13	Admin 2nd Fl	Djones		0.249125	
4	Sat	Clear	0	0.0023	7.4	1.30	34.00	1.00	64.00	0.00						BM		0.201540	
5	Sun	Clear	0	0.0000	7.2	1.17	34.00	0.00	64.00	0.00						BM		0.220032	
6	Mon	Clear	0	0.0025	7.7	1.28	33.00	1.00	64.00	0.00						GD		0.243987	
7	Tue	Clear	0	0.0026	7.6	1.34	32.00	1.00	64.00	0.00						Djones		0.234804	
8	Wed	Clear	0	0.0052	7.5	1.42	31.00	1.00	64.00	0.00			6.8	0.85	Eng Lab	Djones	4.62	0.193622	
9	Thur	Clear	0	0.0052	7.5	1.45	29.00	2.00	64.00	0.00						Djones		0.239281	
10	Fri	Cloudy	0	0.0050	7.6	1.37	48.00	1.00	64.00	0.00			7.2	1.27	Admin 2nd Fl	Djones		0.240887	
11	Sat	Clear	0	0.0025	7.0	1.32	47.00	1.00	64.00	0.00						GD		0.206603	
12	Sun	Rain	0	0.0023	7.0	1.32	46.00	1.00	64.00	0.00						GD		0.226380	
13	Mon	Clear	0	0.0027	7.0	1.30	45.00	1.00	64.00	0.00						Dsmith		0.221486	
14	Tue	Clear	0	0.0050	7.1	1.24	43.00	2.00	64.00	0.00						Djones		0.207981	
15	Wed	Clear	0	0.0053	7.5	1.25	42.00	1.00	64.00	0.00			7.3	1.14	Admin 1st Fl	Djones	4.71	0.239516	
16	Thur	Cloudy	0	0.0066	7.3	1.19	41.00	1.00	64.00	0.00			7.5	1.00	Eng Lab	Djones		0.233625	
17	Fri	Clear	0	0.0057	7.7	1.24	39.00	2.00	64.00	0.00						Djones		0.232618	
18	Sat	Clear	0	0.0025	7.4	1.18	38.00	1.00	64.00	0.00						Djones		0.170183	
19	Sun	Clear	0	0.0009	7.6	1.05	37.00	1.00	64.00	0.00						Djones		0.223862	
20	Mon	Clear	0	0.0041	7.8	1.30	36.00	1.00	64.00	0.00			7.3	1.02	Loading Dock	BM		0.260726	
21	Tue	Clear	0	0.0059	7.6	1.44	35.00	1.00	64.00	0.00						BM		0.215010	
22	Wed	Clear	0	0.0052	7.8	1.38	33.00	2.00	64.00	0.00			7.5	1.28	Admin 2nd Fl	Djones		0.226898	
23	Thur	Clear	0	0.0051	7.5	1.39	31.00	2.00	64.00	0.00						Djones	4.80	0.200355	
24	Fri	Clear	0	0.0048	7.8	1.35	30.00	1.00	64.00	0.00			7.5	1.13	Eng Lab	Djones		0.221935	
25	Sat	Clear	0	0.0051	7.1	1.17	28.00	2.00	64.00	0.00						GD		0.228223	
26	Sun	Cloudy	0	0.0000	6.8	1.03	28.00	0.00	64.00	0.00						GD		0.206854	
27	Mon	Rain	0	0.0045	7.4	1.14	27.00	1.00	64.00	0.00			7.2	0.97	Admin 1st Fl	Djones		0.237710	
28	Tue	Clear	0	0.0052	7.6	1.04	24.00	3.00	64.00	0.00						AP		0.215218	
29	Wed	Cloudy	0	0.0051	6.7	1.24	23.00	1.00	64.00	0.00			6.6	1.17	Loading Dock	Djones		0.215744	
30	Thur	Rain	0	0.0041	7.2	1.20	42.00	1.00	64.00	0.00						Djones	4.82	0.201040	
31																			
Total				0.1206	220.5	37.71	1064.0	36.00	1920.0	0.00	0.0	0.0	79	12				6.655915	
Average				0.0040	7.35	1.26	35.47	1.20	64.00	0.00	0.0	0.0	7.14	1.08				0.221864	
Minimum				0.0000	6.72	1.03	23.00	0.00	64.00	0.00	0.0	0.0	6.61	0.85				0.170183	MOR
Maximum				0.0066	7.83	1.45	48.00	3.00	64.00	0.00	0.0	0.0	7.50	1.28				0.260726	12/04/08

---

**APPENDIX B  
DISCHARGE MONITORING REPORTS  
(JULY - SEPTEMBER 2010)**

---

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.  
 Address 626 Hanover Pike  
 Hampstead, MD 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) MD0001881 (17-19) 001  
 PERMIT NUMBER DISCHARGE NUMBER

Form Approved.  
 OMB No.  
 Approval expires:

Facility Black and Decker WWTP  
 Location 626 Hanover Pike  
 Attn:

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
10	07	01	TO	10	07	31	
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)	


\*\*\* NO DISCHARGE  \*\*\*  
 NOTE: Read instructions before completing this form

State Discharge Permit  
 02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53) (54-61)			(4 Card Only) QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	3	( 19)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY:MX	MG/L		ONCE/MONTH	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	****	6.6	*****	8.4	( 12)	0	TWICE/WEEK	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY:MN	*****	8.5 DAILY:MX	SU		TWICE/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	( 19)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA:AVG	30 DAILY:MX	MG/L		ONCE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	128,806	236,000	(07)	*****	*****	*****	****	0	Measured	RECORD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	( 19)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA:AVG	0.019 DAILY:MX	MG/L		ONCE/MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	( 28)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY:MX	UG/L		ONCE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	( 28)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY:MX	UG/L		ONCE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
 James M. Harkins  
 MES Director  
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUES IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 551001 AND 33 U.S.C. 55 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
  
 TFI PHONE DATE  
 410 729-8350 10 08 27  
 AREA CODE NUMBER YEAR MONTH DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments he

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name AG/GFI Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address 626 Hanover Pike

MD0001881

001

Approval expires

Hampstead, MD 21074

PERMIT NUMBER

DISCHARGE NUMBER

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
10	07	01	TO	10	07	31	
(20-21)		(22-23)		(24-25)		(26-27)	
(28-29)		(30-31)					

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53) QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45) QUALITY OR CONCENTRATION (46-53) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
79141 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L		ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE							DAILY:MX				
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/MONTH	GRAB
TOTAL RECOVERABLE											
70030 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE						30DA AVG	DAILY:MX				
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.				TELEPHONE		DATE			
James M. Harkins						410 729-8350		10	08	26	
MES Director						AREA CODE NUMBER		YEAR	MONTH	DAY	
TYPED OR PRINTED		SIGNATURE OF PRICIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT									

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

\*\*\* NO DISCHARGE  \*\*\*


NOTE: Read instructions before completing this form.

MONITORING PERIOD

FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
10	07	01	10	07	31
(20-21) (22-23) (24-25)			(26-27) (28-29) (30-31)		

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	216,903	327,000	(07)	*****	*****	*****	****	0	ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	GRAB	
COLIFORM, FECAL GENERAL 74055 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/ WEEK	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX	MPN		ONCE/ WEEK	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUES IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.							TELEPHONE		DATE		
James M. Harkins MES Director	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							410	729-8350	10	08	27
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc  
 Address 626 Hanover Pike  
 Hampstead, MD 21074

Facility Black and Decker WWTP  
 Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)

MD0001881  
 PERMIT NUMBER

001  
 DISCHARGE NUMBER

Form Approved.  
 OMB No.  
 Approval expires

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
10	08	01	TO	10	08	31
(20-21) (22-23) (24-25)				(26-27) (28-29) (30-31)		

State Discharge Permit  
 02-DP-0022.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(45-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C)	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	3	(19)	0	ONCE/MONTH	GRAB
00310 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	6.5	*****	7.6	(12)	0	TWICE/WEEK	GRAB
pH	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY MN	*****	8.5 DAILY MX	SU		TWICE/WEEK	GRAB
00400 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	5	5	(19)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	142,387	338,000	(07)	*****	*****	*****	****	0	Measured	RECORD
00530 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	RECORD
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/MONTH	GRAB
CHLORINE, TOTAL RESIDUAL	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L		ONCE/MONTH	GRAB
50060 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
34475 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
1,1,1-TRICHLOROETHANE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB
34506 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	James M. Harkins MES Director	SIGNATURE OF PRICIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT			TELEPHONE		DATE				
TYPED OR PRINTED					410	729-8350	10	09	23		
COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments he		AREA CODE	NUMBER	YEAR	MONTH	DAY					



PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved

OMB No.

Approval expires

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	10	08	01		10	08	31
	(20-21) (22-23) (24-25)				(26-27) (28-29) (30-31)		

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53)			QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB					
79141 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L	0	ONCE/MONTH	GRAB					
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(19)	0	ONCE/MONTH	GRAB					
OIL AND GREASE TOTAL RECOVERABLE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	10	MG/L	0	ONCE/MONTH	GRAB					
70030 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	15	MG/L	0	ONCE/MONTH	GRAB					
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30DA AVG	MG/L	0	ONCE/MONTH	GRAB					
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
James M. Harkins MES Director		410	729-8350	10	09	23
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
10	08	01	10	08	31


FROM

TO

(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	202,516	248,000	(07)	*****	*****	*****	****	0	ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	GRAB	
COLIFORM, FECAL GENERAL 74055 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/ WEEK	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY/MX	MPN		ONCE/ WEEK	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.							TFI PHONE		DATE		
James M. Harkins MES Director	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							410	729-8350	10	09	23
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc  
 Address 626 Hanover Pike  
Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn: \_\_\_\_\_

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
10	09	01	10	09	30
(20-21)		(22-23)	(24-25)	(26-27)	
		(28-29)	(30-31)		

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	3	( 19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	****	6.5	*****	6.9	( 12)	0	TWICE/ WEEK	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY MN	*****	8.5 DAILY MX	SU		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	7	7	( 19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	101,933	130,000	(07)	*****	*****	*****	****	0	Measured	RECORD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	( 19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L		ONCE/ MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	( 28)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	( 28)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUES IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PPHONE		DATE		
James M. Harkins MES Director		410	729-8350	10	10	21
TYPED OR PRINTED						

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments he

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name AG/GFI Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address 626 Hanover Pike

MD0001881

001

Approval expires

Hampstead, MD 21074

PERMIT NUMBER

DISCHARGE NUMBER

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP

MONITORING PERIOD

Location 626 Hanover Pike

YEAR	MO	DAY	YEAR	MO	DAY
10	09	01	10	09	30

State Discharge Permit

Attn:

02-DP-0022

FROM (20-21) (22-23) (24-25) TO (26-27) (28-29) (30-31)

PARAMETER (32-37)		QUANTITY OR LOADING (54-61)			QUALITY OR CONCENTRATION (54-61)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (46-53)	UNITS (46-53)	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (46-53)				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	( 28)	0	ONCE/ MONTH	GRAB
79141 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE						DAILY MX					
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	( 19)	0	ONCE/ MONTH	GRAB
70030 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE						30DA AVG	DAILY MX				
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)					TELEPHONE		DATE			
James M. Harkins MES Director TYPED OR PRINTED						410 729-8350		10	10	21	
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE	NUMBER	YEAR	MONTH	DAY	

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
10	09	01	10	09	30
(20-21)		(22-23)	(24-25)	(26-27)	
		(28-29)	(30-31)		

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	208,467	288,000	(07)	*****	*****	*****	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****			
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	0	ONCE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX			
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  James M. Harkins MES Director  TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS 1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
		410	729-8350	10	10	21
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.  
 Address 626 Hanover Pike  
 Hampstead, MD 21074

Facility Black and Decker WWTP  
 Location 626 Hanover Pike  
 Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) MD0001881 PERMIT NUMBER  
 (17-19) 201 DISCHARGE NUMBER

Form Approved.  
 OMB No.  
 Approval expires

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	07	01	TO	10	09	30
(20-21)				(28-29)		
(22-23)				(30-31)		
(24-25)				(26-27)		

State Discharge Permit  
 02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	231,930	286,802	(07)	*****	*****	*****	****	0	Measured	Record
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	Record
TETRACHLOROETHYLENE 34475 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/Quarter	Grab
1,1,1-TRICHLOROETHANE 34506 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/Quarter	Grab
TRICHLOROETHENE 79141 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/Quarter	Grab
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER James M. Harkins MES Director	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
		410	729-8350	10	10	21
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

---

**APPENDIX C**  
**GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS**  
**(JULY - SEPTEMBER 2010)**

---



**ATLANTIC COAST**  
Laboratories, Incorporated

630 Churchmans Road  
Newark, Delaware 19702  
302-266-9121 • 454-8720 (FAX)  
WWW.ATLANTICCOASTLABS.COM

**REPORT OF ANALYSIS**

Maryland Environmental Services (A)  
259 Najoles Road  
Millersville, MD 21108

Order Number: A10070369  
Project Name: Black & Decker WWTP  
Receive Date: 7/7/2010  
Client Code: MES\_A  
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A10070369-01** **Sample Date: 7/7/2010 9:35**

Site: Black & Decker 001 Matrix: Waste Water  
Client Sample ID:  
Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	3	mg/L	2	SM 5210 B	7/8/2010 11:15:00 AM	Skent
Total Suspended Solids	< 4	mg/L	4	SM 2540D	7/13/2010 12:13:00 PM	KPlatt

**Sample # A10070369-01A** **Sample Date: 7/7/2010 9:35**

Site: Black & Decker 001 Matrix: Waste Water  
Client Sample ID: A  
Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	< 5	mg/L	5	EPA 1664	7/15/2010 3:15:00 PM	JMcGuire

**Sample # A10070369-01B** **Sample Date: 7/7/2010 9:35**

Site: Black & Decker 001 Matrix: Waste Water  
Client Sample ID: B  
Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	7/13/2010 1:40:00 AM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	7/13/2010 1:40:00 AM	JKozlowski
Trichloroethene	< 1	ug/L	1	EPA 8260B	7/13/2010 1:40:00 AM	JKozlowski

Approved: *Warren Van Arsdale*  
Quality Assurance Manager

Reported: 7/23/2010 9:35:17 AM

RDL = Reporting Detection Limit    N/A = Not Applicable  
Laboratory Certification Numbers: Delaware - DE00011    Maryland - #138    Pennsylvania - 68-335    New Jersey - DE568





630 Churchmans Road  
 Newark, Delaware 19702  
 302-266-9121 • 454-8720 (FAX)  
 WWW.ATLANTICCOASTLABS.COM

**REPORT OF ANALYSIS**

Maryland Environmental Services (A)  
 259 Najoles Road  
 Millersville, MD 21108

Order Number: A10070856  
 Project Name: Black & Decker WWTP  
 Receive Date: 7/15/2010  
 Client Code: MES\_A  
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A10070856-01** **Sample Date: 7/7/2010 9:15**

Site: Black & Decker 101  
 Client Sample ID:  
 Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Fecal Coliform, MPN	<1.8	MPN/100 mL	N/A	SM 9221 E	7/7/2010 1:27:00 PM	ChesapeakeEnvironmentalLa

Approved: *Waverly Van Arsdale*  
Quality Assurance Manager

Reported: 7/16/2010 12:40:55 PM

RDL = Reporting Detection Limit    N/A = Not Applicable  
 Laboratory Certification Numbers: Delaware - DE00011    Maryland - #138    Pennsylvania - 68-335    New Jersey - DE568



630 Churchmans Road  
 Newark, Delaware 19702  
 302-266-9121 • 454-8720 (FAX)  
 WWW.ATLANTICCOASTLABS.COM

### REPORT OF ANALYSIS

Maryland Environmental Services (A)  
 259 Najoles Road  
 Millersville, MD 21108

Order Number: A10070688  
 Project Name: Black & Decker WWTP  
 Receive Date: 7/13/2010  
 Client Code: MES\_A  
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A10070688-01** **Sample Date: 7/13/2010 9:30**

Site: Black & Decker 201

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	7/16/2010 8:04:00 AM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	7/16/2010 8:04:00 AM	JKozlowski
Trichloroethene	< 1	ug/L	1	EPA 8260B	7/16/2010 8:04:00 AM	JKozlowski

Approved: *Walter Van Andell*  
Quality Assurance Manager

Reported: 7/20/2010 10:20:05 AM

RDL = Reporting Detection Limit    N/A = Not Applicable  
 Laboratory Certification Numbers: Delaware - DE00011    Maryland - #138    Pennsylvania - 68-335    New Jersey - DE568



**ATLANTIC COAST**  
Laboratories, Incorporated

630 Churchmans Road  
Newark, Delaware 19702  
302-266-9121 • 454-8720 (FAX)  
WWW.ATLANTICCOASTLABS.COM

**REPORT OF ANALYSIS**

Maryland Environmental Services (A)  
259 Najoles Road  
Millersville, MD 21108

Order Number: A10080105  
Project Name: Black & Decker WWTP  
Receive Date: 8/3/2010  
Client Code: MES\_A  
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A10080105-01** **Sample Date: 8/3/2010 9:50**

Site: Black & Decker 101  
Client Sample ID:  
Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	3	mg/L	2	SM 5210 B	8/4/2010 7:30:00 AM	Skent
Total Suspended Solids	5	mg/L	4	SM 2540D	8/9/2010 1:12:00 PM	Kplatt

**Sample # A10080105-02** **Sample Date: 8/3/2010 9:50**

Site: Black & Decker 101  
Client Sample ID:  
Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	< 5	mg/L	5	EPA 1664	8/5/2010 6:25:00 PM	JMcGuire

**Sample # A10080105-03** **Sample Date: 8/3/2010 9:50**

Site: Black & Decker 101  
Client Sample ID:  
Sample Comments: None


Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	< 1	ug/L	1	EPA 8260B	8/12/2010 10:19:00 AM	JKozlowski
Tetrachloroethene	< 1	ug/L	1	EPA 8260B	8/12/2010 10:19:00 AM	JKozlowski
Trichloroethene	< 1	ug/L	1	EPA 8260B	8/12/2010 10:19:00 AM	JKozlowski

Approved: *Keith A. Hausknecht*  
President

Reported: 8/13/2010 1:39:38 PM

RDL = Reporting Detection Limit    N/A = Not Applicable  
Laboratory Certification Numbers: Delaware - DE00011    Maryland - #138    Pennsylvania - 68-335    New Jersey - DE568



630 Churchmans Road  
 Newark, Delaware 19702  
 302-266-9121 • 454-8720 (FAX)  
 WWW.ATLANTICCOASTLABS.COM

**REPORT OF ANALYSIS**

Maryland Environmental Services (A)  
 259 Najoles Road  
 Millersville, MD 21108

Order Number: A10081586  
 Project Name: Black & Decker WWTP  
 Receive Date: 8/26/2010  
 Client Code: MES\_A  
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A10081586-01** **Sample Date: 8/17/2010 9:20**

Site: Black & Decker 101

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Fecal Coliform, MPN	<1.8	MPN/100 mL	N/A	SM 9221 E	8/17/2010 2:20:00 PM	ChesapeakeEnvironmentalLa

Approved: *Warren Van Ardell*  
Quality Assurance Manager

Reported: 8/27/2010 8:26:38 AM

RDL = Reporting Detection Limit    N/A = Not Applicable  
 Laboratory Certification Numbers: Delaware - DE00011    Maryland - #138    Pennsylvania - 68-335    New Jersey - DE568



**ATLANTIC COAST**  
Laboratories, Incorporated

630 Churchmans Road  
Newark, Delaware 19702  
302-266-9121 • 454-8720 (FAX)  
WWW.ATLANTICCOASTLABS.COM

**REPORT OF ANALYSIS**

Maryland Environmental Services (A)  
259 Najoles Road  
Millersville, MD 21108

Order Number: A10090465  
Project Name: Black & Decker WWTP  
Receive Date: 9/8/2010  
Client Code: MES\_A  
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A10090465-01** **Sample Date: 9/8/2010 9:15**

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	3	mg/L	2	SM 5210 B	9/9/2010 11:05:00 AM	Skent
Total Suspended Solids	7	mg/L	4	SM 2540D	9/14/2010 8:40:00 AM	Jsantiago

**Sample # A10090465-02** **Sample Date: 9/8/2010 9:18**

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	<5	mg/L	5	EPA 1664	9/10/2010 3:20:00 PM	JMcGuire

**Sample # A10090465-03** **Sample Date: 9/8/2010 9:20**

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:


Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	9/11/2010 12:04:00 AM	JKozlowski
Tetrachloroethene	<1	ug/L	1	EPA 8260B	9/11/2010 12:04:00 AM	JKozlowski
Trichlorofluoromethane	<1	ug/L	1	EPA 8260B	9/11/2010 12:04:00 AM	JKozlowski

Approved: *Waverly Van Arsdale*  
Quality Assurance Manager

Reported: 9/21/2010 10:31:22 AM

RDL = Reporting Detection Limit    N/A = Not Applicable  
Laboratory Certification Numbers: Delaware - DE00011    Maryland - #138    Pennsylvania - 68-335    New Jersey - DE568



630 Churchmans Road  
 Newark, Delaware 19702  
 302-266-9121 • 454-8720 (FAX)  
 WWW.ATLANTICCOASTLABS.COM

### REPORT OF ANALYSIS

Maryland Environmental Services (A)  
 259 Najoles Road  
 Millersville, MD 21108

Order Number: A10091758  
 Project Name: Black & Decker WWTP  
 Receive Date: 9/30/2010  
 Client Code: MES\_A  
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

**Sample # A10091758-01**

**Sample Date: 9/21/2010 9:10**

Site: Black & Decker 101

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Fecal Coliform, MPN	<1.8	MPN/100 mL	N/A	SM 9221 E	9/21/2010 1:06:00 PM	ChesapeakeEnvironmentalL

Approved:

*Warren Van Arsdale*  
 Quality Assurance Manager

Reported:

9/30/2010 2:48:12 PM

RDL = Reporting Detection Limit    N/A = Not Applicable  
 Laboratory Certification Numbers: Delaware - DE00011    Maryland - #138    Pennsylvania - 68-335    New Jersey - DE568

---

**APPENDIX D  
GROUNDWATER ANALYTICAL DATA PACKAGE  
(AUGUST 2010)**

---

## ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

Job Number: 500-27304-1

Job Description: Black and Decker

For:

Weston Solutions, Inc.

1400 Weston Way

PO BOX 2653

West Chester, PA 19380

Attention: Mr. Tom Cornuet



Approved for release.  
Richard C Wright  
Project Manager II  
8/25/2010 8:28 AM

Richard C Wright

Project Manager II

richard.wright@testamericainc.com

08/25/2010

cc: Greg Flasinski

These test results meet all the requirements of NELAC for accredited parameters.

The Lab Certification ID#:

TestAmerica Chicago 100201

All questions regarding this test report should be directed to the TestAmerica Project Manager whose signature appears on this report. All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.

Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.

TestAmerica Laboratories, Inc.

TestAmerica Chicago 2417 Bond Street, University Park, IL 60484

Tel (708) 534-5200 Fax (708) 534-5211 [www.testamericainc.com](http://www.testamericainc.com)





**Job Narrative**  
**500-27304-1**

**Comments**

No additional comments.

**Receipt**

All samples were received in good condition within temperature requirements.

**GC/MS VOA**

Method(s) 8260B: The following sample(s) was diluted due to the abundance of target analytes: EW-4 (500-27304-19). Elevated reporting limits (RLs) are provided.

No other analytical or quality issues were noted.

## EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method	
<b>500-27304-5</b> cis-1,2-Dichloroethene	<b>RFW-3B</b>	2.6	1.0	ug/L	8260B	
<b>500-27304-6</b> cis-1,2-Dichloroethene Chloroform Trichloroethene Tetrachloroethene	<b>RFW-4A</b>	0.93 0.76 37 29	J J 1.0 1.0	1.0 1.0 1.0 1.0	ug/L ug/L ug/L ug/L	8260B 8260B 8260B 8260B
<b>500-27304-7FD</b> cis-1,2-Dichloroethene Chloroform Trichloroethene Tetrachloroethene	<b>RFW-4A DUP</b>	0.91 0.78 36 29	J J 1.0 1.0	1.0 1.0 1.0 1.0	ug/L ug/L ug/L ug/L	8260B 8260B 8260B 8260B
<b>500-27304-8</b> cis-1,2-Dichloroethene Trichloroethene Tetrachloroethene	<b>RFW-4B</b>	2.0 17 29	1.0 1.0 1.0	ug/L ug/L ug/L	8260B 8260B 8260B	
<b>500-27304-9</b> Trichloroethene Tetrachloroethene	<b>RFW-6</b>	1.2 1.7	1.0 1.0	ug/L ug/L	8260B 8260B	
<b>500-27304-10</b> Trichloroethene	<b>RFW-7</b>	4.4	1.0	ug/L	8260B	
<b>500-27304-11</b> 1,1-Dichloroethene 1,1-Dichloroethane cis-1,2-Dichloroethene Trichloroethene Tetrachloroethene	<b>RFW-9</b>	1.2 1.3 16 14 6.5	1.0 1.0 1.0 1.0 1.0	ug/L ug/L ug/L ug/L ug/L	8260B 8260B 8260B 8260B 8260B	
<b>500-27304-12</b> Trichloroethene	<b>RFW-11B</b>	6.2	1.0	ug/L	8260B	

TestAmerica Chicago

## EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
<b>500-27304-13</b>	<b>RFW-12B</b>				
cis-1,2-Dichloroethene		2.9	1.0	ug/L	8260B
Trichloroethene		180	5.0	ug/L	8260B
Tetrachloroethene		17	1.0	ug/L	8260B
<b>500-27304-14</b>	<b>RFW-13</b>				
cis-1,2-Dichloroethene		1.0	1.0	ug/L	8260B
Trichloroethene		2.8	1.0	ug/L	8260B
Tetrachloroethene		15	1.0	ug/L	8260B
<b>500-27304-17</b>	<b>EW-2</b>				
cis-1,2-Dichloroethene		3.4	1.0	ug/L	8260B
Trichloroethene		380	10	ug/L	8260B
Tetrachloroethene		50	1.0	ug/L	8260B
<b>500-27304-18</b>	<b>EW-3</b>				
cis-1,2-Dichloroethene		2.2	1.0	ug/L	8260B
Trichloroethene		76	1.0	ug/L	8260B
Tetrachloroethene		2.5	1.0	ug/L	8260B
<b>500-27304-19</b>	<b>EW-4</b>				
Trichloroethene		920	50	ug/L	8260B
Tetrachloroethene		19	5.0	ug/L	8260B
<b>500-27304-20</b>	<b>EW-5</b>				
Trichloroethene		130	5.0	ug/L	8260B
Tetrachloroethene		4.2	1.0	ug/L	8260B
<b>500-27304-21</b>	<b>EW-6</b>				
Trichloroethene		7.4	1.0	ug/L	8260B
Tetrachloroethene		15	1.0	ug/L	8260B
<b>500-27304-22</b>	<b>EW-7</b>				
cis-1,2-Dichloroethene		2.2	1.0	ug/L	8260B
Trichloroethene		2.0	1.0	ug/L	8260B
Tetrachloroethene		4.8	1.0	ug/L	8260B

## EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
<b>500-27304-23</b>	<b>EW-8</b>				
cis-1,2-Dichloroethene		20	1.0	ug/L	8260B
Trichloroethene		8.0	1.0	ug/L	8260B
Tetrachloroethene		52	1.0	ug/L	8260B
<b>500-27304-24</b>	<b>EW-9</b>				
Tetrachloroethene		84	1.0	ug/L	8260B
<b>500-27304-25FD</b>	<b>EW-9 DUP</b>				
Tetrachloroethene		83	1.0	ug/L	8260B
<b>500-27304-26</b>	<b>EW-10</b>				
Tetrachloroethene		1.6	1.0	ug/L	8260B

## METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Description	Lab Location	Method	Preparation Method
<b>Matrix: Water</b>			
VOC	TAL CHI	SW846 8260B	
Purge and Trap	TAL CHI		SW846 5030B

### Lab References:

TAL CHI = TestAmerica Chicago

### Method References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

METHOD / ANALYST SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

<u>Method</u>	<u>Analyst</u>	<u>Analyst ID</u>
SW846 8260B	Drabek, Dave J	DJD

## SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-27304-1

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
500-27304-1	RFW-1A	Water	08/16/2010 1010	08/19/2010 1015
500-27304-2	RFW-1B	Water	08/16/2010 1745	08/19/2010 1015
500-27304-3	RFW-2A	Water	08/16/2010 1100	08/19/2010 1015
500-27304-4	RFW-2B	Water	08/16/2010 1110	08/19/2010 1015
500-27304-5	RFW-3B	Water	08/17/2010 0730	08/19/2010 1015
500-27304-6	RFW-4A	Water	08/17/2010 0840	08/19/2010 1015
500-27304-7FD	RFW-4A DUP	Water	08/17/2010 0840	08/19/2010 1015
500-27304-8	RFW-4B	Water	08/17/2010 1010	08/19/2010 1015
500-27304-9	RFW-6	Water	08/16/2010 0700	08/19/2010 1015
500-27304-10	RFW-7	Water	08/16/2010 1255	08/19/2010 1015
500-27304-11	RFW-9	Water	08/17/2010 1255	08/19/2010 1015
500-27304-12	RFW-11B	Water	08/17/2010 1400	08/19/2010 1015
500-27304-13	RFW-12B	Water	08/17/2010 0745	08/19/2010 1015
500-27304-14	RFW-13	Water	08/16/2010 1540	08/19/2010 1015
500-27304-15	RFW-17	Water	08/16/2010 1200	08/19/2010 1015
500-27304-16TB	TRIP BLANK	Water	08/16/2010 0700	08/19/2010 1015
500-27304-17	EW-2	Water	08/17/2010 1300	08/19/2010 1015
500-27304-18	EW-3	Water	08/17/2010 1310	08/19/2010 1015
500-27304-19	EW-4	Water	08/17/2010 1115	08/19/2010 1015
500-27304-20	EW-5	Water	08/16/2010 0945	08/19/2010 1015
500-27304-21	EW-6	Water	08/16/2010 1525	08/19/2010 1015
500-27304-22	EW-7	Water	08/16/2010 1515	08/19/2010 1015
500-27304-23	EW-8	Water	08/16/2010 1510	08/19/2010 1015
500-27304-24	EW-9	Water	08/16/2010 1500	08/19/2010 1015
500-27304-25FD	EW-9 DUP	Water	08/16/2010 1500	08/19/2010 1015
500-27304-26	EW-10	Water	08/16/2010 1600	08/19/2010 1015

# SAMPLE RESULTS



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-1A  
 Lab Sample ID: 500-27304-1

Date Sampled: 08/16/2010 1010  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/21/2010 1353			
<b>Prep Method: 5030B</b>		Date Prepared: 08/21/2010 1353			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-1A  
 Lab Sample ID: 500-27304-1

Date Sampled: 08/16/2010 1010  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromofom	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	93	%		80 - 129	
Toluene-d8 (Surr)	102	%		80 - 115	
4-Bromofluorobenzene (Surr)	95	%		80 - 115	
Dibromofluoromethane	90	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-1B  
 Lab Sample ID: 500-27304-2

Date Sampled: 08/16/2010 1745  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/21/2010 1417			
<b>Prep Method: 5030B</b>		Date Prepared: 08/21/2010 1417			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-1B  
 Lab Sample ID: 500-27304-2

Date Sampled: 08/16/2010 1745  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		80 - 129	
Toluene-d8 (Surr)	102	%		80 - 115	
4-Bromofluorobenzene (Surr)	96	%		80 - 115	
Dibromofluoromethane	94	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-2A  
 Lab Sample ID: 500-27304-3

Date Sampled: 08/16/2010 1100  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/21/2010 1442			
<b>Prep Method: 5030B</b>		Date Prepared: 08/21/2010 1442			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-2A  
 Lab Sample ID: 500-27304-3

Date Sampled: 08/16/2010 1100  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	99	%		80 - 129	
Toluene-d8 (Surr)	104	%		80 - 115	
4-Bromofluorobenzene (Surr)	95	%		80 - 115	
Dibromofluoromethane	92	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-2B  
 Lab Sample ID: 500-27304-4

Date Sampled: 08/16/2010 1110  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed:	08/21/2010 1506		
<b>Prep Method: 5030B</b>		Date Prepared:	08/21/2010 1506		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-2B  
 Lab Sample ID: 500-27304-4

Date Sampled: 08/16/2010 1110  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		80 - 129	
Toluene-d8 (Surr)	103	%		80 - 115	
4-Bromofluorobenzene (Surr)	98	%		80 - 115	
Dibromofluoromethane	95	%		80 - 124	



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-3B  
 Lab Sample ID: 500-27304-5

Date Sampled: 08/17/2010 0730  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/21/2010 1531			
<b>Prep Method: 5030B</b>		Date Prepared: 08/21/2010 1531			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	2.6	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-3B  
 Lab Sample ID: 500-27304-5

Date Sampled: 08/17/2010 0730  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		80 - 129	
Toluene-d8 (Surr)	100	%		80 - 115	
4-Bromofluorobenzene (Surr)	93	%		80 - 115	
Dibromofluoromethane	95	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-4A  
 Lab Sample ID: 500-27304-6

Date Sampled: 08/17/2010 0840  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed:	08/21/2010 1555		
<b>Prep Method: 5030B</b>		Date Prepared:	08/21/2010 1555		
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	0.93 J	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	0.76 J	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	37	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	29	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-4A  
 Lab Sample ID: 500-27304-6

Date Sampled: 08/17/2010 0840  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		80 - 129	
Toluene-d8 (Surr)	100	%		80 - 115	
4-Bromofluorobenzene (Surr)	90	%		80 - 115	
Dibromofluoromethane	93	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-4A DUP  
 Lab Sample ID: 500-27304-7

Date Sampled: 08/17/2010 0840  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/21/2010 1620			
<b>Prep Method: 5030B</b>		Date Prepared: 08/21/2010 1620			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	0.91 J	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	0.78 J	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	36	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	29	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-4A DUP  
 Lab Sample ID: 500-27304-7

Date Sampled: 08/17/2010 0840  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	96	%		80 - 129	
Toluene-d8 (Surr)	97	%		80 - 115	
4-Bromofluorobenzene (Surr)	92	%		80 - 115	
Dibromofluoromethane	92	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-4B  
 Lab Sample ID: 500-27304-8

Date Sampled: 08/17/2010 1010  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/21/2010 1644			
<b>Prep Method: 5030B</b>		Date Prepared: 08/21/2010 1644			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	2.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	17	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	29	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-4B  
 Lab Sample ID: 500-27304-8

Date Sampled: 08/17/2010 1010  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	97	%		80 - 129	
Toluene-d8 (Surr)	103	%		80 - 115	
4-Bromofluorobenzene (Surr)	92	%		80 - 115	
Dibromofluoromethane	94	%		80 - 124	



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-6  
 Lab Sample ID: 500-27304-9

Date Sampled: 08/16/2010 0700  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/21/2010 1709			
<b>Prep Method: 5030B</b>		Date Prepared: 08/21/2010 1709			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	1.2	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	1.7	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-6  
 Lab Sample ID: 500-27304-9

Date Sampled: 08/16/2010 0700  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		80 - 129	
Toluene-d8 (Surr)	97	%		80 - 115	
4-Bromofluorobenzene (Surr)	96	%		80 - 115	
Dibromofluoromethane	98	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-7  
 Lab Sample ID: 500-27304-10

Date Sampled: 08/16/2010 1255  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/21/2010 1733			
<b>Prep Method: 5030B</b>		Date Prepared: 08/21/2010 1733			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	4.4	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-7  
 Lab Sample ID: 500-27304-10

Date Sampled: 08/16/2010 1255  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		80 - 129	
Toluene-d8 (Surr)	102	%		80 - 115	
4-Bromofluorobenzene (Surr)	91	%		80 - 115	
Dibromofluoromethane	95	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-9  
 Lab Sample ID: 500-27304-11

Date Sampled: 08/17/2010 1255  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/21/2010 1758			
<b>Prep Method: 5030B</b>		Date Prepared: 08/21/2010 1758			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	1.2	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	1.3	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	16	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	14	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	6.5	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-9  
 Lab Sample ID: 500-27304-11

Date Sampled: 08/17/2010 1255  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	99	%		80 - 129	
Toluene-d8 (Surr)	101	%		80 - 115	
4-Bromofluorobenzene (Surr)	91	%		80 - 115	
Dibromofluoromethane	97	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-11B  
 Lab Sample ID: 500-27304-12

Date Sampled: 08/17/2010 1400  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/21/2010 1822			
<b>Prep Method: 5030B</b>		Date Prepared: 08/21/2010 1822			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	6.2	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-11B  
 Lab Sample ID: 500-27304-12

Date Sampled: 08/17/2010 1400  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate					
1,2-Dichloroethane-d4 (Surr)	97	%		80 - 129	
Toluene-d8 (Surr)	104	%		80 - 115	
4-Bromofluorobenzene (Surr)	92	%		80 - 115	
Dibromofluoromethane	98	%		80 - 124	



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-12B  
 Lab Sample ID: 500-27304-13

Date Sampled: 08/17/2010 0745  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/21/2010 1847			
<b>Prep Method: 5030B</b>		Date Prepared: 08/21/2010 1847			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	2.9	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	17	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-12B  
 Lab Sample ID: 500-27304-13

Date Sampled: 08/17/2010 0745  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		80 - 129	
Toluene-d8 (Surr)	101	%		80 - 115	
4-Bromofluorobenzene (Surr)	92	%		80 - 115	
Dibromofluoromethane	102	%		80 - 124	
Method: 8260B	Run Type: DL		Date Analyzed: 08/21/2010 1911		
Prep Method: 5030B			Date Prepared: 08/21/2010 1911		
Trichloroethene	180	ug/L	1.2	5.0	5.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	102	%		80 - 129	
Toluene-d8 (Surr)	104	%		80 - 115	
4-Bromofluorobenzene (Surr)	92	%		80 - 115	
Dibromofluoromethane	102	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-13  
 Lab Sample ID: 500-27304-14

Date Sampled: 08/16/2010 1540  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/21/2010 1936			
<b>Prep Method: 5030B</b>		Date Prepared: 08/21/2010 1936			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	2.8	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	15	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-13  
 Lab Sample ID: 500-27304-14

Date Sampled: 08/16/2010 1540  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromofom	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	96	%		80 - 129	
Toluene-d8 (Surr)	103	%		80 - 115	
4-Bromofluorobenzene (Surr)	91	%		80 - 115	
Dibromofluoromethane	96	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-17  
 Lab Sample ID: 500-27304-15

Date Sampled: 08/16/2010 1200  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/23/2010 1047			
<b>Prep Method: 5030B</b>		Date Prepared: 08/23/2010 1047			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: RFW-17  
 Lab Sample ID: 500-27304-15

Date Sampled: 08/16/2010 1200  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate					
1,2-Dichloroethane-d4 (Surr)	100	%		80 - 129	
Toluene-d8 (Surr)	100	%		80 - 115	
4-Bromofluorobenzene (Surr)	96	%		80 - 115	
Dibromofluoromethane	93	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: TRIP BLANK  
 Lab Sample ID: 500-27304-16

Date Sampled: 08/16/2010 0700  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/23/2010 1111			
<b>Prep Method: 5030B</b>		Date Prepared: 08/23/2010 1111			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: TRIP BLANK  
 Lab Sample ID: 500-27304-16

Date Sampled: 08/16/2010 0700  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	99	%		80 - 129	
Toluene-d8 (Surr)	103	%		80 - 115	
4-Bromofluorobenzene (Surr)	93	%		80 - 115	
Dibromofluoromethane	96	%		80 - 124	



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-2  
 Lab Sample ID: 500-27304-17

Date Sampled: 08/17/2010 1300  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/23/2010 1135			
<b>Prep Method: 5030B</b>		Date Prepared: 08/23/2010 1135			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	3.4	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	50	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-2  
 Lab Sample ID: 500-27304-17

Date Sampled: 08/17/2010 1300  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	103	%		80 - 129	
Toluene-d8 (Surr)	107	%		80 - 115	
4-Bromofluorobenzene (Surr)	105	%		80 - 115	
Dibromofluoromethane	100	%		80 - 124	
Method: 8260B	Run Type: DL		Date Analyzed: 08/23/2010 1200		
Prep Method: 5030B			Date Prepared: 08/23/2010 1200		
Trichloroethene	380	ug/L	2.4	10	10
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	100	%		80 - 129	
Toluene-d8 (Surr)	106	%		80 - 115	
4-Bromofluorobenzene (Surr)	97	%		80 - 115	
Dibromofluoromethane	97	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-3  
 Lab Sample ID: 500-27304-18

Date Sampled: 08/17/2010 1310  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/23/2010 1224			
<b>Prep Method: 5030B</b>		Date Prepared: 08/23/2010 1224			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	2.2	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	76	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	2.5	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-3  
 Lab Sample ID: 500-27304-18

Date Sampled: 08/17/2010 1310  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	98	%		80 - 129	
Toluene-d8 (Surr)	104	%		80 - 115	
4-Bromofluorobenzene (Surr)	96	%		80 - 115	
Dibromofluoromethane	96	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-4  
 Lab Sample ID: 500-27304-19

Date Sampled: 08/17/2010 1115  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/23/2010 1249			
<b>Prep Method: 5030B</b>		Date Prepared: 08/23/2010 1249			
Benzene	<5.0	ug/L	0.85	5.0	5.0
Dichlorodifluoromethane	<5.0	ug/L	1.6	5.0	5.0
Chloromethane	<5.0	ug/L	1.2	5.0	5.0
Vinyl chloride	<5.0	ug/L	1.0	5.0	5.0
Bromomethane	<5.0	ug/L	1.9	5.0	5.0
Chloroethane	<5.0	ug/L	1.8	5.0	5.0
Trichlorofluoromethane	<5.0	ug/L	1.0	5.0	5.0
1,1-Dichloroethene	<5.0	ug/L	0.95	5.0	5.0
Carbon disulfide	<25	ug/L	2.8	25	5.0
Acetone	<25	ug/L	8.0	25	5.0
Methylene Chloride	<10	ug/L	3.4	10	5.0
trans-1,2-Dichloroethene	<5.0	ug/L	1.6	5.0	5.0
1,1-Dichloroethane	<5.0	ug/L	1.2	5.0	5.0
2,2-Dichloropropane	<5.0	ug/L	1.2	5.0	5.0
cis-1,2-Dichloroethene	<5.0	ug/L	1.4	5.0	5.0
Methyl Ethyl Ketone	<25	ug/L	12	25	5.0
Bromochloromethane	<5.0	ug/L	1.8	5.0	5.0
Chloroform	<5.0	ug/L	0.75	5.0	5.0
1,1,1-Trichloroethane	<5.0	ug/L	0.90	5.0	5.0
1,1-Dichloropropene	<5.0	ug/L	0.80	5.0	5.0
Carbon tetrachloride	<5.0	ug/L	1.2	5.0	5.0
1,2-Dichloroethane	<5.0	ug/L	1.2	5.0	5.0
1,2-Dichloropropane	<5.0	ug/L	1.0	5.0	5.0
Dibromomethane	<5.0	ug/L	1.5	5.0	5.0
Bromodichloromethane	<5.0	ug/L	0.95	5.0	5.0
cis-1,3-Dichloropropene	<5.0	ug/L	0.85	5.0	5.0
methyl isobutyl ketone	<25	ug/L	4.2	25	5.0
Toluene	<5.0	ug/L	0.95	5.0	5.0
trans-1,3-Dichloropropene	<5.0	ug/L	1.2	5.0	5.0
1,1,2-Trichloroethane	<5.0	ug/L	1.3	5.0	5.0
Tetrachloroethene	19	ug/L	1.1	5.0	5.0
1,3-Dichloropropane	<5.0	ug/L	0.85	5.0	5.0
2-Hexanone	<25	ug/L	4.0	25	5.0
Dibromochloromethane	<5.0	ug/L	1.2	5.0	5.0
1,2-Dibromoethane	<5.0	ug/L	1.8	5.0	5.0
Chlorobenzene	<5.0	ug/L	0.85	5.0	5.0
1,1,1,2-Tetrachloroethane	<5.0	ug/L	0.95	5.0	5.0
Ethylbenzene	<5.0	ug/L	0.90	5.0	5.0
m&p-Xylene	<10	ug/L	1.6	10	5.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-4  
 Lab Sample ID: 500-27304-19

Date Sampled: 08/17/2010 1115  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<5.0	ug/L	1.9	5.0	5.0
Styrene	<5.0	ug/L	0.75	5.0	5.0
Bromoform	<5.0	ug/L	2.1	5.0	5.0
Isopropylbenzene	<5.0	ug/L	1.0	5.0	5.0
Bromobenzene	<5.0	ug/L	1.0	5.0	5.0
1,1,2,2-Tetrachloroethane	<5.0	ug/L	1.4	5.0	5.0
1,2,3-Trichloropropane	<5.0	ug/L	2.4	5.0	5.0
N-Propylbenzene	<5.0	ug/L	0.95	5.0	5.0
2-Chlorotoluene	<5.0	ug/L	0.90	5.0	5.0
1,3,5-Trimethylbenzene	<5.0	ug/L	0.90	5.0	5.0
4-Chlorotoluene	<5.0	ug/L	1.0	5.0	5.0
tert-Butylbenzene	<5.0	ug/L	0.80	5.0	5.0
1,2,4-Trimethylbenzene	<5.0	ug/L	0.70	5.0	5.0
sec-Butylbenzene	<5.0	ug/L	0.80	5.0	5.0
1,3-Dichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
p-Isopropyltoluene	<5.0	ug/L	0.80	5.0	5.0
1,4-Dichlorobenzene	<5.0	ug/L	1.0	5.0	5.0
n-Butylbenzene	<5.0	ug/L	0.90	5.0	5.0
1,2-Dichlorobenzene	<5.0	ug/L	0.85	5.0	5.0
1,2-Dibromo-3-Chloropropane	<10	ug/L	4.8	10	5.0
1,2,4-Trichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
Hexachlorobutadiene	<5.0	ug/L	1.3	5.0	5.0
Naphthalene	<5.0	ug/L	2.2	5.0	5.0
1,2,3-Trichlorobenzene	<5.0	ug/L	1.2	5.0	5.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	100	%		80 - 129	
Toluene-d8 (Surr)	104	%		80 - 115	
4-Bromofluorobenzene (Surr)	96	%		80 - 115	
Dibromofluoromethane	98	%		80 - 124	
Method: 8260B	Run Type: DL		Date Analyzed: 08/23/2010 1314		
Prep Method: 5030B			Date Prepared: 08/23/2010 1314		
Trichloroethene	920	ug/L	12	50	50
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	101	%		80 - 129	
Toluene-d8 (Surr)	105	%		80 - 115	
4-Bromofluorobenzene (Surr)	99	%		80 - 115	
Dibromofluoromethane	100	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-5  
 Lab Sample ID: 500-27304-20

Date Sampled: 08/16/2010 0945  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/23/2010 1339			
<b>Prep Method: 5030B</b>		Date Prepared: 08/23/2010 1339			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	4.2	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-5  
 Lab Sample ID: 500-27304-20

Date Sampled: 08/16/2010 0945  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	102	%	80 - 129
Toluene-d8 (Surr)	103	%	80 - 115
4-Bromofluorobenzene (Surr)	99	%	80 - 115
Dibromofluoromethane	100	%	80 - 124

Method: 8260B Run Type: DL

Date Analyzed: 08/23/2010 1403

Prep Method: 5030B

Date Prepared: 08/23/2010 1403

Trichloroethene	130	ug/L	1.2	5.0	5.0
-----------------	-----	------	-----	-----	-----

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	102	%	80 - 129
Toluene-d8 (Surr)	104	%	80 - 115
4-Bromofluorobenzene (Surr)	99	%	80 - 115
Dibromofluoromethane	98	%	80 - 124



Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-6  
 Lab Sample ID: 500-27304-21

Date Sampled: 08/16/2010 1525  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/23/2010 1428			
<b>Prep Method: 5030B</b>		Date Prepared: 08/23/2010 1428			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	7.4	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	15	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-6  
 Lab Sample ID: 500-27304-21

Date Sampled: 08/16/2010 1525  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate			Acceptance Limits		
1,2-Dichloroethane-d4 (Surr)	92	%		80 - 129	
Toluene-d8 (Surr)	93	%		80 - 115	
4-Bromofluorobenzene (Surr)	86	%		80 - 115	
Dibromofluoromethane	86	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-7  
 Lab Sample ID: 500-27304-22

Date Sampled: 08/16/2010 1515  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/23/2010 1452			
<b>Prep Method: 5030B</b>		Date Prepared: 08/23/2010 1452			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	2.2	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	2.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	4.8	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-7  
 Lab Sample ID: 500-27304-22

Date Sampled: 08/16/2010 1515  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.32	2.0	1.0
o-Xylene	<1.0	ug/L	0.38	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.42	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.20	1.0	1.0
Bromobenzene	<1.0	ug/L	0.21	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.29	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.48	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.19	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.18	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.18	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.21	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.16	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.16	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.21	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.18	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.96	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.26	1.0	1.0
Naphthalene	<1.0	ug/L	0.44	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.24	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	93	%		80 - 129	
Toluene-d8 (Surr)	99	%		80 - 115	
4-Bromofluorobenzene (Surr)	90	%		80 - 115	
Dibromofluoromethane	93	%		80 - 124	

Mr. Tom Cornuet  
 Weston Solutions, Inc.  
 1400 Weston Way  
 PO BOX 2653  
 West Chester, PA 19380

Job Number: 500-27304-1

Client Sample ID: EW-8  
 Lab Sample ID: 500-27304-23

Date Sampled: 08/16/2010 1510  
 Date Received: 08/19/2010 1015  
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
<b>Method: 8260B</b>		Date Analyzed: 08/23/2010 1516			
<b>Prep Method: 5030B</b>		Date Prepared: 08/23/2010 1516			
Benzene	<1.0	ug/L	0.17	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.31	1.0	1.0
Chloromethane	<1.0	ug/L	0.24	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.20	1.0	1.0
Bromomethane	<1.0	ug/L	0.38	1.0	1.0
Chloroethane	<1.0	ug/L	0.36	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.20	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.19	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.55	5.0	1.0
Acetone	<5.0	ug/L	1.6	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.67	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.25	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.24	1.0	1.0
cis-1,2-Dichloroethene	20	ug/L	0.27	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	2.3	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.35	1.0	1.0
Chloroform	<1.0	ug/L	0.15	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.18	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.25	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.24	1.0	1.0
Trichloroethene	8.0	ug/L	0.24	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.21	1.0	1.0
Dibromomethane	<1.0	ug/L	0.30	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.19	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.84	5.0	1.0
Toluene	<1.0	ug/L	0.19	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.24	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.26	1.0	1.0
Tetrachloroethene	52	ug/L	0.22	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.80	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.25	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.37	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.19	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.18	1.0	1.0