

Quarterly Groundwater Monitoring Report

Prepared for

Black & Decker (U.S.) Inc.

Hampstead, Maryland

October 2013

Prepared by

WESTON SOLUTIONS, INC.

West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 3rd Quarter 2013	2-2
Table 2-2 Groundwater Elevation Data – 3rd Quarter 2013.....	2-3
Table 2-3 Effluent Characteristics Summary – 3rd Quarter 2013.....	2-4
Table 2-4 Summary of Groundwater Analytical Results - August 2013.....	2-5
Table 3-1 Treatment System Maintenance Activities – 3rd Quarter 2013	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of July through September 2013.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of July through September 2013, the extraction wells were pumping at an average combined rate of approximately 180 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of July through September 2013 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of July through September 2013, approximately 11.93 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (83 %) and tetrachloroethene (PCE) (17 %). Analytical results of the groundwater collected from the air stripper for the period of July through September 2013 are included in Appendix C.

A summary of the analytical results from the third quarter (August 2013) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 3rd Quarter 2013
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
July 2013	7,319,915
August 2013	7,251,212
September 2013	7,037,943

Table 2-2
Groundwater Elevation Data - 3rd Quarter 2013
Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV.	TOTAL DEPTH	7/19/2013		8/1/2013		9/12/2013	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NC	DRY	NC	DRY	NC
EW-2	849.21	110	93.47	755.74	93.52	755.69	92.70	756.51
EW-3	846.64	118	85.11	761.53	85.83	760.81	85.73	760.91
EW-4	858.01	97.5	PC	NC	PC	NC	PC	NC
EW-5	864.17	98	89.91	774.26	89.94	774.23	89.41	774.76
EW-6	831.98	115	103.00	728.98	103.00	728.98	103.00	728.98
EW-7	818.38	78	74.50	743.88	74.50	743.88	75.50	742.88
EW-8	811.13	98	95.00	716.13	95.00	716.13	96.00	715.13
EW-9	811.35	141	103.00	708.35	103.00	708.35	103.00	708.35
EW-10	807.74	INA	50.11	757.63	51.82	755.92	52.33	755.41
RFW-1A	864.37	78	49.57	814.80	50.37	814.00	50.41	813.96
RFW-1B	864.23	200	49.61	814.62	50.45	813.78	50.49	813.74
RFW-2A	857.41	35	13.63	843.78	15.03	842.38	15.17	842.24
RFW-2B	857.73	75	13.90	843.83	15.67	842.06	15.19	842.54
RFW-3B	839.21	153	30.18	809.03	32.18	807.03	32.21	807.00
RFW-4A	830.37	62	36.84	793.53	36.81	793.56	37.01	793.36
RFW-4B	830.37	120	36.98	793.39	36.72	793.65	36.89	793.48
RFW-5A	817.50	30	DRY	NC	DRY	NC	DRY	NC
RFW-6	785.04	120	2.41	782.63	3.06	781.98	4.11	780.93
RFW-7	805.14	29	6.11	799.03	6.07	799.07	6.82	798.32
RFW-8	860.07	56	DRY	NC	DRY	NC	DRY	NC
RFW-9	862.02	49	25.37	836.65	20.02	842.00	20.10	841.92
RFW-10	852.06	58	DRY	NC	DRY	NC	DRY	NC
RFW-11A	849.32	72	Damaged	NC	Damaged	NC	Damaged	NC
RFW-11B	849.62	116	61.89	787.73	62.76	786.86	62.72	786.90
RFW-12B	844.87	264	49.64	795.23	49.81	795.06	50.01	794.86
RFW-13	849.11	150	59.87	789.24	60.31	788.80	60.43	788.68
RFW-14B	812.39	281	54.01	758.38	53.87	758.52	51.89	760.50
RFW-16	856.14	41	DRY	NC	DRY	NC	DRY	NC
RFW-17	834.66	60.5	25.91	808.75	26.19	808.47	26.30	808.36
RFW-20	842.49	142	32.93	809.56	33.58	808.91	23.65	818.84
RFW-21	832.65	102	19.50	813.15	21.25	811.40	21.31	811.34
PH-7	805.94	89	25.16	780.78	26.24	779.70	26.32	779.62
PH-9	814.94	98	50.57	764.37	51.63	763.31	50.88	764.06
PH-11	820.68	78	51.04	769.64	51.21	769.47	51.26	769.42
PH-12	828.35	87	51.82	776.53	52.06	776.29	51.99	776.36
B-3	803.02	83	10.59	792.43	10.62	792.40	10.70	792.32
Amoco	842.29	INA	NA	NC	NA	NC	NA	NC
Hamp. Town #22	804.96	INA	0.83	804.13	0.59	804.37	1.87	803.09
Pembroke #1	INA	INA	11.22	NC	11.07	NC	11.89	NC
Pembroke #2	INA	INA	Damaged	NC	Damaged	NC	Damaged	NC
N. Houcks. Rd.	INA	INA	10.60	NC	10.84	NC	10.11	NC
E. Century St.	INA	INA	19.22	NC	19.19	NC	19.18	NC
Lwr. Beckleys. Rd.	INA	INA	56.43	NC	56.49	NC	56.24	NC

NA - Not Available/Not Accessible
NC - Not Calculable
INA - Information not available
PC - Pump Cycles

Table 2-3
Effluent Characteristics Summary - 3rd Quarter 2013
Black & Decker
Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				July 2013	August 2013	September 2013	
001	FLOW	average	MGD	NA	0.210	0.217	0.138
		maximum	MGD	NA	0.836	0.693	0.217
	1,1,1-Trichloroethane		ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene		ug/l	5	< 1	< 1	< 1
	Trichloroethylene		ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		monthly average	mg/l	10	< 5	< 5	< 5
	pH	minimum	STD	6.0	7.1	7.1	7.2
		maximum	STD	8.5	8.3	8.2	7.7
BOD		mg/l	15	7.0	4.0	5.0	
TSS	maximum	mg/l	30	11.0	11.0	10.0	
	monthly average	mg/l	20	11.0	11.0	10.0	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.125	0.154	0.175
		maximum	MGD	NA	0.184	0.190	0.205
	Fecal Coliform		MPN/100ml	200	33.0	2.0	1.0
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.235
		maximum	MGD	NA	NR	NR	0.284
	1,1,1-Trichloroethane		ug/l	NA	NR	NR	< 1
	Tetrachloroethylene		ug/l	NA	NR	NR	< 1
	Trichloroethylene		ug/l	NA	NR	NR	< 1

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

Table 2-4
Summary of Groundwater Analytical Results - August 2013
Black & Decker
Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3.9	1 U	1 U	1 U	1 U	4.1	30	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	200	30	530	110	6.1	3.1	10	1 U	0.7	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	43	1.1	12	3.1	11	6	77	110	100	1.2
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
J = Indicates an estimated value.
NS = Not Sampled

Table 2-4
Summary of Groundwater Analytical Results - August 2013
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	2 U	2 U	2 U	2 U	2 U	5.1	5.3	6.3	NS	6.3	7	NS	7.1	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	1.6	1 U	1 U	1.4	NS	1 U	1 U	NS	12	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	0.6	0.4 J	1 U	28	28	0.7	NS	0.8	0.9	NS	7.6	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	19	17	2.9	NS	1.1	1 U	NS	1 U	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicate sample
NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
J = Indicates an estimated value.

Table 2-4
Summary of Groundwater Analytical Results - August 2013
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	RFW-20	RFW-21	Town #22	Town #23	Trip Blank
		USEPA drinking water method 524.2														
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	8.5	2 U	2 U	NS	2 U	ABD	ABD	ABD	2 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	NA	NA	NA	NA	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	2	0.8 J	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.4 J	0.5 U	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trichloroethene	ug/L	NS	2.6	76	2.4	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	0.7	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	1 U	5.5	13	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.3 J	0.5 U	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division.
 Samples from all of the other wells are analyzed with USEPA Method 8260.
 NS = Not sampled
 U = Compound was analyzed but not detected.
 ABD = Well has been abandoned
 RFW -20 was not sampled because it was damaged. The well is now repaired and will be sampled during the 4th quarter.

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells EW-2 and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from well EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (July through September 2013) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 3rd Quarter 2013
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Jul-13	Alarm at the air stripper due to a power outage caused by a thunderstorm. After replacing a control relay at EW-9, the system is back online.
Jul-13	Alarm at the stripper. Found that the pump motor in EW-10 locked up. The motor was replaced and the system is back online.
Jul-12	Alarm at the air stripper due to a power outage. The system is back online.

4. RECOMMENDATIONS

For the reporting period of July through September 2013, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(JULY - SEPTEMBER 2013)

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By: Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 626 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrance Jones 0763, Anthony Phillips 3001, Martin Whitt 0666, James Elliott 3738

Permit Number: 02-DP-0022
Superintendent: Earle Villarreal

Certification # 1017

Month: July
Year: 2013

Date	Appearance	Final Effluent outfall 001										Outfall 101					Outfall 201			Operator	
		Discharge MGD	pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l		Discharge mgd
1	Clear	0.29200									0.129000		0.0	1.0	5.0				0.241656	APhillips	
2	Clear	0.22000	7.35	0.00	< 0.31	< 0.26	< 0.34	7.0	10.6	< 5.0	0.171000	33.0	0.0	1.0	5.0				0.260695	Djones	
3	Clear	0.27800									0.142000		0.0	1.0	5.0				0.229985	APhillips	
4	Clear	0.31700	8.09	0.00							0.167000		0.0	1.0	5.0				0.202856	APhillips	
5	Clear	0.14500									0.173000		0.0	1.0	5.0				0.070246	APhillips	
6	Clear	0.05000									0.149000		0.0	1.0	5.0				0.068368	APhillips	
7	Clear	0.03900									0.144000		0.0	1.0	5.0				0.258258	APhillips	
8	Clear	0.11100									0.171000		0.0	1.0	5.0				0.284103	Djones	
9	Clear	0.16600									0.140000	13.0	0.0	1.0	5.0		< 0.3	< 0.3	< 0.3	0.267865	Djones
10	Clear	0.14300	7.45	0.00							0.158000		0.0	1.0	5.0				0.248106	Djones	
11	Clear	0.21300	8.12	0.00							0.148000		0.0	1.0	5.0				0.248716	Djones	
12	Clear	0.17300									0.184000		0.0	1.0	5.0				0.229126	APhillips	
13	Clear	0.53800									0.158000		0.0	1.0	5.0				0.273399	Mwhitt	
14	Clear	0.22800									0.127000		0.0	1.0	5.0				0.242406	Mwhitt	
15	Clear	0.15700									0.128000		0.0	1.0	5.0				0.254619	Djones	
16	Clear	0.14500	7.98	0.00							0.152000	33.0	0.0	1.0	5.0				0.255128	Djones	
17	Clear	0.11600									0.131000		0.0	1.0	5.0				0.246597	Djones	
18	Clear	0.09300									0.143000		0.0	1.0	5.0				0.240874	Djones	
19	Clear	0.08700	8.25	0.00							0.132000		0.0	1.0	5.0				0.251029	Djones	
20	Clear	0.10300									0.097000		0.0	1.0	5.0				0.237975	Jelliuott	
21	Clear	0.10300									0.078000		0.0	1.0	5.0				0.240789	Jelliuott	
22	Clear	0.09500									0.071000		0.0	1.0	5.0				0.241667	APhillips	
23	Clear	0.38500	7.12	0.00							0.065000	< 1.8	0.0	1.0	5.0				0.254575	APhillips	
24	Clear	0.15100									0.097000		0.0	1.0	5.0				0.241685	APhillips	
25	Clear	0.11700	7.88	0.00							0.083000		0.0	1.0	5.0				0.239306	Mwhitt	
26	Clear	0.05600									0.050000		0.0	1.0	5.0				0.246274	APhillips	
27	Clear	0.08900									0.000000		0.0	1.0	5.0				0.250405	APhillips	
28	Clear	0.38800									0.098000		0.0	1.0	5.0				0.237894	APhillips	
29	Clear	0.83600									0.124000		0.0	1.0	5.0				0.267850	Djones	
30	Clear	0.43600									0.138000	11.0	0.0	1.0	5.0				0.246539	Djones	
31	Clear	0.25200	7.80	0.00							0.128000		0.0	1.0	5.0				0.240924	Djones	
Total		6.52200									3.876000								7.319915		
Average		0.21039	7.8	<0.10	0	0	0	7	11	0	0.125032	18	0.0	1.0	5.0	#####	0	0	0	0.236126	
Minimum		0.03900	7.1	0.00	0	0	0	7	11	0	0.000000	1	0.0	1.0	5.0	0.0	0	0	0	0.068368	
Maximum		0.83600	8.3	<0.10	0	0	0	7	11	0	0.184000	33	0.0	1.0	5.0	0.0	0	0	0	0.284103	MOR 5-11-09

COMMENTS:

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 626 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrance Jones 0763, Gary Dickerson 0782, Martin Whitt 0666, Anthony Phillips 3001, James Elliott 3738

Permit Number: 02-DP-0022
Superintendent: Earle Villarreal
Certification # 1017

Month: August
Year: 2013

Final Effluent outfall 001											Outfall 101					Outfall 201			Operator		
Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Opd	Free Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l		Trichloroethene ug/l	Discharge mgd
1	Clear	0.25400									0.137000		0.0	1.0	1.0	5.0				0.216862	Aphillips
2	Clear	0.24000	7.27	0.00							0.140000		0.0	1.0	1.0	5.0				0.268748	Djones
3	Clear	0.20500									0.127000		0.0	1.0	1.0	5.0				0.240687	Mwhitt
4	Clear	0.18100									0.117000		0.0	1.0	1.0	5.0				0.241644	Mwhitt
5	Clear	0.13700	7.63	0.00							0.133000		0.0	1.0	1.0	5.0				0.247877	Djones
6	Clear	0.09500			< 0.17	< 0.17	< 0.12	4.0	10.8	< 5.0	0.180000	2.0	0.0	1.0	1.0	5.0				0.209944	Djones
7	Clear	0.19900	7.40	0.00							0.159000		0.0	1.0	1.0	5.0				0.203890	Djones
8	Clear	0.59200									0.164000		0.0	1.0	1.0	5.0				0.203749	Djones
9	Clear	0.26000									0.155000		0.0	1.0	1.0	5.0				0.207452	Djones
10	Clear	0.28700									0.173000		0.0	1.0	1.0	5.0				0.210509	Djones
11	Clear	0.21500									0.164000		0.0	1.0	1.0	5.0				0.253265	Djones
12	Clear	0.19500									0.122000		0.0	1.0	1.0	5.0				0.253696	Jelliott
13	Clear	0.69300	7.64	0.00							0.190000	< 1.8	0.0	1.0	1.0	5.0				0.246492	Mwhitt
14	Clear	0.41800									0.158000		0.0	1.0	1.0	5.0				0.245624	Djones
15	Clear	0.29900	7.23	0.00							0.142000		0.0	1.0	1.0	5.0				0.247048	Djones
16	Clear	0.25600									0.159000		0.0	1.0	1.0	5.0				0.228937	Djones
17	Clear	0.26900									0.152000		0.0	1.0	1.0	5.0				0.222915	Jelliott
18	Clear	0.23300									0.151000		0.0	1.0	1.0	5.0				0.239849	Jelliott
19	Clear	0.20000									0.160000		0.0	1.0	1.0	5.0				0.255030	Djones
20	Clear	0.20200	8.21	0.00							0.150000	< 1.8	0.0	1.0	1.0	5.0				0.246750	Djones
21	Clear	0.16300									0.135000		0.0	1.0	1.0	5.0				0.234197	Djones
22	Clear	0.11800									0.165000		0.0	1.0	1.0	5.0				0.239490	Djones
23	Clear	0.14000	7.60	0.00							0.172000		0.0	1.0	1.0	5.0				0.237506	Djones
24	Clear	0.16400									0.141000		0.0	1.0	1.0	5.0				0.233007	Gdickerson
25	Clear	0.08200									0.146000		0.0	1.0	1.0	5.0				0.220055	Gdickerson
26	Clear	0.10400	7.25	0.00							0.156000		0.0	1.0	1.0	5.0				0.259253	Djones
27	Clear	0.11000									0.177000	< 1.8	3.0	1.0	1.0	5.0				0.242489	Djones
28	Clear	0.10400	7.10	0.00							0.157000		3.0	1.0	1.0	5.0				0.234957	Djones
29	Clear	0.12600									0.166000		3.0	1.0	1.0	5.0				0.215536	Djones
30	Clear	0.09900									0.134000		3.0	1.0	1.0	5.0				0.260202	Djones
31	Clear	0.08900									0.184000		3.0	1.0	1.0	5.0				0.183552	Djones
Total		6.72900									4.766000									7.251212	
Average		0.21706	7.5	<0.10	0	0	0	4	11	0	0.153742	1	0.5	1.0	1.0	5.0	#DIV/0!	#DIV/0!	#####	0.233910	
Minimum		0.08200	7.1	0.00	0	0	0	4	11	0	0.117000	1	0.0	1.0	1.0	5.0	0	0	0	0.183552	
Maximum		0.69300	8.2	<0.10	0	0	0	4	11	0	0.190000	2	3.0	1.0	1.0	5.0	0	0	0	0.268748	MOR 5-11-09

COMMENTS:

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By: Facility: BTR Capital Group Permit Number: 02-DP-0022 Month: September
 Maryland Environmental Service Address: 626 Hanover Pike, Hampstead Maryland Superintendent: Earle Villarreal Certification # 1017 Year: 2013
 259 Najoles Road, Millersville MD Additional Op's & cert # - Dorrance Jones 0763, Gary Dickerson 0782, Martin Whitt 0666, James Elliott 3738

Date	Appearance	Discharge MGD	Final Effluent outfall 001								Outfall 101						Outfall 201			Operator	
			pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l		Discharge mgd
1	Clear	0.12600								0.153000		3.0	1.0	1.0	5.0				0.277725	Djones	
2	Clear	0.11100								0.151000		3.0	1.0	1.0	5.0				0.229068	Mwhitt	
3	Clear	0.10600	7.23	0.00						0.131000		3.0	1.0	1.0	5.0				0.239289	Jelliott	
4	Clear	0.07100			< 0.13	< 0.25	< 0.33	5.0	10.2	< 5.0	0.174000	< 1.8	3.0	1.0	1.0	5.0				0.256962	Djones
5	Clear	0.08300	7.35	0.00						0.169000		3.0	1.0	1.0	5.0				0.227812	Djones	
6	Clear	0.12700								0.185000		3.0	1.0	1.0	5.0				0.217145	Djones	
7	Clear	0.11400								0.159000		3.0	1.0	1.0	5.0				0.246412	Jelliott	
8	Clear	0.10100								0.154000		3.0	1.0	1.0	5.0				0.232368	Jelliott	
9	Clear	0.11400								0.143000		3.0	1.0	1.0	5.0				0.237274	Gdickerson	
10	Clear	0.11200	7.21	0.00						0.185000	< 1.8	3.0	1.0	1.0	5.0				0.239236	Gdickerson	
11	Clear	0.11200								0.174000		3.0	1.0	1.0	5.0				0.237652	Djones	
12	Clear	0.11700	7.65	0.00						0.176000		3.0	1.0	1.0	5.0				0.229656	Djones	
13	Clear	0.13200								0.204000	< 1.0	3.0	1.0	1.0	5.0				0.213059	Jelliott	
14	Clear	0.15600								0.187000		3.0	1.0	1.0	5.0				0.240959	Gdickerson	
15	Clear	0.13900								0.172000		3.0	1.0	1.0	5.0				0.234492	Gdickerson	
16	Clear	0.14300								0.195000		3.0	1.0	1.0	5.0				0.243253	Djones	
17	Clear	0.13800	7.17	0.00						0.172000	< 1.8	3.0	1.0	1.0	5.0				0.234773	Djones	
18	Clear	0.21100								0.201000		3.0	1.0	1.0	5.0				0.200539	APhillips	
19	Clear	0.21700	7.40	0.00						0.176000		4.0	1.0	1.0	5.0				0.257232	Djones	
20	Clear	0.18500								0.195000		4.0	1.0	1.0	5.0				0.220074	Djones	
21	Clear	0.17900								0.180000		4.0	1.0	1.0	5.0				0.237918	Djones	
22	Clear	0.17200								0.195000		2.0	1.0	1.0	5.0				0.223445	Djones	
23	Clear	0.16900								0.155000		2.0	1.0	1.0	5.0				0.241173	Mwhitt	
24	Clear	0.15600	7.68	0.00						0.205000		2.0	1.0	1.0	5.0				0.235916	Gdickerson	
25	Clear	0.15300								0.186000		3.0	1.0	1.0	5.0				0.232667	Djones	
26	Clear	0.14900	7.25	0.00						0.182000	< 1.8	3.0	1.0	1.0	5.0				0.230516	Djones	
27	Clear	0.14100								0.179000		3.0	1.0	1.0	5.0				0.225459	Jelliott	
28	Clear	0.13500								0.179000		3.0	1.0	1.0	5.0				0.228239	Jelliott	
29	Clear	0.13300								0.165000		3.0	1.0	1.0	5.0				0.231089	Jelliott	
30	Clear	0.12500								0.168000		3.0	1.0	1.0	5.0				0.236541	Djones	
31																					
Total		4.12700								5.250000									7.037943		
Average		0.13757	7.4	<0.10	0	0	0	5	10	0	0.175000	1	3.0	1.0	1.0	5.0	#DIV/0!	#DIV/0!	#####	0.234598	
Minimum		0.07100	7.2	0.00	0	0	0	5	10	0	0.131000	1	2.0	1.0	1.0	5.0	0	0	0	0.200539	
Maximum		0.21700	7.7	<0.10	0	0	0	5	10	0	0.205000	1	4.0	1.0	1.0	5.0	0	0	0	0.277725	MOR 5-11-09

COMMENTS:

**APPENDIX B
DISCHARGE MONITORING REPORTS
(JULY - SEPTEMBER 2013)**

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

Name AG/GFI Hampstead, Inc
 Address 626 Hanover Pike
Hampstead, MD 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)
 MD0001881 001
PERMIT NUMBER DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires

Facility Black and Decker WWTP
 Location 626 Hanover Pike
 Attn: _____

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
13	07	01	13	07	31	
(20-21) (22-23) (24-25)			(26-27) (28-29) (30-31)			

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form

State Discharge Permit
 02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM				UNITS
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	7	(19)	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/MONTH	GRAB
	SAMPLE MEASUREMENT	*****	*****	****	7.1	*****	8.3	(12)	0	TWICE/WEEK	GRAB
pH 00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY MN	*****	8.5 DAILY MX	SU		TWICE/WEEK	GRAB
	SAMPLE MEASUREMENT	*****	*****	****	*****	11	11	(19)	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/MONTH	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	210,387	836,000	(07)	*****	*****	*****	****	0	Measured	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	RECORD
	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/MONTH	GRAB
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L		ONCE/MONTH	GRAB
	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB
	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER James M. Harkins MES Director TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUES IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 851001 AND 33 U.S.C. 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$13,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410 AREA CODE	729-8350 NUMBER	13 YEAR	08 MONTH	26 DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name **AG/GFI Hampstead, Inc**

Address **626 Hanover Pike**

Hampstead, MD 21074

Facility **Black and Decker WWTP**

Location **626 Hanover Pike**

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***


NOTE: Read instructions before completing this form

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	13	07	01		13	07	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING (48-53) (54-61)			QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
79141 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L		ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE						DAILY MX					
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/MONTH	GRAB
TOTAL RECOVERABLE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONCE/MONTH	GRAB
70030 1 0 0						30DA AVG	DAILY MX				
EFFLUENT GROSS VALUE											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 851001 AND 33 U.S.C. 85 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$12,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.						TELEPHONE		DATE		
James M. Harkins MES Director							410	729-8350	13	08	26
TYPED OR PRINTED							AREA CODE	NUMBER	YEAR	MONTH	DAY
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT											

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.
 Address 626 Hanover Pike
Hampstead, MD 21074

Facility Black and Decker WWTP
 Location 626 Hanover Pike
 Attn: _____

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) MD0001881 (17-19) 101
PERMIT NUMBER **DISCHARGE NUMBER**

Form Approved.
 OMB No. _____
 Approval expires _____

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 13	07	01	TO 13	07	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

State Discharge Permit
 02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	125,032	184,000	(07)	*****	*****	*****	****	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE COLIFORM, FECAL GENERAL 74055 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	33	(30)	0	ONCE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX	MPN		ONCE/ WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS 1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)				TELEPHONE			DATE			
James M. Harkins MES Director TYPED OR PRINTED					SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	410	729-8350	13	08	26	
		AREA CODE	NUMBR	YEAR	MONTH	DAY					

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc
 Address 626 Hanover Pike
Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn: _____

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)
 MD0001881 001
 PERMIT NUMBER DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

State Discharge Permit

02-DP-0022

MONITORING PERIOD						
YEAR	MO	DAY	YEAR	MO	DAY	
FROM 13	08	01	TO 13	08	31	
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)

PARAMETER (32-37)		(3 Card Only) (46-53) QUANTITY OR LOADING			(4 Card Only) (38-45) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	4	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
pH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	7.1	*****	8.2	(12)	0	TWICE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY MN	*****	8.5 DAILY MX	SU		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	11	11	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	217,065	693,000	(07)	*****	*****	*****	****	0	Measured	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L		ONCE/ MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER James M. Harkins MES Director TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 881001 AND 33 U.S.C. 881319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE#		DATE		
		410	729-8350	13	09	23
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 13	08	01	TO	13	08	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING (54-61)			QUALITY OR CONCENTRATION (46-53)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		(3 Card Only) (46-53) AVERAGE	MAXIMUM	UNITS	(4 Card Only) (38-45) MINIMUM	AVERAGE	MAXIMUM	UNITS				
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB	
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	10 30DA AVG	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)							TFI PHONE		DATE		
James M. Harkins MES Director TYPED OR PRINTED								410	729-8350	13	09	23
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-18)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
13	08	01	13	08	31

FROM (20-21) (22-23) (24-25) TO (26-27) (28-29) (30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING (3 Card Only) (46-53)			QUALITY OR CONCENTRATION (4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	153,742	190,000	(07)	*****	*****	*****	****	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	2	(30)	0	ONCE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX	MPN		ONCE/ WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)				TFI PHONE			DATE			
James M. Harkins MES Director					410 729-8350			13	09	23	
TYPED OR PRINTED					AREA CODE	NUMBER	YFAR	MONTH	DAY		
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)					SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires


*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
FROM 13	09	01	TO	13	09	30
(20-21)		(22-23) (24-25)		(26-27)		(28-29) (30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53) QUANTITY OR LOADING			(4 Card Only) (38-45) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	5	(19)	0	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB	
pH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	7.2	*****	7.7	(12)	0	TWICE/ WEEK	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY MN	*****	8.5 DAILY MX	SU		TWICE/ WEEK	GRAB	
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	10	10	(19)	0	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/ MONTH	GRAB	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	137,567	217,000	(07)	*****	*****	*****	****	0	Measured	RECORD	
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	RECORD	
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L		ONCE/ MONTH	GRAB	
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB	
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)							TFF PHONE		DATE		
James M. Harkins MES Director								410	729-8350	13	10	21
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name AG/GFI Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address 626 Hanover Pike

MD0001881

001

Approval expires

Hampstead, MD 21074

PERMIT NUMBER

DISCHARGE NUMBER

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP

MONITORING PERIOD

Location 626 Hanover Pike

YEAR	MO	DAY	YEAR	MO	DAY
13	09	01	13	09	30

State Discharge Permit

Attn:

FROM (20-21) (22-23) (24-25) TO (26-27) (28-29) (30-31)

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53) QUANTITY OR LOADING			(4 Card Only) (38-45) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE (54-51)	MAXIMUM	UNITS	MINIMUM (46-53)	AVERAGE	MAXIMUM (54-61)	UNITS				
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB	
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	10 30DAAVG	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)							TTE PHONE		DATE		
James M. Harkins MES Director								410	729-8350	13	10	21
TYPED OR PRINTED								AREA CODE	NUMBER	YFAR	MONTH	DAY
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)							SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.
 Address 626 Hanover Pike
Hampstead, MD 21074

Facility Black and Decker WWTP
 Location 626 Hanover Pike
 Attn: _____

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) MD0001881 (17-19) 101
 PERMIT NUMBER DISCHARGE NUMBER

Form Approved.
 OMB No.
 Approval expires


*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 13	09	01	TO	13	09	30
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit
 02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	175,000	205,000	(07)	*****	*****	*****	****	0	ONCE/ MONTH	GRAB	
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	GRAB	
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/ WEEK	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX	MPN		ONCE/ WEEK	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 551001 AND 33 U.S.C. 551318. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)							TELEPHONE		DATE		
James M. Harkins MES Director								410	729-8350	13	10	21
TYPED OR PRINTED								AREA CODE	NUMBER	YFAR	MONTH	DAY


 SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike
Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MDO001881

201

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
13	07	01	TO	13	09	30
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(46-53) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	234,881	284,103	(07)	*****	*****	*****	****	0	Measured	Record
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	Record
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)				TFI PHONE		DATE				
James M. Harkins MES Director TYPED OR PRINTED					410	729-8350	13	10	21		
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				AREA CODE	NUMBER	YEAR	MONTH	DAY		

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(JULY - SEPTEMBER 2013)

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE A
 259 NAJOLAS ROAD
 RE: BLACK & DECKER WWTP
 MILLERSVILLE, MD 21108

Order Number: L4639409
 Project Name: BLACK & DECKER WWTP
 Receive Date: 07-02-2013
 Client Code: MES_A
 Project Location: BLACK & DECKER WWTP

Sample ID: L4639409-1 Sample Description: FINAL 001 GRAB Samp. Date/Time/Temp: 07/02/13 09:35am NA C Temp Sampled by: Customer
 Received Date/Time/Temp: 07/02/13 05:10pm 2.3 C Iced (Y/N): Y

Parameter	Method	Result	RLs	Test Date, Time, Analyst
GENERAL CHEMISTRY				
BIOCHEMICAL OXYGEN DEMAND (DELAWARE)	SM 5210B	7.00 mg/l	2.00 mg/l	07/03/13 11:40AM SKJ
TOTAL SUSPENDED SOLIDS (DELAWARE)	SM 2540D	10.6 mg/l	4.00 mg/l	07/05/13 12:00AM MS3
HEXANE EXTR.-HEM (OIL+GREASE)	1664A HEM	ND mg/l	5.00 mg/l	07/05/13 08:30AM RHB
GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES				
1,1,1-TRICHLOROETHANE	EPA 624	ND ug/l	0.260 ug/l*	07/03/13 10:49PM JAD
TRICHLOROETHENE	EPA 624	ND ug/l	0.340 ug/l*	07/03/13 10:49PM JAD
TETRACHLOROETHENE	EPA 624	ND ug/l	0.310 ug/l*	07/03/13 10:49PM JAD
DIBROMOFLUOROMETHANE	EPA 624	112 %		07/03/13 10:49PM JAD
TOLUENE-D8 (SURR)	EPA 624	102 %		07/03/13 10:49PM JAD
4-BROMOFLUOROBENZENE	EPA 624	99 %		07/03/13 10:49PM JAD

Sample Comments:

L4639409-1 :
 For the BOD 5 test on this day, the seed control was 1.42 mg/ml, above the acceptance limit of 0.6 to 1.0 mg/ml.

General Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.
 Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive
 MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.
 The test results meet all requirements of NELAC unless otherwise specified.
 The report shall not be reproduced except in full without the written consent of the laboratory.
 Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.
 The reported results relate only to the samples.
 All samples are collected as "grab" samples unless otherwise identified.
 A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.
 The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), John Pcsolar (Dairy & Food Microbiology),
 QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223

Serial Number: 2881971

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE A
 259 NAJOLES ROAD
 RE: BLACK & DECKER WWTP
 MILLERSVILLE, MD 21108

Order Number: L4695248
 Project Name: BLACK & DECKER WWTP
 Receive Date: 07-22-2013
 Client Code: MES_A
 Project Location: BLACK & DECKER WWTP

Sample ID	Sample Description	Samp. Date/Time/Temp	Sampled by
L4695248-1	BLACK & DECKER 101 Received Date/Time 07/22/13 11:00am	07/02/13 09:25am	NA C Customer

Parameter	Method	Result	RLs	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY				
FECAL COLIFORM-MPN CEL(DELAWARE)	SM 9221E	33 MPN/100ml	MPN/100ml	07/02/13 02:09PM SUB

Fecal coliform was analyzed by Chesapeake Environmental Lab, Inc. in Stevensville, MD.

General Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.
 Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive
 MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.
 The test results meet all requirements of NELAC unless otherwise specified.
 The report shall not be reproduced except in full without the written consent of the laboratory.
 Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.
 The reported results relate only to the samples.
 All samples are collected as "grab" samples unless otherwise identified.
 A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.
 The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), John Pcsolar (Dairy & Food Microbiology),
 QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223
 State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # : 2515238
 E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.



Serial Number: 2909107

QC Laboratories

Analytical Report

Printed 08/14/13 18:58

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE A
 259 NAJILES ROAD
 RE: BLACK & DECKER WWTP
 MILLERSVILLE, MD 21108

Order Number: L4691889
 Project Name: BLACK & DECKER WWTP
 Receive Date: 08-06-2013
 Client Code: MES_A
 Project Location: BLACK & DECKER WWTP

Sample ID	Sample Description	Received Date/Time/Temp	08/06/13 05:00pm 2.2 C	Iced (Y/N):	Y	Samp. Date/Time/Temp	08/06/13 09:30am NA C	Sampled by	Customer
Parameter	Method	Result	RLs	Test Date, Time, Analyst					
GENERAL CHEMISTRY									
BIOCHEMICAL OXYGEN DEMAND (DELAWARE)	SM 5210B	4 mg/l	2.00 mg/l	08/07/13 08:30AM SKJ					
TOTAL SUSPENDED SOLIDS (DELAWARE)	SM 2540D	10.8 mg/l	5.00 mg/l	08/09/13 12:00AM MS3					
HEXANE EXTR.-HEM (OIL+GREASE)	1664A HEM	ND mg/l	5.00 mg/l	08/09/13 09:03AM RHB					
GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES									
1,1,1-TRICHLOROETHANE	EPA 624	ND ug/l	0.170 ug/l*	08/13/13 01:51AM EEW					
TRICHLOROETHENE	EPA 624	ND ug/l	0.120 ug/l*	08/13/13 01:51AM EEW					
TETRACHLOROETHENE	EPA 624	ND ug/l	0.170 ug/l*	08/13/13 01:51AM EEW					
DIBROMOFLUOROMETHANE	EPA 624	113 %		08/13/13 01:51AM EEW					
TOLUENE-D8 (SURR)	EPA 624	102 %		08/13/13 01:51AM EEW					
4-BROMOFLUOROBENZENE	EPA 624	102 %		08/13/13 01:51AM EEW					

General Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.
 Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive
 MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.
 The test results meet all requirements of NELAC unless otherwise specified.
 The report shall not be reproduced except in full without the written consent of the laboratory.
 Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.
 The reported results relate only to the samples.
 All samples are collected as "grab" samples unless otherwise identified.
 A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.
 The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), John Pcsolar (Dairy & Food Microbiology),
 QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223
 State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # : 2515238
 E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.

Serial Number: 2979731

QC Laboratories

Analytical Report

Printed 08/21/13 11:31

CHERYL GRIFFIN
MARYLAND ENVIRONMENTAL SERVICE A
259 NAJOLE'S ROAD
RE: BLACK & DECKER WWTP
MILLERSVILLE, MD 21108

Order Number: L4736362
Project Name: BLACK & DECKER WWTP
Receive Date: 08-20-2013
Client Code: MES_A
Project Location: BLACK & DECKER WWTP

Sample ID L4736362-1 Sample Description BLACK & DECKER 101 Samp. Date/Time/Temp 08/06/13 09:25am NA C Sampled by Customer
Received Date/Time 08/20/13 11:00am

Parameter	Method	Result	RLs	Test Date, Time, Analyst
-----------	--------	--------	-----	--------------------------

ENVIRONMENTAL MICROBIOLOGY

FECAL COLIFORM-MPN CEL(DELAWARE)	SM 9221E	2.0 MPN/100ml	MPN/100ml	08/06/13 02:20PM SUB
-------------------------------------	----------	---------------	-----------	----------------------

Fecal coliform was analyzed by Chesapeake Environmental Lab, Inc. in Stevensville, MD.

General Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.
Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive

MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.

The test results meet all requirements of NELAC unless otherwise specified.

The report shall not be reproduced except in full without the written consent of the laboratory.

Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food

Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.

The reported results relate only to the samples.

All samples are collected as "grab" samples unless otherwise identified.

A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.

The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki

Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), John Pcsolar (Dairy & Food Microbiology),

QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223

State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # : 2515238

E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.



Serial Number: 2994785

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE A
 259 NAJILES ROAD
 RE: BLACK & DECKER WWTP
 MILLERSVILLE, MD 21108

Order Number: L4730527
 Project Name: BLACK & DECKER WWTP
 Receive Date: 09-04-2013
 Client Code: MES_A
 Project Location: BLACK & DECKER WWTP

Sample ID: L4730527-1 Sample Description: FINAL 001 GRAB Samp. Date/Time/Temp: 09/04/13 09:30am NA C Temp Sampled by: Customer
 Received Date/Time/Temp: 09/04/13 05:00pm 3.5 C Iced (Y/N): Y

Parameter	Method	Result	RLs	Test Date, Time, Analyst
GENERAL CHEMISTRY				
BIOCHEMICAL OXYGEN DEMAND (DELAWARE)	SM 5210B	5.00 mg/l	2.00 mg/l	09/05/13 12:00PM SKJ
TOTAL SUSPENDED SOLIDS (DELAWARE)	SM 2540D	10.2 mg/l	4.00 mg/l	09/09/13 12:00AM MS3
HEXANE EXTR.-HEM (OIL+GREASE)	1664A HEM	ND mg/l	5.00 mg/l	09/06/13 01:45PM RHB
GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES				
1,1,1-TRICHLOROETHANE	EPA 624	ND ug/l	0.250 ug/l*	09/11/13 10:08PM JAD
TRICHLOROETHENE	EPA 624	ND ug/l	0.330 ug/l*	09/11/13 10:08PM JAD
TETRACHLOROETHENE	EPA 624	ND ug/l	0.130 ug/l*	09/11/13 10:08PM JAD
DIBROMOFLUOROMETHANE	EPA 624	108 %		09/11/13 10:08PM JAD
TOLUENE-D8 (SURR)	EPA 624	97 %		09/11/13 10:08PM JAD
4-BROMOFLUOROBENZENE	EPA 624	98 %		09/11/13 10:08PM JAD

Sample Comments:

L4730527-1 :
 For the BOD 5 test on this day, the batch control sample recovered at 231 mg/l, outside the acceptance range of 168 to 228 mg/l. Reported BOD 5 results may be biased high.

General Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.
 Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive
 MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.
 The test results meet all requirements of NELAC unless otherwise specified.
 The report shall not be reproduced except in full without the written consent of the laboratory.
 Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.
 The reported results relate only to the samples.
 All samples are collected as "grab" samples unless otherwise identified.
 A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.
 The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), John Pcsolar (Dairy & Food Microbiology),

Serial Number: 3064991

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE A
 259 NAJILES ROAD
 RE: BLACK & DECKER WWTP
 MILLERSVILLE, MD 21108

Order Number: L4681016
 Project Name: BLACK & DECKER WWTP
 Receive Date: 07-09-2013
 Client Code: MES_A
 Project Location: BLACK & DECKER WWTP

Sample ID: L4681016-1 Sample Description: BLACK & DECKER 201 Samp. Date/Time/Temp: 07/09/13 09:30am NA C Sampled by: Customer
 Received Date/Time/Temp: 07/09/13 05:10pm 1.9 C Iced (Y/N): Y

Parameter	Method	Result	RLs	Test Date, Time, Analyst
GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES				
1,1,1-TRICHLOROETHANE	EPA 624	ND ug/l	0.260 ug/l*	07/17/13 01:01AM JAD
TRICHLOROETHENE	EPA 624	ND ug/l	0.340 ug/l*	07/17/13 01:01AM JAD
TETRACHLOROETHENE	EPA 624	ND ug/l	0.310 ug/l*	07/17/13 01:01AM JAD
DIBROMOFLUOROMETHANE	EPA 624	127 %		07/17/13 01:01AM JAD
TOLUENE-D8 (SURR)	EPA 624	101 %		07/17/13 01:01AM JAD
4-BROMOFLUOROBENZENE	EPA 624	92 %		07/17/13 01:01AM JAD

General Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.
 Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive
 MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.
 The test results meet all requirements of NELAC unless otherwise specified.
 The report shall not be reproduced except in full without the written consent of the laboratory.
 Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.
 The reported results relate only to the samples.
 All samples are collected as "grab" samples unless otherwise identified.
 A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.
 The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), John Pcsolar (Dairy & Food Microbiology),
 QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223
 State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # : 2515238
 E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.
 * - The "RLs" represents a reporting/quantitation limit. When an "*" is present in the column identified as the "RLs", it is being reported as a Method Detection Limit (MDL).



Serial Number: 2900546

CHERYL GRIFFIN
 MARYLAND ENVIRONMENTAL SERVICE A
 259 NAJOLES ROAD
 RE: BLACK & DECKER WWTP
 MILLERSVILLE, MD 21108

Order Number: L4774606
 Project Name: BLACK & DECKER WWTP
 Receive Date: 09-24-2013
 Client Code: MES_A
 Project Location: BLACK & DECKER WWTP

Sample ID	Sample Description	Samp. Date/Time/Temp	Sampled by
L4774606-1	BLACK & DECKER 101	09/10/13 09:03am	NA C Customer
	Received Date/Time 09/24/13 09:30am		

Parameter	Method	Result	RLs	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY				
FECAL COLIFORM-MPN CEL(DELAWARE)	SM 9221E	<1.8 MPN/100ml	MPN/100ml	09/10/13 01:56PM SUB

Fecal coliform was analyzed by Chesapeake Environmental Lab, Inc. in Stevensville, MD.

General Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.
 Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive
 MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.
 The test results meet all requirements of NELAC unless otherwise specified.
 The report shall not be reproduced except in full without the written consent of the laboratory.
 Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.
 The reported results relate only to the samples.
 All samples are collected as "grab" samples unless otherwise identified.
 A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.
 The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), John Pcsolar (Dairy & Food Microbiology),
 QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223
 State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # : 2515238
 E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.



**APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(AUGUST 2013)**

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.
TestAmerica Chicago
2417 Bond Street
University Park, IL 60484
Tel: (708)534-5200

TestAmerica Job ID: 500-60429-1
Client Project/Site: Black and Decker

For:
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, Pennsylvania 19380

Attn: Mr. Tom Cornuet



Authorized for release by:
8/19/2013 2:39:48 PM

Richard Wright, Project Manager II
richard.wright@testamericainc.com

LINKS

Review your project
results through
Total Access

Have a Question?

? Ask
The
Expert

Visit us at:
www.testamericainc.com

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

Table of Contents

Cover Page	1
Table of Contents	2
Case Narrative	3
Detection Summary	4
Method Summary	7
Sample Summary	8
Client Sample Results	9
Definitions	61
QC Association	62
Surrogate Summary	63
QC Sample Results	64
Chronicle	80
Certification Summary	85
Chain of Custody	86
Receipt Checklists	89



Case Narrative

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Job ID: 500-60429-1

Laboratory: TestAmerica Chicago

Narrative

Job Narrative
500-60429-1

Comments

No additional comments.

Receipt

The samples were received on 8/3/2013 9:15 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 3.6° C.

GC/MS VOA

Method(s) 8260B: The matrix spike / matrix spike duplicate (MS/MSD) precision for bromoform in batch 197129 was outside control limits.

Method(s) 8260B: The laboratory control sample (LCS) for batch 197263 recovered outside control limits for the following analytes: Dichlorodifluoromethane, Carbon Tetrachloride, 4-Isopropyltoluene. These analytes were biased high in the LCS but were not detected in the associated samples; therefore, the data has been reported.

No other analytical or quality issues were noted.



Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-2

Lab Sample ID: 500-60429-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	3.9		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	200		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	43		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-3

Lab Sample ID: 500-60429-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	30		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	1.1		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-4

Lab Sample ID: 500-60429-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Tetrachloroethene	12		1.0	0.17	ug/L	1		8260B	Total/NA
Trichloroethene - DL	530		10	3.8	ug/L	20		8260B	Total/NA

Client Sample ID: EW-5

Lab Sample ID: 500-60429-4

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	110		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	3.1		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-6

Lab Sample ID: 500-60429-5

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	6.1		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	11		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-7

Lab Sample ID: 500-60429-6

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	4.1		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	3.1		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	6.0		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-8

Lab Sample ID: 500-60429-7

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	30		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	10		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	77		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-9

Lab Sample ID: 500-60429-8

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Tetrachloroethene	110		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-9 DUP

Lab Sample ID: 500-60429-9

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-9 DUP (Continued)

Lab Sample ID: 500-60429-9

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.71		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	100		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-10

Lab Sample ID: 500-60429-10

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Tetrachloroethene	1.2		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-1A

Lab Sample ID: 500-60429-11

No Detections.

Client Sample ID: RFW-1B

Lab Sample ID: 500-60429-12

No Detections.

Client Sample ID: RFW-2A

Lab Sample ID: 500-60429-13

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.59		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-2B

Lab Sample ID: 500-60429-14

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.40	J	0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-3B

Lab Sample ID: 500-60429-15

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	1.6		1.0	0.12	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-4A

Lab Sample ID: 500-60429-16

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Methylene Chloride	5.1		5.0	0.68	ug/L	1		8260B	Total/NA
Trichloroethene	28		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	19		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-4A DUP

Lab Sample ID: 500-60429-17

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Methylene Chloride	5.3		5.0	0.68	ug/L	1		8260B	Total/NA
Trichloroethene	28		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	17		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-4B

Lab Sample ID: 500-60429-18

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Methylene Chloride	6.3		5.0	0.68	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	1.4		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	0.70		0.50	0.19	ug/L	1		8260B	Total/NA

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-4B (Continued)

Lab Sample ID: 500-60429-18

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Tetrachloroethene	2.9		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-6

Lab Sample ID: 500-60429-19

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Methylene Chloride	6.3		5.0	0.68	ug/L	1		8260B	Total/NA
Trichloroethene	0.83		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	1.1		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-7

Lab Sample ID: 500-60429-20

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Methylene Chloride	7.0		5.0	0.68	ug/L	1		8260B	Total/NA
Trichloroethene	0.90		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-9

Lab Sample ID: 500-60429-21

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Methylene Chloride	7.1		5.0	0.68	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	12		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	7.6		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-11B

Lab Sample ID: 500-60429-22

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Methylene Chloride	8.5		5.0	0.68	ug/L	1		8260B	Total/NA
Trichloroethene	2.6		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-12B

Lab Sample ID: 500-60429-23

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	2.0		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	76		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	5.5		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-13

Lab Sample ID: 500-60429-24

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.77	J	1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	2.4		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	13		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-17

Lab Sample ID: 500-60429-25

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Benzene	0.68		0.50	0.074	ug/L	1		8260B	Total/NA

Client Sample ID: Trip Blank

Lab Sample ID: 500-60429-26

No Detections.

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Method Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Method	Method Description	Protocol	Laboratory
8260B	VOC	SW846	TAL CHI

Protocol References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200



Sample Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
500-60429-1	EW-2	Water	08/02/13 10:45	08/03/13 09:15
500-60429-2	EW-3	Water	08/02/13 07:55	08/03/13 09:15
500-60429-3	EW-4	Water	08/02/13 08:20	08/03/13 09:15
500-60429-4	EW-5	Water	08/01/13 09:10	08/03/13 09:15
500-60429-5	EW-6	Water	08/01/13 13:15	08/03/13 09:15
500-60429-6	EW-7	Water	08/01/13 13:25	08/03/13 09:15
500-60429-7	EW-8	Water	08/01/13 13:30	08/03/13 09:15
500-60429-8	EW-9	Water	08/01/13 13:45	08/03/13 09:15
500-60429-9	EW-9 DUP	Water	08/01/13 13:45	08/03/13 09:15
500-60429-10	EW-10	Water	08/01/13 13:55	08/03/13 09:15
500-60429-11	RFW-1A	Water	08/01/13 09:00	08/03/13 09:15
500-60429-12	RFW-1B	Water	08/01/13 16:30	08/03/13 09:15
500-60429-13	RFW-2A	Water	08/01/13 07:50	08/03/13 09:15
500-60429-14	RFW-2B	Water	08/01/13 08:00	08/03/13 09:15
500-60429-15	RFW-3B	Water	08/01/13 15:10	08/03/13 09:15
500-60429-16	RFW-4A	Water	08/02/13 09:20	08/03/13 09:15
500-60429-17	RFW-4A DUP	Water	08/02/13 09:20	08/03/13 09:15
500-60429-18	RFW-4B	Water	08/02/13 10:10	08/03/13 09:15
500-60429-19	RFW-6	Water	08/01/13 16:35	08/03/13 09:15
500-60429-20	RFW-7	Water	08/01/13 12:55	08/03/13 09:15
500-60429-21	RFW-9	Water	08/01/13 17:15	08/03/13 09:15
500-60429-22	RFW-11B	Water	08/02/13 08:20	08/03/13 09:15
500-60429-23	RFW-12B	Water	08/02/13 11:10	08/03/13 09:15
500-60429-24	RFW-13	Water	08/01/13 16:25	08/03/13 09:15
500-60429-25	RFW-17	Water	08/01/13 09:50	08/03/13 09:15
500-60429-26	Trip Blank	Water	08/01/13 07:00	08/03/13 09:15

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-2

Lab Sample ID: 500-60429-1

Date Collected: 08/02/13 10:45

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/08/13 14:19	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			08/08/13 14:19	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/08/13 14:19	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/08/13 14:19	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/08/13 14:19	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/08/13 14:19	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/08/13 14:19	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/08/13 14:19	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/08/13 14:19	1
Acetone	<5.0		5.0	1.3	ug/L			08/08/13 14:19	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			08/08/13 14:19	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/08/13 14:19	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/08/13 14:19	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/08/13 14:19	1
cis-1,2-Dichloroethene	3.9		1.0	0.12	ug/L			08/08/13 14:19	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/08/13 14:19	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/08/13 14:19	1
Chloroform	<1.0		1.0	0.20	ug/L			08/08/13 14:19	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/08/13 14:19	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/08/13 14:19	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			08/08/13 14:19	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 14:19	1
Trichloroethene	200		0.50	0.19	ug/L			08/08/13 14:19	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/08/13 14:19	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/08/13 14:19	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/08/13 14:19	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/08/13 14:19	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/08/13 14:19	1
Toluene	<0.50		0.50	0.11	ug/L			08/08/13 14:19	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/08/13 14:19	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 14:19	1
Tetrachloroethene	43		1.0	0.17	ug/L			08/08/13 14:19	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/08/13 14:19	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/08/13 14:19	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/08/13 14:19	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/08/13 14:19	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/08/13 14:19	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/08/13 14:19	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/08/13 14:19	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/08/13 14:19	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/08/13 14:19	1
Styrene	<1.0		1.0	0.10	ug/L			08/08/13 14:19	1
Bromoform	<1.0		1.0	0.28	ug/L			08/08/13 14:19	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 14:19	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/08/13 14:19	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/08/13 14:19	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/08/13 14:19	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 14:19	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/08/13 14:19	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-2

Lab Sample ID: 500-60429-1

Date Collected: 08/02/13 10:45

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/08/13 14:19	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/08/13 14:19	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 14:19	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 14:19	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/08/13 14:19	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 14:19	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/08/13 14:19	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 14:19	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 14:19	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/08/13 14:19	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/08/13 14:19	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/08/13 14:19	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/08/13 14:19	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/08/13 14:19	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/08/13 14:19	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	92		75 - 125		08/08/13 14:19	1
Toluene-d8 (Surr)	102		75 - 120		08/08/13 14:19	1
4-Bromofluorobenzene (Surr)	93		75 - 120		08/08/13 14:19	1
Dibromofluoromethane	98		75 - 120		08/08/13 14:19	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-3

Lab Sample ID: 500-60429-2

Date Collected: 08/02/13 07:55

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/08/13 15:12	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			08/08/13 15:12	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/08/13 15:12	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/08/13 15:12	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/08/13 15:12	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/08/13 15:12	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/08/13 15:12	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/08/13 15:12	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/08/13 15:12	1
Acetone	<5.0		5.0	1.3	ug/L			08/08/13 15:12	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			08/08/13 15:12	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/08/13 15:12	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/08/13 15:12	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/08/13 15:12	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			08/08/13 15:12	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/08/13 15:12	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/08/13 15:12	1
Chloroform	<1.0		1.0	0.20	ug/L			08/08/13 15:12	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/08/13 15:12	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/08/13 15:12	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			08/08/13 15:12	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 15:12	1
Trichloroethene	30		0.50	0.19	ug/L			08/08/13 15:12	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/08/13 15:12	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/08/13 15:12	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/08/13 15:12	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/08/13 15:12	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/08/13 15:12	1
Toluene	<0.50		0.50	0.11	ug/L			08/08/13 15:12	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/08/13 15:12	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 15:12	1
Tetrachloroethene	1.1		1.0	0.17	ug/L			08/08/13 15:12	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/08/13 15:12	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/08/13 15:12	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/08/13 15:12	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/08/13 15:12	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/08/13 15:12	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/08/13 15:12	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/08/13 15:12	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/08/13 15:12	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/08/13 15:12	1
Styrene	<1.0		1.0	0.10	ug/L			08/08/13 15:12	1
Bromoform	<1.0		1.0	0.28	ug/L			08/08/13 15:12	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 15:12	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/08/13 15:12	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/08/13 15:12	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/08/13 15:12	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 15:12	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/08/13 15:12	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-3

Lab Sample ID: 500-60429-2

Date Collected: 08/02/13 07:55

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/08/13 15:12	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/08/13 15:12	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 15:12	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 15:12	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/08/13 15:12	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 15:12	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/08/13 15:12	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 15:12	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 15:12	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/08/13 15:12	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/08/13 15:12	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/08/13 15:12	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/08/13 15:12	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/08/13 15:12	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/08/13 15:12	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	90		75 - 125					08/08/13 15:12	1
Toluene-d8 (Surr)	102		75 - 120					08/08/13 15:12	1
4-Bromofluorobenzene (Surr)	95		75 - 120					08/08/13 15:12	1
Dibromofluoromethane	94		75 - 120					08/08/13 15:12	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-4
Date Collected: 08/02/13 08:20
Date Received: 08/03/13 09:15

Lab Sample ID: 500-60429-3
Matrix: Water

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/09/13 15:34	1
Dichlorodifluoromethane	<1.0	*	1.0	0.20	ug/L			08/09/13 15:34	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/09/13 15:34	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/09/13 15:34	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/09/13 15:34	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/09/13 15:34	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/09/13 15:34	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/09/13 15:34	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/09/13 15:34	1
Acetone	<5.0		5.0	1.3	ug/L			08/09/13 15:34	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			08/09/13 15:34	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/09/13 15:34	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/09/13 15:34	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/09/13 15:34	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			08/09/13 15:34	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/09/13 15:34	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/09/13 15:34	1
Chloroform	<1.0		1.0	0.20	ug/L			08/09/13 15:34	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/09/13 15:34	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/09/13 15:34	1
Carbon tetrachloride	<1.0	*	1.0	0.26	ug/L			08/09/13 15:34	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/09/13 15:34	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/09/13 15:34	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/09/13 15:34	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/09/13 15:34	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/09/13 15:34	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/09/13 15:34	1
Toluene	<0.50		0.50	0.11	ug/L			08/09/13 15:34	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/09/13 15:34	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/09/13 15:34	1
Tetrachloroethene	12		1.0	0.17	ug/L			08/09/13 15:34	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/09/13 15:34	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/09/13 15:34	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/09/13 15:34	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/09/13 15:34	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/09/13 15:34	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/09/13 15:34	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/09/13 15:34	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/09/13 15:34	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/09/13 15:34	1
Styrene	<1.0		1.0	0.10	ug/L			08/09/13 15:34	1
Bromoform	<1.0		1.0	0.28	ug/L			08/09/13 15:34	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 15:34	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/09/13 15:34	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/09/13 15:34	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/09/13 15:34	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/09/13 15:34	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/09/13 15:34	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/09/13 15:34	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-4

Lab Sample ID: 500-60429-3

Date Collected: 08/02/13 08:20

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/09/13 15:34	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 15:34	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 15:34	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/09/13 15:34	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/09/13 15:34	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/09/13 15:34	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/09/13 15:34	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/09/13 15:34	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/09/13 15:34	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/09/13 15:34	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/09/13 15:34	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/09/13 15:34	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/09/13 15:34	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/09/13 15:34	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	92		75 - 125		08/09/13 15:34	1
Toluene-d8 (Surr)	100		75 - 120		08/09/13 15:34	1
4-Bromofluorobenzene (Surr)	95		75 - 120		08/09/13 15:34	1
Dibromofluoromethane	97		75 - 120		08/09/13 15:34	1

Method: 8260B - VOC - DL

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Trichloroethene	530		10	3.8	ug/L			08/08/13 16:06	20

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	90		75 - 125		08/08/13 16:06	20
Toluene-d8 (Surr)	103		75 - 120		08/08/13 16:06	20
4-Bromofluorobenzene (Surr)	94		75 - 120		08/08/13 16:06	20
Dibromofluoromethane	96		75 - 120		08/08/13 16:06	20

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-5
Date Collected: 08/01/13 09:10
Date Received: 08/03/13 09:15

Lab Sample ID: 500-60429-4
Matrix: Water

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/08/13 16:33	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			08/08/13 16:33	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/08/13 16:33	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/08/13 16:33	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/08/13 16:33	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/08/13 16:33	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/08/13 16:33	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/08/13 16:33	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/08/13 16:33	1
Acetone	<5.0		5.0	1.3	ug/L			08/08/13 16:33	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			08/08/13 16:33	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/08/13 16:33	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/08/13 16:33	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/08/13 16:33	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			08/08/13 16:33	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/08/13 16:33	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/08/13 16:33	1
Chloroform	<1.0		1.0	0.20	ug/L			08/08/13 16:33	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/08/13 16:33	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/08/13 16:33	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			08/08/13 16:33	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 16:33	1
Trichloroethene	110		0.50	0.19	ug/L			08/08/13 16:33	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/08/13 16:33	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/08/13 16:33	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/08/13 16:33	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/08/13 16:33	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/08/13 16:33	1
Toluene	<0.50		0.50	0.11	ug/L			08/08/13 16:33	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/08/13 16:33	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 16:33	1
Tetrachloroethene	3.1		1.0	0.17	ug/L			08/08/13 16:33	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/08/13 16:33	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/08/13 16:33	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/08/13 16:33	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/08/13 16:33	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/08/13 16:33	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/08/13 16:33	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/08/13 16:33	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/08/13 16:33	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/08/13 16:33	1
Styrene	<1.0		1.0	0.10	ug/L			08/08/13 16:33	1
Bromoform	<1.0		1.0	0.28	ug/L			08/08/13 16:33	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 16:33	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/08/13 16:33	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/08/13 16:33	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/08/13 16:33	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 16:33	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/08/13 16:33	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-5

Lab Sample ID: 500-60429-4

Date Collected: 08/01/13 09:10

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/08/13 16:33	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/08/13 16:33	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 16:33	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 16:33	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/08/13 16:33	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 16:33	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/08/13 16:33	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 16:33	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 16:33	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/08/13 16:33	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/08/13 16:33	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/08/13 16:33	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/08/13 16:33	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/08/13 16:33	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/08/13 16:33	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	94		75 - 125		08/08/13 16:33	1
Toluene-d8 (Surr)	101		75 - 120		08/08/13 16:33	1
4-Bromofluorobenzene (Surr)	96		75 - 120		08/08/13 16:33	1
Dibromofluoromethane	95		75 - 120		08/08/13 16:33	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-6
Date Collected: 08/01/13 13:15
Date Received: 08/03/13 09:15

Lab Sample ID: 500-60429-5
Matrix: Water

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/08/13 17:00	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			08/08/13 17:00	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/08/13 17:00	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/08/13 17:00	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/08/13 17:00	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/08/13 17:00	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/08/13 17:00	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/08/13 17:00	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/08/13 17:00	1
Acetone	<5.0		5.0	1.3	ug/L			08/08/13 17:00	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			08/08/13 17:00	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/08/13 17:00	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/08/13 17:00	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/08/13 17:00	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			08/08/13 17:00	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/08/13 17:00	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/08/13 17:00	1
Chloroform	<1.0		1.0	0.20	ug/L			08/08/13 17:00	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/08/13 17:00	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/08/13 17:00	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			08/08/13 17:00	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 17:00	1
Trichloroethene	6.1		0.50	0.19	ug/L			08/08/13 17:00	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/08/13 17:00	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/08/13 17:00	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/08/13 17:00	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/08/13 17:00	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/08/13 17:00	1
Toluene	<0.50		0.50	0.11	ug/L			08/08/13 17:00	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/08/13 17:00	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 17:00	1
Tetrachloroethene	11		1.0	0.17	ug/L			08/08/13 17:00	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/08/13 17:00	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/08/13 17:00	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/08/13 17:00	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/08/13 17:00	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/08/13 17:00	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/08/13 17:00	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/08/13 17:00	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/08/13 17:00	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/08/13 17:00	1
Styrene	<1.0		1.0	0.10	ug/L			08/08/13 17:00	1
Bromoform	<1.0		1.0	0.28	ug/L			08/08/13 17:00	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 17:00	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/08/13 17:00	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/08/13 17:00	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/08/13 17:00	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 17:00	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/08/13 17:00	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-6

Lab Sample ID: 500-60429-5

Date Collected: 08/01/13 13:15

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/08/13 17:00	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/08/13 17:00	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 17:00	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 17:00	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/08/13 17:00	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 17:00	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/08/13 17:00	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 17:00	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 17:00	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/08/13 17:00	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/08/13 17:00	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/08/13 17:00	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/08/13 17:00	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/08/13 17:00	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/08/13 17:00	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	93		75 - 125					08/08/13 17:00	1
Toluene-d8 (Surr)	102		75 - 120					08/08/13 17:00	1
4-Bromofluorobenzene (Surr)	95		75 - 120					08/08/13 17:00	1
Dibromofluoromethane	97		75 - 120					08/08/13 17:00	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-7

Lab Sample ID: 500-60429-6

Date Collected: 08/01/13 13:25

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/08/13 17:27	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			08/08/13 17:27	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/08/13 17:27	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/08/13 17:27	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/08/13 17:27	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/08/13 17:27	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/08/13 17:27	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/08/13 17:27	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/08/13 17:27	1
Acetone	<5.0		5.0	1.3	ug/L			08/08/13 17:27	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			08/08/13 17:27	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/08/13 17:27	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/08/13 17:27	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/08/13 17:27	1
cis-1,2-Dichloroethene	4.1		1.0	0.12	ug/L			08/08/13 17:27	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/08/13 17:27	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/08/13 17:27	1
Chloroform	<1.0		1.0	0.20	ug/L			08/08/13 17:27	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/08/13 17:27	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/08/13 17:27	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			08/08/13 17:27	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 17:27	1
Trichloroethene	3.1		0.50	0.19	ug/L			08/08/13 17:27	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/08/13 17:27	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/08/13 17:27	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/08/13 17:27	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/08/13 17:27	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/08/13 17:27	1
Toluene	<0.50		0.50	0.11	ug/L			08/08/13 17:27	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/08/13 17:27	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 17:27	1
Tetrachloroethene	6.0		1.0	0.17	ug/L			08/08/13 17:27	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/08/13 17:27	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/08/13 17:27	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/08/13 17:27	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/08/13 17:27	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/08/13 17:27	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/08/13 17:27	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/08/13 17:27	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/08/13 17:27	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/08/13 17:27	1
Styrene	<1.0		1.0	0.10	ug/L			08/08/13 17:27	1
Bromoform	<1.0		1.0	0.28	ug/L			08/08/13 17:27	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 17:27	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/08/13 17:27	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/08/13 17:27	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/08/13 17:27	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 17:27	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/08/13 17:27	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-7

Lab Sample ID: 500-60429-6

Date Collected: 08/01/13 13:25

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/08/13 17:27	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/08/13 17:27	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 17:27	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 17:27	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/08/13 17:27	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 17:27	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/08/13 17:27	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 17:27	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 17:27	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/08/13 17:27	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/08/13 17:27	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/08/13 17:27	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/08/13 17:27	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/08/13 17:27	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/08/13 17:27	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	92		75 - 125		08/08/13 17:27	1
Toluene-d8 (Surr)	101		75 - 120		08/08/13 17:27	1
4-Bromofluorobenzene (Surr)	93		75 - 120		08/08/13 17:27	1
Dibromofluoromethane	95		75 - 120		08/08/13 17:27	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-8
Date Collected: 08/01/13 13:30
Date Received: 08/03/13 09:15

Lab Sample ID: 500-60429-7
Matrix: Water

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/08/13 17:54	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			08/08/13 17:54	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/08/13 17:54	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/08/13 17:54	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/08/13 17:54	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/08/13 17:54	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/08/13 17:54	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/08/13 17:54	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/08/13 17:54	1
Acetone	<5.0		5.0	1.3	ug/L			08/08/13 17:54	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			08/08/13 17:54	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/08/13 17:54	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/08/13 17:54	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/08/13 17:54	1
cis-1,2-Dichloroethene	30		1.0	0.12	ug/L			08/08/13 17:54	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/08/13 17:54	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/08/13 17:54	1
Chloroform	<1.0		1.0	0.20	ug/L			08/08/13 17:54	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/08/13 17:54	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/08/13 17:54	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			08/08/13 17:54	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 17:54	1
Trichloroethene	10		0.50	0.19	ug/L			08/08/13 17:54	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/08/13 17:54	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/08/13 17:54	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/08/13 17:54	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/08/13 17:54	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/08/13 17:54	1
Toluene	<0.50		0.50	0.11	ug/L			08/08/13 17:54	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/08/13 17:54	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 17:54	1
Tetrachloroethene	77		1.0	0.17	ug/L			08/08/13 17:54	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/08/13 17:54	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/08/13 17:54	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/08/13 17:54	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/08/13 17:54	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/08/13 17:54	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/08/13 17:54	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/08/13 17:54	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/08/13 17:54	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/08/13 17:54	1
Styrene	<1.0		1.0	0.10	ug/L			08/08/13 17:54	1
Bromoform	<1.0		1.0	0.28	ug/L			08/08/13 17:54	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 17:54	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/08/13 17:54	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/08/13 17:54	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/08/13 17:54	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 17:54	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/08/13 17:54	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-8

Lab Sample ID: 500-60429-7

Date Collected: 08/01/13 13:30

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/08/13 17:54	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/08/13 17:54	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 17:54	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 17:54	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/08/13 17:54	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 17:54	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/08/13 17:54	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 17:54	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 17:54	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/08/13 17:54	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/08/13 17:54	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/08/13 17:54	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/08/13 17:54	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/08/13 17:54	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/08/13 17:54	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	91		75 - 125		08/08/13 17:54	1
Toluene-d8 (Surr)	103		75 - 120		08/08/13 17:54	1
4-Bromofluorobenzene (Surr)	93		75 - 120		08/08/13 17:54	1
Dibromofluoromethane	97		75 - 120		08/08/13 17:54	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-9

Lab Sample ID: 500-60429-8

Date Collected: 08/01/13 13:45

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/08/13 18:21	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			08/08/13 18:21	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/08/13 18:21	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/08/13 18:21	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/08/13 18:21	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/08/13 18:21	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/08/13 18:21	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/08/13 18:21	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/08/13 18:21	1
Acetone	<5.0		5.0	1.3	ug/L			08/08/13 18:21	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			08/08/13 18:21	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/08/13 18:21	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/08/13 18:21	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/08/13 18:21	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			08/08/13 18:21	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/08/13 18:21	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/08/13 18:21	1
Chloroform	<1.0		1.0	0.20	ug/L			08/08/13 18:21	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/08/13 18:21	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/08/13 18:21	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			08/08/13 18:21	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 18:21	1
Trichloroethene	<0.50		0.50	0.19	ug/L			08/08/13 18:21	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/08/13 18:21	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/08/13 18:21	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/08/13 18:21	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/08/13 18:21	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/08/13 18:21	1
Toluene	<0.50		0.50	0.11	ug/L			08/08/13 18:21	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/08/13 18:21	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 18:21	1
Tetrachloroethene	110		1.0	0.17	ug/L			08/08/13 18:21	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/08/13 18:21	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/08/13 18:21	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/08/13 18:21	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/08/13 18:21	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/08/13 18:21	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/08/13 18:21	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/08/13 18:21	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/08/13 18:21	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/08/13 18:21	1
Styrene	<1.0		1.0	0.10	ug/L			08/08/13 18:21	1
Bromoform	<1.0		1.0	0.28	ug/L			08/08/13 18:21	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 18:21	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/08/13 18:21	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/08/13 18:21	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/08/13 18:21	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 18:21	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/08/13 18:21	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-9

Lab Sample ID: 500-60429-8

Date Collected: 08/01/13 13:45

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/08/13 18:21	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/08/13 18:21	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 18:21	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 18:21	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/08/13 18:21	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 18:21	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/08/13 18:21	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 18:21	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 18:21	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/08/13 18:21	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/08/13 18:21	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/08/13 18:21	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/08/13 18:21	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/08/13 18:21	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/08/13 18:21	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	93		75 - 125		08/08/13 18:21	1
Toluene-d8 (Surr)	102		75 - 120		08/08/13 18:21	1
4-Bromofluorobenzene (Surr)	98		75 - 120		08/08/13 18:21	1
Dibromofluoromethane	97		75 - 120		08/08/13 18:21	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-9 DUP

Lab Sample ID: 500-60429-9

Date Collected: 08/01/13 13:45

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/08/13 18:47	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			08/08/13 18:47	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/08/13 18:47	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/08/13 18:47	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/08/13 18:47	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/08/13 18:47	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/08/13 18:47	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/08/13 18:47	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/08/13 18:47	1
Acetone	<5.0		5.0	1.3	ug/L			08/08/13 18:47	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			08/08/13 18:47	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/08/13 18:47	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/08/13 18:47	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/08/13 18:47	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			08/08/13 18:47	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/08/13 18:47	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/08/13 18:47	1
Chloroform	<1.0		1.0	0.20	ug/L			08/08/13 18:47	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/08/13 18:47	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/08/13 18:47	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			08/08/13 18:47	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 18:47	1
Trichloroethene	0.71		0.50	0.19	ug/L			08/08/13 18:47	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/08/13 18:47	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/08/13 18:47	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/08/13 18:47	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/08/13 18:47	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/08/13 18:47	1
Toluene	<0.50		0.50	0.11	ug/L			08/08/13 18:47	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/08/13 18:47	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 18:47	1
Tetrachloroethene	100		1.0	0.17	ug/L			08/08/13 18:47	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/08/13 18:47	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/08/13 18:47	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/08/13 18:47	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/08/13 18:47	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/08/13 18:47	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/08/13 18:47	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/08/13 18:47	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/08/13 18:47	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/08/13 18:47	1
Styrene	<1.0		1.0	0.10	ug/L			08/08/13 18:47	1
Bromoform	<1.0		1.0	0.28	ug/L			08/08/13 18:47	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 18:47	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/08/13 18:47	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/08/13 18:47	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/08/13 18:47	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 18:47	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/08/13 18:47	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-9 DUP

Lab Sample ID: 500-60429-9

Date Collected: 08/01/13 13:45

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/08/13 18:47	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/08/13 18:47	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 18:47	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 18:47	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/08/13 18:47	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 18:47	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/08/13 18:47	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 18:47	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 18:47	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/08/13 18:47	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/08/13 18:47	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/08/13 18:47	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/08/13 18:47	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/08/13 18:47	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/08/13 18:47	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	95		75 - 125		08/08/13 18:47	1
Toluene-d8 (Surr)	102		75 - 120		08/08/13 18:47	1
4-Bromofluorobenzene (Surr)	97		75 - 120		08/08/13 18:47	1
Dibromofluoromethane	96		75 - 120		08/08/13 18:47	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-10
Date Collected: 08/01/13 13:55
Date Received: 08/03/13 09:15

Lab Sample ID: 500-60429-10
Matrix: Water

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/08/13 19:14	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			08/08/13 19:14	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/08/13 19:14	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/08/13 19:14	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/08/13 19:14	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/08/13 19:14	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/08/13 19:14	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/08/13 19:14	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/08/13 19:14	1
Acetone	<5.0		5.0	1.3	ug/L			08/08/13 19:14	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			08/08/13 19:14	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/08/13 19:14	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/08/13 19:14	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/08/13 19:14	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			08/08/13 19:14	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/08/13 19:14	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/08/13 19:14	1
Chloroform	<1.0		1.0	0.20	ug/L			08/08/13 19:14	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/08/13 19:14	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/08/13 19:14	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			08/08/13 19:14	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 19:14	1
Trichloroethene	<0.50		0.50	0.19	ug/L			08/08/13 19:14	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/08/13 19:14	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/08/13 19:14	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/08/13 19:14	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/08/13 19:14	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/08/13 19:14	1
Toluene	<0.50		0.50	0.11	ug/L			08/08/13 19:14	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/08/13 19:14	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 19:14	1
Tetrachloroethene	1.2		1.0	0.17	ug/L			08/08/13 19:14	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/08/13 19:14	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/08/13 19:14	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/08/13 19:14	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/08/13 19:14	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/08/13 19:14	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/08/13 19:14	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/08/13 19:14	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/08/13 19:14	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/08/13 19:14	1
Styrene	<1.0		1.0	0.10	ug/L			08/08/13 19:14	1
Bromoform	<1.0		1.0	0.28	ug/L			08/08/13 19:14	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 19:14	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/08/13 19:14	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/08/13 19:14	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/08/13 19:14	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 19:14	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/08/13 19:14	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: EW-10

Lab Sample ID: 500-60429-10

Date Collected: 08/01/13 13:55

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/08/13 19:14	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/08/13 19:14	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 19:14	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 19:14	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/08/13 19:14	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 19:14	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/08/13 19:14	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 19:14	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 19:14	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/08/13 19:14	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/08/13 19:14	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/08/13 19:14	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/08/13 19:14	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/08/13 19:14	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/08/13 19:14	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	94		75 - 125		08/08/13 19:14	1
Toluene-d8 (Surr)	101		75 - 120		08/08/13 19:14	1
4-Bromofluorobenzene (Surr)	94		75 - 120		08/08/13 19:14	1
Dibromofluoromethane	96		75 - 120		08/08/13 19:14	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-60429-11

Date Collected: 08/01/13 09:00

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/08/13 19:41	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			08/08/13 19:41	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/08/13 19:41	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/08/13 19:41	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/08/13 19:41	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/08/13 19:41	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/08/13 19:41	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/08/13 19:41	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/08/13 19:41	1
Acetone	<5.0		5.0	1.3	ug/L			08/08/13 19:41	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			08/08/13 19:41	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/08/13 19:41	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/08/13 19:41	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/08/13 19:41	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			08/08/13 19:41	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/08/13 19:41	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/08/13 19:41	1
Chloroform	<1.0		1.0	0.20	ug/L			08/08/13 19:41	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/08/13 19:41	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/08/13 19:41	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			08/08/13 19:41	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 19:41	1
Trichloroethene	<0.50		0.50	0.19	ug/L			08/08/13 19:41	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/08/13 19:41	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/08/13 19:41	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/08/13 19:41	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/08/13 19:41	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/08/13 19:41	1
Toluene	<0.50		0.50	0.11	ug/L			08/08/13 19:41	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/08/13 19:41	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 19:41	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			08/08/13 19:41	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/08/13 19:41	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/08/13 19:41	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/08/13 19:41	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/08/13 19:41	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/08/13 19:41	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/08/13 19:41	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/08/13 19:41	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/08/13 19:41	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/08/13 19:41	1
Styrene	<1.0		1.0	0.10	ug/L			08/08/13 19:41	1
Bromoform	<1.0		1.0	0.28	ug/L			08/08/13 19:41	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 19:41	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/08/13 19:41	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/08/13 19:41	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/08/13 19:41	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 19:41	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/08/13 19:41	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-60429-11

Date Collected: 08/01/13 09:00

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/08/13 19:41	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/08/13 19:41	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 19:41	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 19:41	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/08/13 19:41	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 19:41	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/08/13 19:41	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 19:41	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 19:41	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/08/13 19:41	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/08/13 19:41	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/08/13 19:41	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/08/13 19:41	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/08/13 19:41	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/08/13 19:41	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	93		75 - 125		08/08/13 19:41	1
Toluene-d8 (Surr)	103		75 - 120		08/08/13 19:41	1
4-Bromofluorobenzene (Surr)	95		75 - 120		08/08/13 19:41	1
Dibromofluoromethane	98		75 - 120		08/08/13 19:41	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-60429-12

Date Collected: 08/01/13 16:30

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/08/13 20:08	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			08/08/13 20:08	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/08/13 20:08	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/08/13 20:08	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/08/13 20:08	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/08/13 20:08	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/08/13 20:08	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/08/13 20:08	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/08/13 20:08	1
Acetone	<5.0		5.0	1.3	ug/L			08/08/13 20:08	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			08/08/13 20:08	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/08/13 20:08	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/08/13 20:08	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/08/13 20:08	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			08/08/13 20:08	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/08/13 20:08	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/08/13 20:08	1
Chloroform	<1.0		1.0	0.20	ug/L			08/08/13 20:08	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/08/13 20:08	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/08/13 20:08	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			08/08/13 20:08	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 20:08	1
Trichloroethene	<0.50		0.50	0.19	ug/L			08/08/13 20:08	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/08/13 20:08	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/08/13 20:08	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/08/13 20:08	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/08/13 20:08	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/08/13 20:08	1
Toluene	<0.50		0.50	0.11	ug/L			08/08/13 20:08	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/08/13 20:08	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 20:08	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			08/08/13 20:08	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/08/13 20:08	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/08/13 20:08	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/08/13 20:08	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/08/13 20:08	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/08/13 20:08	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/08/13 20:08	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/08/13 20:08	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/08/13 20:08	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/08/13 20:08	1
Styrene	<1.0		1.0	0.10	ug/L			08/08/13 20:08	1
Bromoform	<1.0		1.0	0.28	ug/L			08/08/13 20:08	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 20:08	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/08/13 20:08	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/08/13 20:08	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/08/13 20:08	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 20:08	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/08/13 20:08	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-60429-12

Date Collected: 08/01/13 16:30

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/08/13 20:08	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/08/13 20:08	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 20:08	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 20:08	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/08/13 20:08	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 20:08	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/08/13 20:08	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 20:08	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 20:08	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/08/13 20:08	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/08/13 20:08	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/08/13 20:08	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/08/13 20:08	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/08/13 20:08	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/08/13 20:08	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	94		75 - 125		08/08/13 20:08	1
Toluene-d8 (Surr)	103		75 - 120		08/08/13 20:08	1
4-Bromofluorobenzene (Surr)	98		75 - 120		08/08/13 20:08	1
Dibromofluoromethane	97		75 - 120		08/08/13 20:08	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-60429-13

Date Collected: 08/01/13 07:50

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/08/13 20:35	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			08/08/13 20:35	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/08/13 20:35	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/08/13 20:35	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/08/13 20:35	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/08/13 20:35	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/08/13 20:35	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/08/13 20:35	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/08/13 20:35	1
Acetone	<5.0		5.0	1.3	ug/L			08/08/13 20:35	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			08/08/13 20:35	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/08/13 20:35	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/08/13 20:35	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/08/13 20:35	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			08/08/13 20:35	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/08/13 20:35	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/08/13 20:35	1
Chloroform	<1.0		1.0	0.20	ug/L			08/08/13 20:35	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/08/13 20:35	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/08/13 20:35	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			08/08/13 20:35	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 20:35	1
Trichloroethene	0.59		0.50	0.19	ug/L			08/08/13 20:35	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/08/13 20:35	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/08/13 20:35	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/08/13 20:35	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/08/13 20:35	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/08/13 20:35	1
Toluene	<0.50		0.50	0.11	ug/L			08/08/13 20:35	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/08/13 20:35	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 20:35	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			08/08/13 20:35	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/08/13 20:35	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/08/13 20:35	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/08/13 20:35	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/08/13 20:35	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/08/13 20:35	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/08/13 20:35	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/08/13 20:35	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/08/13 20:35	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/08/13 20:35	1
Styrene	<1.0		1.0	0.10	ug/L			08/08/13 20:35	1
Bromoform	<1.0		1.0	0.28	ug/L			08/08/13 20:35	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 20:35	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/08/13 20:35	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/08/13 20:35	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/08/13 20:35	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 20:35	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/08/13 20:35	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-60429-13

Date Collected: 08/01/13 07:50

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/08/13 20:35	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/08/13 20:35	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 20:35	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 20:35	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/08/13 20:35	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 20:35	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/08/13 20:35	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 20:35	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 20:35	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/08/13 20:35	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/08/13 20:35	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/08/13 20:35	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/08/13 20:35	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/08/13 20:35	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/08/13 20:35	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	95		75 - 125		08/08/13 20:35	1
Toluene-d8 (Surr)	101		75 - 120		08/08/13 20:35	1
4-Bromofluorobenzene (Surr)	94		75 - 120		08/08/13 20:35	1
Dibromofluoromethane	98		75 - 120		08/08/13 20:35	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-60429-14

Date Collected: 08/01/13 08:00

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/08/13 21:02	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			08/08/13 21:02	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/08/13 21:02	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/08/13 21:02	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/08/13 21:02	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/08/13 21:02	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/08/13 21:02	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/08/13 21:02	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/08/13 21:02	1
Acetone	<5.0		5.0	1.3	ug/L			08/08/13 21:02	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			08/08/13 21:02	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/08/13 21:02	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/08/13 21:02	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/08/13 21:02	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			08/08/13 21:02	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/08/13 21:02	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/08/13 21:02	1
Chloroform	<1.0		1.0	0.20	ug/L			08/08/13 21:02	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/08/13 21:02	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/08/13 21:02	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			08/08/13 21:02	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 21:02	1
Trichloroethene	0.40	J	0.50	0.19	ug/L			08/08/13 21:02	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/08/13 21:02	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/08/13 21:02	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/08/13 21:02	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/08/13 21:02	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/08/13 21:02	1
Toluene	<0.50		0.50	0.11	ug/L			08/08/13 21:02	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/08/13 21:02	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/08/13 21:02	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			08/08/13 21:02	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/08/13 21:02	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/08/13 21:02	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/08/13 21:02	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/08/13 21:02	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/08/13 21:02	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/08/13 21:02	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/08/13 21:02	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/08/13 21:02	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/08/13 21:02	1
Styrene	<1.0		1.0	0.10	ug/L			08/08/13 21:02	1
Bromoform	<1.0		1.0	0.28	ug/L			08/08/13 21:02	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 21:02	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/08/13 21:02	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/08/13 21:02	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/08/13 21:02	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 21:02	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/08/13 21:02	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-60429-14

Date Collected: 08/01/13 08:00

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/08/13 21:02	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/08/13 21:02	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 21:02	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/08/13 21:02	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/08/13 21:02	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 21:02	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/08/13 21:02	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/08/13 21:02	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/08/13 21:02	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/08/13 21:02	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/08/13 21:02	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/08/13 21:02	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/08/13 21:02	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/08/13 21:02	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/08/13 21:02	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	96		75 - 125		08/08/13 21:02	1
Toluene-d8 (Surr)	103		75 - 120		08/08/13 21:02	1
4-Bromofluorobenzene (Surr)	96		75 - 120		08/08/13 21:02	1
Dibromofluoromethane	99		75 - 120		08/08/13 21:02	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-60429-15

Date Collected: 08/01/13 15:10

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/09/13 16:01	1
Dichlorodifluoromethane	<1.0	*	1.0	0.20	ug/L			08/09/13 16:01	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/09/13 16:01	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/09/13 16:01	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/09/13 16:01	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/09/13 16:01	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/09/13 16:01	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/09/13 16:01	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/09/13 16:01	1
Acetone	<5.0		5.0	1.3	ug/L			08/09/13 16:01	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			08/09/13 16:01	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/09/13 16:01	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/09/13 16:01	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/09/13 16:01	1
cis-1,2-Dichloroethene	1.6		1.0	0.12	ug/L			08/09/13 16:01	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/09/13 16:01	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/09/13 16:01	1
Chloroform	<1.0		1.0	0.20	ug/L			08/09/13 16:01	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/09/13 16:01	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/09/13 16:01	1
Carbon tetrachloride	<1.0	*	1.0	0.26	ug/L			08/09/13 16:01	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/09/13 16:01	1
Trichloroethene	<0.50		0.50	0.19	ug/L			08/09/13 16:01	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/09/13 16:01	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/09/13 16:01	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/09/13 16:01	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/09/13 16:01	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/09/13 16:01	1
Toluene	<0.50		0.50	0.11	ug/L			08/09/13 16:01	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/09/13 16:01	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/09/13 16:01	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			08/09/13 16:01	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/09/13 16:01	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/09/13 16:01	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/09/13 16:01	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/09/13 16:01	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/09/13 16:01	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/09/13 16:01	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/09/13 16:01	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/09/13 16:01	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/09/13 16:01	1
Styrene	<1.0		1.0	0.10	ug/L			08/09/13 16:01	1
Bromoform	<1.0		1.0	0.28	ug/L			08/09/13 16:01	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 16:01	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/09/13 16:01	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/09/13 16:01	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/09/13 16:01	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/09/13 16:01	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/09/13 16:01	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-60429-15

Date Collected: 08/01/13 15:10

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/09/13 16:01	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/09/13 16:01	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 16:01	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 16:01	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/09/13 16:01	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/09/13 16:01	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/09/13 16:01	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/09/13 16:01	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/09/13 16:01	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/09/13 16:01	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/09/13 16:01	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/09/13 16:01	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/09/13 16:01	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/09/13 16:01	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/09/13 16:01	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	94		75 - 125		08/09/13 16:01	1
Toluene-d8 (Surr)	103		75 - 120		08/09/13 16:01	1
4-Bromofluorobenzene (Surr)	96		75 - 120		08/09/13 16:01	1
Dibromofluoromethane	98		75 - 120		08/09/13 16:01	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-4A

Lab Sample ID: 500-60429-16

Date Collected: 08/02/13 09:20

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/09/13 16:28	1
Dichlorodifluoromethane	<1.0	*	1.0	0.20	ug/L			08/09/13 16:28	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/09/13 16:28	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/09/13 16:28	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/09/13 16:28	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/09/13 16:28	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/09/13 16:28	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/09/13 16:28	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/09/13 16:28	1
Acetone	<5.0		5.0	1.3	ug/L			08/09/13 16:28	1
Methylene Chloride	5.1		5.0	0.68	ug/L			08/09/13 16:28	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/09/13 16:28	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/09/13 16:28	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/09/13 16:28	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			08/09/13 16:28	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/09/13 16:28	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/09/13 16:28	1
Chloroform	<1.0		1.0	0.20	ug/L			08/09/13 16:28	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/09/13 16:28	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/09/13 16:28	1
Carbon tetrachloride	<1.0	*	1.0	0.26	ug/L			08/09/13 16:28	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/09/13 16:28	1
Trichloroethene	28		0.50	0.19	ug/L			08/09/13 16:28	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/09/13 16:28	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/09/13 16:28	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/09/13 16:28	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/09/13 16:28	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/09/13 16:28	1
Toluene	<0.50		0.50	0.11	ug/L			08/09/13 16:28	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/09/13 16:28	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/09/13 16:28	1
Tetrachloroethene	19		1.0	0.17	ug/L			08/09/13 16:28	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/09/13 16:28	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/09/13 16:28	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/09/13 16:28	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/09/13 16:28	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/09/13 16:28	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/09/13 16:28	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/09/13 16:28	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/09/13 16:28	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/09/13 16:28	1
Styrene	<1.0		1.0	0.10	ug/L			08/09/13 16:28	1
Bromoform	<1.0		1.0	0.28	ug/L			08/09/13 16:28	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 16:28	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/09/13 16:28	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/09/13 16:28	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/09/13 16:28	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/09/13 16:28	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/09/13 16:28	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-4A

Lab Sample ID: 500-60429-16

Date Collected: 08/02/13 09:20

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/09/13 16:28	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/09/13 16:28	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 16:28	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 16:28	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/09/13 16:28	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/09/13 16:28	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/09/13 16:28	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/09/13 16:28	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/09/13 16:28	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/09/13 16:28	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/09/13 16:28	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/09/13 16:28	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/09/13 16:28	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/09/13 16:28	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/09/13 16:28	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	93		75 - 125		08/09/13 16:28	1
Toluene-d8 (Surr)	102		75 - 120		08/09/13 16:28	1
4-Bromofluorobenzene (Surr)	96		75 - 120		08/09/13 16:28	1
Dibromofluoromethane	97		75 - 120		08/09/13 16:28	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-4A DUP

Lab Sample ID: 500-60429-17

Date Collected: 08/02/13 09:20

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/09/13 16:54	1
Dichlorodifluoromethane	<1.0	*	1.0	0.20	ug/L			08/09/13 16:54	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/09/13 16:54	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/09/13 16:54	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/09/13 16:54	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/09/13 16:54	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/09/13 16:54	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/09/13 16:54	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/09/13 16:54	1
Acetone	<5.0		5.0	1.3	ug/L			08/09/13 16:54	1
Methylene Chloride	5.3		5.0	0.68	ug/L			08/09/13 16:54	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/09/13 16:54	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/09/13 16:54	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/09/13 16:54	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			08/09/13 16:54	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/09/13 16:54	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/09/13 16:54	1
Chloroform	<1.0		1.0	0.20	ug/L			08/09/13 16:54	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/09/13 16:54	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/09/13 16:54	1
Carbon tetrachloride	<1.0	*	1.0	0.26	ug/L			08/09/13 16:54	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/09/13 16:54	1
Trichloroethene	28		0.50	0.19	ug/L			08/09/13 16:54	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/09/13 16:54	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/09/13 16:54	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/09/13 16:54	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/09/13 16:54	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/09/13 16:54	1
Toluene	<0.50		0.50	0.11	ug/L			08/09/13 16:54	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/09/13 16:54	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/09/13 16:54	1
Tetrachloroethene	17		1.0	0.17	ug/L			08/09/13 16:54	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/09/13 16:54	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/09/13 16:54	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/09/13 16:54	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/09/13 16:54	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/09/13 16:54	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/09/13 16:54	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/09/13 16:54	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/09/13 16:54	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/09/13 16:54	1
Styrene	<1.0		1.0	0.10	ug/L			08/09/13 16:54	1
Bromoform	<1.0		1.0	0.28	ug/L			08/09/13 16:54	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 16:54	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/09/13 16:54	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/09/13 16:54	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/09/13 16:54	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/09/13 16:54	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/09/13 16:54	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-4A DUP

Lab Sample ID: 500-60429-17

Date Collected: 08/02/13 09:20

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/09/13 16:54	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/09/13 16:54	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 16:54	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 16:54	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/09/13 16:54	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/09/13 16:54	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/09/13 16:54	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/09/13 16:54	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/09/13 16:54	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/09/13 16:54	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/09/13 16:54	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/09/13 16:54	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/09/13 16:54	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/09/13 16:54	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/09/13 16:54	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	95		75 - 125		08/09/13 16:54	1
Toluene-d8 (Surr)	100		75 - 120		08/09/13 16:54	1
4-Bromofluorobenzene (Surr)	96		75 - 120		08/09/13 16:54	1
Dibromofluoromethane	97		75 - 120		08/09/13 16:54	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-4B

Lab Sample ID: 500-60429-18

Date Collected: 08/02/13 10:10

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/09/13 17:21	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			08/09/13 17:21	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/09/13 17:21	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/09/13 17:21	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/09/13 17:21	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/09/13 17:21	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/09/13 17:21	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/09/13 17:21	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/09/13 17:21	1
Acetone	<5.0		5.0	1.3	ug/L			08/09/13 17:21	1
Methylene Chloride	6.3		5.0	0.68	ug/L			08/09/13 17:21	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/09/13 17:21	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/09/13 17:21	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/09/13 17:21	1
cis-1,2-Dichloroethene	1.4		1.0	0.12	ug/L			08/09/13 17:21	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/09/13 17:21	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/09/13 17:21	1
Chloroform	<1.0		1.0	0.20	ug/L			08/09/13 17:21	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/09/13 17:21	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/09/13 17:21	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			08/09/13 17:21	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/09/13 17:21	1
Trichloroethene	0.70		0.50	0.19	ug/L			08/09/13 17:21	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/09/13 17:21	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/09/13 17:21	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/09/13 17:21	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/09/13 17:21	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/09/13 17:21	1
Toluene	<0.50		0.50	0.11	ug/L			08/09/13 17:21	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/09/13 17:21	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/09/13 17:21	1
Tetrachloroethene	2.9		1.0	0.17	ug/L			08/09/13 17:21	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/09/13 17:21	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/09/13 17:21	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/09/13 17:21	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/09/13 17:21	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/09/13 17:21	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/09/13 17:21	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/09/13 17:21	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/09/13 17:21	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/09/13 17:21	1
Styrene	<1.0		1.0	0.10	ug/L			08/09/13 17:21	1
Bromoform	<1.0		1.0	0.28	ug/L			08/09/13 17:21	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 17:21	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/09/13 17:21	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/09/13 17:21	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/09/13 17:21	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/09/13 17:21	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/09/13 17:21	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-4B

Lab Sample ID: 500-60429-18

Date Collected: 08/02/13 10:10

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/09/13 17:21	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/09/13 17:21	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 17:21	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 17:21	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/09/13 17:21	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/09/13 17:21	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/09/13 17:21	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/09/13 17:21	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/09/13 17:21	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/09/13 17:21	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/09/13 17:21	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/09/13 17:21	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/09/13 17:21	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/09/13 17:21	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/09/13 17:21	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	94		75 - 125		08/09/13 17:21	1
Toluene-d8 (Surr)	102		75 - 120		08/09/13 17:21	1
4-Bromofluorobenzene (Surr)	95		75 - 120		08/09/13 17:21	1
Dibromofluoromethane	100		75 - 120		08/09/13 17:21	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-6

Lab Sample ID: 500-60429-19

Date Collected: 08/01/13 16:35

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/09/13 17:47	1
Dichlorodifluoromethane	<1.0	*	1.0	0.20	ug/L			08/09/13 17:47	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/09/13 17:47	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/09/13 17:47	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/09/13 17:47	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/09/13 17:47	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/09/13 17:47	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/09/13 17:47	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/09/13 17:47	1
Acetone	<5.0		5.0	1.3	ug/L			08/09/13 17:47	1
Methylene Chloride	6.3		5.0	0.68	ug/L			08/09/13 17:47	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/09/13 17:47	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/09/13 17:47	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/09/13 17:47	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			08/09/13 17:47	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/09/13 17:47	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/09/13 17:47	1
Chloroform	<1.0		1.0	0.20	ug/L			08/09/13 17:47	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/09/13 17:47	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/09/13 17:47	1
Carbon tetrachloride	<1.0	*	1.0	0.26	ug/L			08/09/13 17:47	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/09/13 17:47	1
Trichloroethene	0.83		0.50	0.19	ug/L			08/09/13 17:47	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/09/13 17:47	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/09/13 17:47	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/09/13 17:47	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/09/13 17:47	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/09/13 17:47	1
Toluene	<0.50		0.50	0.11	ug/L			08/09/13 17:47	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/09/13 17:47	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/09/13 17:47	1
Tetrachloroethene	1.1		1.0	0.17	ug/L			08/09/13 17:47	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/09/13 17:47	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/09/13 17:47	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/09/13 17:47	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/09/13 17:47	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/09/13 17:47	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/09/13 17:47	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/09/13 17:47	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/09/13 17:47	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/09/13 17:47	1
Styrene	<1.0		1.0	0.10	ug/L			08/09/13 17:47	1
Bromoform	<1.0		1.0	0.28	ug/L			08/09/13 17:47	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 17:47	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/09/13 17:47	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/09/13 17:47	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/09/13 17:47	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/09/13 17:47	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/09/13 17:47	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-6

Lab Sample ID: 500-60429-19

Date Collected: 08/01/13 16:35

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			08/09/13 17:47	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			08/09/13 17:47	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 17:47	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 17:47	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			08/09/13 17:47	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/09/13 17:47	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			08/09/13 17:47	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			08/09/13 17:47	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			08/09/13 17:47	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			08/09/13 17:47	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			08/09/13 17:47	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			08/09/13 17:47	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			08/09/13 17:47	1
Naphthalene	<1.0		1.0	0.16	ug/L			08/09/13 17:47	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			08/09/13 17:47	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	94		75 - 125		08/09/13 17:47	1
Toluene-d8 (Surr)	101		75 - 120		08/09/13 17:47	1
4-Bromofluorobenzene (Surr)	95		75 - 120		08/09/13 17:47	1
Dibromofluoromethane	96		75 - 120		08/09/13 17:47	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-60429-1

Client Sample ID: RFW-7

Lab Sample ID: 500-60429-20

Date Collected: 08/01/13 12:55

Matrix: Water

Date Received: 08/03/13 09:15

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			08/09/13 18:14	1
Dichlorodifluoromethane	<1.0	*	1.0	0.20	ug/L			08/09/13 18:14	1
Chloromethane	<1.0		1.0	0.18	ug/L			08/09/13 18:14	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			08/09/13 18:14	1
Bromomethane	<1.0		1.0	0.31	ug/L			08/09/13 18:14	1
Chloroethane	<1.0		1.0	0.34	ug/L			08/09/13 18:14	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			08/09/13 18:14	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			08/09/13 18:14	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			08/09/13 18:14	1
Acetone	<5.0		5.0	1.3	ug/L			08/09/13 18:14	1
Methylene Chloride	7.0		5.0	0.68	ug/L			08/09/13 18:14	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			08/09/13 18:14	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			08/09/13 18:14	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			08/09/13 18:14	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			08/09/13 18:14	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			08/09/13 18:14	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			08/09/13 18:14	1
Chloroform	<1.0		1.0	0.20	ug/L			08/09/13 18:14	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			08/09/13 18:14	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			08/09/13 18:14	1
Carbon tetrachloride	<1.0	*	1.0	0.26	ug/L			08/09/13 18:14	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			08/09/13 18:14	1
Trichloroethene	0.90		0.50	0.19	ug/L			08/09/13 18:14	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			08/09/13 18:14	1
Dibromomethane	<1.0		1.0	0.33	ug/L			08/09/13 18:14	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			08/09/13 18:14	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			08/09/13 18:14	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			08/09/13 18:14	1
Toluene	<0.50		0.50	0.11	ug/L			08/09/13 18:14	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			08/09/13 18:14	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			08/09/13 18:14	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			08/09/13 18:14	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			08/09/13 18:14	1
2-Hexanone	<5.0		5.0	0.56	ug/L			08/09/13 18:14	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			08/09/13 18:14	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			08/09/13 18:14	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			08/09/13 18:14	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			08/09/13 18:14	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			08/09/13 18:14	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			08/09/13 18:14	1
o-Xylene	<0.50		0.50	0.068	ug/L			08/09/13 18:14	1
Styrene	<1.0		1.0	0.10	ug/L			08/09/13 18:14	1
Bromoform	<1.0		1.0	0.28	ug/L			08/09/13 18:14	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			08/09/13 18:14	1
Bromobenzene	<1.0		1.0	0.25	ug/L			08/09/13 18:14	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			08/09/13 18:14	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			08/09/13 18:14	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			08/09/13 18:14	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			08/09/13 18:14	1

TestAmerica Chicago