

**Quarterly Groundwater Monitoring Report**

Prepared for

**Black & Decker (U.S.) Inc.**

Hampstead, Maryland

October 2014

Prepared by

**WESTON SOLUTIONS, INC.**

West Chester, Pennsylvania 19380-1499

---

## TABLE OF CONTENTS

---

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES .....	2-1
2.2 EFFLUENT CHARACTERISTICS .....	2-1
2.3 GROUNDWATER QUALITY DATA .....	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

---

## LIST OF APPENDICES

---

**APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS**

**APPENDIX B - DISCHARGE MONITORING REPORTS**

**APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS**

**APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE**

---

## LIST OF TABLES

---

<b>Table</b>	<b>Page</b>
Table 2-1 Treatment System Pumping Records – 3rd Quarter 2014 .....	2-2
Table 2-2 Groundwater Elevation Data – 3rd Quarter 2014.....	2-3
Table 2-3 Effluent Characteristics Summary – 3rd Quarter 2014.....	2-4
Table 2-4 Summary of Groundwater Analytical Results - August 2014.....	2-5
Table 3-1 Treatment System Maintenance Activities – 3rd Quarter 2014.....	3-2

## 1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

## **2. SITE CHARACTERISTICS**

### **2.1 HYDRAULIC PROPERTIES**

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of July through September 2014.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of July through September 2014, the extraction wells were pumping at an average combined rate of approximately 185 gallons per minute (gpm).

### **2.2 EFFLUENT CHARACTERISTICS**

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of July through September 2014 are included in Appendix B.

### **2.3 GROUNDWATER QUALITY DATA**

For the reporting period of July through September 2014, approximately 12.26 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (76.2 %) and tetrachloroethene (PCE) (23.8 %). Analytical results of the groundwater collected from the air stripper for the period of July through September 2014 are included in Appendix C.

A summary of the analytical results from the third quarter (August 2014) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

**Table 2-1**  
**Treatment System Pumping Records - 3rd Quarter 2014**  
**Black & Decker**  
**Hampstead, Maryland**

<b>Date</b>	<b>Water Pumped (gallons)</b>
<b>July 2014</b>	8,365,626
<b>August 2014</b>	7,970,793
<b>September 2014</b>	7,680,935

**Table 2-2**  
**Groundwater Elevation Data - 3rd Quarter 2014**  
**Black & Decker**  
**Hampstead, Maryland**

WELL NO.	TOC ELEV.	TOTAL DEPTH	7/15/2014		8/27/2014		9/25/2014	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NC	DRY	NC	DRY	NC
EW-2	849.21	110	72.74	776.47	78.84	770.37	78.10	771.11
EW-3	846.64	118	89.19	757.45	86.49	760.15	85.94	760.70
EW-4	858.01	97.5	PC	NC	PC	NC	PC	NC
EW-5	864.17	98	89.75	774.42	89.91	774.26	89.74	774.43
EW-6	831.98	115	74.30	757.68	77.91	754.07	78.11	753.87
EW-7	818.38	78	59.44	758.94	55.36	763.02	57.23	761.15
EW-8	811.13	98	93.00	718.13	91.43	719.70	91.30	719.83
EW-9	811.35	141	96.30	715.05	95.87	715.48	95.81	715.54
EW-10	807.74	INA	53.22	754.52	48.97	758.77	49.73	758.01
RFW-1A	864.37	78	48.02	816.35	47.92	816.45	48.11	816.26
RFW-1B	864.23	200	48.05	816.18	47.99	816.24	48.18	816.05
RFW-2A	857.41	35	11.31	846.10	14.51	842.90	14.53	842.88
RFW-2B	857.73	75	11.82	845.91	15.16	842.57	15.21	842.52
RFW-3B	839.21	153	27.01	812.20	30.33	808.88	30.30	808.91
RFW-4A	830.37	62	32.91	797.46	35.78	794.59	35.84	794.53
RFW-4B	830.37	120	32.63	797.74	35.69	794.68	35.77	794.60
RFW-5A	817.50	30	DRY	NC	DRY	NC	DRY	NC
RFW-6	785.04	120	4.02	781.02	2.95	782.09	4.10	780.94
RFW-7	805.14	29	7.65	797.49	5.81	799.33	7.03	798.11
RFW-8	860.07	56	DRY	NC	DRY	NC	DRY	NC
RFW-9	862.02	49	23.83	838.19	25.55	836.47	26.03	835.99
RFW-10	852.06	58	DRY	NC	DRY	NC	DRY	NC
RFW-11A	849.32	72	Damaged	NC	Damaged	NC	Damaged	NC
RFW-11B	849.62	116	58.13	791.49	59.44	790.18	58.73	790.89
RFW-12B	844.87	264	49.28	795.59	48.23	796.64	48.94	795.93
RFW-13	849.11	150	60.51	788.60	57.29	791.82	59.04	790.07
RFW-14B	812.39	281	53.47	758.92	53.79	758.60	54.80	757.59
RFW-16	856.14	41	DRY	NC	DRY	NC	DRY	NC
RFW-17	834.66	60.5	23.52	811.14	24.36	810.30	34.41	800.25
RFW-20	842.49	142	30.31	812.18	32.16	810.33	32.21	810.28
RFW-21	832.65	102	19.29	813.36	20.18	812.47	20.19	812.46
PH-7	805.94	89	26.04	779.90	27.43	778.51	27.81	778.13
PH-9	814.94	98	50.39	764.55	43.28	771.66	44.24	770.70
PH-11	820.68	78	47.17	773.51	48.11	772.57	48.23	772.45
PH-12	828.35	87	48.13	780.22	49.06	779.29	49.01	779.34
B-3	803.02	83	10.84	792.18	9.88	793.14	10.37	792.65
Amoco	842.29	INA	NA	NC	NA	NC	NA	NC
Hamp. Town #22	804.96	INA	1.29	803.67	1.03	803.93	1.43	803.53
Pembroke #1	INA	INA	10.45	NC	10.58	NC	10.73	NC
Pembroke #2	INA	INA	Damaged	NC	Damaged	NC	Damaged	NC
N. Houcks. Rd.	INA	INA	9.96	NC	10.39	NC	10.51	NC
E. Century St.	INA	INA	19.29	NC	19.21	NC	19.27	NC
Lwr. Beckleys. Rd.	INA	INA	53.56	NC	54.55	NC	54.21	NC

NA - Not Available/Not Accessible  
NC - Not Calculable  
INA - Information not available  
PC - Pump Cycles

**Table 2-3  
Effluent Characteristics Summary - 3rd Quarter 2014  
Black & Decker  
Hampstead, Maryland**

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				July 2014	August 2014	September 2014	
001	FLOW	average	MGD	NA	0.311	0.231	0.155
		maximum	MGD	NA	0.777	0.819	0.419
	1,1,1-Trichloroethane	ug/l	5	< 1	< 1	< 1	
	Tetrachloroethylene	ug/l	5	< 1	< 1	< 1	
	Trichloroethylene	ug/l	5	< 1	< 1	< 1	
	Total Residual Chlorine	mg/l	< 0.1	< 0.1	< 0.1	< 0.1	
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		monthly average	mg/l	10	< 5	< 5	< 5
	pH	minimum	STD	6.0	7.2	7.1	7.4
		maximum	STD	8.5	8.4	8.2	8.3
BOD		mg/l	15	5.0	7.0	5.0	
TSS	maximum	mg/l	30	0	0	0	
	monthly average	mg/l	20	0	0	0	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.180	0.149	0.145
		maximum	MGD	NA	0.210	0.190	0.163
	Fecal Coliform	MPN/100ml	200	10.0	1.0	1.0	
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.261
		maximum	MGD	NA	NR	NR	0.314
	1,1,1-Trichloroethane	ug/l	NA	NR	NR	< 1	
	Tetrachloroethylene	ug/l	NA	NR	NR	< 1	
	Trichloroethylene	ug/l	NA	NR	NR	< 1	

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported



Table 2-4

**Summary of Groundwater Analytical Results - August 2014**  
**Black & Decker**  
**Hampstead, Maryland**

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	0.8 J	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3	1.8	1 U	1 U	1 U	2.9	23	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	130	34	540	100	4.6	2	6.8	0.4 J	0.5 J	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	51	1.4	11	3.6	10	5.1	73	98	99	2
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

NS = Not Sampled

**Table 2-4**  
**Summary of Groundwater Analytical Results - August 2014**  
**Black & Decker**  
**Hampstead, Maryland**

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1.6	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	2 U	2 U	2 U	2 U	2 U	1 U	1 U	1 U	NS	1 U	7	NS	1 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	0.6 J	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	0.7 J	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	1.2	0.9 J	0.9 J	3	NS	1 U	1 U	NS	15	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	0.6 J	0.5 J	1.2	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	0.6 J	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	0.3 J	0.3 J	1 U	34	33	48	NS	0.5 J	2.1	NS	7.5	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	0.2 J	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	0.7 J	28	28	84	NS	0.7 J	1 U	NS	4.2	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicate sample  
NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.  
J = Indicates an estimated value.

Table 2-4

**Summary of Groundwater Analytical Results - August 2014**  
**Black & Decker**  
**Hampstead, Maryland**

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	USEPA drinking water method 524.2				
												RFW-20	RFW-21	Town #22	Town #23	Trip Blank
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	1 U	2 U	2 U	NS	2 U	ABD	ABD	ABD	2 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	NA	NA	NA	NA	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	1.6	0.7 J	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.4 J	0.5 U	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trichloroethene	ug/L	NS	1.8	60	2.5	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	0.6	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	1 U	4.5	15	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division.

Samples from all of the other wells are analyzed with USEPA Method 8260.

NS = Not sampled

U = Compound was analyzed but not detected.

ABD = Well has been abandoned

RFW -20 was not sampled because it was damaged. The well is now repaired and will be sampled during the 4th quarter.

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells EW-2 and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from wells RFW-4B & EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

### 3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (July through September 2014) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

**Table 3-1**  
**Treatment System Maintenance Activities - 3rd Quarter 2014**  
**Black & Decker**  
**Hampstead, Maryland**

<b>Date</b>	<b>Event/Corrective Action</b>
Aug-14	EW -10 is off due to bad underground control wires. EW-10 was repaired and back in service.
Aug-14	Scheduled power outage for work in the yard substation. Power was off for 9:30 hours. Everything restarted and running.

#### 4. RECOMMENDATIONS

For the reporting period of July through September 2014, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

---

**APPENDIX A**  
**GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS**  
**(JULY – SEPTEMBER 2014)**

---



ENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:  
Maryland Environmental Service  
259 Najoles Road, Millersville MD

Facility: BTR Capital Group  
Address: 627 Hanover Pike, Hampstead Maryland  
Additional Op's & cert # - Dorrance Jones 0763, James Elliott 3738, Anthony Phillips 3001

Permit Number: 07-DP-0022  
Superintendent: Earle Villarreal Certification # 1017

Month: July  
Year: 2014

Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Final Effluent outfall 001										Outfall 101					Outfall 201			Operator			
					Turbidity ug/l	SS ug/l	TSS mg/l	BOD <sub>5</sub> mg/l	TKN mg/l	N+N mg/l	TP mg/l	TN mg/l	O&G mg/l	eColi mpn	Flow MGD	eColi mpn	Basin inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Turbidity ug/l	SS ug/l		Discharge mgd		
1	Clear	0.17300													<1	0.163000	<1	1.0	1.0	1.0	5.0				0.278164	APhillips
2	Clear	0.21000	7.45	0.00												0.173000		3.0	1.0	1.0	5.0				0.270754	Djones
3	Clear	0.19300	8.16	0.00												0.181000		3.0	1.0	1.0	5.0				0.286041	Djones
4	Clear	0.65600														0.202000		0.0	1.0	1.0	5.0				0.186051	Djones
5	Clear	0.28200														0.177000		0.0	1.0	1.0	5.0				0.290171	APhillips
6	Clear	0.24800														0.175000		0.0	1.0	1.0	5.0				0.265684	APhillips
7	Clear	0.27300	7.47	0.00											0.165000		3.0	1.0	1.0	5.0				0.283729	Djones	
8	Clear	0.27400			<1	<1	<1	5.00	15.80	0.99	0.90	0.09	1.9	<5	30.6	0.186000	9.90	3.0	1.0	1.0	5.0				0.273107	Djones
9	Clear	0.36800	7.19	0.00											0.196000		1.0	1.0	1.0	5.0				0.283062	Djones	
10	Clear	0.44400													0.183000		1.0	1.0	1.0	5.0				0.261373	Djones	
11	Clear	0.62600													0.198000		0.0	1.0	1.0	5.0				0.274277	Djones	
12	Clear	0.23600													0.184000		0.0	1.0	1.0	5.0				0.263635	APhillips	
13	Clear	0.24400													0.180000		0.0	1.0	1.0	5.0				0.271356	APhillips	
14	Clear	0.77700													0.185000		0.0	1.0	1.0	5.0				0.281417	Djones	
15	Clear	0.77100	8.38	0.00											0.185000	<1	0.0	1.0	1.0	5.0				0.270180	Djones	
16	Clear	0.35200													0.186000		0.0	1.0	1.0	5.0				0.271524	Djones	
17	Clear	0.28000	7.26	0.00											0.197000		1.0	1.0	1.0	5.0				0.265816	Djones	
18	Clear	0.27800													0.190000		1.0	1.0	1.0	5.0				0.277019	Djones	
19	Clear	0.28000													0.171000		1.0	1.0	1.0	5.0				0.273880	Djones	
20	Clear	0.26000													0.192000		1.0	1.0	1.0	5.0				0.257874	Djones	
21	Clear	0.27500	8.32	0.00											0.178000		1.0	1.0	1.0	5.0				0.285224	APhillips	
22	Clear	0.27000	8.17	0.00											0.175000	<1	1.0	1.0	1.0	5.0				0.270208	APhillips	
23	Clear	0.21300													0.146000		1.0	1.0	1.0	5.0				0.270000	APhillips	
24	Clear	0.30100													0.196000		1.0	1.0	1.0	5.0				0.224602	APhillips	
25	Clear	0.24700													0.187000		1.0	1.0	1.0	5.0				0.303062	Jelliott	
26	Clear	0.15000													0.166000		1.0	1.0	1.0	5.0				0.249405	Jelliott	
27	Clear	0.17400													0.150000		1.0	1.0	1.0	5.0				0.266828	Jelliott	
28	Clear	0.37800	8.34	0.00											0.210000		1.0	1.0	1.0	5.0				0.264684	Jelliott	
29	Clear	0.16900	7.29	0.00											0.175000	<1	1.0	1.0	1.0	5.0				0.284753	A.phillips	
30	Clear	0.11800													0.176000		2.0	1.0	1.0	5.0				0.284042	Djones	
31	Clear	0.12300													0.165000		2.0	1.0	1.0	5.0				0.277704	Djones	
Total		9.64300													5.593000										8.365626	
Average		0.31106	7.8	<0.10	0.000	0.000	0.000	5	16	1	1	0	2	0	6	0.180419	1.6	1.0	1.0	1.0	5.0	#DIV/0!	#DIV/0!	#DIV/0!	0.269859	
Minimum		0.11800	7.2	0.00	0.000	0.000	0.000	5	16	1	1	0	2	0	0	0.146000	0.0	0.0	1.0	1.0	5.0	0.0	0.0	0.0	0.186051	
Maximum		0.77700	8.4	<0.10	0.000	0.000	0.000	5	16	1	1	0	2	0	31	0.210000	10	3.0	1.0	1.0	5.0	0.0	0.0	0.0	0.303062	MOR 01-3-14

COMMENTS:

Created By:  
Maryland Environmental Service  
9 Najoles Road, Millersville MD

Facility: BTR Capital Group  
Address: 627 Hanover Pike, Hampstead Maryland  
Additional Op's & cert # - Dorrance Jones 0763, Keith White 4609, Chris Dallas 6202, Anthony Phillips 3001

Permit Number: 07-DP-0022  
Superintendent: Earle Villarreal

Certification # 1017

Month: August  
Year: 2014

Date	Appearance	Discharge MGD	pH	Cl2 mg/l	Final Effluent outfall 001										Outfall 101					Outfall 201			Operator				
					Turbidity ug/l	1,1,1-Trichloroethane ug/l	Trichloroethane ug/l	BOD5 mg/l	TSS mg/l	TKN mg/l	N+N mg/l	TP mg/l	TN mg/l	O&G mg/l	eColi mpn	Flow MGD	eColi mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Turbidity ug/l		1,1,1-Trichloroethane ug/l	Trichloroethane ug/l	Discharge mgd	
1	Clear	0.10800														0.188000		2.0	1.0	1.0	5.0				0.270051	Djones	
2	Clear	0.12500														0.163000		2.0	1.0	1.0	5.0				0.255688	APhillips	
3	Clear	0.58200														0.173000		0.0	1.0	1.0	5.0				0.247096	APhillips	
4	Clear	0.27000														0.140000		0.0	1.0	1.0	5.0				0.297789	Djones	
5	Clear	0.14100				<1	<1	<1	7.00	9.60	0.999	0.85	<0.05	1.9	<5	9.9	0.160000	<1	0.0	1.0	1.0	5.0				0.227908	Djones
6	Clear	0.16700	7.14	0.00												0.163000		0.0	1.0	1.0	5.0				0.245214	Kwhite	
7	Clear	0.12700														0.133000		0.0	1.0	1.0	5.0				0.232003	Kwhite	
8	Clear	0.10000	7.55	0.00												0.149000		0.0	1.0	1.0	5.0				0.239082	Kwhite	
9	Clear	0.12000														0.138000		0.0	2.0	1.0	5.0				0.252032	Djones	
10	Clear	0.12300														0.155000		0.0	5.0	1.0	5.0				0.254093	Djones	
11	Clear	0.40000														0.130000		0.0	5.0	1.0	5.0				0.297872	Kwhite	
12	Clear	0.41400														0.144000	<1	0.0	5.0	1.0	5.0				0.265889	Kwhite	
13	Clear	0.81900	7.65	0.00												0.148000		0.0	5.0	1.0	5.0				0.249227	Kwhite	
14	Clear	0.19400	8.02	0.00												0.156000		0.0	5.0	1.0	5.0				0.215517	Kwhite	
15	Clear	0.13300														0.162000		0.0	5.0	1.0	5.0				0.259543	Kwhite	
16	Clear	0.13100														0.115000		0.0	5.0	1.0	5.0				0.281408	Kwhite	
17	Clear	0.12500														0.190000		0.0	5.0	1.0	5.0				0.253190	Kwhite	
18	Clear	0.12700														0.003500	<1	0.0	5.0	1.0	5.0				0.251014	Cdallas	
19	Clear	0.12200														0.147000		0.0	5.0	1.0	5.0				0.233688	Cdallas	
20	Clear	0.17300	7.18	0.00												0.154000		0.0	5.0	1.0	5.0				0.307327	Cdallas	
21	Clear	0.14000	8.16	0.00												0.143000		0.0	5.0	1.0	5.0				0.239568	Djones	
22	Clear	0.13400														0.151000		0.0	5.0	1.0	5.0				0.256905	Djones	
23	Clear	0.14500														0.144000		0.0	5.0	1.0	5.0				0.260362	APhillips	
24	Clear	0.49300														0.168000		0.0	5.0	1.0	5.0				0.250706	APhillips	
25	Clear	0.28400	7.43	0.00												0.167000		0.0	5.0	1.0	5.0				0.309336	Djones	
26	Clear	0.44100														0.160000	<1	0.0	5.0	1.0	5.0	<1	<1	<1	0.261267	Djones	
27	Clear	0.28100														0.149000		0.0	5.0	1.0	5.0				0.259180	Kwhite	
28	Clear	0.33700	7.81	0.00												0.168000		1.0	5.0	1.0	5.0				0.267688	Kwhite	
29	Clear	0.12900														0.131000		1.0	5.0	1.0	5.0				0.257533	Kwhite	
30	Clear	0.07400														0.157000		1.0	5.0	1.0	5.0				0.206407	Djones	
31	Clear	0.18800														0.159000		1.0	5.0	1.0	5.0				0.266210	Djones	
Total		7.14700														4.608500										7.970793	
Average		0.23055	7.6	<0.10	0.000	0.000	0.000	7.0	9.6	1.0	0.9	0.0	1.9	0.0	9.9	0.148661	1.0	0.3	3.9	1.0	5.0	0.0	0.0	0.0	0.257122		
Minimum		0.07400	7.1	0.00	0.000	0.000	0.000	7.0	9.6	1.0	0.9	0.0	1.9	0.0	9.9	0.003500	0.0	0.0	1.0	1.0	5.0	0.0	0.0	0.0	0.206407		
Maximum		0.81900	8.2	<0.10	0.000	0.000	0.000	7.0	9.6	1.0	0.9	0.0	1.9	0.0	9.9	0.190000	0.0	2.0	5.0	1.0	5.0	0.0	0.0	0.0	0.309336	MOR 01-3-14	

COMMENTS:

ENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:  
Maryland Environmental Service  
259 Najoles Road, Millersville MD

Facility: BTR Capital Group  
Address: 627 Hanover Pike, Hampstead Maryland  
Additional Op's & cert # - Dorrance Jones 0763, James Elliott 3738, Anthony Phillips 3001, Keith White 4609, Ryan Thomas 0781

Permit Number: 07-DP-0022  
Superintendent: Earle Villarreal Certification # 1017

Month: September  
Year: 2014

Date	Appearance	Discharge MGD	pH su	Cl2 mg/l	Final Effluent outfall 001										Outfall 101					Outfall 201			Operator						
					Turbidity ug/l	1,1,1-Trichloroethane ug/l	Toxics ug/l	BOD <sub>5</sub> mg/l	TSS mg/l	TKN mg/l	N+N mg/l	TP mg/l	TN mg/l	O&G mg/l	eColi mpn	Flow MGD	eColi mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Turbidity ug/l		1,1,1-Trichloroethane ug/l	Toxics ug/l	Discharge mgd			
1	Clear	0.11000																0.157000		1.0	5.0	1.0	5.0					0.155349	APhillips
2	Clear	0.14900	8.03	0.00														0.148000		1.0	5.0	1.0	5.0					0.266203	APhillips
3	Clear	0.18900			<1	<1	<1	5.00	4.80	<0.2	10.20	<0.05	10.2	<5.0			0.158000	<1	1.0	5.0	1.0	5.0					0.265283	APhillips	
4	Clear	0.15300	7.52	0.00													0.139000		3.0	5.0	1.0	5.0					0.313562	Kwhite	
5	Clear	0.15400															0.137000		3.0	5.0	1.0	5.0					0.246148	Djones	
6	Clear	0.24100															0.142000		3.0	5.0	1.0	5.0					0.258635	Jelliott	
7	Clear	0.17100															0.143000		3.0	5.0	1.0	5.0					0.212615	Jelliott	
8	Clear	0.16300	8.03	0.00													0.163000		4.0	5.0	1.0	5.0					0.280140	Djones	
9	Clear	0.16400															0.140000	<1	4.0	5.0	1.0	5.0					0.262659	Djones	
10	Clear	0.12700	7.81	0.00													0.139000		5.0	5.0	1.0	5.0					0.260544	Djones	
11	Clear	0.10500															0.145000		5.0	5.0	1.0	5.0					0.241583	Djones	
12	Clear	0.12700															0.155000		6.0	5.0	1.0	5.0					0.281308	Djones	
13	Clear	0.11400															0.147000		6.0	5.0	1.0	5.0					0.251917	APhillips	
14	Clear	0.11200															0.148000		6.0	5.0	1.0	5.0					0.247922	APhillips	
15	Clear	0.11300	8.32	0.00													0.145000		6.0	5.0	1.0	5.0					0.275320	Djones	
16	Clear	0.11600															0.131000	<1	6.0	5.0	1.0	5.0					0.263449	Djones	
17	Clear	0.09900															0.143000		6.0	5.0	1.0	5.0					0.233644	Djones	
18	Clear	0.11400	7.87	0.00													0.151000		6.0	5.0	1.0	5.0					0.293304	Djones	
19	Clear	0.18300															0.155000		6.0	5.0	1.0	5.0					0.243354	Djones	
20	Clear	0.10100															0.128000		6.0	5.0	1.0	5.0					0.260188	Djones	
21	Clear	0.09100															0.138000		6.0	5.0	1.0	5.0					0.250180	Djones	
22	Clear	0.17500															0.151000		6.0	5.0	1.0	5.0					0.277903	Kwhite	
23	Clear	0.11000	7.57	0.00													0.158000	1.00	6.0	5.0	1.0	5.0					0.244783	Kwhite	
24	Clear	0.11400															0.135000		6.0	5.0	1.0	5.0					0.262788	Kwhite	
25	Clear	0.41900	7.58	0.00													0.153000		5.0	5.0	1.0	5.0					0.227985	Kwhite	
26	Clear	0.38500													5.2		0.134000		5.0	5.0	1.0	5.0					0.285616	Kwhite	
27	Clear	0.11900															0.147000		5.0	5.0	1.0	5.0					0.235148	Kwhite	
28	Clear	0.15300															0.134000		5.0	5.0	1.0	5.0					0.268768	Kwhite	
29	Clear	0.12800	7.36	0.00													0.141000		5.0	5.0	1.0	5.0					0.254968	Rthomas	
30	Clear	0.14800	8.21	0.00													0.143000	<1	5.0	5.0	1.0	5.0					0.259669	Rthomas	
31																													
Total		4.64700															4.348000											7.680935	
Average		0.15490	7.8	<0.10	0	0	0	5.0	5	0.0	10.2	0	10	0	5	0.144933	1.0	4.7	5.0	1.0	5.0	#DIV/0!	#DIV/0!	#DIV/0!		0.256031			
Minimum		0.09100	7.4	0.00	0	0	0	5.0	5	0.0	10.2	0	10	0	5	0.128000	0.0	1.0	5.0	1.0	5.0	0.0	0.0	0.0		0.155349			
Maximum		0.41900	8.3	<0.10	0	0	0	5.0	5	0.0	10.2	0	10	0	5	0.163000	1.0	6.0	5.0	1.0	5.0	0.0	0.0	0.0		0.313562	MOR 01-3-14		

COMMENTS:

---

**APPENDIX B  
DISCHARGE MONITORING REPORTS  
(JULY - SEPTEMBER 2014)**

---

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name **BTR Hampstead, Inc**  
 Address **c/o BTR Capital Group Management**  
**222 Courthouse Ct., Suite 300, Towson MD 21204**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) **MD0001881** (17-19) **001**  
**PERMIT NUMBER** **DISCHARGE NUMBER**

Form Approved.  
 OMB No.  
 Approval expires

Facility **Groundwater Remediation and WWTP**

Location **626 Hanover Pike**

Attn:

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

State Discharge Permit  
 07-DP-0022

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
14	07	01	TO	14	07	31
(20-21)		(22-23)	(24-25)	(26-27)		(28-29) (30-31)

PARAMETER (32-37)		(3 Card Only) (46-53) QUANTITY OR LOADING			(4 Card Only) (38-45) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	5	( 19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
pH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	7.2	*****	8.4	( 12)	0	TWICE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	DAILY MN	*****	8.5 DAILY MX	SU		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	36	Lbs/day	*****	16	16	( 19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	1,271	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
SOLIDS, TOTAL SUSPENDED 00530 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	2,917	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0 EFFLUENT GROSS VALUE	MEASUREMENT	*****	*****	****	*****	0	0	( 19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	10 30DA AVG	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
NITROGEN, TOTAL (AS N) 00600 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	4	Lbs/day	*****	2	2	( 19)	0	ONCE/ MONTH	COMP -8
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	Req. Mon. DAILY MX	MG/L		ONCE/ MONTH	COMP -8
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)				TELEPHONE			DATE			
Nicole Finneyrock Property Manager					410 729-8350			14	08	21	
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				AREA CODE	NUMBER	YEAR	MONTH	DAY		

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments he

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name BTR Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address c/o BTR Captial Group Management

MD0001881

001

Approval expires

222 Courthouse Ct., Suite 300, Towson MD 21204

PERMIT NUMBER

DISCHARGE NUMBER

Facility Groundwater Remediation and WWTP

MONITORING PERIOD

\*\*\* NO DISCHARGE  \*\*\*  
NOTE: Read instructions before completing this form

Location 626 Hanover Pike

Attn:

FROM 14 07 01 TO 14 07 31  
(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

State Discharge Permit  
07-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
NITROGEN, TOTAL (AS N) 00600 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	152	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
NITROGEN, TOTAL (AS N) 00600 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	1,524	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/day	*****	0	0	( 19)	0	ONCE/ MONTH	COMP -8
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	DAILY MX	MG/L		ONCE/ MONTH	COMP -8
PHOSPHOROUS, TOTAL (AS P) 00665 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	7	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
PHOSPHOROUS, TOTAL (AS P) 00665 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	26	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
TETRACHLOROETHYLE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	( 28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	( 28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Nicole Finneyrock Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410	729-8350	14	08	21
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)  
 Name **BTR Hampstead, Inc**  
 Address **c/o BTR Capital Group Management**  
**222 Courthouse Ct., Suite 300, Towson MD 21204**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

**DISCHARGE MONITORING REPORT (DMR)**

(2-16) **MD0001881** (17-19) **001**  
**PERMIT NUMBER** **DISCHARGE NUMBER**

Form Approved.  
 OMB No.  
 Approval expires

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

Facility **Groundwater Remediation and WWTP**  
 Location **626 Hanover Pike**  
 Attn:


MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
14	07	01	14	07	31
FROM (20-21) (22-23) (24-25)			TO (26-27) (28-29) (30-31)		

State Discharge Permit  
 07-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0.3111	0.7770	(03)	*****	*****	*****	0	ONCE/ MONTH	Measured
	PERMIT REQUIREMENT	REPORT	REPORT	MGD	*****	*****	*****			
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX			
E. COLI, MPN 51040 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	6	*****	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	Req. Mon. GEO MEAN	*****			
TRICHLOROETHENE 78391 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TI  
**Nicole Finneyfrock**  
**Property Manager**  
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 8 MONTHS AND 5 YEARS.)

  
 SIGNATURE OF PRINCIPAL EXECUTIVE  
 OFFICER OR AUTHORIZED AGENT

TELEPHONE  
 410 729-8350  
 AREA CODE NUMBER

DATE  
 14 08 21  
 YEAR MONTH DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name **BTR Hampstead, Inc**  
 Address **c/o BTR Captial Group Management**  
**222 Courthouse Ct., Suite 300, Towson MD 21204**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

**DISCHARGE MONITORING REPORT (DMR)**

(2-16) **MD0001881** (17-19) **101**  
**PERMIT NUMBER** **DISCHARGE NUMBER**

Form Approved.  
 OMB No.  
 Approval expires

Facility **Groundwater Remediation and WWTP**

Location **626 Hanover Pike**

Attn:

\*\*\* NO DISCHARGE  \*\*\*


NOTE: Read instructions before completing this form

State Discharge Permit

07-DP-0022

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
14	07	01	14	07	31
FROM		TO			
(20-21)		(22-23) (24-25)		(26-27) (28-29) (30-31)	

PARAMETER (32-37)		(3 Card Only) (46-53) QUANTITY OR LOADING			(4 Card Only) (38-45) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (54-51)	MAXIMUM (54-51)	UNITS	MINIMUM (54-51)	AVERAGE (54-51)	MAXIMUM (54-51)	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	180,419	210,000	(07)	*****	*****	*****	****	0	ONCE/ WEEK	Measured/ Recorded
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****			
E.COLI, MPN 51040 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	10	(30)	0	ONCE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	126 DAILY MX	MPN			
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  <b>Nicole Finneyfrock</b> Property Manager	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
		TYPED OR PRINTED		410	729-8350	14
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YFAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)



ERMITTEE NAME/ADDRESS (Include  
activity Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.  
OMB No.  
Approval expires

ame BTR Hampstead, Inc  
ddress c/o BTR Capital Group Management  
222 Courthouse Ct., Suite 300, Towson MD 21204

(2-16)	(17-19)
MD0001881	001
PERMIT NUMBER	DISCHARGE NUMBER

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

activity Groundwater Remediation and WWTP  
ocation 626 Hanover Pike  
ttn:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 14	08	01	TO 14	08	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

State Discharge Permit  
07-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(3 Card Only) (46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(4 Card Only) (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
30D, 5-DAY (20 DEG. C)	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	7	( 19)	0	ONCE/ MONTH	GRAB
00310 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
04H	SAMPLE MEASUREMENT	*****	*****	****	7.1	*****	8.2	( 12)	0	TWICE/ WEEK	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	DAILY MN	*****	8.5 DAILY MX	SU		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	11	Lbs/day	*****	10	10	( 19)	0	ONCE/ MONTH	GRAB
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	572	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
00530 1 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	3,489	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
00530 1 2 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	( 19)	0	ONCE/ MONTH	GRAB
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10 30DA AVG	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
NITROGEN, TOTAL (AS N)	SAMPLE MEASUREMENT	*****	2	Lbs/day	*****	2	2	( 19)	0	ONCE/ MONTH	COMP -8
00600 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	Req. Mon. DAILY MX	MG/L		ONCE/ MONTH	COMP -8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  Nicole Finneyfrock Property Manager  TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
		410	729-8350	14	09	22
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments he

ERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name BTR Hampstead, Inc  
 Address c/o BTR Capital Group Management  
 222 Courthouse Ct., Suite 300, Towson MD 21204

(2-16)	(17-19)
MD0001881	001
PERMIT NUMBER	DISCHARGE NUMBER

OMB No.

Approval expires

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attention:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
14	08	01	14	08	31
FROM				TO	
(20-21)		(22-23)		(24-25)	
				(26-27)	
				(28-29)	
				(30-31)	

State Discharge Permit

07-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING (3 Card Only) (46-53)			QUALITY OR CONCENTRATION (4 Card Only) (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
NITROGEN, TOTAL (AS N) 00600 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	110	Lbs/mo	*****	*****	*****	0	ONCE/ MONTH	Calculated	
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****		ONCE/ MONTH	Calculated	
NITROGEN, TOTAL (AS N) 00600 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	1,635	Lbs/yr	*****	*****	*****	0	ONCE/ MONTH	Calculated	
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****		ONCE/ MONTH	Calculated	
PHOSPHOROUS, TOTAL (AS P) 00665 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/day	*****	0	0	( 19)	0	ONCE/ MONTH	COMP -8
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	DAILY MX			ONCE/ MONTH	COMP -8
PHOSPHOROUS, TOTAL (AS P) 00665 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/mo	*****	*****	*****	0	ONCE/ MONTH	Calculated	
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****		ONCE/ MONTH	Calculated	
PHOSPHOROUS, TOTAL (AS P) 00665 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	26	Lbs/yr	*****	*****	*****	0	ONCE/ MONTH	Calculated	
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****		ONCE/ MONTH	Calculated	
TETRACHLOROETHYLE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	( 28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	( 28)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			ONCE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  Nicole Finneyrock Property Manager  TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410	729-8350	14	09	22
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

ERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

name BTR Hampstead, Inc  
 address c/o BTR Captial Group Management  
222 Courthouse Ct., Suite 300, Towson MD 21204

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)

MD0001881	001
PERMIT NUMBER	DISCHARGE NUMBER

Form Approved.  
 OMB No.  
 Approval expires

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

Facility Groundwater Remediation and WWTP  
 Location 626 Hanover Pike  
 City/State

State Discharge Permit  
 07-DP-0022

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
14	08	01	TO	14	08	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

PARAMETER (32-37)		(3 Card Only)			(4 Card Only)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		QUANTITY OR LOADING			QUALITY OR CONCENTRATION						
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM				UNITS
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.2305	0.8190	(03)	*****	*****	*****	0	ONCE/MONTH	Measured	
50050 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	MGD	*****	*****	*****		ONCE/MONTH	Measured	
EFFLUENT GROSS VALUE CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	( 19)	0	ONCE/MONTH	GRAB
50060 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	0.011	0.019	MG/L		ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE E.COLI, MPN	SAMPLE MEASUREMENT	*****	*****	****	*****	10	*****	( 30)	0	ONCE/MONTH	GRAB
51040 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	Req. Mon. GEO MEAN	*****	MPN		ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	( 28)	0	ONCE/MONTH	GRAB
78391 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L		ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TI  
 Nicole Finneyfrock  
 Property Manager  
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN: AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE  
 410 729-8350

DATE  
 14 09 22

AREA CODE NUMBER YEAR MONTH DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)  
 Name BTR Hampstead, Inc  
 Address c/o BTR Captial Group Management  
 222 Courthouse Ct., Suite 300, Towson MD 21204  
 Facility Groundwater Remediation and WWTP  
 Location 626 Hanover Pike  
 Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDE)

DISCHARGE MONITORING REPORT (DMR)

(2-16) MD0001881 PERMIT NUMBER  
 (17-19) 101 DISCHARGE NUMBER

Form Approved.  
 OMB No.  
 Approval expires

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

State Discharge Permit  
 07-DP-0022

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
14	08	01	14	08	31
(20-21)		(22-23)	(24-25)	(28-27) (28-29) (30-31)	

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	148,661	190,000	(07)	*****	*****	*****	****	0	ONCE/WEEK	Measured/Recorded
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/MONTH	Measured/Recorded
E.COLI, MPN 51040 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	126 DAILY MX	MPN		ONCE/WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Nicole Finneyfrack Property Manager TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
		410	729-8350	14	09	22
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN	AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name **BTR Hampstead, Inc**

Address **c/o BTR Capital Group Management**

**222 Courthouse Ct., Suite 300, Towson MD 21204**

Facility **Groundwater Remediation and WWTP**

Location **626 Hanover Pike**

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

\*\*\* NO-DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

State Discharge Permit  
07-DP-0022

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
14	09	01	14	09	30
(20-21)		(22-23)	(24-25)	(26-27) (28-29) (30-31)	

PARAMETER (32-37)		(3 Card Only) (46-53)			(4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	5	( 19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT	*****	*****	****	7.4	*****	8.3	( 12)	0	TWICE/ WEEK	GRAB
PH 00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	DAILY MN	*****	8.5 DAILY MX	SU		TWICE/ WEEK	GRAB
	SAMPLE MEASUREMENT	*****	8	Lbs/day	*****	5	5	( 19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 C EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	186	Lbs/mo	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
	SAMPLE MEASUREMENT	*****	3,675	Lbs/yr	*****	*****	*****	****	0	ONCE/ MONTH	Calculated
SOLIDS, TOTAL SUSPENDED 00530 1 2 C EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/ MONTH	Calculated
	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	( 19)	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	10 30DA AVG	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	16	Lbs/day	*****	10	10	( 19)	0	ONCE/ MONTH	COMP -8
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	Req. Mon. DAILY MX	MG/L		ONCE/ MONTH	COMP -8
	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	*****	****		ONCE/ MONTH	Calculated

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN

T/FI FPHONE		DATE		
410	729-8350	14	10	20
AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDE)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name BTR Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address c/o BTR Capital Group Management

MD0001881

001

Approval expires

222 Courthouse Ct., Suite 300, Towson MD 21204

PERMIT NUMBER

DISCHARGE NUMBER

\*\*\* NO DISCHARGE  \*\*\*

Facility Groundwater Remediation and WWTP

MONITORING PERIOD

NOTE: Read instructions before completing this form

Location 626 Hanover Pike

YEAR	MO	DAY	YEAR	MO	DAY
14	09	01	14	09	30
FROM (20-21) (22-23) (24-25)			TO (26-27) (28-29) (30-31)		

State Discharge Permit

07-DP-0022

Attn:

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (45-53) (54-61)			(4 Card Only) QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
NITROGEN, TOTAL (AS N) 00600 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	395	Lbs/mo	*****	*****	*****	****	0	ONCE/MONTH	Calculated	
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/MONTH	Calculated	
NITROGEN, TOTAL (AS N) 00600 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	2,030	Lbs/yr	*****	*****	*****	****	0	ONCE/MONTH	Calculated	
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/MONTH	Calculated	
PHOSPHOROUS, TOTAL (AS P) 00665 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/day	*****	0	0	( 19)	0	ONCE/MONTH	COMP -8	
	PERMIT REQUIREMENT	*****	Req. Mon. MO MAX		*****	Req. Mon. 30DA AVG	DAILY MX	MG/L		ONCE/MONTH	COMP -8	
PHOSPHOROUS, TOTAL (AS P) 00665 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	Lbs/mo	*****	*****	*****	****	0	ONCE/MONTH	Calculated	
	PERMIT REQUIREMENT	*****	Req. Mon. MO TOTAL		*****	*****	*****	****		ONCE/MONTH	Calculated	
PHOSPHOROUS, TOTAL (AS P) 00665 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	26	Lbs/yr	*****	*****	*****	****	0	ONCE/MONTH	Calculated	
	PERMIT REQUIREMENT	*****	Req. Mon. CUM TOTAL		*****	*****	*****	****		ONCE/MONTH	Calculated	
TETRACHLOROETHYLE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	( 28)	0	ONCE/MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****		*****	*****	5	DAILY MX	UG/L		ONCE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	( 28)	0	ONCE/MONTH	GRAB	
	PERMIT REQUIREMENT	*****	*****		*****	*****	5	DAILY MX	UG/L		ONCE/MONTH	GRAB

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 651001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN

TFI PHONE		DATE		
410	729-8350	14	10	20
AREA CODE	NUMBER	YFAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name BTR Hampstead, Inc

Address c/o BTR Captial Group Management

222 Courthouse Ct., Suite 300, Towson MD 21204

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

State Discharge Permit  
07-DP-0022

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
FROM 14	09	01		14	09	30
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE SUREMENT	0.1549	0.4190	(03)	*****	*****	*****	****	0	ONCE/ MONTH	Measured
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	MGD	*****	*****	*****	****		ONCE/ MONTH	Measured
CHLORINE, TOTAL RESIDUAL 50060 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	( 19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L		ONCE/ MONTH	GRAB
E. COLI, MPN 51040 1 0 1	SAMPLE MEASUREMENT	*****	*****	****	*****	5	*****	( 30)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	Req. Mon. GEO MEAN	*****	MPN		ONCE/ MONTH	GRAB
TRICHLOROETHENE 78391 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	( 28)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TI  Nicole Finneyrock Property Manager  TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410	729-8350	14	10	20
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN	AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name BTR Hampstead, Inc

Address c/o BTR Capital Group Management

222 Courthouse Ct., Suite 300, Towson MD 21204

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDE)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

MONITORING PERIOD

FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
14	09	01	14	09	30
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

State Discharge Permit

07-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		(3 Card Only) (46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(4 Card Only) (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	144,933	163,000	(07)	*****	*****	*****	****	0	ONCE/ WEEK	Measured/ Recorded	
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	Measured/ Recorded	
E. COLI, MPN 51040 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/ WEEK	GRAB	
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	126 DAILY MX	MPN		ONCE/ WEEK	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 881001 AND 33 U.S.C. 88 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)							TFI PHONE		DATE		
Nicole Finneyrock Property Manager TYPED OR PRINTED								410	729-8350	14	10	20
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN							AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)



PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name BTR Hampstead, Inc

Address c/o BTR Captial Group Management

222 Courthouse Ct., Suite 300, Towson MD 21204

Facility Groundwater Remediation and WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDE)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

201

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
14	07	01		14	09	30
(20-21) (22-23) (24-25)				(26-27) (28-29) (30-31)		

State Discharge Permit

07-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		(48-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM				UNITS
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	261,058	313,562	(07)	*****	*****	*****	****	0	Measured	Record
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	Record
Total Volatile Organics (VOC) 51415 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	100	UG/L		One/ Quarter	Grab
TRICHLOROETHENE 78391 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  Nicole Finneyfrock Property Manager  TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDULES IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TELEPHONE		DATE		
		410 AREA CODE	729-8350 NUMBER	14 YEAR	10 MONTH	20 DAY

*[Signature]*  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGEN

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

---

**APPENDIX C**  
**GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS**  
**(JULY - SEPTEMBER 2014)**

---

# QC Laboratories

# Analytical Report

Printed 07/16/14 19:36 DE36

CHERYL GRIFFIN  
 MARYLAND ENVIRONMENTAL SERVICE A  
 259 NAJOLLES ROAD  
 RE: BLACK & DECKER WWTP  
 MILLERSVILLE, MD 21108

Order Number: L5113810  
 Project Name: BLACK & DECKER WWTP  
 Receive Date: 07-08-2014  
 Client Code: MES\_A  
 Project Location: BLACK & DECKER WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A  
 Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No: Inv. No: MES\_AL0341  
 PWSID No:

Sample ID Sample Description Samp. Date/Time/Temp Sampled by  
 L5113810-1 BTR 001 GRAB 07/08/14 09:30am NA C Customer  
 Received Date/Time/Temp 07/08/14 04:30pm 2.5 C Iced (Y/N): Y

Satellite Received Temp 4.0 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

### GENERAL CHEMISTRY

Hexane Ext. Material-HEM (oil+grease)	ND	5.00	mg/l	1664B HEM	1		07/11/14 12:20PM AGM
Total Suspended Solids (Delaware)	15.8	4.00	mg/l	SM 2540D	1		07/09/14 12:31PM MS3
Biochemical Oxygen Demand, 5 Day (DE)	5.00	2.00	mg/l	SM 5210B	1.5		07/09/14 08:35AM SKJ

### GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES

1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		07/10/14 04:15PM JAD
Tetrachloroethene	ND	1.00	ug/l	EPA 624	1		07/10/14 04:15PM JAD
Trichloroethene	ND	1.00	ug/l	EPA 624	1		07/10/14 04:15PM JAD

Sample ID Sample Description Samp. Date/Time/Temp Sampled by  
 L5113810-2 BTR 001 COMP 07/08/14 09:32am NA C Customer  
 Received Date/Time/Temp 07/08/14 04:30pm 4.0 C Iced (Y/N): Y

Satellite Received Temp 4.0 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

PIN: 17237

Serial Number: 3826372



# QC Laboratories

# Analytical Report

Printed 08/18/14 15:25 DE36

CHERYL GRIFFIN  
 MARYLAND ENVIRONMENTAL SERVICE A  
 259 NAJOLES ROAD  
 RE: BLACK & DECKER WWTP  
 MILLERSVILLE, MD 21108

Order Number: L5159511  
 Project Name: BLACK & DECKER WWTP  
 Receive Date: 08-05-2014  
 Client Code: MES\_A  
 Project Location: BLACK & DECKER WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A  
 Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:                      Inv. No: MES\_AL0341  
    PWSID No:

Sample ID    Sample Description    Samp. Date/Time/Temp    Sampled by  
 L5159511-1    BTR 001 GRAB    08/05/14 09:15am NA C    Customer  
    Received Date/Time/Temp 08/05/14 04:30pm 2.4 C    Iced (Y/N): Y

Satellite Received Temp 4.1 C    Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

**GENERAL CHEMISTRY**

Hexane Ext. Material-HEM (oil+grease)	ND	5.00	mg/l	1664B HEM	1		08/07/14 06:35PM AGM
Total Suspended Solids (Delaware)	9.60	4.00	mg/l	SM 2540D	1		08/06/14 12:55PM MS3
Biochemical Oxygen Demand, 5 Day (DE)	7.00	2.00	mg/l	SM 5210B	1.5		08/06/14 10:25AM SKJ

**GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES**

1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		08/07/14 09:31PM JAD
Tetrachloroethene	ND	1.00	ug/l	EPA 624	1		08/07/14 09:31PM JAD
Trichloroethene	ND	1.00	ug/l	EPA 624	1		08/07/14 09:31PM JAD

Sample ID    Sample Description    Samp. Date/Time/Temp    Sampled by  
 L5159511-2    BTR 001 COMP    08/05/14 09:15am NA C    Customer  
    Received Date/Time/Temp 08/05/14 04:30pm 2.4 C    Iced (Y/N): Y

Satellite Received Temp 4.1 C    Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

PIN: 17237

Serial Number: 3949465



# QC Laboratories

# Analytical Report

Printed 09/04/14 16:56 DE36

CHERYL GRIFFIN  
 MARYLAND ENVIRONMENTAL SERVICE A  
 259 NAJILES ROAD  
 RE: BLACK & DECKER WWTP  
 MILLERSVILLE, MD 21108

Order Number: L5214985  
 Project Name: BLACK & DECKER WWTP  
 Receive Date: 08-26-2014  
 Client Code: MES\_A  
 Project Location: BLACK & DECKER WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A  
 Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No: Inv. No: MES\_AL0341  
 PWSID No:

Sample ID L5214985-1 Sample Description BTR 201 QRTLY  
 Received Date/Time/Temp 08/26/14 04:45pm 0.4 C Iced (Y/N): Y  
 Smp. Date/Time/Temp Sampled by 08/26/14 09:03am NA C Customer

Satellite Received Temp 2.3 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
<b>GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES</b>							
1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,1,2,2-Tetrachloroethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,1,2-Trichloroethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,1-Dichloroethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,1-Dichloroethene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,2-Dichlorobenzene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,2-Dichloroethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,2-Dichloropropane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,3-Dichlorobenzene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
1,4-Dichlorobenzene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
2-Chloroethyl vinyl ether	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Benzene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Bromodichloromethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Bromoform	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Bromomethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Carbon tetrachloride	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Chlorobenzene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Chloroethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Chloroform	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Chloromethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
cis-1,3-Dichloropropene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Dibromochloromethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Ethylbenzene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Methylene chloride	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Tetrachloroethene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Toluene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
trans-1,2-Dichloroethene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
trans-1,3-Dichloropropene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Trichloroethene	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD

PIN: 17237

Serial Number: 4006097

# QC Laboratories

# Analytical Report

Printed 09/04/14 16:56

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A  
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES\_AL0341  
PWSID No:

Sample ID: L5214985-1    Sample Description: BTR 201 QRTL  
Received Date/Time/Temp: 08/26/14 04:45pm 0.4 C    Iced (Y/N): Y  
Samp. Date/Time/Temp: 08/26/14 09:03am NA C    Sampled by: Customer

Satellite Received Temp: 2.3 C    Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
<b>GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES continued</b>							
Trichlorofluoromethane	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD
Vinyl chloride	ND	1.00	ug/l	EPA 624	1		08/28/14 03:48PM JAD



PIN: 17237

Serial Number: 4006097



# QC Laboratories

# Analytical Report

Printed 09/10/14 12:56 DE36

CHERYL GRIFFIN  
 MARYLAND ENVIRONMENTAL SERVICE A  
 259 NAJOLAS ROAD  
 RE: BLACK & DECKER WWTP  
 MILLERSVILLE, MD 21108

Order Number: L5203439  
 Project Name: BLACK & DECKER WWTP  
 Receive Date: 09-03-2014  
 Client Code: MES\_A  
 Project Location: BLACK & DECKER WWTP

Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A  
 Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No: Inv. No: MES\_AL0341  
 PWSID No:

Sample ID L5203439-1 Sample Description BTR 001 GRAB  
 Received Date/Time/Temp 09/03/14 04:30pm 4.7 C Iced (Y/N): Y  
 Samp. Date/Time/Temp Sampled by 09/03/14 09:50am NA C Customer

Satellite Received Temp 3.3 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
<b>GENERAL CHEMISTRY</b>							
Hexane Ext. Material-HEM (oil+grease)	ND	5.00	mg/l	1664B HEM	1		09/08/14 04:00PM RSK
Total Suspended Solids (Delaware)	4.80	4.00	mg/l	SM 2540D	1		09/04/14 01:25PM MS3
Biochemical Oxygen Demand, 5 Day (DE)	5.00	2.00	mg/l	SM 5210B	1.5		09/04/14 10:30AM SKJ
<b>GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES</b>							
1,1,1-Trichloroethane	ND	1.00	ug/l	EPA 624	1		09/06/14 04:39AM JAD
Tetrachloroethane	ND	1.00	ug/l	EPA 624	1		09/06/14 04:39AM JAD
Trichloroethane	ND	1.00	ug/l	EPA 624	1		09/06/14 04:39AM JAD

Sample ID L5203439-2 Sample Description BTR 001 COMP  
 Received Date/Time/Temp 09/03/14 04:30pm 4.7 C Iced (Y/N): Y  
 Samp. Date/Time/Temp Sampled by 09/03/14 09:50am NA C Customer

Satellite Received Temp 3.3 C Iced (Y/N): Y

Parameter	Result	RL	Units	Method	DF	Qual	Test Date, Time, Analyst
-----------	--------	----	-------	--------	----	------	--------------------------

PIN: 17237

Serial Number: 4018385



---

**APPENDIX D  
GROUNDWATER ANALYTICAL DATA PACKAGE  
(AUGUST 2014)**

---

# TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

## ANALYTICAL REPORT

TestAmerica Laboratories, Inc.  
TestAmerica Chicago  
2417 Bond Street  
University Park, IL 60484  
Tel: (708)534-5200

TestAmerica Job ID: 500-83243-1  
Client Project/Site: Black and Decker

For:  
Weston Solutions, Inc.  
1400 Weston Way  
PO BOX 2653  
West Chester, Pennsylvania 19380

Attn: Mr. Tom Cornuet



Authorized for release by:  
9/8/2014 1:21:14 PM

Richard Wright, Senior Project Manager  
(708)534-5200  
richard.wright@testamericainc.com

### LINKS

Review your project  
results through  
**Total Access**

Have a Question?

Ask  
The  
Expert

Visit us at:  
[www.testamericainc.com](http://www.testamericainc.com)

*The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.*

*This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.*

*Results relate only to the items tested and the sample(s) as received by the laboratory.*

# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	2
Case Narrative . . . . .	3
Detection Summary . . . . .	4
Method Summary . . . . .	8
Sample Summary . . . . .	9
Client Sample Results . . . . .	10
Definitions . . . . .	62
QC Association . . . . .	63
Surrogate Summary . . . . .	64
QC Sample Results . . . . .	65
Chronicle . . . . .	78
Certification Summary . . . . .	83
Chain of Custody . . . . .	84
Receipt Checklists . . . . .	87



# Case Narrative

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Job ID: 500-83243-1

Laboratory: TestAmerica Chicago

## Narrative

Job Narrative  
500-83243-1

## Comments

No additional comments.

## Receipt

The samples were received on 8/29/2014 10:30 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 3.4° C.

## GC/MS VOA

Method(s) 8260B: The laboratory control sample (LCS) for batch 25282 recovered outside control limits for the following analytes: Chloroethane. These analytes were biased high in the LCS and were not detected in the associated samples; therefore, the data have been reported.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

## Detection Summary

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

**Client Sample ID: RFW-1A**

**Lab Sample ID: 500-83243-1**

No Detections.

**Client Sample ID: RFW-1B**

**Lab Sample ID: 500-83243-2**

No Detections.

**Client Sample ID: RFW-2A**

**Lab Sample ID: 500-83243-3**

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.26	J	0.50	0.19	ug/L	1		8260B	Total/NA

**Client Sample ID: RFW-2B**

**Lab Sample ID: 500-83243-4**

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.33	J	0.50	0.19	ug/L	1		8260B	Total/NA

**Client Sample ID: RFW-3B**

**Lab Sample ID: 500-83243-5**

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloroethane	1.6		1.0	0.34	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	1.2		1.0	0.12	ug/L	1		8260B	Total/NA
Tetrachloroethene	0.71	J	1.0	0.17	ug/L	1		8260B	Total/NA

**Client Sample ID: RFW-4A**

**Lab Sample ID: 500-83243-6**

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.94	J	1.0	0.12	ug/L	1		8260B	Total/NA
Chloroform	0.55	J	1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	34		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	28		1.0	0.17	ug/L	1		8260B	Total/NA

**Client Sample ID: RFW-4A Dup**

**Lab Sample ID: 500-83243-7**

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.92	J	1.0	0.12	ug/L	1		8260B	Total/NA
Chloroform	0.53	J	1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	33		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	28		1.0	0.17	ug/L	1		8260B	Total/NA

**Client Sample ID: RFW-4B**

**Lab Sample ID: 500-83243-8**

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	3.0		1.0	0.12	ug/L	1		8260B	Total/NA
Chloroform	1.2		1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	48		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	84		1.0	0.17	ug/L	1		8260B	Total/NA

**Client Sample ID: RFW-6**

**Lab Sample ID: 500-83243-9**

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.46	J	0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	0.72	J	1.0	0.17	ug/L	1		8260B	Total/NA

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

## Detection Summary

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

### Client Sample ID: RFW-7

Lab Sample ID: 500-83243-10

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Benzene	0.20	J	0.50	0.074	ug/L	1		8260B	Total/NA
Trichloroethene	2.1		0.50	0.19	ug/L	1		8260B	Total/NA

### Client Sample ID: RFW-9

Lab Sample ID: 500-83243-11

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethene	0.63	J	1.0	0.31	ug/L	1		8260B	Total/NA
1,1-Dichloroethane	0.65	J	1.0	0.19	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	15		1.0	0.12	ug/L	1		8260B	Total/NA
1,1,1-Trichloroethane	0.60	J	1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	7.5		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	4.2		1.0	0.17	ug/L	1		8260B	Total/NA

### Client Sample ID: RFW-11B

Lab Sample ID: 500-83243-12

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	1.8		0.50	0.19	ug/L	1		8260B	Total/NA

### Client Sample ID: RFW-12B

Lab Sample ID: 500-83243-13

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	1.6		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	60		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	4.5		1.0	0.17	ug/L	1		8260B	Total/NA

### Client Sample ID: RFW-13

Lab Sample ID: 500-83243-14

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.67	J	1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	2.5		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	15		1.0	0.17	ug/L	1		8260B	Total/NA

### Client Sample ID: RFW-17

Lab Sample ID: 500-83243-15

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Benzene	0.62		0.50	0.074	ug/L	1		8260B	Total/NA

### Client Sample ID: Trip Blank

Lab Sample ID: 500-83243-16

No Detections.

### Client Sample ID: EW-2

Lab Sample ID: 500-83243-17

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	3.0		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	130		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	51		1.0	0.17	ug/L	1		8260B	Total/NA

### Client Sample ID: EW-3

Lab Sample ID: 500-83243-18

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago



## Detection Summary

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

### Client Sample ID: EW-3 (Continued)

Lab Sample ID: 500-83243-18

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	1.8		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	34		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	1.4		1.0	0.17	ug/L	1		8260B	Total/NA

### Client Sample ID: EW-4

Lab Sample ID: 500-83243-19

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Tetrachloroethene	11		1.0	0.17	ug/L	1		8260B	Total/NA
Trichloroethene - DL	540		5.0	1.9	ug/L	10		8260B	Total/NA

### Client Sample ID: EW-5

Lab Sample ID: 500-83243-20

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	100		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	3.6		1.0	0.17	ug/L	1		8260B	Total/NA

### Client Sample ID: EW-6

Lab Sample ID: 500-83243-21

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	4.6		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	10		1.0	0.17	ug/L	1		8260B	Total/NA

### Client Sample ID: EW-7

Lab Sample ID: 500-83243-22

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	2.9		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	2.0		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	5.1		1.0	0.17	ug/L	1		8260B	Total/NA

### Client Sample ID: EW-8

Lab Sample ID: 500-83243-23

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethane	0.76	J	1.0	0.19	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	23		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	6.8		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	73		1.0	0.17	ug/L	1		8260B	Total/NA

### Client Sample ID: EW-9

Lab Sample ID: 500-83243-24

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.43	J	0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	98		1.0	0.17	ug/L	1		8260B	Total/NA

### Client Sample ID: EW-9 Dup

Lab Sample ID: 500-83243-25

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.49	J	0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	99		1.0	0.17	ug/L	1		8260B	Total/NA

### Client Sample ID: EW-10

Lab Sample ID: 500-83243-26

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

# Detection Summary

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-10 (Continued)

Lab Sample ID: 500-83243-26

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Tetrachloroethene	2.0		1.0	0.17	ug/L	1		8260B	Total/NA

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

# Method Summary

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

---

Method	Method Description	Protocol	Laboratory
8260B	VOC	SW846	TAL CHI

---

**Protocol References:**

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

**Laboratory References:**

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200



# Sample Summary

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
500-83243-1	RFW-1A	Water	08/27/14 09:25	08/29/14 10:30
500-83243-2	RFW-1B	Water	08/27/14 16:55	08/29/14 10:30
500-83243-3	RFW-2A	Water	08/27/14 10:40	08/29/14 10:30
500-83243-4	RFW-2B	Water	08/27/14 10:50	08/29/14 10:30
500-83243-5	RFW-3B	Water	08/27/14 16:45	08/29/14 10:30
500-83243-6	RFW-4A	Water	08/28/14 08:45	08/29/14 10:30
500-83243-7	RFW-4A Dup	Water	08/28/14 08:45	08/29/14 10:30
500-83243-8	RFW-4B	Water	08/28/14 07:45	08/29/14 10:30
500-83243-9	RFW-6	Water	08/27/14 12:50	08/29/14 10:30
500-83243-10	RFW-7	Water	08/27/14 11:04	08/29/14 10:30
500-83243-11	RFW-9	Water	08/27/14 16:00	08/29/14 10:30
500-83243-12	RFW-11B	Water	08/28/14 10:40	08/29/14 10:30
500-83243-13	RFW-12B	Water	08/28/14 12:15	08/29/14 10:30
500-83243-14	RFW-13	Water	08/27/14 14:05	08/29/14 10:30
500-83243-15	RFW-17	Water	08/27/14 15:10	08/29/14 10:30
500-83243-16	Trip Blank	Water	08/27/14 06:00	08/29/14 10:30
500-83243-17	EW-2	Water	08/28/14 12:00	08/29/14 10:30
500-83243-18	EW-3	Water	08/28/14 10:30	08/29/14 10:30
500-83243-19	EW-4	Water	08/28/14 10:20	08/29/14 10:30
500-83243-20	EW-5	Water	08/27/14 09:35	08/29/14 10:30
500-83243-21	EW-6	Water	08/27/14 12:10	08/29/14 10:30
500-83243-22	EW-7	Water	08/27/14 12:15	08/29/14 10:30
500-83243-23	EW-8	Water	08/27/14 12:25	08/29/14 10:30
500-83243-24	EW-9	Water	08/27/14 12:40	08/29/14 10:30
500-83243-25	EW-9 Dup	Water	08/27/14 12:40	08/29/14 10:30
500-83243-26	EW-10	Water	08/27/14 12:50	08/29/14 10:30

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-83243-1

Date Collected: 08/27/14 09:25

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 04:47	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 04:47	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 04:47	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 04:47	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 04:47	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 04:47	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 04:47	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 04:47	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 04:47	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 04:47	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 04:47	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 04:47	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 04:47	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 04:47	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 04:47	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 04:47	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 04:47	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 04:47	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 04:47	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 04:47	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 04:47	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 04:47	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/04/14 04:47	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 04:47	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 04:47	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 04:47	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 04:47	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 04:47	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 04:47	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 04:47	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 04:47	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 04:47	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 04:47	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 04:47	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 04:47	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 04:47	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 04:47	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 04:47	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 04:47	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 04:47	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 04:47	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 04:47	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 04:47	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 04:47	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 04:47	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 04:47	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 04:47	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 04:47	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 04:47	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-83243-1

Date Collected: 08/27/14 09:25

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 04:47	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 04:47	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 04:47	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 04:47	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 04:47	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 04:47	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 04:47	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 04:47	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 04:47	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 04:47	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 04:47	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 04:47	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 04:47	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 04:47	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 04:47	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	105		75 - 125		09/04/14 04:47	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 04:47	1
4-Bromofluorobenzene (Surr)	84		75 - 120		09/04/14 04:47	1
Dibromofluoromethane	100		75 - 120		09/04/14 04:47	1

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-83243-2

Date Collected: 08/27/14 16:55

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 05:12	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 05:12	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 05:12	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 05:12	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 05:12	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 05:12	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 05:12	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 05:12	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 05:12	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 05:12	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 05:12	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 05:12	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 05:12	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 05:12	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 05:12	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 05:12	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 05:12	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 05:12	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 05:12	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 05:12	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 05:12	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 05:12	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/04/14 05:12	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 05:12	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 05:12	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 05:12	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 05:12	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 05:12	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 05:12	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 05:12	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 05:12	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 05:12	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 05:12	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 05:12	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 05:12	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 05:12	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:12	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 05:12	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 05:12	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 05:12	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 05:12	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 05:12	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 05:12	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:12	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 05:12	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 05:12	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 05:12	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 05:12	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 05:12	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-83243-2

Date Collected: 08/27/14 16:55

Matrix: Water

Date Received: 08/29/14 10:30

## Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 05:12	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 05:12	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:12	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:12	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 05:12	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 05:12	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 05:12	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 05:12	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 05:12	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 05:12	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 05:12	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 05:12	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 05:12	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 05:12	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 05:12	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	107		75 - 125		09/04/14 05:12	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 05:12	1
4-Bromofluorobenzene (Surr)	84		75 - 120		09/04/14 05:12	1
Dibromofluoromethane	99		75 - 120		09/04/14 05:12	1



# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-83243-3

Date Collected: 08/27/14 10:40

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 05:37	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 05:37	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 05:37	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 05:37	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 05:37	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 05:37	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 05:37	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 05:37	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 05:37	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 05:37	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 05:37	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 05:37	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 05:37	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 05:37	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 05:37	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 05:37	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 05:37	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 05:37	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 05:37	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 05:37	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 05:37	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 05:37	1
Trichloroethene	0.26	J	0.50	0.19	ug/L			09/04/14 05:37	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 05:37	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 05:37	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 05:37	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 05:37	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 05:37	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 05:37	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 05:37	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 05:37	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 05:37	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 05:37	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 05:37	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 05:37	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 05:37	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:37	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 05:37	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 05:37	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 05:37	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 05:37	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 05:37	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 05:37	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:37	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 05:37	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 05:37	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 05:37	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 05:37	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 05:37	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-83243-3

Date Collected: 08/27/14 10:40

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 05:37	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 05:37	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:37	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 05:37	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 05:37	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 05:37	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 05:37	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 05:37	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 05:37	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 05:37	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 05:37	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 05:37	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 05:37	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 05:37	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 05:37	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		75 - 125		09/04/14 05:37	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 05:37	1
4-Bromofluorobenzene (Surr)	84		75 - 120		09/04/14 05:37	1
Dibromofluoromethane	99		75 - 120		09/04/14 05:37	1

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-83243-4

Date Collected: 08/27/14 10:50

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 06:02	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 06:02	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 06:02	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 06:02	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 06:02	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 06:02	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 06:02	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 06:02	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 06:02	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 06:02	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 06:02	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 06:02	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 06:02	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 06:02	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 06:02	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 06:02	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 06:02	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 06:02	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 06:02	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 06:02	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 06:02	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 06:02	1
Trichloroethene	0.33	J	0.50	0.19	ug/L			09/04/14 06:02	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 06:02	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 06:02	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 06:02	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 06:02	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 06:02	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 06:02	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 06:02	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 06:02	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 06:02	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 06:02	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 06:02	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 06:02	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 06:02	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:02	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 06:02	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 06:02	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 06:02	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 06:02	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 06:02	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 06:02	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:02	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 06:02	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 06:02	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 06:02	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 06:02	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 06:02	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-83243-4

Date Collected: 08/27/14 10:50

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 06:02	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 06:02	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:02	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:02	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:02	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:02	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 06:02	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:02	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 06:02	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 06:02	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 06:02	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 06:02	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 06:02	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 06:02	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 06:02	1
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>				<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
1,2-Dichloroethane-d4 (Surr)	104		75 - 125					09/04/14 06:02	1
Toluene-d8 (Surr)	95		75 - 120					09/04/14 06:02	1
4-Bromofluorobenzene (Surr)	83		75 - 120					09/04/14 06:02	1
Dibromofluoromethane	99		75 - 120					09/04/14 06:02	1

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-83243-5

Date Collected: 08/27/14 16:45

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 06:27	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 06:27	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 06:27	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 06:27	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 06:27	1
Chloroethane	1.6		1.0	0.34	ug/L			09/04/14 06:27	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 06:27	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 06:27	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 06:27	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 06:27	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 06:27	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 06:27	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 06:27	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 06:27	1
cis-1,2-Dichloroethene	1.2		1.0	0.12	ug/L			09/04/14 06:27	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 06:27	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 06:27	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 06:27	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 06:27	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 06:27	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 06:27	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 06:27	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/04/14 06:27	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 06:27	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 06:27	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 06:27	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 06:27	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 06:27	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 06:27	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 06:27	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 06:27	1
Tetrachloroethene	0.71	J	1.0	0.17	ug/L			09/04/14 06:27	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 06:27	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 06:27	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 06:27	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 06:27	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:27	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 06:27	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 06:27	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 06:27	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 06:27	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 06:27	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 06:27	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:27	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 06:27	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 06:27	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 06:27	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 06:27	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 06:27	1

TestAmerica Chicago

## Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-83243-5

Date Collected: 08/27/14 16:45

Matrix: Water

Date Received: 08/29/14 10:30

### Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 06:27	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 06:27	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:27	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:27	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:27	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:27	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 06:27	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:27	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 06:27	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 06:27	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 06:27	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 06:27	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 06:27	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 06:27	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 06:27	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		75 - 125		09/04/14 06:27	1
Toluene-d8 (Surr)	95		75 - 120		09/04/14 06:27	1
4-Bromofluorobenzene (Surr)	84		75 - 120		09/04/14 06:27	1
Dibromofluoromethane	99		75 - 120		09/04/14 06:27	1

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

**Client Sample ID: RFW-4A**

**Lab Sample ID: 500-83243-6**

Date Collected: 08/28/14 08:45

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 06:52	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 06:52	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 06:52	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 06:52	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 06:52	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 06:52	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 06:52	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 06:52	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 06:52	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 06:52	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 06:52	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 06:52	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 06:52	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 06:52	1
cis-1,2-Dichloroethene	0.94	J	1.0	0.12	ug/L			09/04/14 06:52	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 06:52	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 06:52	1
Chloroform	0.55	J	1.0	0.20	ug/L			09/04/14 06:52	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 06:52	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 06:52	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 06:52	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 06:52	1
Trichloroethene	34		0.50	0.19	ug/L			09/04/14 06:52	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 06:52	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 06:52	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 06:52	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 06:52	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 06:52	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 06:52	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 06:52	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 06:52	1
Tetrachloroethene	28		1.0	0.17	ug/L			09/04/14 06:52	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 06:52	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 06:52	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 06:52	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 06:52	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:52	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 06:52	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 06:52	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 06:52	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 06:52	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 06:52	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 06:52	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:52	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 06:52	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 06:52	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 06:52	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 06:52	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 06:52	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

**Client Sample ID: RFW-4A**

**Lab Sample ID: 500-83243-6**

Date Collected: 08/28/14 08:45

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 06:52	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 06:52	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:52	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 06:52	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:52	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:52	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 06:52	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 06:52	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 06:52	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 06:52	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 06:52	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 06:52	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 06:52	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 06:52	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 06:52	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	105		75 - 125		09/04/14 06:52	1
Toluene-d8 (Surr)	95		75 - 120		09/04/14 06:52	1
4-Bromofluorobenzene (Surr)	83		75 - 120		09/04/14 06:52	1
Dibromofluoromethane	99		75 - 120		09/04/14 06:52	1



# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-4A Dup

Lab Sample ID: 500-83243-7

Date Collected: 08/28/14 08:45

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 07:17	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 07:17	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 07:17	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 07:17	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 07:17	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 07:17	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 07:17	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 07:17	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 07:17	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 07:17	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 07:17	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 07:17	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 07:17	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 07:17	1
cis-1,2-Dichloroethene	0.92	J	1.0	0.12	ug/L			09/04/14 07:17	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 07:17	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 07:17	1
Chloroform	0.53	J	1.0	0.20	ug/L			09/04/14 07:17	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 07:17	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 07:17	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 07:17	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 07:17	1
Trichloroethene	33		0.50	0.19	ug/L			09/04/14 07:17	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 07:17	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 07:17	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 07:17	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 07:17	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 07:17	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 07:17	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 07:17	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 07:17	1
Tetrachloroethene	28		1.0	0.17	ug/L			09/04/14 07:17	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 07:17	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 07:17	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 07:17	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 07:17	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 07:17	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 07:17	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 07:17	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 07:17	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 07:17	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 07:17	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 07:17	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 07:17	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 07:17	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 07:17	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 07:17	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 07:17	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 07:17	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-4A Dup

Lab Sample ID: 500-83243-7

Date Collected: 08/28/14 08:45

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 07:17	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 07:17	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 07:17	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 07:17	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 07:17	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 07:17	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 07:17	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 07:17	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 07:17	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 07:17	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 07:17	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 07:17	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 07:17	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 07:17	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 07:17	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		75 - 125		09/04/14 07:17	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 07:17	1
4-Bromofluorobenzene (Surr)	83		75 - 120		09/04/14 07:17	1
Dibromofluoromethane	100		75 - 120		09/04/14 07:17	1

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-4B

Lab Sample ID: 500-83243-8

Date Collected: 08/28/14 07:45

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 13:29	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 13:29	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 13:29	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 13:29	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 13:29	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 13:29	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 13:29	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 13:29	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 13:29	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 13:29	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 13:29	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 13:29	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 13:29	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 13:29	1
cis-1,2-Dichloroethene	3.0		1.0	0.12	ug/L			09/04/14 13:29	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 13:29	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 13:29	1
Chloroform	1.2		1.0	0.20	ug/L			09/04/14 13:29	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 13:29	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 13:29	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 13:29	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 13:29	1
Trichloroethene	48		0.50	0.19	ug/L			09/04/14 13:29	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 13:29	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 13:29	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 13:29	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 13:29	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 13:29	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 13:29	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 13:29	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 13:29	1
Tetrachloroethene	84		1.0	0.17	ug/L			09/04/14 13:29	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 13:29	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 13:29	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 13:29	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 13:29	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:29	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 13:29	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 13:29	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 13:29	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 13:29	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 13:29	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 13:29	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:29	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 13:29	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 13:29	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 13:29	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 13:29	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 13:29	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

**Client Sample ID: RFW-4B**

**Lab Sample ID: 500-83243-8**

Date Collected: 08/28/14 07:45

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 13:29	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 13:29	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:29	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:29	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 13:29	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 13:29	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 13:29	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 13:29	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 13:29	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 13:29	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 13:29	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 13:29	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 13:29	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 13:29	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 13:29	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		75 - 125		09/04/14 13:29	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 13:29	1
4-Bromofluorobenzene (Surr)	84		75 - 120		09/04/14 13:29	1
Dibromofluoromethane	98		75 - 120		09/04/14 13:29	1

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-6

Lab Sample ID: 500-83243-9

Date Collected: 08/27/14 12:50

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 13:54	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 13:54	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 13:54	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 13:54	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 13:54	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 13:54	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 13:54	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 13:54	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 13:54	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 13:54	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 13:54	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 13:54	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 13:54	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 13:54	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 13:54	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 13:54	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 13:54	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 13:54	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 13:54	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 13:54	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 13:54	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 13:54	1
Trichloroethene	0.46	J	0.50	0.19	ug/L			09/04/14 13:54	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 13:54	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 13:54	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 13:54	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 13:54	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 13:54	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 13:54	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 13:54	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 13:54	1
Tetrachloroethene	0.72	J	1.0	0.17	ug/L			09/04/14 13:54	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 13:54	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 13:54	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 13:54	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 13:54	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:54	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 13:54	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 13:54	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 13:54	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 13:54	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 13:54	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 13:54	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:54	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 13:54	1
1,1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 13:54	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 13:54	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 13:54	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 13:54	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-6

Lab Sample ID: 500-83243-9

Date Collected: 08/27/14 12:50

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 13:54	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 13:54	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:54	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 13:54	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 13:54	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 13:54	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 13:54	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 13:54	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 13:54	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 13:54	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 13:54	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 13:54	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 13:54	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 13:54	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 13:54	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		75 - 125		09/04/14 13:54	1
Toluene-d8 (Surr)	95		75 - 120		09/04/14 13:54	1
4-Bromofluorobenzene (Surr)	86		75 - 120		09/04/14 13:54	1
Dibromofluoromethane	99		75 - 120		09/04/14 13:54	1

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

**Client Sample ID: RFW-7**

**Lab Sample ID: 500-83243-10**

Date Collected: 08/27/14 11:04

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	0.20	J	0.50	0.074	ug/L			09/04/14 14:19	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 14:19	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 14:19	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 14:19	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 14:19	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 14:19	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 14:19	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 14:19	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 14:19	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 14:19	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 14:19	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 14:19	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 14:19	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 14:19	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 14:19	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 14:19	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 14:19	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 14:19	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 14:19	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 14:19	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 14:19	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 14:19	1
Trichloroethene	2.1		0.50	0.19	ug/L			09/04/14 14:19	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 14:19	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 14:19	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 14:19	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 14:19	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 14:19	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 14:19	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 14:19	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 14:19	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 14:19	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 14:19	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 14:19	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 14:19	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 14:19	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:19	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 14:19	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 14:19	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 14:19	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 14:19	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 14:19	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 14:19	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:19	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 14:19	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 14:19	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 14:19	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 14:19	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 14:19	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-7

Lab Sample ID: 500-83243-10

Date Collected: 08/27/14 11:04

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 14:19	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 14:19	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:19	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:19	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 14:19	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 14:19	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 14:19	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 14:19	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 14:19	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 14:19	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 14:19	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 14:19	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 14:19	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 14:19	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 14:19	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		75 - 125		09/04/14 14:19	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 14:19	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 14:19	1
Dibromofluoromethane	99		75 - 120		09/04/14 14:19	1



# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-9

Lab Sample ID: 500-83243-11

Date Collected: 08/27/14 16:00

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 14:44	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 14:44	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 14:44	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 14:44	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 14:44	1
Chloroethane	<1.0	*	1.0	0.34	ug/L			09/04/14 14:44	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 14:44	1
1,1-Dichloroethene	0.63	J	1.0	0.31	ug/L			09/04/14 14:44	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 14:44	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 14:44	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 14:44	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 14:44	1
1,1-Dichloroethane	0.65	J	1.0	0.19	ug/L			09/04/14 14:44	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 14:44	1
cis-1,2-Dichloroethene	15		1.0	0.12	ug/L			09/04/14 14:44	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 14:44	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 14:44	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 14:44	1
1,1,1-Trichloroethane	0.60	J	1.0	0.20	ug/L			09/04/14 14:44	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 14:44	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 14:44	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 14:44	1
Trichloroethene	7.5		0.50	0.19	ug/L			09/04/14 14:44	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 14:44	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 14:44	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 14:44	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 14:44	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 14:44	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 14:44	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 14:44	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 14:44	1
Tetrachloroethene	4.2		1.0	0.17	ug/L			09/04/14 14:44	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 14:44	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 14:44	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 14:44	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 14:44	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:44	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 14:44	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 14:44	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 14:44	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 14:44	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 14:44	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 14:44	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:44	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 14:44	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 14:44	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 14:44	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 14:44	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 14:44	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-9

Lab Sample ID: 500-83243-11

Date Collected: 08/27/14 16:00

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 14:44	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 14:44	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:44	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 14:44	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 14:44	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 14:44	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 14:44	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 14:44	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 14:44	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 14:44	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 14:44	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 14:44	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 14:44	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 14:44	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 14:44	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	103		75 - 125		09/04/14 14:44	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 14:44	1
4-Bromofluorobenzene (Surr)	86		75 - 120		09/04/14 14:44	1
Dibromofluoromethane	98		75 - 120		09/04/14 14:44	1

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-11B

Lab Sample ID: 500-83243-12

Date Collected: 08/28/14 10:40

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 15:09	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 15:09	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 15:09	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 15:09	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 15:09	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 15:09	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 15:09	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 15:09	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 15:09	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 15:09	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 15:09	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 15:09	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 15:09	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 15:09	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 15:09	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 15:09	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 15:09	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 15:09	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 15:09	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 15:09	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 15:09	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 15:09	1
Trichloroethene	1.8		0.50	0.19	ug/L			09/04/14 15:09	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 15:09	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 15:09	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 15:09	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 15:09	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 15:09	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 15:09	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 15:09	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 15:09	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 15:09	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 15:09	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 15:09	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 15:09	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 15:09	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:09	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 15:09	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 15:09	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 15:09	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 15:09	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 15:09	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 15:09	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:09	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 15:09	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 15:09	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 15:09	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 15:09	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 15:09	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-11B

Lab Sample ID: 500-83243-12

Date Collected: 08/28/14 10:40

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 15:09	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 15:09	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:09	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:09	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:09	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:09	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 15:09	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:09	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 15:09	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 15:09	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 15:09	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 15:09	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 15:09	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 15:09	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 15:09	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		75 - 125		09/04/14 15:09	1
Toluene-d8 (Surr)	95		75 - 120		09/04/14 15:09	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 15:09	1
Dibromofluoromethane	99		75 - 120		09/04/14 15:09	1

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

**Client Sample ID: RFW-12B**

**Lab Sample ID: 500-83243-13**

Date Collected: 08/28/14 12:15

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 15:34	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 15:34	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 15:34	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 15:34	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 15:34	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 15:34	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 15:34	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 15:34	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 15:34	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 15:34	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 15:34	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 15:34	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 15:34	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 15:34	1
cis-1,2-Dichloroethene	1.6		1.0	0.12	ug/L			09/04/14 15:34	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 15:34	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 15:34	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 15:34	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 15:34	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 15:34	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 15:34	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 15:34	1
Trichloroethene	60		0.50	0.19	ug/L			09/04/14 15:34	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 15:34	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 15:34	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 15:34	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 15:34	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 15:34	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 15:34	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 15:34	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 15:34	1
Tetrachloroethene	4.5		1.0	0.17	ug/L			09/04/14 15:34	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 15:34	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 15:34	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 15:34	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 15:34	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:34	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 15:34	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 15:34	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 15:34	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 15:34	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 15:34	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 15:34	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:34	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 15:34	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 15:34	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 15:34	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 15:34	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 15:34	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-12B

Lab Sample ID: 500-83243-13

Date Collected: 08/28/14 12:15

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 15:34	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 15:34	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:34	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:34	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:34	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:34	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 15:34	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:34	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 15:34	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 15:34	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 15:34	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 15:34	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 15:34	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 15:34	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 15:34	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		75 - 125		09/04/14 15:34	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 15:34	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 15:34	1
Dibromofluoromethane	98		75 - 120		09/04/14 15:34	1

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-13

Lab Sample ID: 500-83243-14

Date Collected: 08/27/14 14:05

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 15:58	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 15:58	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 15:58	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 15:58	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 15:58	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 15:58	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 15:58	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 15:58	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 15:58	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 15:58	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 15:58	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 15:58	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 15:58	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 15:58	1
cis-1,2-Dichloroethene	0.67	J	1.0	0.12	ug/L			09/04/14 15:58	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 15:58	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 15:58	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 15:58	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 15:58	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 15:58	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 15:58	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 15:58	1
Trichloroethene	2.5		0.50	0.19	ug/L			09/04/14 15:58	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 15:58	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 15:58	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 15:58	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 15:58	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 15:58	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 15:58	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 15:58	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 15:58	1
Tetrachloroethene	15		1.0	0.17	ug/L			09/04/14 15:58	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 15:58	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 15:58	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 15:58	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 15:58	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:58	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 15:58	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 15:58	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 15:58	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 15:58	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 15:58	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 15:58	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:58	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 15:58	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 15:58	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 15:58	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 15:58	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 15:58	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-13

Lab Sample ID: 500-83243-14

Date Collected: 08/27/14 14:05

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 15:58	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 15:58	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:58	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 15:58	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:58	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:58	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 15:58	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 15:58	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 15:58	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 15:58	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 15:58	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 15:58	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 15:58	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 15:58	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 15:58	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	103		75 - 125		09/04/14 15:58	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 15:58	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 15:58	1
Dibromofluoromethane	97		75 - 120		09/04/14 15:58	1



# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-17

Lab Sample ID: 500-83243-15

Date Collected: 08/27/14 15:10

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	0.62		0.50	0.074	ug/L			09/04/14 16:23	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 16:23	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 16:23	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 16:23	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 16:23	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 16:23	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 16:23	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 16:23	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 16:23	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 16:23	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 16:23	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 16:23	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 16:23	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 16:23	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 16:23	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 16:23	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 16:23	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 16:23	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 16:23	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 16:23	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 16:23	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 16:23	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/04/14 16:23	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 16:23	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 16:23	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 16:23	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 16:23	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 16:23	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 16:23	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 16:23	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 16:23	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 16:23	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 16:23	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 16:23	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 16:23	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 16:23	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:23	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 16:23	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 16:23	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 16:23	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 16:23	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 16:23	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 16:23	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:23	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 16:23	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 16:23	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 16:23	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 16:23	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 16:23	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: RFW-17

Lab Sample ID: 500-83243-15

Date Collected: 08/27/14 15:10

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 16:23	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 16:23	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:23	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:23	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 16:23	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 16:23	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 16:23	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 16:23	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 16:23	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 16:23	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 16:23	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 16:23	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 16:23	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 16:23	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 16:23	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	105		75 - 125		09/04/14 16:23	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 16:23	1
4-Bromofluorobenzene (Surr)	84		75 - 120		09/04/14 16:23	1
Dibromofluoromethane	99		75 - 120		09/04/14 16:23	1

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: Trip Blank

Lab Sample ID: 500-83243-16

Date Collected: 08/27/14 06:00

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 16:48	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 16:48	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 16:48	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 16:48	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 16:48	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 16:48	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 16:48	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 16:48	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 16:48	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 16:48	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 16:48	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 16:48	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 16:48	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 16:48	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			09/04/14 16:48	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 16:48	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 16:48	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 16:48	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 16:48	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 16:48	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 16:48	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 16:48	1
Trichloroethene	<0.50		0.50	0.19	ug/L			09/04/14 16:48	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 16:48	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 16:48	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 16:48	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 16:48	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 16:48	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 16:48	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 16:48	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 16:48	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			09/04/14 16:48	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 16:48	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 16:48	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 16:48	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 16:48	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:48	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 16:48	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 16:48	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 16:48	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 16:48	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 16:48	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 16:48	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:48	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 16:48	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 16:48	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 16:48	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 16:48	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 16:48	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: Trip Blank

Lab Sample ID: 500-83243-16

Date Collected: 08/27/14 06:00

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 16:48	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 16:48	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:48	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 16:48	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 16:48	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 16:48	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 16:48	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 16:48	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 16:48	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 16:48	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 16:48	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 16:48	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 16:48	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 16:48	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 16:48	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	105		75 - 125		09/04/14 16:48	1
Toluene-d8 (Surr)	96		75 - 120		09/04/14 16:48	1
4-Bromofluorobenzene (Surr)	85		75 - 120		09/04/14 16:48	1
Dibromofluoromethane	99		75 - 120		09/04/14 16:48	1

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-2

Lab Sample ID: 500-83243-17

Date Collected: 08/28/14 12:00

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			09/04/14 17:13	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			09/04/14 17:13	1
Chloromethane	<1.0		1.0	0.18	ug/L			09/04/14 17:13	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			09/04/14 17:13	1
Bromomethane	<1.0		1.0	0.31	ug/L			09/04/14 17:13	1
Chloroethane	<1.0		1.0	0.34	ug/L			09/04/14 17:13	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			09/04/14 17:13	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			09/04/14 17:13	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			09/04/14 17:13	1
Acetone	<5.0		5.0	1.3	ug/L			09/04/14 17:13	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			09/04/14 17:13	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			09/04/14 17:13	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			09/04/14 17:13	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			09/04/14 17:13	1
cis-1,2-Dichloroethene	3.0		1.0	0.12	ug/L			09/04/14 17:13	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			09/04/14 17:13	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			09/04/14 17:13	1
Chloroform	<1.0		1.0	0.20	ug/L			09/04/14 17:13	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			09/04/14 17:13	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			09/04/14 17:13	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			09/04/14 17:13	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 17:13	1
<b>Trichloroethene</b>	<b>130</b>		0.50	0.19	ug/L			09/04/14 17:13	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			09/04/14 17:13	1
Dibromomethane	<1.0		1.0	0.33	ug/L			09/04/14 17:13	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			09/04/14 17:13	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			09/04/14 17:13	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			09/04/14 17:13	1
Toluene	<0.50		0.50	0.11	ug/L			09/04/14 17:13	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			09/04/14 17:13	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			09/04/14 17:13	1
<b>Tetrachloroethene</b>	<b>51</b>		1.0	0.17	ug/L			09/04/14 17:13	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			09/04/14 17:13	1
2-Hexanone	<5.0		5.0	0.56	ug/L			09/04/14 17:13	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			09/04/14 17:13	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			09/04/14 17:13	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			09/04/14 17:13	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			09/04/14 17:13	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			09/04/14 17:13	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			09/04/14 17:13	1
o-Xylene	<0.50		0.50	0.068	ug/L			09/04/14 17:13	1
Styrene	<1.0		1.0	0.10	ug/L			09/04/14 17:13	1
Bromoform	<1.0		1.0	0.28	ug/L			09/04/14 17:13	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 17:13	1
Bromobenzene	<1.0		1.0	0.25	ug/L			09/04/14 17:13	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			09/04/14 17:13	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			09/04/14 17:13	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 17:13	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			09/04/14 17:13	1

TestAmerica Chicago

# Client Sample Results

Client: Weston Solutions, Inc.  
Project/Site: Black and Decker

TestAmerica Job ID: 500-83243-1

Client Sample ID: EW-2

Lab Sample ID: 500-83243-17

Date Collected: 08/28/14 12:00

Matrix: Water

Date Received: 08/29/14 10:30

**Method: 8260B - VOC (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			09/04/14 17:13	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			09/04/14 17:13	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 17:13	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			09/04/14 17:13	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			09/04/14 17:13	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 17:13	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			09/04/14 17:13	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			09/04/14 17:13	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			09/04/14 17:13	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			09/04/14 17:13	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			09/04/14 17:13	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			09/04/14 17:13	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			09/04/14 17:13	1
Naphthalene	<1.0		1.0	0.16	ug/L			09/04/14 17:13	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			09/04/14 17:13	1
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>				<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
1,2-Dichloroethane-d4 (Surr)	105		75 - 125					09/04/14 17:13	1
Toluene-d8 (Surr)	96		75 - 120					09/04/14 17:13	1
4-Bromofluorobenzene (Surr)	85		75 - 120					09/04/14 17:13	1
Dibromofluoromethane	98		75 - 120					09/04/14 17:13	1